

Olin

ALGAESTAT SOLUTION

FOR INDUSTRIAL RECIRCULATION COOLING WATER TOWER TREATMENT

ACTIVE INGREDIENT: Sodium Chlorite*.....25%

INERT INGREDIENTS:75%

*AVAILABLE CHLORINE...39%

CONTAINS 2.58 LBS. OF SODIUM CHLORITE PER GALLON AT 70°F.

DANGER! KEEP OUT OF REACH OF CHILDREN

May be harmful or fatal if swallowed. May cause chemical burns. May cause irritation of skin, eyes, nose and throat. Do not get in eyes, on skin or on clothing. Strong Oxidant. Do not mix with other chemicals. Mix only with water. Keep container closed when not in use. Rinse empty container thoroughly with water and discard in a safe place. Do not reuse empty container.

SPILL: If spilled, flush with plenty of water. If spilled on clothing wash clothing thoroughly.

ANTIDOTE: External – flood skin or eyes with plenty of water for 15 minutes. If irritation to skin persists, get medical attention. For eyes – call physician immediately. Internal – drink large quantities of water or milk. Follow with milk of magnesia, vegetable oil, or beaten eggs. Call physician immediately.

DIRECTIONS FOR CONTROLLING THE GROWTH OF ALGAE IN INDUSTRIAL RECIRCULATING COOLING WATER TOWERS.

1. Clean badly fouled systems before starting treatment.
2. Where algae are visible, add an initial dosage of 8.5 fl. oz. of Olin Algaestat Solution per 1,000 gallons of water in the system. Repeat if necessary until control is evident.
3. Where algae control is evident, use a subsequent dose of 4.25 fl. ozs. of Olin Algaestat Solution per 1,000 gallons of water in the system twice a week or as needed to maintain control.
4. Add Olin Algaestat Solution directly to the cooling tower drip pan near the inlet to the recirculating pump.

55 GALS. NET

Olin CHEMICALS

Olin Corporation, 120 Long Ridge Rd., Stamford, Conn. 06904

BOCS-872

ACCEPTED

9/13/72

REGISTERED TRADE
MARK FOR ALL
POISON REGISTER

EPA Reg. No. 1258-930

1258-930