



Re: FGD WWTS Flow
palmeag to: John King

07/12/2011 05:11 PM

From: palmeag@nu.com
To: John King/R1/USEPA/US@EPA

History: This message has been replied to and forwarded.

Yup, still holding at 70,000 gpd

From: John King <king.john@epamail.epa.gov>
To: Allan G. Palmer/NUS@NU
Date: 07/12/2011 08:15 AM
Subject: FGD WWTS Flow

Allan,

Has the effluent discharge flow rate of the FGD WWTS been settled? Last that we talked 70,000 GPD was going to be the flow is that still holding?

Thank you, John

***** This e-mail, including any files or attachments transmitted with it, is confidential and/or proprietary and is intended for a specific purpose and for use only by the individual or entity to whom it is addressed. Any disclosure, copying or distribution of this e-mail or the taking of any action based on its contents, other than for its intended purpose, is strictly prohibited. If you have received this e-mail in error, please notify the sender immediately and delete it from your system. Any views or opinions expressed in this e-mail are not necessarily those of Northeast Utilities, its subsidiaries and affiliates (NU). E-mail transmission cannot be guaranteed to be error-free or secure or free from viruses, and NU disclaims all liability for any resulting damage, errors, or omissions.



FGD WWTS Effluent Flow Rate

John King to: palmeag

Cc: David Webster, Mark Stein, Sharon DeMeo, sspanos, Jeff.Andrews

07/12/2011 04:03 PM

From: John King/R1/USEPA/US

To: Allan G. Palmer

Cc: David Webster/R1/USEPA/US@EPA, Mark Stein/R1/USEPA/US@EPA, Sharon DeMeo/R1/USEPA/US@EPA, sspanos@des.state.nh.us, Jeff.Andrews@des.nh.gov

Allan,

I acknowledge you sent me an email indicating that Merrimack Station's FGD WWTS effluent flow rate has been increased to 70,000 gpd to prevent the build-up of chlorides in the absorber unit. This proposed change will directly effect calculations EPA and NHDES have completed for possible revised or new effluent limitations at several Merrimack Station outfalls.

It is requested that PSNH either update your May 5, 2010, NPDES permit application revision or provided a letter to EPA and NHDES stating that the FGD WWTS effluent flow has been increased to 70,000 gpd.

If you have any questions or comments, please do not hesitate to contact me.

Thank you, John