

Generic Environmental Impact Statement for License Renewal of Nuclear Plants

Supplement 30

Regarding
Vermont Yankee Nuclear Power Station

Draft Report for Comment

U.S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, DC 20555-0001



AVAILABILITY OF REFERENCE MATERIALS IN NRC PUBLICATIONS

NRC Reference Material

As of November 1999, you may electronically access NUREG-series publications and other NRC records at NRC's Public Electronic Reading Room at <http://www.nrc.gov/reading-rm.html>.

Publicly released records include, to name a few, NUREG-series publications; *Federal Register* notices; applicant, licensee, and vendor documents and correspondence; NRC correspondence and internal memoranda; bulletins and information notices; inspection and investigative reports; licensee event reports; and Commission papers and their attachments.

NRC publications in the NUREG series, NRC regulations, and *Title 10, Energy*, in the Code of *Federal Regulations* may also be purchased from one of these two sources.

1. The Superintendent of Documents

U.S. Government Printing Office
Mail Stop SSOP
Washington, DC 20402-0001
Internet: bookstore.gpo.gov
Telephone: 202-512-1800
Fax: 202-512-2250

2. The National Technical Information Service

Springfield, VA 22161-0002
www.ntis.gov
1-800-553-6847 or, locally, 703-605-6000

A single copy of each NRC draft report for comment is available free, to the extent of supply, upon written request as follows:

Address: Office of Administration,
Printing and Mail Services Branch
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

E-mail: DISTRIBUTION@nrc.gov
Facsimile: 301-415-2289

Some publications in the NUREG series that are posted at NRC's Web site address <http://www.nrc.gov/reading-rm/doc-collections/nuregs> are updated periodically and may differ from the last printed version. Although references to material found on a Web site bear the date the material was accessed, the material available on the date cited may subsequently be removed from the site.

Non-NRC Reference Material

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, and transactions, *Federal Register* notices, Federal and State legislation, and congressional reports. Such documents as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings may be purchased from their sponsoring organization.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at—

The NRC Technical Library
Two White Flint North
11545 Rockville Pike
Rockville, MD 20852-2738

These standards are available in the library for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from—

American National Standards Institute
11 West 42nd Street
New York, NY 10036-8002
www.ansi.org
212-642-4900

Legally binding regulatory requirements are stated only in laws; NRC regulations; licenses, including technical specifications; or orders, not in NUREG-series publications. The views expressed in contractor-prepared publications in this series are not necessarily those of the NRC.

The NUREG series comprises (1) technical and administrative reports and books prepared by the staff (NUREG-XXXX) or agency contractors (NUREG/CR-XXXX), (2) proceedings of conferences (NUREG/CP-XXXX), (3) reports resulting from international agreements (NUREG/IA-XXXX), (4) brochures (NUREG/BR-XXXX), and (5) compilations of legal decisions and orders of the Commission and Atomic and Safety Licensing Boards and of Directors' decisions under Section 2.206 of NRC's regulations (NUREG-0750).

Generic Environmental Impact Statement for License Renewal of Nuclear Plants

Supplement 30

Regarding Vermont Yankee Nuclear Power Station

Draft Report for Comment

Manuscript Completed: December 2006

Date Published: December 2006

**Division of License Renewal
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001**



COMMENTS ON DRAFT REPORT

Any interested party may submit comments on this report for consideration by the NRC staff. Comments may be accompanied by additional relevant information or supporting data. Please specify the report number NUREG-1437, Supplement 30, draft, in your comments, and send them by March 7, 2007, to the following address:

Chief, Rules Review and Directives Branch
U.S. Nuclear Regulatory Commission
Mail Stop T6-D59
Washington, DC 20555-0001

Electronic comments may be submitted to the NRC by the Internet at
VermontYankeeEIS@nrc.gov.

For any questions about the material in this report, please contact:

R. Emch
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001
Phone: 301-415-1590
E-mail: RLE@nrc.gov

Abstract

The U.S. Nuclear Regulatory Commission (NRC) considered the environmental impacts of renewing nuclear power plant operating licenses (OLs) for a 20-year period in its *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, Volumes 1 and 2, and codified the results in Title 10, Part 51, of the *Code of Federal Regulations* (10 CFR Part 51). In the GEIS (and its Addendum 1), the NRC staff identifies 92 environmental issues and reaches generic conclusions related to environmental impacts for 69 of these issues that apply to all plants or to plants with specific design or site characteristics. Additional plant-specific review is required for the remaining 23 issues. These plant-specific reviews are to be included in a supplement to the GEIS.

This draft Supplemental Environmental Impact Statement (SEIS) has been prepared in response to an application submitted to the NRC by Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy), to renew the OL for Vermont Yankee Nuclear Power Station (VYNPS) for an additional 20 years under 10 CFR Part 54. This draft SEIS includes the NRC staff's analysis that considers and weighs the environmental impacts of the proposed action, the environmental impacts of alternatives to the proposed action, and mitigation measures available for reducing or avoiding adverse impacts. It also includes the NRC staff's preliminary recommendation regarding the proposed action.

Regarding the 69 issues for which the GEIS reached generic conclusions, neither Entergy nor the NRC staff has identified information that is both new and significant for any issue that applies to VYNPS. In addition, the NRC staff determined that information provided during the scoping process did not call into question the conclusions in the GEIS. Therefore, the NRC staff concludes that the impacts of renewing the VYNPS OL would not be greater than the impacts identified for these issues in the GEIS. For each of these issues, the NRC staff's conclusion in the GEIS is that the impact is of SMALL^(a) significance (except for collective offsite radiological impacts from the fuel cycle and high-level waste and spent fuel, which were not assigned a single significance level).

Regarding the remaining 23 issues, those that apply to VYNPS are addressed in this draft SEIS. For each applicable issue, the NRC staff concludes that the significance of the potential environmental impacts of renewal of the OL is SMALL. The NRC staff also concludes that no additional mitigation is warranted. However, under the provisions of the Clean Water Act 316(b) Phase II regulations, the Vermont Department of Environmental Conservation may impose further restrictions or require modifications to the cooling system to reduce the impacts on

(a) Environmental effects are not detectable or are so minor that they will neither destabilize nor noticeably alter any important attribute of the resource.

Abstract

1 aquatic resources from entrainment and impingement. The NRC staff determined that
2 information provided during the scoping process did not identify any new issue that has a
3 significant environmental impact.

4
5 The NRC staff's preliminary recommendation is that the Commission determine that the adverse
6 environmental impacts of license renewal for VYNPS are not so great that preserving the option
7 of license renewal for energy-planning decisionmakers would be unreasonable. This
8 recommendation is based on (1) the analysis and findings in the GEIS; (2) the Environmental
9 Report submitted by Entergy; (3) consultation with Federal, State, and local agencies; (4) the
10 NRC staff's own independent review; and (5) the NRC staff's consideration of public comments
11 received during the scoping process.
12

Contents

Abstract	iii
Executive Summary	xv
Abbreviations/Acronyms	xx
1.0 Introduction	1-1
1.1 Report Contents	1-1
1.2 Background	1-3
1.2.1 Generic Environmental Impact Statement	1-3
1.2.2 License Renewal Evaluation Process	1-5
1.3 The Proposed Federal Action	1-8
1.4 The Purpose and Need for the Proposed Action	1-8
1.5 Compliance and Consultations	1-9
1.6 References	1-9
2.0 Description of Nuclear Power Plant and Site and Plant Interaction with the Environment	2-1
2.1 Plant and Site Description and Proposed Plant Operation During the Renewal Term	2-1
2.1.1 External Appearance and Setting	2-1
2.1.2 Reactor Systems	2-6
2.1.3 Cooling and Auxiliary Water Systems	2-8
2.1.4 Radioactive Waste Management Systems and Effluent Control Systems	2-10
2.1.4.1 Liquid Waste Processing Systems and Effluent Controls	2-11
2.1.4.2 Gaseous Waste Processing Systems and Effluent Controls	2-13
2.1.4.3 Solid Waste Processing	2-14
2.1.5 Nonradioactive Waste Systems	2-15
2.1.6 Plant Operation and Maintenance	2-16
2.1.7 Power Transmission System	2-16
2.2 Plant Interaction with the Environment	2-17

Contents

1	2.2.1 Land Use	2-20
2	2.2.2 Water Use	2-21
3		
4	2.2.2.1 Surface Water	2-21
5	2.2.2.2 Groundwater	2-26
6		
7	2.2.3 Water Quality	2-27
8		
9	2.2.3.1 Surface Water	2-27
10	2.2.3.2 Groundwater	2-39
11		
12	2.2.4 Air Quality	2-40
13		
14	2.2.4.1 Climate and Meteorology	2-40
15	2.2.4.2 Air Quality Impacts	2-42
16		
17	2.2.5 Aquatic Resources	2-45
18		
19	2.2.5.1 Description of the Aquatic Resources 20 in the Vicinity of VYNPS	2-45
21	2.2.5.2 Threatened or Endangered Aquatic Species	2-56
22		
23	2.2.6 Terrestrial Resources	2-58
24		
25	2.2.6.1 Description of Terrestrial Resources in the Vicinity 26 of VYNPS	2-58
27	2.2.6.2 Threatened or Endangered Terrestrial Species	2-60
28		
29	2.2.7 Radiological Impacts	2-68
30	2.2.8 Socioeconomic Factors	2-71
31		
32	2.2.8.1 Housing	2-71
33	2.2.8.2 Public Services	2-73
34	2.2.8.3 Offsite Land Use	2-75
35	2.2.8.4 Visual Aesthetics and Noise	2-77
36	2.2.8.5 Demography	2-78
37	2.2.8.6 Economy	2-79
38		
39	2.2.9 Historic and Archaeological Resources	2-82
40		
41	2.2.9.1 Cultural Background	2-82
42	2.2.9.2 Historic and Archaeological Resources at the VYNPS Site ..	2-83

Contents

1	2.2.10 Related Federal Project Activities and Consultations	2-84
2		
3	2.3 References	2-85
4		
5	3.0 Environmental Impacts of Refurbishment	3-1
6		
7	3.1 References	3-4
8		
9	4.0 Environmental Impacts of Operation	4-1
10		
11	4.1 Cooling System	4-2
12		
13	4.1.1 Water Use Conflicts (Make-Up from a Small River)	4-13
14	4.1.2 Entrainment of Fish and Shellfish in Early Life Stages	4-14
15	4.1.3 Impingement of Fish and Shellfish	4-17
16	4.1.4 Heat Shock	4-20
17	4.1.5 Microbiological Organisms (Public Health)	4-22
18		
19	4.2 Transmission Lines	4-23
20		
21	4.2.1 Electromagnetic Fields – Acute Effects	4-27
22	4.2.2 Electromagnetic Fields – Chronic Effects	4-28
23		
24	4.3 Radiological Impacts of Normal Operations	4-29
25	4.4 Socioeconomic Impacts of Plant Operations During the License	
26	Renewal Period	4-30
27		
28	4.4.1 Housing Impacts During Operations	4-33
29	4.4.2 Public Services: Public Utility Impacts During Operations	4-33
30	4.4.3 Offsite Land Use During Operations	4-34
31	4.4.4 Public Services: Transportation Impacts During Operations	4-36
32	4.4.5 Historic and Archaeological Resources	4-37
33	4.4.6 Environmental Justice	4-38
34		
35	4.5 Groundwater Use and Quality	4-42
36		
37	4.5.1 Groundwater-Use Conflicts (Make-Up from a Small River)	4-43
38		
39	4.6 Threatened or Endangered Species	4-44
40		
41	4.6.1 Aquatic Species	4-45
42	4.6.2 Terrestrial Species	4-46

Contents

1	4.7 Evaluation of New and Potentially Significant Information on Impacts of Operations During the Renewal Term	4-47
2	4.7.1 Evaluation of Potential New and Significant Information Concerning Biocides in Cooling Water Drift	4-48
3	4.7.2 Evaluation of Potential New and Significant Information Concerning Thermal Discharges to the Connecticut River	4-49
4	4.8 Cumulative Impacts	4-51
5	4.8.1 Cumulative Impacts on Aquatic Resources	4-52
6	4.8.2 Cumulative Impacts on Terrestrial Resources	4-54
7	4.8.3 Cumulative Human Health Impacts	4-55
8	4.8.4 Cumulative Socioeconomic Impacts	4-56
9	4.8.5 Cumulative Impacts on Groundwater Use and Quality	4-57
10	4.8.6 Conclusions Regarding Cumulative Impacts	4-58
11	4.9 Summary of Impacts of Operations During the Renewal Term	4-58
12	4.10 References	4-59
13	5.0 Environmental Impacts of Postulated Accidents	5-1
14	5.1 Postulated Plant Accidents	5-1
15	5.1.1 Design-Basis Accidents	5-2
16	5.1.2 Severe Accidents	5-3
17	5.2 Severe Accident Mitigation Alternatives	5-4
18	5.2.1 Introduction	5-5
19	5.2.2 Estimate of Risk	5-6
20	5.2.3 Potential Plant Improvements	5-6
21	5.2.4 Evaluation of Risk Reduction and Costs of Improvements	5-8
22	5.2.5 Cost-Benefit Comparison	5-8
23	5.2.6 Conclusions	5-10
24	5.3 References	5-10
25	6.0 Environmental Impacts of the Uranium Fuel Cycle and Solid Waste Management	6-1
26	6.1 The Uranium Fuel Cycle	6-2

Contents

1	6.2 References	6-9
2		
3	7.0 Environmental Impacts of Decommissioning	7-1
4		
5	7.1 Decommissioning	7-2
6	7.2 References	7-4
7		
8	8.0 Environmental Impacts of Alternatives	8-1
9		
10	8.1 No-Action Alternative	8-1
11		
12	8.2 Alternative Energy Sources	8-6
13		
14	8.2.1 Coal-Fired Plant Generation	8-8
15		
16	8.2.1.1 Coal-Fired Plant with a Closed-Cycle Cooling System	8-9
17	8.2.1.2 Coal-Fired Plant with a Once-Through Cooling System	8-19
18		
19	8.2.2 Natural-Gas-Fired Plant Generation	8-19
20		
21	8.2.2.1 Natural-Gas-Fired Plant with a Closed-Cycle 22 Cooling System	8-21
23	8.2.2.2 Natural-Gas-Fired Plant with a Once-Through 24 Cooling System	8-31
25		
26	8.2.3 Nuclear Power Plant Generation	8-32
27		
28	8.2.3.1 New Nuclear Plant with a Closed-Cycle 29 Cooling System	8-32
30	8.2.3.2 New Nuclear Plant with a Once-Through 31 Cooling System	8-37
32		
33	8.2.4 Purchased Electrical Power	8-38
34	8.2.5 Other Alternatives	8-39
35		
36	8.2.5.1 Oil-Fired Plant Generation	8-39
37	8.2.5.2 Wind Power	8-39
38	8.2.5.3 Solar Power	8-41
39	8.2.5.4 Hydropower	8-41
40	8.2.5.5 Geothermal Energy	8-42
41	8.2.5.6 Wood Waste	8-42
42	8.2.5.7 Municipal Solid Waste	8-43

Contents

1	8.2.5.8 Other Biomass-Derived Fuels	8-44
2	8.2.5.9 Fuel Cells	8-44
3	8.2.5.10 Delayed Retirement	8-45
4	8.2.5.11 Utility-Sponsored Conservation	8-45
5		
6	8.2.6 Combination of Alternatives	8-45
7		
8	8.3 Summary of Alternatives Considered	8-51
9	8.4 References	8-51
10		
11	9.0 Summary and Conclusions	9-1
12		
13	9.1 Environmental Impacts of the Proposed Action – License Renewal	9-4
14		
15	9.1.1 Unavoidable Adverse Impacts	9-5
16	9.1.2 Irreversible or Irretrievable Resource Commitments	9-6
17	9.1.3 Short-Term Use Versus Long-Term Productivity	9-6
18		
19	9.2 Relative Significance of the Environmental Impacts of License Renewal and Alternatives	9-7
20		
21	9.3 NRC Staff Conclusions and Recommendations	9-7
22	9.4 References	9-9
23		
24	Appendix A - Comments Received on the Environmental Review	A-1
25	Appendix B - Contributors to the Supplement	B-1
26	Appendix C - Chronology of NRC Staff Environmental Review Correspondence Related to the Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. Application for License Renewal of Vermont Yankee Nuclear Power Station	C-1
27		
28		
29		
30	Appendix D - Organizations Contacted	D-1
31	Appendix E - Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. Compliance Status and Consultation Correspondence ..	E-1
32		
33	Appendix F - Generic Environmental Impact Statement Environmental Issues Not Applicable to Vermont Yankee Nuclear Power Station	F-1
34		
35	Appendix G - NRC Staff Evaluation of Severe Accident Mitigation Alternatives (SAMAs) for Vermont Yankee Nuclear Power Station, in Support of the License Renewal Application Review	G-1
36		
37		
38		
39		

Figures

2-1	Location of Vermont Yankee Nuclear Power Station, 50-mi Region	2-2
2-2	Location of Vermont Yankee Nuclear Power Station, 6-mi Region	2-3
2-3	Vermont Yankee Nuclear Power Station Site Layout	2-4
2-4	Vermont Yankee Nuclear Power Station Exclusion Zone	2-5
2-5	Major State and Federal Lands Within 50 mi of Vermont Yankee Nuclear Power Station	2-7
2-6	Location of the Chestnut Hill Transmission Line	2-18
2-7	Location of the Coolidge Transmission Line	2-19
2-8	Average Monthly Flow Rates at Vernon Dam from 2000 to 2005	2-22
2-9	Average Monthly Flow Rates at Vernon Dam for 2004 and 2005	2-22
2-10	Locations of NPDES Outfalls at the VYNPS	2-25
2-11	Locations of Vernon Dam and River Monitoring Stations 3 and 7 Relative to VYNPS	2-29
2-12	Seasonal Variation in Temperature at River Monitoring Station 3, Located About 0.65 Miles Downstream of Vernon Dam (2000-2004)	2-35
2-13	Seasonal Variation in Temperature at River Monitoring Station 7, Located 4 Miles Upstream of VYNPS (2000-2004)	2-35
2-14	Difference in Average Monthly Temperatures Between River Monitoring Stations 3 (downstream) and 7 (upstream)	2-36
2-15	Locations of Thermistor Stations at Vernon Pool	2-37
4-1	Geographic Distribution of Minority Populations (shown in shaded areas) Within 50 mi of the VYNPS Based on Census Block Group Data	4-40
4-2	Geographic Distribution of Low-Income Populations (shown in shaded areas) Within 50 mi of the VYNPS Site Based on Census Block Group Data	4-41

Tables

2-1	VYNPS NPDES Discharge Locations	2-24
2-2	VYNPS Potable Water Wells	2-26
2-3	Monitoring Requirements for Water Quality Parameters at NPDES Outfalls	2-30
2-4	Discharge Temperature Requirements Under the Current and Amended NPDES Permits for VYNPS	2-31
2-5	Maximum Calculated River Temperature Increase at River Monitoring Station 3 During the NPDES Winter Period (October 15 through May 15)	2-33
2-6	Maximum Calculated River Temperature Increase at River Monitoring Station 3 During the NPDES Summer Period (May 16 through October 14)	2-34
2-7	Total Water Depth and Temperature Sampling Depths in Vernon Pool	2-38
2-8	Summary of Migratory Fish Passage at Vernon Dam, 1981 Through 2006	2-49
2-9	Summary of Migratory Fish Passage at Holyoke, Turners Falls, Vernon, and Bellows Falls Dams, 2004 and 2005	2-49
2-10	American Shad Counts at Holyoke, Turners Falls, and Vernon Dams from 1981 Through 2005	2-52
2-11	Federally and Vermont-Listed Aquatic Species Potentially Occurring in the Vicinity of VYNPS and Associated Transmission Lines	2-56
2-12	Federally Listed and State-Listed Terrestrial Species Whose Ranges Include the VYNPS Site, Transmission Lines Within the Scope of License Renewal, and Vicinity	2-61
2-13	VYNPS Permanent Employee Residence Information by County and City	2-72
2-14	Housing Units and Housing Units Vacant (Available) by County During 1990 and 2000	2-73
2-15	Major County Public Water Supply Systems in 2004	2-74
2-16	Population Growth in Windham County, Cheshire County, and Franklin County, 1970 to 2032	2-79
2-17	Major Employment Facilities Within 10 mi of the VYNPS Site	2-80
2-18	VYNPS Contribution to Vernon Tax Revenues	2-81
3-1	Category 1 Issues for Refurbishment Evaluation	3-2
3-2	Category 2 Issues for Refurbishment Evaluation	3-3
4-1	Category 1 Issues Applicable to the Operation of the VYNPS Cooling System During the Renewal Term	4-3
4-2	Category 2 Issues Applicable to the Operation of the VYNPS Cooling System During the Renewal Term	4-12
4-3	Percentages (and Numbers) of Fish Eggs and Larvae Entrained at VYNPS	4-16
4-4	Percentages (and Numbers) of Fish Species Impinged at VYNPS	4-19

Tables

1	4-5	Thermal Preferences and Tolerances of Warmwater Species That Occur in the VYNPS Area	4-22
2	4-6	Category 1 Issues Applicable to the VYNPS Transmission Lines During the Renewal Term	4-24
3	4-7	Category 2 and Uncategorized Issues Applicable to the VYNPS Transmission Lines During the Renewal Term	4-27
4	4-8	Category 1 Issues Applicable to Radiological Impacts of Normal Operations During the Renewal Term	4-29
5	4-9	Category 1 Issues Applicable to Socioeconomics During the Renewal Term	4-31
6	4-10	Environmental Justice and GEIS Category 2 Issues Applicable to Socioeconomics During the Renewal Term	4-32
7	4-11	Category 1 Issue Applicable to Groundwater Use and Quality During the Renewal Term	4-42
8	4-12	Category 2 Issue Applicable to Groundwater Use and Quality During the Renewal Term	4-43
9	4-13	Category 2 Issue Applicable to Threatened or Endangered Species During the Renewal Term	4-44
10			
11	5-1	Category 1 Issue Applicable to Postulated Accidents During the Renewal Term	5-3
12	5-2	Category 2 Issue Applicable to Postulated Accidents During the Renewal Term	5-4
13	5-3	VYNPS Core Damage Frequency	5-7
14	5-4	Breakdown of Population Dose by Containment Release Mode	5-7
15			
16	6-1	Category 1 Issues Applicable to the Uranium Fuel Cycle and Solid Waste Management During the Renewal Term	6-2
17			
18	7-1	Category 1 Issues Applicable to the Decommissioning of VYNPS Following the Renewal Term	7-2
19			
20	8-1	Summary of Environmental Impacts of the No-Action Alternative	8-3
21	8-2	Summary of Environmental Impacts of a Coal-Fired Plant Using Closed-Cycle Cooling at an Alternate Site	8-10
22	8-3	Summary of Environmental Impacts of Coal-Fired Plant Generation at an Alternate Site with Once-Through Cooling System	8-20
23	8-4	Summary of Environmental Impacts of a Natural-Gas-Fired Plant Using Closed-Cycle Cooling at the VYNPS Site and at an Alternate Site	8-22
24	8-5	Summary of Environmental Impacts of Natural-Gas-Fired Generation at an Alternate Site with Once-Through Cooling	8-31
25	8-6	Summary of Environmental Impacts of a New Nuclear Power Plant Using Closed-Cycle Cooling at an Alternate Site	8-33

Tables

1	8-7	Summary of Environmental Impacts of a New Nuclear Power Plant Using Once-Through Cooling	8-38
2	8-8	Summary of Environmental Impacts of Combination of Alternatives at the VYNPS Site and at an Alternate Site	8-47
5			
6	9-1	Summary of Environmental Significance of License Renewal, the No Action Alternative, and Alternative Power Generation Using Closed-Cycle Cooling	9-8
7			
10	A-1	Individuals Providing Comments During Scoping Comment Period	A-3
11			
12	E-1	Consultation Correspondence	E-1
13	E-2	Federal, State, Local, and Regional Licenses, Permits, Consultations, and Other Approvals for Vermont Yankee Nuclear Power Station	E-3
14			
15			
16	F-1	Generic Environmental Impact Statement Environmental Issues Not Applicable to VYNPS	F-1
17			
19	G-1	VYNPS Core Damage Frequency	G-3
20	G-2	Breakdown of Population Dose by Containment Release Mode	G-5
21	G-3	VYNPS PSA Historical Summary	G-7
22	G-4	SAMA Cost-Benefit Screening Analysis for VYNPS	G-18
23	G-5	Uncertainty in the Calculated CDF for VYNPS	G-32
24			
25			

Executive Summary

By letter dated January 25, 2006, Entergy Nuclear Vermont Yankee, LLC, and Entergy Nuclear Operations, Inc. (Entergy), submitted an application to the U.S. Nuclear Regulatory Commission (NRC) to renew the operating license (OL) for Vermont Yankee Nuclear Power Station (VYNPS) for an additional 20 years. If the OL is renewed, State regulatory agencies and Entergy will ultimately decide whether the plant will continue to operate based on factors such as the need for power or other matters within the State's jurisdiction or the purview of the owners. If the OL is not renewed, then the plant must be shut down at or before the expiration date of the current OL, which is March 21, 2012. Should the NRC staff's license renewal review not be completed by this date, the plant may continue to operate past that date until the NRC staff has taken final action to either approve or deny the license renewal.

The NRC has implemented Section 102 of the National Environmental Policy Act (NEPA), Title 42, Section 4321, of the *United States Code* (42 USC 4321) in Title 10, Part 51, of the *Code of Federal Regulations* (10 CFR Part 51). In 10 CFR 51.20(b)(2), the Commission requires preparation of an Environmental Impact Statement (EIS) or a supplement to an EIS for renewal of a reactor OL. In addition, 10 CFR 51.95(c) states that the EIS prepared at the OL renewal stage will be a supplement to the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, Volumes 1 and 2.^(a)

Upon acceptance of the Entergy application, the NRC began the environmental review process described in 10 CFR Part 51 by publishing a Notice of Intent to prepare an EIS and conduct scoping. The NRC staff visited the VYNPS site in May 2006, conducted an open house on June 6, 2006, at which comments were accepted, and held public scoping meetings on June 7, 2006, in Brattleboro, Vermont. In the preparation of this draft Supplemental Environmental Impact Statement (SEIS) for VYNPS, the NRC staff reviewed the Entergy Environmental Report (ER) and compared it with the GEIS, consulted with other agencies, conducted an independent review of the issues following the guidance set forth in NUREG-1555, Supplement 1, *Standard Review Plans for Environmental Reviews for Nuclear Power Plants, Supplement 1: Operating License Renewal*, and considered the public comments received during the scoping process. The public comments received during the scoping process that were considered to be within the scope of the environmental review are provided in Appendix A, Part 1, of this draft SEIS.

The NRC staff will hold two public meetings in Brattleboro, Vermont, in January 2007, to describe the preliminary results of the NRC environmental review, to answer questions, and to provide members of the public with information to assist them in formulating comments on this draft SEIS. When the comment period ends, the NRC staff will consider and address all of the comments received. These comments will be addressed in Appendix A, Part 2, of the final SEIS.

(a) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and its Addendum 1.

Executive Summary

This draft SEIS includes the NRC staff's preliminary analysis that considers and weighs the environmental effects of the proposed action, the environmental impacts of alternatives to the proposed action, and mitigation measures for reducing or avoiding adverse effects. It also includes the NRC staff's preliminary recommendation regarding the proposed action.

The Commission has adopted the following statement of purpose and need for license renewal from the GEIS:

The purpose and need for the proposed action (renewal of an operating license) is to provide an option that allows for power generation capability beyond the term of a current nuclear power plant operating license to meet future system generating needs, as such needs may be determined by State, utility, and, where authorized, Federal (other than NRC) decisionmakers.

The evaluation criterion for the NRC staff's environmental review, as defined in 10 CFR 51.95(c)(4) and the GEIS, is to determine

... whether or not the adverse environmental impacts of license renewal are so great that preserving the option of license renewal for energy-planning decisionmakers would be unreasonable.

Both the statement of purpose and need and the evaluation criterion implicitly acknowledge that there are factors, in addition to license renewal, that will ultimately determine whether an existing nuclear power plant continues to operate beyond the period of the current OL.

NRC regulations (10 CFR 51.95(c)(2)) contain the following statement regarding the content of SEISs prepared at the license renewal stage:

The supplemental environmental impact statement for license renewal is not required to include discussion of need for power or the economic costs and economic benefits of the proposed action or of alternatives to the proposed action except insofar as such benefits and costs are either essential for a determination regarding the inclusion of an alternative in the range of alternatives considered or relevant to mitigation. In addition, the supplemental environmental impact statement prepared at the license renewal stage need not discuss other issues not related to the environmental effects of the proposed action and the alternatives, or any aspect of the storage of spent fuel for the facility within the scope of the generic determination in § 51.23(a) ("Temporary storage of spent fuel after cessation of reactor operation—generic determination of no significant environmental impact") and in accordance with § 51.23(b).

The GEIS contains the results of a systematic evaluation of the consequences of renewing an OL and operating a nuclear power plant for an additional 20 years. It evaluates 92 environmental issues using the NRC's three-level standard of significance – SMALL, MODERATE, or LARGE – developed using the Council on Environmental Quality guidelines. The following definitions of the three significance levels are set forth in footnotes to Table B-1 of 10 CFR Part 51, Subpart A, Appendix B:

SMALL – Environmental effects are not detectable or are so minor that they will neither destabilize nor noticeably alter any important attribute of the resource.

MODERATE – Environmental effects are sufficient to alter noticeably, but not to destabilize, important attributes of the resource.

LARGE – Environmental effects are clearly noticeable and are sufficient to destabilize important attributes of the resource.

For 69 of the 92 issues considered in the GEIS, the analysis in the GEIS reached the following conclusions:

- (1) The environmental impacts associated with the issue have been determined to apply either to all plants or, for some issues, to plants having a specific type of cooling system or other specified plant or site characteristics.
- (2) A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to the impacts (except for collective offsite radiological impacts from the fuel cycle and from high-level waste and spent fuel disposal).
- (3) Mitigation of adverse impacts associated with the issue has been considered in the analysis, and it has been determined that additional plant-specific mitigation measures are not likely to be sufficiently beneficial to warrant implementation.

These 69 issues were identified in the GEIS as Category 1 issues. In the absence of new and significant information, the NRC staff relied on conclusions as amplified by supporting information in the GEIS for issues designated as Category 1 in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B.

Of the 23 issues that do not meet the criteria set forth above, 21 are classified as Category 2 issues requiring analysis in a plant-specific supplement to the GEIS. The remaining two issues, environmental justice and chronic effects of electromagnetic fields, were not categorized. Environmental justice was not evaluated on a generic basis and must be addressed in a plant-specific supplement to the GEIS. Information on the chronic effects of electromagnetic fields was not conclusive at the time the GEIS was prepared.

Executive Summary

This draft SEIS documents the NRC staff's consideration of all 92 environmental issues identified in the GEIS. The NRC staff considered the environmental impacts associated with alternatives to license renewal and compared the environmental impacts of license renewal and the alternatives. The alternatives to license renewal that were considered include the no-action alternative (not renewing the OL for VYNPS) and alternative methods of power generation. Based on projections made by the U.S. Department of Energy's Energy Information Administration, gas- and coal-fired generation appear to be the most likely power-generation alternatives if the power from VYNPS is replaced. These alternatives are evaluated assuming that the replacement power-generation plant is located at either the VYNPS site or at some other unspecified alternate location.

Entergy and the NRC staff have established independent processes for identifying and evaluating the significance of any new information on the environmental impacts of license renewal. Neither Entergy nor the NRC staff has identified information that is both new and significant related to Category 1 issues that would call into question the conclusions in the GEIS. Similarly, neither the scoping process nor the NRC staff has identified any new issue applicable to VYNPS that has a significant environmental impact. Therefore, the NRC staff relies upon the conclusions of the GEIS for all of the Category 1 issues that are applicable to VYNPS.

Entergy's license renewal application presents an analysis of the Category 2 issues. The NRC staff has reviewed the Entergy analysis for each issue and has conducted an independent review of each issue. Three Category 2 issues are not applicable because they are related to plant design features or site characteristics not found at VYNPS. Four Category 2 issues are not discussed in this draft SEIS because they are specifically related to refurbishment. Entergy has stated that its evaluation of structures and components, as required by 10 CFR 54.21, did not identify any major plant refurbishment activities or modifications as necessary to support the continued operation of VYNPS for the license renewal period. In addition, any replacement of components or additional inspection activities are within the bounds of normal plant operation and are not expected to affect the environment outside of the bounds of the plant operations evaluated in the U.S. Atomic Energy Commission's 1972 *Final Environmental Statement Related to Operation of the Vermont Yankee Nuclear Power Station, Vermont Yankee Nuclear Power Corporation*.

Fourteen Category 2 issues related to operational impacts and postulated accidents during the renewal term, as well as environmental justice and chronic effects of electromagnetic fields, are discussed in detail in this draft SEIS. Five of the Category 2 issues and environmental justice apply to both refurbishment and to operation during the renewal term and are only discussed in this draft SEIS in relation to operation during the renewal term. For all 14 Category 2 issues and environmental justice, the NRC staff concludes that the potential environmental effects are of SMALL significance in the context of the standards set forth in the GEIS. In addition, the NRC staff determined that appropriate Federal health agencies have not reached a consensus

Executive Summary

1 on the existence of chronic adverse effects from electromagnetic fields. Therefore, no further
2 evaluation of this issue is required. For severe accident mitigation alternatives (SAMAs), the
3 NRC staff concludes that a reasonable, comprehensive effort was made to identify and evaluate
4 SAMAs. Based on its review of the SAMAs for VYNPS and the plant improvements already
5 made, the NRC staff concludes that several candidate SAMAs are potentially cost-beneficial.
6 However, none of these SAMAs relate to adequately managing the effects of aging during the
7 period of extended operation. Therefore, they need not be implemented as part of license
8 renewal pursuant to 10 CFR Part 54.

9
10 Mitigation measures were considered for each Category 2 issue. Current measures to mitigate
11 the environmental impacts of plant operation were found to be adequate, and no additional
12 mitigation is warranted. However, under the provisions of the Clean Water Act 316(b) Phase II
13 regulations, the Vermont Department of Environmental Conservation may impose further
14 restrictions or require modifications to the cooling system to reduce the impacts on aquatic
15 resources from entrainment and impingement.

16
17 Cumulative impacts of past, present, and reasonably foreseeable future actions were
18 considered, regardless of what agency (Federal or non-Federal) or person undertakes such
19 other actions. For purposes of this analysis, where VYNPS license renewal impacts are
20 deemed to be SMALL, the NRC staff concluded that these impacts would not result in significant
21 cumulative impacts on potentially affected resources.

22
23 If the VYNPS OL is not renewed and the plant ceases operation on or before the expiration of
24 its current OL, then the adverse impacts of likely alternatives would not be smaller than those
25 associated with continued operation of VYNPS. The impacts may, in fact, be greater in some
26 areas.

27
28 The preliminary recommendation of the NRC staff is that the Commission determine that the
29 adverse environmental impacts of license renewal for VYNPS are not so great that preserving
30 the option of license renewal for energy-planning decisionmakers would be unreasonable. This
31 recommendation is based on (1) the analysis and findings in the GEIS; (2) the ER submitted by
32 Entergy; (3) consultation with other Federal, State, and local agencies; (4) the NRC staff's own
33 independent review; and (5) the NRC staff's consideration of public comments received during
34 the scoping process.

Abbreviations/Acronyms

°	degree
μCi	microcurie(s)
μg	microgram(s)
μm	micrometer(s)
μSv	microsievert(s)
ac	acre(s)
AC	alternating current
ACC	averted cleanup and decontamination costs
AD	Anno Domini
ADAMS	Agencywide Documents Access and Management System
AEA	Atomic Energy Act
AEC	U.S. Atomic Energy Commission
AFB	Air Force Base
ALARA	as low as reasonably achievable
AOC	averted offsite property damage costs
AOE	averted occupational exposure
AOSC	averted onsite costs
APCD	Air Pollution Control Division
APE	averted public exposure
AQCR	Air Quality Control Region
ASME	American Society of Mechanical Engineers
ATWS	anticipated transient without scram
ATV	all-terrain vehicle
BA	biological assessment
BC	Before Christ
Bq	becquerel(s)
BO	Biological Opinion
Btu	British thermal unit(s)
BWR	boiling water reactor
BWROG	Boiling Water Reactor Owners Group
C	Celsius
CAA	Clean Air Act
CAB	Containment Access Building
CAFRA	Coastal Area Facility Review Act
CBS	Connecticut Botanical Society
CCW	component cooling water
CDC	Centers for Disease Control and Prevention
CDF	core damage frequency or combined disposal facility

Abbreviations/Acronyms

CDEP	Connecticut Department of Environmental Protection
CEQ	Council on Environmental Quality
CFR	<i>Code of Federal Regulations</i>
cfs	cubic feet per second
Ci	curie(s)
cm	centimeter(s)
CMA	Chemical Manufacturer's Association
CO	carbon monoxide
CO ₂	carbon dioxide
COE	cost of enhancement
CPC	Center for Plant Conservation
CVDEM	Code of Virginia, Department of Emergency Management
CWA	Clean Water Act
CZMA	Coastal Zone Management Act
d	day(s)
dBA	"A-weighted" decibel level
DBA	design-basis accident
DC	direct current
DDT	dichloro-diphenyl-trichloroethane
DOC	U.S. Department of Commerce
DOD	U.S. Department of Defense
DOE	U.S. Department of Energy
DOI	U.S. Department of the Interior
DOL	U.S. Department of Labor
Dominion	Dominion Nuclear North Anna, LLC
DOT	U.S. Department of Transportation
DPR	demonstration project reactor
DSM	demand-side management
EA	environmental assessment
EFH	essential fish habitat
EIA	Energy Information Administration
EIS	Environmental Impact Statement
ELF-EMF	extremely low frequency-electromagnetic field
Entergy	Entergy Nuclear Vermont Yankee, LLC, and Entergy Nuclear Operations, Inc.
EPA	U.S. Environmental Protection Agency
EPRI	Electric Power Research Institute, Inc.
EPU	extended power uprate
ER	Environmental Report
ESA	Endangered Species Act

Abbreviations/Acronyms

ESMP	Environmental Surveillance and Monitoring Program
Exelon	Exelon Generation Company, LLC
F	Fahrenheit
FAA	Federal Aviation Administration
FERC	Federal Energy Regulatory Commission
FES	Final Environmental Statement
FONSI	Finding of No Significant Impact
FPRA	Fire Probabilistic Risk Assessment
FR	<i>Federal Register</i>
FSAR	Final Safety Analysis Report
ft	foot (feet)
FWS	U.S. Fish and Wildlife Service
g	gram(s)
gal	gallon(s)
GEIS	Generic Environmental Impact Statement for License Renewal of Nuclear Plants, NUREG-1437
gpd	gallon(s) per day
gpm	gallon(s) per minute
HAC	hazardous air contaminant
HAP	hazardous air pollutant
HEPA	high-efficiency particulate air
HLW	high-level waste
hp	horsepower
hr	hour(s)
Hz	Hertz
ICE	internal combustion engine
IEEE	Institute of Electrical and Electronic Engineers
in.	inch(es)
INEEL	Idaho National Engineering and Environmental Laboratory
ISLOCA	interfacing systems loss-of-coolant accident
ISRA	Industrial Site Recovery Act
ITS	Incidental Take Statement
J	joule(s)
kg	kilogram(s)
km	kilometer(s)
kV	kilovolt(s)

Abbreviations/Acronyms

kW	kilowatt(s)
kWh	kilowatt hour(s)
L	liter(s)
lb	pound(s)
LERF	large early release frequency
LLC	limited liability company
LLTF	Lessons Learned Task Force
LOCA	loss-of-coolant accident
LOOP	loss of offsite power
m	meter(s)
m^2	square meter(s)
m^3	cubic meter(s)
mA	milliampere(s)
MAAP	Modular Accident Analysis Program
MACCS2	Melcor Accident Consequence Code System 2
MDFW	Massachusetts Department of Fisheries and Wildlife
MEI	maximally exposed individual
mg	milligram(s)
mi	mile(s)
mi^2	square mile(s)
min	minute(s)
mL	milliliter(s)
mm	millimeter(s)
MMACR	modified maximum averted cost risk
MMSC	Marine Mammal Stranding Center
mph	mile(s) per hour
mrad	millirad(s)
mrem	millirem(s)
mR	milliRoentgen(s)
MSL	mean sea level
mSv	millisievert(s)
MT	metric ton(s) (or tonne(s))
MTBE	methyl tertiary-butyl ether
MTU	metric ton(s)-uranium
MW	megawatt(s)
MWd	megawatt-day(s)
MW(e)	megawatt(s) electric
MW(t)	megawatt(s) thermal
MWh	megawatt hour(s)

Abbreviations/Acronyms

NAAQS	National Ambient Air Quality Standards
NAGPRA	Native American Graves Protection and Repatriation Act
NAS	National Academy of Sciences
NCDC	National Climatic Data Center
NCES	National Center for Educational Statistics
NCDC	National Climatic Data Center
NEPA	National Environmental Policy Act
NESC	National Electric Safety Code
NFSC	Northeast Fisheries Science Center
ng	nanogram(s)
NHDHR	New Hampshire Division of Historic Resources
NHFGD	New Hampshire Fish and Game Resources Department
NHPA	National Historic Preservation Act
NIEHS	National Institute of Environmental Health Sciences
NMFS	National Marine Fisheries Service
NO _x	nitrogen oxides
NOAA	National Oceanic and Atmospheric Administration
NPDES	National Pollutant Discharge Elimination System
NRC	U.S. Nuclear Regulatory Commission
NREL	National Renewable Energy Laboratory
NRHP	<i>National Register of Historic Places</i>
NRO	Office of New Reactors
NYSDEC	New York State Department of Environmental Conservation
ODC	ozone-depleting chemical
ODCM	Offsite Dose Calculation Manual
OL	operating license
PA	Preliminary Assessment
PAH	polycyclic aromatic hydrocarbon
PCB	polychlorinated biphenyl
pCi	picocurie(s)
PL	Public Law
PM _{2.5}	particulate matter, 2.5 microns or less in diameter
PM ₁₀	particulate matter, 10 microns or less in diameter
PNNL	Pacific Northwest National Laboratory
ppm	part(s) per million
ppt	part(s) per thousand
PRA	Probabilistic Risk Assessment
PSA	Probabilistic Safety Assessment
PSD	Prevention of Significant Deterioration
PTE	potential to emit

Abbreviations/Acronyms

RAI	request for additional information
REMP	radiological environmental monitoring program
RG	Regulatory Guide
RI	Remedial Investigation
RM	river mile
ROI	region of interest
ROW(s)	right(s)-of-way
RPC	replacement power cost
rpm	revolution(s) per minute
RRW	risk reduction worth
s	second(s)
SAMA	severe accident mitigation alternative
SAR	Safety Analysis Report
SAV	submerged aquatic vegetation
SCDHEC	South Carolina Department of Health and Environmental Control
SCR	selective catalytic reduction
SECA	Solid State Energy Conservation Alliance
SEIS	Supplemental Environmental Impact Statement
SER	Safety Evaluation Report
SERI	Systems Energy Resources, Inc.
SHPO	State Historic Preservation Office
SI	Site Investigation
SO ₂	sulfur dioxide
SO _x	sulfur oxides
SRHP	<i>State Register of Historic Places</i>
Sv	sievert
TDS	total dissolved solids
TEL	threshold effect level
TLAA	time-limited aging analysis
TLD	thermoluminescent dosimeter
TS	technical specification
TSS	total suspended solids
UFSAR	Updated Final Safety Analysis Report
U.S.	United States
USACE	U.S. Army Corps of Engineers
USC	<i>United States Code</i>
USCB	U.S. Census Bureau
USDA	U.S. Department of Agriculture
USGS	U.S. Geological Survey

VAC	volts alternating current
VANR	Vermont Agency of Natural Resources
VDEC	Vermont Department of Environmental Conservation
VDH	Vermont Department of Health
VELCO	Vermont Electric Power Company, Inc.
VNNHP	Vermont Nongame and Natural Heritage Program
VOC	volatile organic compound
VYNPS	Vermont Yankee Nuclear Power Station
W	watt(s)
yr	year(s)

1.0 Introduction

Under the U.S. Nuclear Regulatory Commission's (NRC's) environmental protection regulations in Title 10, Part 51, of the *Code of Federal Regulations* (10 CFR Part 51), which implement the National Environmental Policy Act (NEPA), renewal of a nuclear power plant operating license (OL) requires the preparation of an Environmental Impact Statement (EIS). In preparing the EIS, the NRC staff is required first to issue the statement in draft form for public comment, and then issue a final statement after considering public comments on the draft. To support the preparation of the EIS, the NRC staff has prepared a *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, Volumes 1 and 2 (NRC 1996, 1999).^(a) The GEIS is intended to (1) provide an understanding of the types and severity of environmental impacts that may occur as a result of license renewal of nuclear power plants under 10 CFR Part 54, (2) identify and assess the impacts that are expected to be generic to license renewal, and (3) support 10 CFR Part 51 to define the number and scope of issues that need to be addressed by the applicants in plant-by-plant renewal proceedings. Use of the GEIS guides the preparation of complete plant-specific information in support of the OL renewal process.

Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy), operates the Vermont Yankee Nuclear Power Station (VYNPS) in Vernon, Vermont, under OL DPR-28, which was issued by the NRC. This OL will expire in March 2012. By letter dated January 25, 2006, Entergy submitted an application to the NRC to renew the VYNPS OL for an additional 20 years under 10 CFR Part 54 (Entergy 2006a). Entergy is a *licensee* for the purposes of its current OL and an *applicant* for the renewal of the OL. Pursuant to 10 CFR 51.53(c) and 54.23, Entergy submitted an Environmental Report (ER) (Entergy 2006b) in which Entergy analyzed the environmental impacts associated with the proposed license renewal action, considered alternatives to the proposed action, and evaluated mitigation measures for reducing adverse environmental effects.

This report is the draft plant-specific supplement to the GEIS (the supplemental EIS (SEIS)) for the Entergy license renewal application. This draft SEIS is a supplement to the GEIS because it relies, in part, on the findings of the GEIS. The NRC staff will also prepare a separate Safety Evaluation Report in accordance with 10 CFR Part 54.

1.1 Report Contents

The following sections of this introduction (1) describe the background for the preparation of this draft SEIS, including the development of the GEIS and the process used by the NRC staff to

(a) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and its Addendum 1.

Introduction

1 assess the environmental impacts associated with license renewal, (2) describe the proposed
2 Federal action to renew the VYNPS OL, (3) discuss the purpose and need for the proposed
3 action, and (4) present the status of Entergy's compliance with environmental quality standards
4 and requirements that have been imposed by Federal, State, regional, and local agencies that
5 are responsible for environmental protection.

6
7 The ensuing chapters of this draft SEIS closely parallel the contents and organization of the
8 GEIS. Chapter 2 describes the site, power plant, and interactions of the plant with the
9 environment. Chapters 3 and 4, respectively, discuss the potential environmental impacts of
10 plant refurbishment and plant operation during the renewal term. Chapter 5 contains an
11 evaluation of potential environmental impacts of plant accidents and includes consideration of
12 severe accident mitigation alternatives. Chapter 6 discusses the uranium fuel cycle and solid
13 waste management. Chapter 7 discusses decommissioning, and Chapter 8 discusses
14 alternatives to license renewal. Finally, Chapter 9 summarizes the findings of the preceding
15 chapters and draws conclusions about the adverse impacts that cannot be avoided; the
16 relationship between short-term uses of man's environment and the maintenance and
17 enhancement of long-term productivity; and the irreversible or irretrievable commitment of
18 resources. Chapter 9 also presents the NRC staff's preliminary recommendation with respect to
19 the proposed license renewal action.

20
21 Additional information is included in appendixes. Appendix A contains public comments related
22 to the environmental review for license renewal and NRC staff responses to those comments.
23 Appendixes B through G, respectively, list the following:

- 25 • The preparers of the supplement,
- 26
- 27 • A chronology of the NRC staff's environmental review correspondence related to this
28 draft SEIS,
- 29
- 30 • The organizations contacted during the development of this draft SEIS,
- 31
- 32 • Entergy's compliance status in Table E-1 (this appendix also contains copies of
33 consultation correspondence prepared and sent during the evaluation process),
- 34
- 35 • GEIS environmental issues that are not applicable to VYNPS, and
- 36
- 37 • Severe accident mitigation alternatives (SAMAs).

1.2 Background

Use of the GEIS, which examines the possible environmental impacts that could occur as a result of renewing individual nuclear power plant OLs under 10 CFR Part 54, and the established license renewal evaluation process support the thorough evaluation of the impacts of renewal of OLs.

1.2.1 Generic Environmental Impact Statement

The NRC initiated a generic assessment of the environmental impacts associated with the license renewal term to improve the efficiency of the license renewal process by documenting the assessment results and codifying the results in the Commission's regulations. This assessment is provided in the GEIS, which serves as the principal reference for all nuclear power plant license renewal EISs.

The GEIS documents the results of the systematic approach that was taken to evaluate the environmental consequences of renewing the licenses of individual nuclear power plants and operating them for an additional 20 years. For each potential environmental issue, the GEIS (1) describes the activity that affects the environment, (2) identifies the population or resource that is affected, (3) assesses the nature and magnitude of the impact on the affected population or resource, (4) characterizes the significance of the effect for both beneficial and adverse effects, (5) determines whether the results of the analysis apply to all plants, and (6) considers whether additional mitigation measures would be warranted for impacts that would have the same significance level for all plants.

The NRC's standard of significance for impacts was established using the Council on Environmental Quality (CEQ) terminology for "significantly" (40 CFR 1508.27, which requires consideration of both "context" and "intensity"). Using the CEQ terminology, the NRC established three significance levels – SMALL, MODERATE, or LARGE. The definitions of the three significance levels are presented in the footnotes to Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, as follows:

SMALL – Environmental effects are not detectable or are so minor that they will neither destabilize nor noticeably alter any important attribute of the resource.

MODERATE – Environmental effects are sufficient to alter noticeably, but not to destabilize, important attributes of the resource.

LARGE – Environmental effects are clearly noticeable and are sufficient to destabilize important attributes of the resource.

1 Introduction

2 The GEIS assigns a significance level to each environmental issue, assuming that ongoing
3 mitigation measures would continue.

4 The GEIS includes a determination of whether the analysis of the environmental issue could be
5 applied to all plants and whether additional mitigation measures would be warranted. Issues
6 are assigned a Category 1 or a Category 2 designation. As set forth in the GEIS, Category 1
7 issues are those that meet all of the following criteria:

- 8
- 9 (1) The environmental impacts associated with the issue have been determined to apply
10 either to all plants or, for some issues, to plants having a specific type of cooling system
11 or other specified plant or site characteristics.
- 12
- 13 (2) A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to
14 the impacts (except for collective off-site radiological impacts from the fuel cycle and
15 from high-level waste and spent fuel disposal).
- 16
- 17 (3) Mitigation of adverse impacts associated with the issue has been considered in the
18 analysis, and it has been determined that additional plant-specific mitigation measures
19 are likely not to be sufficiently beneficial to warrant implementation.

20

21 For issues that meet the three Category 1 criteria, no additional plant-specific analysis is
22 required in this draft SEIS unless new and significant information is identified.

23

24 Category 2 issues are those that do not meet one or more of the criteria of Category 1, and,
25 therefore, additional plant-specific review for these issues is required.

26

27 In the GEIS, the NRC staff assessed 92 environmental issues and determined that 69 qualified
28 as Category 1 issues, 21 qualified as Category 2 issues, and 2 issues were not categorized.
29 The two uncategorized issues are environmental justice and chronic effects of electromagnetic
30 fields. Environmental justice was not evaluated on a generic basis and must be addressed in a
31 plant-specific supplement to the GEIS. Information on the chronic effects of electromagnetic
32 fields was not conclusive at the time the GEIS was prepared.

33

34 Of the 92 issues, 11 are related only to refurbishment, 6 are related only to decommissioning,
35 67 apply only to operation during the renewal term, and 8 apply to both refurbishment and
36 operation during the renewal term. A summary of the findings for all 92 issues in the GEIS is
37 codified in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B.

38

39 The NRC staff has identified a new issue that was not previously addressed in the GEIS related
40 to essential fish habitat (EFH). The consultation requirements of Section 305(b) of the
41 Magnuson-Stevens Fishery Conservation and Management Act, as amended by the National
42 Marine Fisheries Service Sustainable Fisheries Act of 1996, provide that Federal agencies must

1 consult with the Secretary of Commerce on all actions or proposed actions authorized, funded,
2 or undertaken by the agency that may adversely affect EFH. Therefore, concurrent with
3 issuance of this draft SEIS, the NRC staff has requested initiation of an EFH consultation with
4 the National Marine Fisheries Service. The EFH Assessment to support this consultation is
5 presented in Appendix E of this draft SEIS.

7 **1.2.2 License Renewal Evaluation Process**

9 An applicant seeking to renew its OL is required to submit an ER as part of its application. The
10 license renewal evaluation process involves careful review of the applicant's ER and assurance
11 that all new and potentially significant information not already addressed in or available during
12 the GEIS evaluation is identified, reviewed, and assessed to verify the environmental impacts of
13 the proposed license renewal.

15 In accordance with 10 CFR 51.53(c)(2) and (3), the ER submitted by the applicant must

- 17 • Provide an analysis of the Category 2 issues in Table B-1 of 10 CFR Part 51, Subpart A,
18 Appendix B, in accordance with 10 CFR 51.53(c)(3)(ii), and
- 20 • Discuss actions to mitigate any adverse impacts associated with the proposed action
21 and environmental impacts of alternatives to the proposed action.

23 In accordance with 10 CFR 51.53(c)(2), the ER does not need to

- 25 • Consider the economic benefits and costs of the proposed action and alternatives to the
26 proposed action except insofar as such benefits and costs are either (1) essential for
27 making a determination regarding the inclusion of an alternative in the range of
28 alternatives considered, or (2) relevant to mitigation;
- 30 • Consider the need for power and other issues not related to the environmental effects of
31 the proposed action and the alternatives;
- 33 • Discuss any aspect of the storage of spent fuel within the scope of the generic
34 determination in 10 CFR 51.23(a) in accordance with 10 CFR 51.23(b); and
- 36 • Contain an analysis of any Category 1 issue unless there is significant new information
37 on a specific issue – this is pursuant to 10 CFR 51.23(c)(3)(iii) and (iv).

39 New and significant information is (1) information that identifies a significant environmental
40 issue not covered in the GEIS and codified in Table B-1 of 10 CFR Part 51, Subpart A,

Introduction

1 Appendix B, or (2) information that was not considered in the analyses summarized in the GEIS
2 and that leads to an impact finding that is different from the finding presented in the GEIS and
3 codified in 10 CFR Part 51.

4
5 In preparing to submit its application to renew the VYNPS OL, Entergy developed a process to
6 ensure that information not addressed in or available during the GEIS evaluation regarding the
7 environmental impacts of license renewal for VYNPS would be properly reviewed before
8 submitting the ER, and to ensure that such new and potentially significant information related to
9 renewal of the OL for VYNPS would be identified, reviewed, and assessed during the period of
10 NRC review. Entergy reviewed the Category 1 issues that appear in Table B-1 of 10 CFR
11 Part 51, Subpart A, Appendix B, to verify that the conclusions of the GEIS remained valid with
12 respect to VYNPS. This review was performed by personnel from Entergy and its support
13 organization who were familiar with NEPA issues and the scientific disciplines involved in the
14 preparation of a license renewal ER.

15
16 The NRC staff also has a process for identifying new and significant information. That process
17 is described in detail in *Standard Review Plans for Environmental Reviews for Nuclear Power*
18 *Plants, Supplement 1: Operating License Renewal*, NUREG-1555, Supplement 1 (NRC 2000).
19 The search for new information includes (1) review of an applicant's ER and the process for
20 discovering and evaluating the significance of new information; (2) review of records of public
21 comments; (3) review of environmental quality standards and regulations; (4) coordination with
22 Federal, State, and local environmental protection and resource agencies; and (5) review of the
23 technical literature. New information discovered by the NRC staff is evaluated for significance
24 using the criteria set forth in the GEIS. For Category 1 issues where new and significant
25 information is identified, reconsideration of the conclusions for those issues is limited in scope to
26 the assessment of the relevant new and significant information; the scope of the assessment
27 does not include other facets of the issue that are not affected by the new information.

28
29 Chapters 3 through 7 discuss the environmental issues considered in the GEIS that are
30 applicable to VYNPS. At the beginning of the discussion of each set of issues, there is a table
31 that identifies the issues to be addressed and lists the sections in the GEIS where the issue is
32 discussed. Category 1 and Category 2 issues are listed in separate tables. For Category 1
33 issues for which there is no new and significant information, the table is followed by a set of
34 short paragraphs that state the GEIS conclusion codified in Table B-1 of 10 CFR Part 51,
35 Subpart A, Appendix B, followed by the NRC staff's analysis and conclusion. For Category 2
36 issues, in addition to the list of GEIS sections where the issue is discussed, the tables list the
37 subparagraph of 10 CFR 51.53(c)(3)(ii) that describes the analysis required and the draft SEIS
38 sections where the analysis is presented. The draft SEIS sections that discuss the Category 2
39 issues are presented immediately following the table.

1 The NRC prepares an independent analysis of the environmental impacts of license renewal
2 and compares these impacts with the environmental impacts of alternatives. The evaluation of
3 the Entergy license renewal application began with publication of a Notice of Acceptance for
4 docketing and opportunity for a hearing in the *Federal Register* (Volume 71, page 15220
5 (71 FR 15220) (NRC 2006a)) on March 27, 2006. The NRC staff published a Notice of Intent to
6 prepare an EIS and conduct scoping (71 FR 20733 (NRC 2006b)) on April 21, 2006. An open
7 house was held on June 6, 2006, at which comments were accepted, and two public scoping
8 meetings were held on June 7, 2006, in Brattleboro Vermont. Comments received during the
9 scoping period were summarized in the *Environmental Impact Statement Scoping Process:*
10 *Summary Report – Vermont Yankee Nuclear Power Station, Windham County, Vermont*
11 (NRC 2006c), dated October 30, 2006. Comments that are applicable to this environmental
12 review are presented in Part 1 of Appendix A.

13
14 The NRC staff followed the review guidance contained in NUREG-1555, Supplement 1
15 (NRC 2000). The NRC staff and contractors retained to assist the NRC staff visited the VYNPS
16 site on May 22 through 26, 2006, and again on August 8 through 10, 2006, to gather information
17 and to become familiar with the site and its environs. The NRC staff also reviewed the
18 comments received during scoping and consulted with Federal, State, regional, and local
19 agencies. Appendix C contains a chronological listing of correspondences related to the license
20 renewal process. A list of the organizations consulted is provided in Appendix D. Other
21 documents related to VYNPS were reviewed and are referenced in this draft SEIS.

22
23 This draft SEIS presents the NRC staff's analysis that considers and weighs the environmental
24 effects of the proposed renewal of the OL for VYNPS, the environmental impacts of alternatives
25 to license renewal, and mitigation measures available for avoiding adverse environmental
26 effects. Chapter 9, "Summary and Conclusions," provides the NRC staff's preliminary
27 recommendation to the Commission on whether or not the adverse environmental impacts of
28 license renewal are so great that preserving the option of license renewal for energy-planning
29 decisionmakers would be unreasonable.

30
31 A 75-day comment period will begin on the date of publication of the U.S. Environmental
32 Protection Agency Notice of Filing of the draft SEIS to allow members of the public to comment
33 on the preliminary results of the NRC staff's review. During this comment period, two public
34 meetings will be held in Battleboro, Vermont, in January 2007. During these meetings, the NRC
35 staff will describe the preliminary results of the NRC environmental review and answer
36 questions related to it to provide members of the public with information to assist them in
37 formulating their comments.

1.3 The Proposed Federal Action

2
3 The proposed Federal action is renewal of the OL for VYNPS. The current OL for VYNPS
4 expires on March 21, 2012. By letter dated January 25, 2006, Entergy submitted an application
5 to the NRC (Entergy 2006a) to renew this OL for an additional 20 years of operation (i.e., until
6 March 21, 2032).

7
8 VYNPS is located in the town of Vernon, Vermont, in Windham County on the west shore of the
9 Connecticut River. The plant is situated approximately 5 mi southeast of Brattleboro, Vermont,
10 and about 30 and 28 mi north of Northhampton and Amherst, Massachusetts, respectively.
11 VYNPS is a single-unit plant with a boiling water reactor and steam turbine supplied by General
12 Electric. The unit was originally licensed for a reactor core power of 1593 megawatts thermal
13 (MW(t)), with a net electrical capacity of 540 megawatts electric (MW(e)). However, a recently
14 approved power uprate has increased the power level to 1912 MW(t), with a corresponding
15 output of 650 MW(e). Plant cooling is provided by a closed-cycle, open-cycle, or hybrid-cycle
16 system that draws water from, and discharges water back to, the Connecticut River.

1.4 The Purpose and Need for the Proposed Action

20 Although a licensee must have a renewed license to operate a reactor beyond the term of the
21 existing OL, the possession of that license is just one of a number of conditions that must be
22 met for the licensee to continue plant operation during the term of the renewed license. Once
23 an OL is renewed, State regulatory agencies and the owners of the plant will ultimately decide
24 whether the plant will continue to operate based on factors such as the need for power or other
25 matters within the State's jurisdiction or the purview of the owners.

26 Thus, for license renewal reviews, the NRC has adopted the following definition of purpose and
27 need (GEIS Section 1.3):

30 The purpose and need for the proposed action (renewal of an operating license) is to
31 provide an option that allows for power generation capability beyond the term of a
32 current nuclear power plant operating license to meet future system generating needs,
33 as such needs may be determined by State, utility, and where authorized, Federal (other
34 than NRC) decisionmakers.

36 This definition of purpose and need reflects the Commission's recognition that, unless there are
37 findings in the safety review required by the Atomic Energy Act of 1954 or findings in the NEPA
38 environmental analysis that would lead the NRC to reject a license renewal application, the
39 NRC does not have a role in the energy-planning decisions of State regulators and utility
40 officials as to whether a particular nuclear power plant should continue to operate. From the

1 perspective of the licensee and the State regulatory authority, the purpose of renewing an OL is
2 to maintain the availability of the nuclear plant to meet system energy requirements beyond the
3 current term of the plant's license.

5 **1.5 Compliance and Consultations**

7 Entergy is required to hold certain Federal, State, and local environmental permits, as well as
8 meet relevant Federal and State statutory requirements. In its ER, Entergy (2006b) provided a
9 list of the authorizations from Federal, State, and local authorities for current operations as well
10 as environmental approvals and consultations associated with VYNPS license renewal.
11 Authorizations and consultations relevant to the proposed OL renewal action are included in
12 Appendix E.

14 The NRC staff has reviewed the list and consulted with the appropriate Federal, State, and local
15 agencies to identify any compliance or permit issues or significant environmental issues of
16 concern to the reviewing agencies. These agencies did not identify any new and significant
17 environmental issues. The ER states that Entergy is in compliance with applicable
18 environmental standards and requirements for VYNPS. The NRC staff has not identified any
19 environmental issues that are both new and significant.

21 **1.6 References**

23 10 CFR Part 51. *Code of Federal Regulations*, Title 10, Energy, Part 51, "Environmental
24 Protection Regulations for Domestic Licensing and Related Regulatory Functions."

26 10 CFR Part 54. *Code of Federal Regulations*, Title 10, Energy, Part 54, "Requirements for
27 Renewal of Operating Licenses for Nuclear Power Plants."

29 40 CFR Part 1508. *Code of Federal Regulations*, Title 40, *Protection of Environment*,
30 "Terminology and Index."

32 Atomic Energy Act of 1954 (AEA). 42 USC 2011, et seq.

34 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006a.
35 *License Renewal Application, Vermont Yankee Nuclear Power Station, Facility Operating*
36 *License No. DPR-28*. Docket No. 50-271. Brattleboro, Vermont. (January 25, 2006).

38 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006b.
39 *Applicant's Environmental Report – Operating License Renewal Stage, Vermont Yankee*
40 *Nuclear Power Station*. Docket No. 50-271. Brattleboro, Vermont. (January 25, 2006).

Introduction

- 1 National Environmental Policy Act of 1969 (NEPA), as amended. 42 USC 4321, et seq.
- 2
- 3 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement*
4 *for License Renewal of Nuclear Plants*. NUREG-1437, Vols. 1 and 2, Washington, D.C.
- 5
- 6 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement*
7 *for License Renewal of Nuclear Plants, Main Report*, "Section 6.3 – Transportation, Table 9.1,
8 Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants, Final
9 Report." NUREG-1437, Vol. 1, Addendum 1, Washington, D.C.
- 10
- 11 U.S. Nuclear Regulatory Commission (NRC). 2000. *Standard Review Plans for Environmental*
12 *Reviews for Nuclear Power Plants, Supplement 1: Operating License Renewal*. NUREG-1555,
13 Supplement 1, Washington, D.C.
- 14
- 15 U.S. Nuclear Regulatory Commission (NRC). 2006a. "Entergy Nuclear Operations, Inc.,
16 Vermont Yankee Nuclear Power Station; Notice of Acceptance for Docketing of the Application
17 and Notice of Opportunity for Hearing Regarding Renewal of Facility Operating License
18 No. DRP-28 for an Additional 20-Year Period." *Federal Register*, Vol. 71, No. 58,
19 pp. 15220–15223. Washington, D.C. (March 27, 2006).
- 20
- 21 U.S. Nuclear Regulatory Commission (NRC). 2006b. "Entergy Nuclear Operations, Inc.,
22 Vermont Yankee Nuclear Power Station; Notice of Intent to Prepare an Environmental Impact
23 Statement and Conduct Scoping Process." *Federal Register*, Vol. 71, No. 77,
24 pp. 20733–20735. Washington, D.C. (April 21, 2006).
- 25
- 26 U.S. Nuclear Regulatory Commission (NRC). 2006c. *Environmental Impact Statement Scoping*
27 *Process: Summary Report – Vermont Yankee Nuclear Power Station, Windham County,*
28 *Vermont*. Washington, D.C. (October 30, 2006).

1 **2.0 Description of Nuclear Power Plant and Site 2 and Plant Interaction with the Environment**

3

4

5 The Vermont Yankee Nuclear Power Station (VYNPS) is owned and operated by Entergy
6 Nuclear Vermont Yankee, LLC (Entergy), a wholly owned subsidiary of Entergy Nuclear
7 Operations, Inc. VYNPS is located on the shore of the Connecticut River in the town of Vernon,
8 in Windham County, Vermont. The plant consists of a single boiling water reactor that produces
9 steam that turns turbines to generate electricity. The site includes a reactor building, a turbine
10 building, an office building, radioactive waste buildings, a stack, and several other support
11 buildings. The plant and its environs are described in Section 2.1, and the plant's interaction
12 with the environment is presented in Section 2.2.

13

14 **2.1 Plant and Site Description and Proposed Plant Operation 15 During the Renewal Term**

16

17 This section provides a description of the VYNPS plant, the larger site on which it is located,
18 and the regional setting. In addition, summary descriptions are provided for the reactor system,
19 radioactive waste management and effluent control systems, the cooling and auxiliary water
20 systems, the nonradioactive waste management systems, plant operation and maintenance, as
21 well as the power transmission system.

23 **2.1.1 External Appearance and Setting**

24

25 The VYNPS is located on approximately 125 ac of land owned by Entergy and a narrow strip of
26 land between the Connecticut River and the east boundary of the VYNPS property to which
27 Entergy has perpetual rights and easements from its owner. The property is approximately 5 mi
28 southeast of Brattleboro, Vermont, and about 28 mi north of Amherst, Massachusetts. Besides
29 Brattleboro, Vermont, the only other settlement of any size within 5 mi of the site is the town of
30 Hinsdale, New Hampshire, east of the Connecticut River. Figures 2-1 and 2-2 show the site
31 location and features within 50 mi and 6 mi, respectively (Entergy 2006a).

32

33 The 125-ac VYNPS property boundaries are shown in Figure 2-3. The property is bounded on
34 the north, south, and west by privately owned land and on the east by the Connecticut River.
35 The site is surrounded by an exclusion area, as shown in Figure 2-4. No residences are
36 permitted within this exclusion zone. During an accident condition of radiological significance,
37 the licensee would possess the capability for exercising immediate and direct control over
38 activities in the exclusion area for the purpose of radiological protection. The nearest
39 residences lie outside the site boundary to the southwest at 0.26 mi. The areas adjacent to the
40 site to the north, west, and south are primarily farm and pasture lands.

Plant and the Environment




Figure 2-1. Location of Vermont Yankee Nuclear Power Station, 50-mi Region
(Source: Entergy 2006a)




Figure 2-2. Location of Vermont Yankee Nuclear Power Station,
6-mi Region (Source: Entergy 2006a)

Plant and the Environment




Figure 2-3. Vermont Yankee Nuclear Power Station Site Layout (Source: Entergy 2006a)




Figure 2-4. Vermont Yankee Nuclear Power Station Exclusion Zone
(Source: Entergy 2006a)

Plant and the Environment

The area within the 5-mi radius is predominantly rural with the exception of a portion of the town of Brattleboro, Vermont, and the town of Hinsdale, New Hampshire. Between 75 and 80 percent of the area within 5 mi of the station is wooded. The remainder is occupied by farms and small industries. Downstream of the plant on the Connecticut River is the Vernon Hydroelectric Station.

There are no Native American lands within a 50-mi radius of VYNPS. There are a number of Federal and State lands within the 50-mi radius of the VYNPS, as shown in Figure 2-5.

2.1.2 Reactor Systems

VYNPS is a nuclear-powered, steam electric-generating facility that began commercial operation on November 30, 1972. VYNPS is powered by a boiling water reactor manufactured by General Electric and features a Mark I containment. The unit was originally licensed for a reactor core power of 1593 megawatts-thermal (MW(t)), with a net electrical capacity of 540 MW(e). However, on March 2, 2006, the U.S. Nuclear Regulatory Commission (NRC) approved a power uprate to increase the maximum core power level from 1593 MW(t) to 1912 MW(t). The gross electrical output corresponding to 1912 MW(t) is approximately 650 MW(e).

The VYNPS site layout is shown in Figure 2-3. Major buildings and structures include the reactor building and primary containment, turbine building, control building, radioactive waste building, intake structure, cooling towers, and main stack. The site has begun construction of an independent spent fuel storage facility for dry storage of spent nuclear fuel onsite.

The reactor's primary containment is a pressure suppression system consisting of a drywell, a pressure-absorption chamber, and vent pipes connecting the drywell to the pressure-absorption chamber. The drywell is a steel pressure vessel with a spherical lower portion and a cylindrical upper portion. The pressure-absorption chamber is a steel pressure vessel in the shape of a torus, located below and encircling the drywell, and is approximately half-filled with water. The vent system from the drywell terminates below the water level in the torus, so that in the event of a pipe failure in the drywell, the released steam passes directly to the water where it is condensed (Entergy 2004c).

Secondary containment is provided by the reactor building, which is constructed of reinforced concrete to the refueling floor. Above the refueling floor, the structure is a steel framework with insulated, corrosion-resistant metal siding. The reactor building also houses all refueling equipment, including the spent fuel storage pool and the new fuel storage vault.

The reactor fuel is uranium dioxide pellets sealed in Zircaloy-2 tubes. The fuel is enriched to no more than 5 percent. The reactor is refueled on a 18-month refueling cycle. Spent fuel is




Figure 2-5. Major State and Federal Lands Within 50 mi of Vermont Yankee Nuclear Power Station (Source: Entergy 2006a)

Plant and the Environment

1 currently stored onsite in the storage pool. Some of the spent fuel currently stored in the spent
2 fuel pool will be moved to the independent spent fuel storage facility being constructed onsite.

4 2.1.3 Cooling and Auxiliary Water Systems

5
6 The Connecticut River is the source for cooling water for the main condenser at the VYNPS.
7 Cooling river water can be circulated through the station in one of three modes of operation:
8 open-cycle (also called once-through cooling), hybrid-cycle, or closed-cycle. The mode of
9 operation is selected by the applicant to limit the heat discharged to the river to ensure
10 compliance with the thermal limits of the National Pollutant Discharge Elimination System
11 (NPDES) permit (Entergy 2004c, NRC 2006a).

12
13 In all three modes, the circulating water exits the condenser and flows into the discharge
14 structure. In the open-cycle mode, after entering the discharge structure the water returns to
15 the river through an aerating structure. The cooling towers are not used in the open-cycle mode
16 of operation. In both the closed-cycle and hybrid cycle, after entering the discharge structure,
17 the circulating water is pumped up to the cooling towers. After being cooled, the water returns
18 to a weir collection chamber in the discharge structure. A gate inside this chamber allows all or
19 a portion of the water to return to the intake structure. In the closed-cycle mode all of the tower
20 cooled water is returned to the intake structure for re-use in the condenser. In the hybrid cycle
21 mode of operation a portion of the water returns to the intake structure while the remainder is
22 returned to the river through the aerating structure. The exact amount of water returned to both
23 the intake structure and the river in hybrid mode depends on seasonal variation in
24 environmental parameters, particularly the temperature in the Connecticut River. Blowdown
25 from the circulating water system is discharged to the river through piping near the discharge
26 structure. Make-up water lost from blowdown and evaporation from the cooling towers is
27 withdrawn from the river. VYNPS has two mechanical draft cooling towers, one of which has a
28 deep basin holding 1.4 million gal of water for emergency cooling (VDEC 2003, VDEC 2006a,
29 Entergy 2004c).

30
31 The concrete intake structure, located on the west bank of Vernon Pool just east of the plant,
32 has three pump bays for three circulating water pumps and two service water bays for four
33 service water pumps and two fire water pumps. All bays are provided with trash racks and
34 traveling water screens to strain debris in the intake water.

35
36 Water treatment equipment at the intake structure delivers chlorine and bromine to both the
37 circulating water and service water pump bays, to minimize marine growth and bacteria in the
38 system. Corrosive control agents and chemicals to adjust pH are also added (see Table 2-3,
39 Section 2.2.3.1) (Entergy 2004c).

40
41 In its report to the State of air pollutant emissions for calendar year 2005, Entergy reported
42 release of four Category III HACs from the operation of its cooling tower (Entergy 2006j). The

specific chemicals were components of two biocides in use during the period. Spectrus NX-1104, manufactured by Betzdearborn, a subsidiary of Hercules Canada, contains dodecylguanidine hydrochloride, ethyl alcohol, and isopropyl alcohol (Betzdearborn 2003). Nalco H-550, manufactured by Ondeo Nalco, contains glutaraldehyde (Nalco 2006).

Cooling water for the main condenser is drawn from the Connecticut River using three vertical circulating water pumps, which provide a total flow capacity of 360,000 gpm. Cooling water returns to the Connecticut River through the discharge structure near the riverbank southeast of the plant (at NPDES Outfall 1). The structure is approximately 199 ft long by 108 ft wide by 46 ft deep. The discharge structure consists of an aerating spillway that provides air entrainment, energy dissipation, and warm water dispersion of the discharged cooling water. Sheet piling is used to prevent scouring of the aerating apron (Entergy 2004c).

The thermal limits of the plant's discharge to Vernon Pool are regulated through Vermont's NPDES program (see also Section 2.2.3.1). During the NPDES winter period (October 15 through May 15), the NPDES permit requires that the plant-induced temperature at downstream River Monitoring Station 3 never exceed 65°F and that the increase in temperature above the ambient temperature at that station never exceeds 13.4°F (or a rate of increase of 5°F per hour). During the NPDES summer period (May 16 through October 14), the temperature increase at Station 3 is required to be less than 2°F above the ambient temperature for water that is above 63°F and less than 5°F above the ambient temperature for water that is below 55°F (VDEC 2003).

Flow limitations for circulating water discharged at the discharge structure are 543 million gpd for open- and hybrid-cycle cooling modes and 12.1 million gpd for closed-cycle cooling modes (see Table 2-1, Section 2.2.2.1).

Water is also drawn from the Connecticut River for the plant's service water system, which provides water for turbine and reactor auxiliary equipment cooling, reactor shutdown cooling, and miscellaneous services. Four vertical, two-stage, turbine-like pumps, located at the north end of the intake structure, supply water to the service water system, providing a total flow capacity of 13,400 gpm. The service water system also provides water to the normal and standby fuel pool cooling subsystems for the reactor building's spent fuel pool (Entergy 2004c). Service water is returned to the river via the discharge structure.

Two pumps, with a total flow capacity of 5000 gpm, are located at the north end of the intake structure to withdraw water from the Connecticut River for fire protection. Water is drawn as needed to supply the automatic wet pipe sprinkler systems, standpipes, and hose stations throughout the plant (Entergy 2004c).

2.1.4 Radioactive Waste Management Systems and Effluent Control Systems

Radioactive wastes resulting from plant operations are classified as liquid, gaseous, and solid wastes. VYNPS uses liquid, gaseous, and solid radioactive waste management systems to collect and process these wastes before they are released to the environment or shipped to offsite disposal facilities. The waste disposal system meets the release limits as set forth in Title 10, Part 20, of the *Code of Federal Regulations* (10 CFR Part 20) and the dose design objectives of 10 CFR Part 50, Appendix I ("Numerical Guide for Design Objectives and Limiting Conditions for Operation to Meet the Criterion 'As Low As is Reasonably Achievable' for Radiological Material in Light-Water-Cooled Nuclear Power Reactor Effluents"), and controls the processing, disposal, and release of radioactive wastes. Unless otherwise noted, the description of the radioactive waste management systems and effluent control systems for liquid, gaseous, and solid wastes presented here (Sections 2.1.4.1, 2.1.4.2, and 2.1.4.3, respectively) is based on information provided in the applicant's Environmental Report (ER) (Entergy 2006a) or the VYNPS Updated Final Safety Analysis Report (UFSAR) (Entergy 2004c) and was confirmed during the NRC staff's site visit May 22-25, 2006.

The liquid and gaseous radioactive waste systems are designed to reduce the radioactivity in the wastes such that the concentrations in routine discharges are below the applicable regulatory limits. If necessary, liquid waste releases to the Connecticut River occur in batches that are monitored during discharge and diluted by the circulating water. VYNPS has not had any radioactive liquid discharges to the Connecticut River over the last 5 years and does not plan to release radioactive liquids in the future. Gaseous wastes are processed and routed to a common tall stack for release to the atmosphere. The gaseous effluents are continuously monitored, and discharge is stopped if the effluent concentrations exceed predetermined levels.

The Offsite Dose Calculation Manual (ODCM) for VYNPS (Entergy 2002c) describes the methods used for calculating radioactivity concentrations in the environment and the estimated potential offsite doses associated with liquid and gaseous effluents from VYNPS. The ODCM also specifies controls for release of liquid and gaseous effluents to ensure compliance with NRC regulations.

Radioactive fission products build up within the fuel as a consequence of the fission process. These fission products are contained in the sealed fuel rods; however, as a result of fuel cladding failure and corrosion, small quantities escape from the fuel rods and contaminate the reactor coolant. Neutron activation of the primary coolant system is also responsible for coolant contamination. Nonfuel solid wastes result from treating and separating radionuclides from gases and liquids and from removing contaminated material from various reactor areas. Solid wastes also consist of reactor components, equipment, and tools removed from service as well as contaminated protective clothing, paper, rags, and other trash generated from plant operations, design modification, and routine maintenance activities. The solid waste disposal

1 system is designed to package solid wastes for removal to offsite treatment or disposal facilities.
2 Some solid low-level waste is stored onsite temporarily before offsite shipment.

3
4 Fuel assemblies that have exhausted a certain percentage of their fuel and that are removed
5 from the reactor core for disposal are called spent fuel. VYNPS currently operates on a
6 18-month refueling cycle. Spent fuel is stored in a spent fuel pool in the reactor building. Some
7 of the older spent fuel will also be stored in an onsite independent spent fuel storage
8 installation.

9
10 **2.1.4.1 Liquid Waste Processing Systems and Effluent Controls**

11
12 The liquid radioactive waste system receives and processes all radioactive or potentially
13 radioactive liquid wastes from multiple sources. These wastes are collected in sumps and drain
14 tanks at various locations throughout the plant and then transferred to the appropriate collection
15 tanks for treatment, storage, and disposal. Although VYNPS operates as a zero discharge plant
16 relative to radioactive liquids, very low levels of radioactivity in liquid effluents from VYNPS
17 could be released to the Connecticut River in accordance with limits specified in NRC
18 regulations, VYNPS ODCM, and the NPDES permit.

19
20 Included in the liquid radioactive waste system are (1) floor and equipment drain systems for
21 handling potentially radioactive wastes; and (2) tanks, piping, pumps, process equipment,
22 instrumentation, and auxiliaries necessary to collect, process, store, and dispose of potentially
23 radioactive wastes. The equipment used by the liquid radioactive waste system is located in the
24 radioactive waste building, with the exception of the cleanup phase separator equipment
25 (located in the reactor building), the condensate backwash receiving tank and pump (located in
26 the turbine building), and waste sample tanks, floor drain sample tank, and waste surge tank
27 (located outdoors at grade level).

28
29 The liquid wastes received are of different purities and chemical compositions. The liquid
30 radioactive waste system is used to process these wastes to make them suitable for reuse
31 within the plant or, if necessary, for release to the discharge structure where dilution occurs with
32 the circulating water.

33
34 The principal sources of liquid wastes are equipment leakage, drainage, and process waste
35 produced by plant operations. This is a batch-type system wherein the wastes are separately
36 collected and processed. The liquid wastes are broadly categorized as high-purity, low-purity,
37 chemical, or detergent wastes. The terms "high" and "low" purity refer to conductivity, not
38 radioactivity.

39
40 High-purity (low-conductivity) liquid wastes are collected in the waste collector tank from a
41 variety of sources, including the equipment drain sumps in the drywell, reactor building,
42 radioactive waste building, and turbine building, and from decants from cleanup and

Plant and the Environment

condensate phase separators, resin rinse, and rapid dewatering systems. They are processed by filtration and ion exchange through waste collector filter or fuel pool filters and waste dimineralizers, as required. After processing, the liquid is pumped to the waste sample tank where it is sampled and either recycled for additional processing or transferred to the condensate storage tank for reuse in the nuclear system. VYNPS has operated as a zero radioactive liquid discharge facility over the last several years and intends to continue to operate in the same mode. However, should discharge be necessary, wastes would be sampled on a batch basis and analyzed for water quality and radioactivity. If high-purity requirements are met, the contents would be transferred to the condensate storage tank. If high-purity requirements are not met, the liquid wastes would be recycled through the radioactive waste system or could be discharged. Discharges would be monitored and the release would be automatically terminated if the monitor set points are exceeded.

Low-purity (high-conductivity) liquid wastes are collected in the floor drain collector tank, which receives wastes from the floor drains of the drywell, reactor building, radioactive waste building, and the turbine building. These wastes generally have low concentrations of radioactive impurities, and processing consists of filtration and combination with high-purity waste in the waste collector tank, with subsequent processing as high-purity waste.

Chemical wastes are collected in the chemical waste tank and are from the following sources: chemical laboratory waste, laboratory drains, and sample sinks. When the chemical concentrations are low enough, these wastes may be neutralized and processed by filtration in the same manner and with the same equipment as the low-purity wastes. When the chemical concentrations are too high, these wastes may receive additional processing.

Detergent wastes are collected in the detergent waste tank. These wastes are primarily from radioactive decontamination solutions that contain detergents. Because detergents will foul ion exchange resins, their use is minimized in the plant. VYNPS uses an offsite cleaning laundry, thus minimizing the quantity of detergent waste generated. Detergent wastes are normally dumped to the floor drain collector tank for processing with low-purity waste.

The NRC staff reviewed the annual liquid effluent releases reported in the VYNPS Annual Radioactive Effluent Release Reports for the years 2001 through 2005 (Entergy 2002b, 2003b, 2004b, 2005b, 2006c). During this 5-year period, there were no routine or unplanned liquid effluent releases from the liquid radioactive waste processing system. In 2006, NRC issued a license amendment to Entergy that allowed Entergy to increase the thermal power of the VYNPS by 20 percent (to 1912 MW(t)). In the environmental assessment (EA) and the Finding of No Significant Impact (FONSI) accompanying the license amendment (NRC 2006a), it is estimated that the volume of liquid radioactive waste generated could increase by 1.2 percent of the current total as a consequence of the 20-percent extended power uprate (EPU). It is also stated in the EA that this is an increase in the volume of radioactive waste that would require processing, not an increase in radioactive liquid effluent. It is also indicated that the liquid waste

1 processing system at VYNPS was designed to handle the increased volume of radioactive
2 waste. Entergy does not anticipate the discharge of any radioactive liquid waste during the
3 renewal period.

4

5 **2.1.4.2 Gaseous Waste Processing Systems and Effluent Controls**

6

7 At VYNPS, the gaseous radioactive waste system includes subsystems that process gases from
8 the main condenser air ejectors, the startup vacuum pump, and the gland seal condenser. This
9 system also processes gases from the standby treatment system and most station ventilation
10 exhausts including from portions of the turbine building, reactor building, and radioactive waste
11 building. The processed gases are routed to the plant stack for dilution and elevated release
12 (318 ft above grade) to the atmosphere. VYNPS ventilation systems are designed to maintain
13 gaseous effluents at levels as low as reasonably achievable. This is done by a combination of
14 holdups for decay of short-lived radioactive material, filtration, and monitoring. Continuous
15 radiation monitoring is provided at various points in the system.

16 During normal operation, noncondensable gases are produced in the reactor coolant and must
17 be continuously removed to maintain turbine efficiency. These gases include hydrogen and
18 oxygen from radiolysis of water, gases introduced or generated as a result of chemical control in
19 the primary system, mixed fission products, activation products, and air from condenser
20 in-leakage. Off-gas is discharged from the condenser via steam-jet air ejectors and passed
21 through holdup piping and high-efficiency particulate air (HEPA) filters. The off-gas is then
22 passed through a hydrogen dilution and recombiner system where hydrogen and oxygen are
23 catalytically recombined into water. After recombination, the off-gas is routed to a chiller to
24 remove moisture, and then through seven charcoal delay beds that provide a long delay period
25 for radioisotope decay as the off-gas passes through. The off-gas is then passed through
26 HEPA filters and vacuum pumps before it is routed to the 318-ft plant stack for release to the
27 environment. The effluent is continuously monitored and an alarm is activated in the control
28 room if the monitor set points are exceeded. The operators would then take action to reduce or
29 terminate the release.

30
31 A new gaseous radioactive waste subsystem was installed at VYNPS to permit the incineration
32 of slightly radioactive waste oil for space heating purposes. This incinerator is located in the
33 north warehouse on the site. The environmental releases listed below and the doses to
34 receptors in the vicinity of the plant listed in Section 2.2.7 include the emissions from this
35 incinerator.

36
37 The NRC staff reviewed the gaseous effluent releases reported in the VYNPS Annual
38 Radioactive Effluent Release Reports for the years 2001 through 2005 (Entergy 2002b, 2003b,
39 2004b, 2005b, 2006c). During this 5-year period, the average annual release of radioactive
40 effluents was about 40.2 Ci/yr, consisting of the following:

Plant and the Environment

- 1 • 31.7 Ci/yr of fission and activation gases,
- 2
- 3 • 1.17×10^{-3} Ci/yr of iodines,
- 4
- 5 • 2.7×10^{-4} Ci/yr of beta and gamma emitters as particulates, and
- 6
- 7 • 8.55 Ci/yr of tritium.
- 8

9 In March 2006, the NRC issued a license amendment to Entergy that allowed Entergy to
10 increase the thermal power of the VYNPS by 20 percent. In the EA and the FONSI
11 accompanying the license amendment (NRC 2006a), it is estimated that the gaseous effluents
12 from the VYNPS due to the EPU could increase by as much as 20 percent, consistent with the
13 percent increase in power. However, it is estimated that the gaseous effluents will remain within
14 the regulatory limits (NRC 2006a). Except for the impact of the EPU, no increases in
15 radioactive gaseous releases are expected during the license renewal period.
16 See Section 2.2.7 for a discussion of the theoretical doses to the maximally exposed individual
17 (MEI) as a result of gaseous releases.

18

19 **2.1.4.3 Solid Waste Processing**

20

21 The solid waste management system at VYNPS is designed to collect, process, store, package,
22 and prepare wet and dry solid radioactive waste materials for offsite shipment. Some solid
23 waste is temporarily stored onsite in shielded structures prior to shipment from the plant. Solid
24 wastes include wet wastes consisting of spent resins and filter sludges and dry wastes
25 consisting of air filters from radioactive ventilation systems; miscellaneous paper, rags, shoe
26 covers, etc., from contaminated areas; contaminated clothing, tools, and equipment parts, which
27 cannot be effectively decontaminated; solid laboratory wastes; used reactor equipment such as
28 spent control rod blades, fuel channels, and incore ion chambers; and large pieces of
29 contaminated equipment.

30

31 The wet wastes are pumped from the phase separators or waste sludge tanks as a slurry to
32 disposable liners preplaced within the licensed transportation casks. The slurry is then
33 dewatered from within the liner using a remote controlled dewatering system. After filling and
34 dewatering, the liner is closed and the cask is taken to a decontamination area in the
35 radioactive waste building where the cask is wiped or washed down to remove external surface
36 contamination. The cask is lifted to a truck for transportation to the onsite waste storage area or
37 offsite to a waste disposal site.

38

39 The dry solid waste is normally stored temporarily in various work areas and then moved to the
40 process area. Most waste of this type has relatively low radioactive content and may be
41 handled manually. Used reactor equipment, because of its high radioactivity, is stored in the
42 fuel storage pool for a sufficiently long time to allow for radioactive decay before packaging and

1 shipment offsite. A hydraulic box compactor is used to compress and reduce the volume of
2 compressible dry wastes. As an alternative, these types of wastes can be collected in shipping
3 containers and sent to an offsite processor for volume reduction.

4
5 Transportation and disposal of solid radioactive wastes are performed in accordance with the
6 applicable requirements of 10 CFR Part 71 and Part 61, respectively. There are no releases to
7 the environment from solid radioactive wastes created at VYNPS. In 2005, 23 waste shipments
8 were made from VYNPS to treatment or disposal facilities. The total volume and activity of the
9 radioactive waste shipped offsite in 2005 were 619 m³ and 229 Ci, respectively (Entergy 2006c).
10 These values are representative of the quantities of radioactive waste generated and shipped
11 from the site in previous years. However, the EPU granted in March 2006 is expected to result
12 in an increase in the amount of radioactive waste generated annually. The increase is expected
13 to be less than 18 percent (NRC 2006a). Except for the impact of the EPU, no increase in
14 radiological solid waste is expected during the license renewal period.
15

16 **2.1.5 Nonradioactive Waste Systems**

17

18 The principal nonradioactive wastes from VYNPS include various solid waste, chemical wastes,
19 and sanitary waste. Noncontaminated solid waste is collected inside the restricted area in
20 designated containers located throughout the plant. Once filled, the containers are surveyed for
21 the presence of loose surface contamination and are then transported to the clean material
22 processing facility. Noncontaminated chemicals, paint, oil, fluorescent bulbs, and other items
23 that have either been used or exceeded their useful shelf life are collected in a central collection
24 area. The materials are received in various forms and are processed to meet all regulatory
25 requirements prior to final disposition. Most items are packaged and shipped to vendors for
26 processing offsite.
27

28 Sanitary wastewater and laboratory wastewater from all plant locations are discharged to the
29 onsite septic systems covered under a permit from the Vermont Department of Environmental
30 Conservation. The solids from the septic tanks are periodically pulled out and spread in a land
31 spreading area on the site. Monitoring of the groundwater around the septic tanks and around
32 the land spreading area has showed no indication of radioactive contamination.
33

34 Entergy has a corporate policy and a plan for waste minimization at its nuclear power plants,
35 including VYNPS. The plan provides a hierarchy of waste minimization options that emphasize
36 (1) source reduction, (2) reuse/recycling, (3) treatment to reduce volume and/or toxicity, and
37 (4) disposal, in that order (Entergy 2006p). It is expected that Entergy would continue to
38 maintain and implement its waste minimization policy and plan during the license renewal period
39 of the VYNPS.
40
41
42

Plant and the Environment

2.1.6 Plant Operation and Maintenance

Routine maintenance performed on plant systems and components is necessary for the safe and reliable operation of a nuclear power plant. Maintenance activities conducted at VYNPS include inspection, testing, and surveillance to maintain the current licensing basis of the plant and to ensure compliance with environmental and safety requirements. Certain activities can be performed while the reactor is operating. Others require that the plant be shut down. Long-term outages are scheduled for refueling and for certain types of repairs or maintenance, such as the replacement of a major component. The reactor is refueled on a 18-month schedule.

As part of the License Renewal Application (Application), Entergy conducted an aging management review to manage the impacts of aging on systems, structures, and components in accordance with 10 CFR Part 54. Section 4 of the Application documents the evaluations of time-limited aging analyses (TLAAs) for the license renewal period. Appendix B of the Application provides descriptions of the programs and activities that would manage the impacts of aging for the renewal period. These summary descriptions of aging management program activities and TLAAs would be incorporated into the UFSAR for VYNPS following the issuance of the renewed operating license (OL). Entergy expects to conduct the activities related to the management of aging impacts during plant operation or normal refueling and other outages, but does not plan any outages specifically for the purpose of refurbishment.

2.1.7 Power Transmission System

Transmission corridors considered in the scope for license renewal are those constructed specifically to connect the facility to the transmission system (10 CFR 51.53(c)(3)(ii)(H)). The Final Environmental Statement (FES) for VYNPS (AEC 1972) described two transmission lines that connected VYNPS with the regional transmission grid. Both of the lines described in the FES utilize 115-kV lines. The two lines described in the FES, the Chestnut Hill and Coolidge lines, are considered in the scope for the Supplemental Environmental Impact Statement (SEIS) because they connect VYNPS to the regional grid. Three other lines that connect to the VYNPS switchyard, the Amherst line, the Northfield line, and the Vernon Hydro line were not constructed in support of the VYNPS, and therefore are not considered in the scope for the SEIS. None of the transmission lines connecting to the VYNPS switchyard are owned, operated, or maintained by Entergy.

From the VYNPS switchyard, the 115-kV Chestnut Hill line runs east across the Connecticut River for two miles to the Chestnut Hill substation in Hinsdale, New Hampshire (Figure 2-6). The line crosses the Connecticut River on galvanized steel towers and then is carried on wooden H-pole structures to the substation. From the VYNPS switchyard to the New Hampshire State line, the lines are owned by Vermont Electric Power Company, Inc. (VELCO). From the State line to the Chestnut Hill substation, the line is owned by Public Service Company of New Hampshire (a subsidiary of the Northeast Utilities System). The right-of-way (ROW) is

1 300 ft wide and occupies approximately 73 ac. The 115-kV Keene Line is identified in
2 Figure 2-6. The Keene line starts at the Chestnut Hill Substation and is out of scope.

3
4 The second transmission line, the Coolidge line, extends north from the VYNPS 345-kV
5 substation for roughly 50 miles to the Coolidge substation located near Ludlow, Vermont
6 (Figure 2-7). The line extends north from VYNPS on steel, single-pole structures for 2 miles
7 and then on wooden H-pole structures to the Coolidge substation. The Coolidge line is owned
8 and operated by VELCO. The line was built in 1971 to 345-kV standards but initially operated at
9 115 kV; in 1974, it began operating at 345 kV. The ROW is 200 ft wide and occupies
10 approximately 1212 ac.

11
12 Two other 345-kV lines that enter the VYNPS 345-kV substation were not built to connect
13 VYNPS to the grid. The Amherst 345-kV transmission line and the Northfield 345-kV
14 transmission line were constructed in the 1970s as part of a regional 345-kV upgrade of the
15 northeast grid. The Amherst line (also known as the Scobie line) is owned and operated by
16 Public Service Company of New Hampshire. The Northfield line is owned and operated by
17 Western Massachusetts Electric Company. The owners of the Amherst and Northfield lines are
18 subsidiaries of the Northeast Utilities System. The final transmission line entering VYNPS is a
19 buried 13.2-kV line from the Vernon Hydro Station that provides a source of offsite power for the
20 plant.

21
22 Maintenance and monitoring of the Coolidge and Chestnut Hill transmission line ROWs in
23 Vermont are managed by VELCO. Right-of-way vegetation maintenance practices in Vermont
24 include the use of mechanical clearing and hand-applied herbicides (Entergy 2006e).
25 Regulated wetlands are avoided, and widespread application of herbicides is avoided.
26 Wetlands, wildlife, aesthetics, erosion, and rare and uncommon natural areas and sites with
27 rare plants or invasive nuisance plants are considered in the maintenance of the Coolidge line.
28 Maintenance of the Chestnut Hill line in New Hampshire is by Northeast Utilities System.
29 Vegetation control is achieved using only mechanical methods and vegetation planting practices
30 (Entergy 2006e). No herbicides are used in maintenance of the ROW in New Hampshire.
31 Monitoring of the transmission lines by the respective owners is accomplished through aerial
32 inspection (Entergy 2006e). No changes in the design and operation of the transmission lines
33 are anticipated during the VYNPS license renewal period.

35 **2.2 Plant Interaction with the Environment**

36
37 Sections 2.2.1 through 2.2.8 provide general descriptions of the environment near VYNPS as
38 background information. They also provide detailed descriptions where needed to support the
39 analysis of potential environmental impacts of refurbishment and operation during the renewal
40 term, as discussed in Chapters 3 and 4. Section 2.2.9 describes the historic and archaeological
41 resources in the area, and Section 2.2.10 describes possible impacts associated with other
42 Federal project activities.

Plant and the Environment




Figure 2-6. Location of the Chestnut Hill Transmission Line




Figure 2-7. Location of the Coolidge Transmission Line

Plant and the Environment

1 **2.2.1 Land Use**

2
3 The VYNPS site is located in the town of Vernon, Vermont, in Windham County, in the
4 southeastern corner of the State and approximately 4 mi north of the Massachusetts state line
5 (Figure 2-2). The 125-ac site, about 1 mi wide, is owned by Entergy Nuclear Vermont Yankee,
6 LLC and is situated on the west shore of the Connecticut River across from Hinsdale, New
7 Hampshire, on the east side of the river (Figure 2-3). Entergy has received perpetual rights and
8 easements from the owner of a narrow strip of land between the Connecticut River and the east
9 boundary of the VYNPS property. The property bounding the site to the north, south, and west
10 is privately owned. VYNPS controls the river water between the northern and southern
11 boundary fences extending out to the state border near the middle of the river. The site is
12 located on Vernon Pond, formed by Vernon Dam and Hydroelectric Station located immediately
13 downstream 0.75 mi from the VYNPS site (Entergy 2006a; Entergy 2004c).

14
15 The station site natural grade level is at an elevation of 250 ft mean sea level (MSL). It is
16 situated on glacial deposits from the Pleistocene Age, with an average 30 ft of glacial
17 overburden over local bedrock. Bedrock exists at or near the foundation grades of several
18 structures. The land use within the site boundaries is characterized by grasslands and early
19 succession areas (53 percent), developed areas (28 percent), mixed softwood and hardwood
20 forested areas (16 percent), shrubs (2 percent), and wetlands (1 percent) (Entergy 2006b). The
21 principal structures at VYNPS consist of a reactor building and primary containment, turbine
22 building, control building, radioactive waste building, intake structure, cooling tower, and main
23 stack. The Governor Jonathan Hunt house, built in the 1780s, is situated on the western
24 boundary of the site and is maintained as an office and meeting facility. Entergy, with approval
25 by the Vermont Public Service Board, is developing an independent spent fuel storage
26 installation for dry cask storage using approximately 1 ac of site land to the north of the plant
27 (Entergy 2004c, 2006a, 2006f).

28
29 The immediate area surrounding the VYNPS site is delineated by a 6-ft high-security perimeter
30 fence topped by barbed wire and signs posted clearly informing an individual that the area is
31 private property and unauthorized entry is strictly prohibited. Recreational users are precluded
32 from landing on station waterfront property. Authorized access to the site is possible from either
33 Governor Hunt Road through the main gate or from a spur of the New England Central Railroad.
34 Vernon Pond to the south of the site is used to some extent for recreational purposes (Entergy
35 2004c, 2006a).

36
37 The town of Vernon has no zoning ordinances, subdivision ordinances, or development review
38 board that would affect or determine the site's land use. The town prepared and officially
39 adopted the 2003 Vernon Town Plan to chart a course for development that will benefit the town
40 and its future generations and represent a conscious community decision about the town's
41 future character and its priorities for land use and conservation of natural resources (Town of
42 Vernon 2003a; Entergy 2006a).

1 **2.2.2 Water Use**

2
3 VYNPS does not use public water supplies for plant operations but instead relies on surface
4 water from the Connecticut River and groundwater from onsite potable wells.
5

6 **2.2.2.1 Surface Water**

7
8 The VYNPS is located on the west bank of Vernon Pool on the Connecticut River, about 0.75 mi
9 upstream of the Vernon Hydroelectric Dam (Vernon Dam), which is located at river mile (RM)
10 142. Vernon Pool is the impounded portion of the Connecticut River directly upstream of the
11 dam; it is both the source and receiving water body for the plant's cooling system. The pond
12 covers 2250 ac (at full-pool elevation of 220.13 ft behind Vernon Dam) and extends to Bellows
13 Falls Dam at RM 174. It is about a half mile wide with a maximum depth of about 40 ft (AEC
14 1972; Entergy 2006a).

15
16 The Connecticut River has an average daily flow of 10,500 cubic feet per second (cfs) at Vernon
17 Dam, based on flows measured from 1944 to 1988 (Entergy 2006a). During this period,
18 monthly flow rate averages ranged from 4005 cfs in August to 30,799 cfs in April. The average
19 daily flow from 2000 to 2005 was 11,101 cfs at Vernon Dam (based on measurements reported
20 in Normandeau 2001, 2002, 2003, 2004b, 2005; DeWald 2006a). During this period, monthly
21 flow rate averages ranged from 4525 cfs in September to 30,824 cfs in April (Figure 2-8).

22
23 Figure 2-9 is a plot of the monthly flow rate averages for 2004 and 2005, illustrating the degree
24 of variability that can occur from year to year. In 2004, the average daily flow was 9851 cfs at
25 Vernon Dam, with monthly flow rate averages ranging from 3967 cfs in October to 23,570 cfs in
26 April (Normandeau 2005). In 2005, the average daily flow was 14,334 cfs at Vernon Dam, with
27 monthly flow rate averages ranging from 2661 cfs in August to 36,764 cfs in April (DeWald
28 2006a). According to the Indirect Discharge Permit (ID-9-0036), the low median monthly flow^(a)
29 at Vernon Pool is 3050 cfs; the flow under drought conditions^(b) is 1523 cfs (VDEC 2005c).

30
31 The Vernon Dam, owned and operated by TransCanada, regulates the river discharge to
32 maintain a minimum sustained flow of 1250 cfs, although under severe drought conditions, flow
33 rates may drop below 1250 cfs. There are a total of nine hydroelectric dams and three storage
34 dams on the main stem of the Connecticut River upstream of the dam and three hydroelectric

(a) According to the Vermont Water Quality Standards, Section 1-01.B.24, low median monthly flow is the median monthly flow for the month having the lowest median monthly flow in a given year (VWRB 2006).

(b) Drought flow is referred to as 7Q10 in Vermont Water Quality Standards, Section 3-01.C.1.b (VWRB 2006), and is the 7-day average low flow over a 10-year return period, adjusted to nullify any effects of artificial flow regulation, that has a 10 percent chance of occurring in a given year.

Plant and the Environment




Figure 2-8. Average Monthly Flow Rates at Vernon Dam from 2000 to 2005
(Data sources: Normandeau 2001, 2002, 2003, 2004b, 2005;
DeWald 2006a)




Figure 2-9. Average Monthly Flow Rates at Vernon Dam for 2004 and 2005
(Data sources: Normandeau 2005; DeWald 2006a)

1 dams and one pumped-storage facility downstream of the dam (Normandeau 2004a).
2 Impounded water in Vernon Pond allows for some flexibility in flow release from Vernon Dam;
3 its surface elevation may fluctuate as much as 8 ft due to operations at upstream and
4 downstream dams and runoff inflow (Entergy 2006a).

5

6 **Cooling Water Use**

7

8 The VYNPS withdraws water for its variable cooling system from Vernon Pool on the
9 Connecticut River. Cooling water can be circulated through the system in one of three modes of
10 operation: open-cycle (also called once-through cooling), closed-cycle, or a combination hybrid-
11 cycle (Entergy 2004c; NRC 2006a). The plant has the highest water usage in the open-cycle
12 mode of operation, withdrawing up to 360,000 gpm (802 cfs) from Vernon Pond. In the closed-
13 cycle mode, the rate of water pumped is reduced to about 10,000 gpm (22 cfs) (Entergy 2006a).
14 The rate of water withdrawn from Vernon Pool in the hybrid-cycle mode falls between that of the
15 open- and closed-cycle modes.

16

17 Cooling water is discharged back to Vernon Pool through NPDES Outfall 1 at the discharge
18 structure about 1700 ft downstream of the intake structure, as shown in Figure 2-10. A
19 description of the plant's outfalls and their daily flow rate limits is provided in Table 2-1. For
20 open- and hybrid-cycle cooling, the daily discharge limit at NPDES Outfall 1 is 543 million
21 gallons per day (gpd) (840 cfs); for closed-cycle cooling, it is 12.1 million gpd (19 cfs).

22

23 Maximum consumptive water use, which occurs through cooling tower evaporation when the
24 plant is operating in a closed-cycle mode, is estimated to be about 5000 gpm (11 cfs)
25 (AEC 1972). (Consumptive use refers to the amount of water withdrawn from the river that is
26 not returned to the river because of evaporative losses.)

27

28 An extended power uprate at VYNPS was authorized on March 2, 2006. While the rate of river
29 water withdrawal from Vernon Pool is not affected by the uprate, there may be a small increase
30 in the amount of water consumed while the plant is operating in closed- and hybrid-cycle
31 modes. This is due to the need to operate the cooling towers more often to dissipate heat to the
32 atmosphere rather than the river to meet the thermal limits set in the NPDES permit
33 (see Section 2.2.3.1). During the NPDES summer period (May 16 to October 14), as defined in
34 the NPDES permit currently in effect (VDEC 2003), the increased water consumption is
35 estimated to be less than 0.1 percent of the average monthly river flow. During the NPDES
36 winter period (October 15 to May 15), the increased water consumption will be less than
37 0.2 percent of the average monthly river flow (NRC 2006a).

38

39 **Auxiliary Water Use**

40

41 Water is drawn from Vernon Pool for the plant's service water system, which provides water for
42 turbine and reactor auxiliary equipment cooling, reactor shutdown cooling, and miscellaneous

Plant and the Environment

Table 2-1. VYNPS NPDES Discharge Locations

	Outfall	Permitted Daily Flow Rate (gpd)	Description
5	S/N 001	543 million (Open/hybrid cycles) 12.1 million (Closed cycle)	Circulating water discharge – main condenser cooling water and service water. Discharged to the Connecticut River at discharge structure 1700 ft downstream from intake.
6	S/N 002	10,000	Radioactive high purity water; discharged to the Connecticut River at discharge structure. No discharge has occurred at this outfall since 1981.
7	S/N 003	1000	Plant heating boiler water (blowdown); discharged to the Connecticut River at discharge structure.
8	S/N 004	10,000	Water treatment carbon filter backwash; discharged to the Connecticut River at discharge structure.
9	S/N 005	14,000 ^(a)	Cooling water discharge from the four residual heat removal (RHR) service water pumps; discharged to the Connecticut River at discharge structure.
10	S/N 006	10,000 ^{(b), (c)}	Stormwater runoff and demineralized trailer rinse down water. North storm system discharge point, about 600 ft to the north of the intake structure.
11	S/N 007	— ^(c)	Stormwater runoff; south storm system discharge point to the forebay of the discharge structure (includes discharges from S/N 003, S/N 004, and S/N 005).
12	S/N 008	— ^(c)	Stormwater runoff; southeast storm system discharge point to the southeast of the east cooling tower, about 2100 ft downstream from discharge structure.
13	S/N 009	50,000	Strainer and traveling screen backwash; discharge to the Connecticut River at the intake structure.
14	S/N 010	— ^(c)	Stormwater runoff; 345-kV switchyard storm system discharge point about 900 ft north of the intake structure.
15	S/N 011	— ^(c)	Stormwater runoff; 115-kV switchyard storm system discharge point about 1200 ft north of the intake structure.
16	S/N 012 ^(d)	— ^(c)	Stormwater runoff from new gravel parking lot; new outfall (as of 2005) about 1500 ft north of the intake structure.

17 (a) Discharge limit could increase to 46,500 gpd under the amended permit (issued March 30, 2006) if it is reinstated.

18 (b) Permitted flow rate value for demineralized trailer rinse down water.

19 (c) Effluent limits and monitoring are not required for stormwater discharges.

20 (d) Outfall is a new stormwater discharge specified in the VYNPS NPDES permit renewal application, submitted on
21 September 29, 2005.

22 Sources: Entergy 2005e; VDEC 2003; VDEC 2006a




Figure 2-10. Locations of NPDES Outfalls at the VYNPS (Source: Entergy 2006a)

Plant and the Environment

services. Pumps at the intake structure can withdraw up to 13,400 gpm (30 cfs) for the service water system. The service water system also provides water for normal and standby cooling of the reactor building's spent fuel pool (Entergy 2004c).

Additional pumps at the intake structure can also withdraw up to 5000 gpm (11 cfs) as needed for the plant's fire protection system. This water supplies the automatic wet pipe sprinkler systems, standpipes, and hose stations throughout the station (Entergy 2004c).

2.2.2.2 Groundwater

Groundwater at the site occurs under unconfined conditions within both unconsolidated glacial overburden sediments and the underlying fractured bedrock. In the vicinity of the major plant structures, groundwater is approximately 20 ft below ground surface. In the northern portion of the site, depth to groundwater varies from about 5 ft to 18 ft below ground surface. Along the southern portion of the site, depth to groundwater is approximately 30 ft. Groundwater at the site generally flows towards the Connecticut River (Entergy 2004c).

At VYNPS, potable water is supplied to various locations from four onsite wells, as shown in Table 2-2. These wells are classified as nontransient, noncommunity public water systems and are permitted and regulated by the State of Vermont. Based on pump rates and measured

Table 2-2. VYNPS Potable Water Wells

Well	Areas Served	Well Depth (ft)	Well Rating (gpm)	Maximum Water Demand (gpm)
Construction Office Building	Construction Office Building	362	9	6.4
Southwest	Main Building complex; secondary/backup source for West Well	500	10.5	— ^(a)
West	Main Building complex; Gate House 1 and 2, South Warehouse, and Governor Hunt House	555	73.7	25
New Engineering Office Building	New Engineering Office Building	500	30	4
Total rates (gpm):			123.2	35.4

(a) Not available.

Sources: Entergy 2004c, 2005d

water usage during 2002 and 2003, the maximum pump rate from all wells was 8.54 gpm; however, given the well rating capacities, the total pump rate could be as high as 123.2 gpm, if all the wells are operated simultaneously.

The maximum groundwater demand on the VYNPS site would occur during a refueling outage and is estimated to be 35.4 gpm, as shown in Table 2-2.

2.2.3 Water Quality

2.2.3.1 Surface Water

The Vermont Water Resources Board classifies the Connecticut River at the station's point of discharge as a Class B water (VDEC 2006a). Class B waters are managed to achieve and maintain a level of quality that supports aquatic biota, wildlife, and aquatic habitat; has aesthetic value; and is suitable for public water supply with filtration and disinfection, for swimming and other water-based recreation, and for crop irrigation and other agricultural uses (VWRB 2006).

Surface water quality is regulated through the U.S. Environmental Protection Agency's (EPA) NPDES permit program. Section 402 of the Clean Water Act specifies that "NPDES prohibits [discharges] of pollutants from any point source into the nation's waters except as allowed under an NPDES permit." Its purpose is to regulate the discharge of wastewater to maintain water quality of receiving water bodies. The State of Vermont has been delegated responsibility by the EPA for administration of the NPDES program in Vermont. NPDES permits are issued by the Vermont Department of Environmental Conservation (VDEC) on a five-year cycle (EPA 2006c).

VYNPS is currently operating under the NPDES permit issued on June 9, 2003 (VDEC Permit No. 3-1199, NPDES Number VT0000264; VDEC 2003). The permit specifies the discharge standards and monitoring requirements for effluents at the plant's 11 outfalls on the Connecticut River (an additional stormwater outfall, NPDES Outfall 12, was identified in the NPDES permit renewal application, submitted on September 29, 2005, approval pending; VDEC 2005a). The locations of the NPDES outfalls are shown on Figure 2-10; their monitoring requirements are summarized in Table 2-3.

In addition to the water quality parameters listed in Table 2-3, the plant is also required to monitor:

- River flow rates on an hourly basis at Vernon Dam,
- Temperatures on an hourly basis at River Monitoring Station 3 (0.65 miles downstream of dam) and River Monitoring Station 7 (4 miles upstream of plant), and

Plant and the Environment

- 1 • Concentrations of three metals (copper, iron, and zinc) via monthly grab samples at
2 NPDES Outfall 1 and at River Monitoring Stations 3 and 7.

3
4 Figure 2-11 shows the locations of Vernon Dam and River Monitoring Stations 3 and 7. River
5 flow rates at Vernon Dam are discussed in Section 2.2.2; temperatures and metal
6 concentrations are discussed in the following sections.
7

8 **Temperature Requirements under the Current NPDES Permit**
9

10 The current NPDES permit (VDEC 2003) defines two seasonal periods (winter, from October 15
11 through May 15; and summer, from May 16 through October 14) and sets limits for the increase
12 in temperatures at River Monitoring Station 3, less than a mile downstream of Vernon Dam.
13 These are presented in detail in Table 2-4.
14

15 NPDES permits are issued for five years at a time. On July 11, 2001, VDEC issued a renewed
16 permit for VYNPS with an expiration date of March 31, 2006, and the permit was amended on
17 June 9, 2003 (VDEC 2003). On February 20, 2003, Entergy applied to the VDEC to amend the
18 permit for VYNPS to increase the temperature of the Connecticut River by 1°F as determined at
19 River Monitoring Station 3 (downstream monitoring station) during the NPDES summer period
20 (May 16 through October 14). On March 30, 2006, VDEC issued an amendment to the permit
21 for VYNPS; however, the amended permit only authorized the requested temperature increase
22 for the period from June 16 through October 14 (VDEC 2006a). VDEC concluded that
23 additional information was needed to evaluate the impacts of the temperature increase on
24 migrating salmon smolt during the May 16 through June 15 portion of the NPDES summer
25 period, since it marks the end of the smolt outmigration period. The permit would have expired
26 on March 31, 2006; however, Entergy submitted an application for a renewed permit on
27 September 29, 2005 (Entergy 2005e). By letter dated September 30, 2005, VDEC informed
28 Entergy that the renewal application was timely and that the permit would remain valid under an
29 administrative extension until VDEC completes the review of the permit renewal application
30 (VDEC 2005a).
31

32 In May 2006, the New England Coalition (NEC) appealed the NPDES permit amendment that
33 was issued on March 30, 2006. The amendment was stayed by the State of Vermont
34 Environmental Court on August 28, 2006. At the time this SEIS was published, VYNPS was
35 operating under the NPDES permit as issued on June 9, 2003 (VDEC 2003). The future status
36 of the permit depends on the outcome of the NEC appeal. If the appeal is upheld, an increase
37 in thermal discharge will not be granted and the discharge requirements in the current permit
38 (issued June 9, 2003) will continue until a new permit is issued. If the appeal is denied, the
39 NPDES permit as amended March 30, 2006, will be reinstated and remain in effect until a new
40 permit is issued by VDEC (NRC 2006d). The temperature requirements of the current and
41 amended NPDES permits are presented in Table 2-4.
42




Figure 2-11. Locations of Vernon Dam and River Monitoring Stations 3 and 7
Relative to VYNPS (Source Entergy 2006a)

Plant and the Environment

Table 2-3. Monitoring Requirements for Water Quality Parameters at NPDES Outfalls

Outfall Name	Parameter (Limits)	Monitoring Requirement
S/N 001	Free residual chlorine ^(a,b) (0.2 mg/L)	Chlorine/oxidant injection limited to closed-cycle cooling; daily grab samples required during period when treatment is occurring
	Total residual oxidant ^(b)	
	pH (6.5 to 8.5)	Daily grab samples
S/N 002	Radioactivity (5 pCi/L)	Daily when discharge occurs ^(c)
	pH (6.5-8.5)	Daily grab samples
S/N 003	Control OS7700 ^(d) (15 ppm hydroquinone)	No monitoring required
S/N 004	Total suspended solids (8.3 lb)	No monitoring required
S/N 005	No limits specified	No monitoring required
S/N 006	No limits specified	No monitoring required
S/N 007	No limits specified	No monitoring required
S/N 008	No limits specified	No monitoring required
S/N 009	Bulab 8006 ^(d) (20 ppm within service water system)	No monitoring required
S/N 010	No limits specified	No monitoring required
S/N 011	No limits specified	No monitoring required
S/N 012	— ^(e)	— ^(e)

- (a) Oxidant or chlorine injection is limited to discharge during a closed cycle or when service water system is treated during open/hybrid-cycle operation; detectable residuals are not to exceed 2 hours/day.
- (b) Total oxidant is chlorine, bromine, or a combination of the two.
- (c) Vermont Wastewater Management Division must be notified prior to discharge or, if necessary, within 24 hr following the discharge.
- (d) VYNPS is also authorized to use Bulab 7034 or Depositrol BL5303 for corrosion control in service and circulating water with a maximum permitted concentration of 30 ppm; Bulab 9027 or Inhibitor AZ8103 for copper corrosion control in circulating water with maximum permitted concentrations of 10 ppm and 50 ppm, respectively; Dianodic DN2301, a dispersant for service and circulating water with a maximum permitted concentration of 20 ppm; Control OS7700, an oxygen scavenger and pH control agent (containing hydroquinone) with a maximum permitted concentration of 15 ppm hydroquinone in boiler discharge; Ferroquest FQ7101 for biological and corrosion fouling control in service water system, with a maximum permitted concentration of 96 ppm for 1 min eight times per year; and Ferroquest FQ7102 for pH control, with a maximum permitted concentration of 7 ppm for 1 min eight times per year.
- (e) Outfall is a new discharge location (stormwater) specified in the VYNPS NPDES permit renewal application, submitted on September 29, 2005 (approval pending).

Source: VDEC 2003

Plant and the Environment

Table 2-4. Discharge Temperature Requirements Under the Current and Amended NPDES Permits for VYNPS

	Currently Enforced NPDES Permit (June 9, 2003)	March 30, 2006 Amendment Request to NPDES Permit
3	Winter (October 15 through May 15) at downstream Station 3 ^(a) :	Winter (October 15 through May 15) at downstream Station 3 ^(a) :
4	• Temperature shall not exceed 65°F;	• Temperature shall not exceed 65°F;
5	• The rate of change of temperature (i.e., the mean difference between consecutive hourly average temperatures) shall not exceed 5°F per hour;	• The rate of change of temperature (i.e., the mean difference between consecutive hourly average temperatures) shall not exceed 5°F per hour;
6	• The plant-induced increase in temperature above ambient water temperature as measured at Station 7 ^(b) shall not exceed 13.4°F.	• The plant-induced increase in temperature above ambient water temperature as measured at Station 7 ^(b) shall not exceed 13.4°F.
7		Early Summer (May 16 through June 15):
8	• The increase in river water temperature at Station 3 above ambient water temperature as measured at Station 7 shall not exceed the following:	• The increase in river water temperature at Station 3 above ambient water temperatures as measured at Station 7 shall not exceed the following:
9		
10		
11		
12	Summer (May 16 through October 14):	
13		
14	• The increase in river water temperature at Station 3 above ambient water temperature as measured at Station 7 shall not exceed the following:	• The increase in river water temperature at Station 3 above ambient water temperatures as measured at Station 7 shall not exceed the following:
15		
16		
17		
18	Upstream Station 7 temperatures	<u>Upstream Station 7 temperatures</u>
19	<u>Temperature increase</u> above Station 7 measured at Station 3 shall not exceed	<u>Temperature increase</u> above Station 7 measured at Station 3 shall not exceed
20		
21	Above 63°F >59°F, ≤ 63°F ≥ 55°F, ≤ 59°F Below 55°F	Above 63°F >59°F, ≤ 63°F ≥ 55°F, ≤ 59°F Below 55°F
22	2°F	2°F
23	3°F	3°F
24	4°F	4°F
25	5°F	5°F
26		
27		
28		
29		
30		
31		
32		
33		
34		
35		
36		
37		
38		
39		
40		
41		
42		
43		

(a) Station 3 is located 1.4 mi downstream of VYNPS.
 (b) Station 7 is located 3.7 mi upstream of VYNPS.

1
2 Plant and the Environment

3
4 The NRC staff's evaluation of the environmental impact in this SEIS considered the 1°F
5 increase for the time period May 16 through October 14. This evaluation would be bounding if
6 the VDEC grants Entergy the 1°F increase in the May 16 through June 14 time period or the
7 NEC appeal is denied or the NEC appeal is upheld.

8 **Methods of Demonstrating Compliance**

9 The permit requirements in effect at the time this SEIS was issued are described below. The
10 NPDES permit requires that during the winter period (October 15 through May 15), the plant-
11 induced temperature at downstream River Monitoring Station 3 shall not exceed 65°F (Table 2-
12 4). The plant-induced temperature increase is calculated using the equation published in the
13 executive summary of the 1978 demonstration report (Aquatec 1978). The equation is based
14 on the principle of conservation of energy and takes into account the heat content of the plant's
15 circulating water system and cooling towers, the heat content of the plant's cooling water
16 discharge to the river, and the average discharge (flow) of the Connecticut River as measured
17 at Vernon Dam^(a). Measurement and cooling system data are linked to a process computer that
18 allows plant personnel to adjust operations on the basis of continual real-time data to meet the
19 thermal requirements of the permit (Normandeau 2005).

20
21 The Vernon Dam regulates the river discharge to maintain a minimum sustained flow of
22 1250 cfs. At 1250 cfs, the permitted theoretical maximum increase in temperature at River
23 Monitoring Station 3 due to the plant's thermal discharge is 12.9°F. In effect, the plant can
24 operate in an open-cycle cooling mode (without cooling tower operation) when ambient river
25 temperatures as measured at the upstream monitoring station (River Monitoring Station 7) are
26 less than 52.1°F (i.e., 65°F minus 12.9°F) during the winter period. At ambient temperatures
27 equal to or greater than 52.1°F, the plant's heat discharge can be reduced by using the cooling
28 towers to dissipate heat to the atmosphere (especially during periods of low river flow)
29 (Normandeau 2005). The NPDES permit requires that the plant-induced increase in
30 temperature above the ambient temperature at River Monitoring Station 3 (downstream of
31 VYNPS) never exceeds 13.4°F and that the rate of increase never exceeds 5°F per hour.
32 These two limitations were included in NPDES permit dated July 11, 2001 and the amendments
33 dated June 9, 2003 and March 30, 2006.

34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100
101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200
201
202
203
204
205
206
207
208
209
210
211
212
213
214
215
216
217
218
219
220
221
222
223
224
225
226
227
228
229
230
231
232
233
234
235
236
237
238
239
240
241
242
243
244
245
246
247
248
249
250
251
252
253
254
255
256
257
258
259
260
261
262
263
264
265
266
267
268
269
270
271
272
273
274
275
276
277
278
279
280
281
282
283
284
285
286
287
288
289
290
291
292
293
294
295
296
297
298
299
300
301
302
303
304
305
306
307
308
309
310
311
312
313
314
315
316
317
318
319
320
321
322
323
324
325
326
327
328
329
330
331
332
333
334
335
336
337
338
339
340
341
342
343
344
345
346
347
348
349
350
351
352
353
354
355
356
357
358
359
360
361
362
363
364
365
366
367
368
369
370
371
372
373
374
375
376
377
378
379
380
381
382
383
384
385
386
387
388
389
390
391
392
393
394
395
396
397
398
399
400
401
402
403
404
405
406
407
408
409
410
411
412
413
414
415
416
417
418
419
420
421
422
423
424
425
426
427
428
429
430
431
432
433
434
435
436
437
438
439
440
441
442
443
444
445
446
447
448
449
450
451
452
453
454
455
456
457
458
459
460
461
462
463
464
465
466
467
468
469
470
471
472
473
474
475
476
477
478
479
480
481
482
483
484
485
486
487
488
489
490
491
492
493
494
495
496
497
498
499
500
501
502
503
504
505
506
507
508
509
510
511
512
513
514
515
516
517
518
519
520
521
522
523
524
525
526
527
528
529
530
531
532
533
534
535
536
537
538
539
540
541
542
543
544
545
546
547
548
549
550
551
552
553
554
555
556
557
558
559
5510
5511
5512
5513
5514
5515
5516
5517
5518
5519
5520
5521
5522
5523
5524
5525
5526
5527
5528
5529
5530
5531
5532
5533
5534
5535
5536
5537
5538
5539
55310
55311
55312
55313
55314
55315
55316
55317
55318
55319
55320
55321
55322
55323
55324
55325
55326
55327
55328
55329
55330
55331
55332
55333
55334
55335
55336
55337
55338
55339
55340
55341
55342
55343
55344
55345
55346
55347
55348
55349
55350
55351
55352
55353
55354
55355
55356
55357
55358
55359
55360
55361
55362
55363
55364
55365
55366
55367
55368
55369
55370
55371
55372
55373
55374
55375
55376
55377
55378
55379
55380
55381
55382
55383
55384
55385
55386
55387
55388
55389
55390
55391
55392
55393
55394
55395
55396
55397
55398
55399
553100
553101
553102
553103
553104
553105
553106
553107
553108
553109
553110
553111
553112
553113
553114
553115
553116
553117
553118
553119
553120
553121
553122
553123
553124
553125
553126
553127
553128
553129
553130
553131
553132
553133
553134
553135
553136
553137
553138
553139
553140
553141
553142
553143
553144
553145
553146
553147
553148
553149
553150
553151
553152
553153
553154
553155
553156
553157
553158
553159
553160
553161
553162
553163
553164
553165
553166
553167
553168
553169
553170
553171
553172
553173
553174
553175
553176
553177
553178
553179
553180
553181
553182
553183
553184
553185
553186
553187
553188
553189
553190
553191
553192
553193
553194
553195
553196
553197
553198
553199
553200
553201
553202
553203
553204
553205
553206
553207
553208
553209
553210
553211
553212
553213
553214
553215
553216
553217
553218
553219
553220
553221
553222
553223
553224
553225
553226
553227
553228
553229
553230
553231
553232
553233
553234
553235
553236
553237
553238
553239
553240
553241
553242
553243
553244
553245
553246
553247
553248
553249
553250
553251
553252
553253
553254
553255
553256
553257
553258
553259
553260
553261
553262
553263
553264
553265
553266
553267
553268
553269
553270
553271
553272
553273
553274
553275
553276
553277
553278
553279
553280
553281
553282
553283
553284
553285
553286
553287
553288
553289
553290
553291
553292
553293
553294
553295
553296
553297
553298
553299
553300
553301
553302
553303
553304
553305
553306
553307
553308
553309
553310
553311
553312
553313
553314
553315
553316
553317
553318
553319
553320
553321
553322
553323
553324
553325
553326
553327
553328
553329
553330
553331
553332
553333
553334
553335
553336
553337
553338
553339
553340
553341
553342
553343
553344
553345
553346
553347
553348
553349
553350
553351
553352
553353
553354
553355
553356
553357
553358
553359
553360
553361
553362
553363
553364
553365
553366
553367
553368
553369
553370
553371
553372
553373
553374
553375
553376
553377
553378
553379
553380
553381
553382
553383
553384
553385
553386
553387
553388
553389
553390
553391
553392
553393
553394
553395
553396
553397
553398
553399
553400
553401
553402
553403
553404
553405
553406
553407
553408
553409
553410
553411
553412
553413
553414
553415
553416
553417
553418
553419
553420
553421
553422
553423
553424
553425
553426
553427
553428
553429
553430
553431
553432
553433
553434
553435
553436
553437
553438
553439
553440
553441
553442
553443
553444
553445
553446
553447
553448
553449
553450
553451
553452
553453
553454
553455
553456
553457
553458
553459
553460
553461
553462
553463
553464
553465
553466
553467
553468
553469
553470
553471
553472
553473
553474
553475
553476
553477
553478
553479
553480
553481
553482
553483
553484
553485
553486
553487
553488
553489
553490
553491
553492
553493
553494
553495
553496
553497
553498
553499
553500
553501
553502
553503
553504
553505
553506
553507
553508
553509
553510
553511
553512
553513
553514
553515
553516
553517
553518
553519
553520
553521
553522
553523
553524
553525
553526
553527
553528
553529
553530
553531
553532
553533
553534
553535
553536
553537
553538
553539
553540
553541
553542
553543
553544
553545
553546
553547
553548
553549
553550
553551
553552
553553
553554
553555
553556
553557
553558
553559
553560
553561
553562
553563
553564
553565
553566
553567
553568
553569
553570
553571
553572
553573
553574
553575
553576
553577
553578
553579
553580
553581
553582
553583
553584
553585
553586
553587
553588
553589
553590
553591
553592
553593
553594
553595
553596
553597
553598
553599
553600
553601
553602
553603
553604
553605
553606
553607
553608
553609
553610
553611
553612
553613
553614
553615
553616
553617
553618
553619
553620
553621
553622
553623
553624
553625
553626
553627
553628
553629
553630
553631
553632
553633
553634
553635
553636
553637
553638
553639
553640
553641
553642
553643
553644
553645
553646
553647
553648
553649
553650
553651
553652
553653
553654
553655
553656
553657
553658
553659
553660
553661
553662
553663
553664
553665
553666
553667
553668
553669
5536610
5536611
5536612
5536613
5536614
5536615
5536616
5536617
5536618
5536619
5536620
5536621
5536622
5536623
5536624
5536625
5536626
5536627
5536628
5536629
5536630
5536631
5536632
5536633
5536634
5536635
5536636
5536637
5536638
5536639
5536640
5536641
5536642
5536643
5536644
5536645
5536646
5536647
5536648
5536649
5536650
5536651
5536652
5536653
5536654
5536655
5536656
5536657
5536658
5536659
5536660
5536661
5536662
5536663
5536664
5536665
5536666
5536667
5536668
5536669
55366610
55366611
55366612
55366613
55366614
55366615
55366616
55366617
55366618
55366619
55366620
55366621
55366622
55366623
55366624
55366625
55366626
55366627
55366628
55366629
55366630
55366631
55366632
55366633
55366634
55366635
55366636
55366637
55366638
55366639
55366640
55366641
55366642
55366643
55366644
55366645
55366646
55366647
55366648
55366649
55366650
55366651
55366652
55366653
55366654
55366655
55366656
55366657
55366658
55366659
55366660
55366661
55366662
55366663
55366664
55366665
55366666
55366667
55366668
55366669
553666610
553666611
553666612
553666613
553666614
553666615
553666616
553666617
553666618
553666619
553666620
553666621
553666622
553666623
553666624
553666625
553666626
553666627
553666628
553666629
553666630
553666631
553666632
553666633
553666634
553666635
553666636
553666637
553666638
553666639
553666640
553666641
553666642
553666643
553666644
553666645
553666646
553666647
553666648
553666649
553666650
553666651
553666652
553666653
553666654
553666655
553666656
553666657
553666658
553666659
553666660
553666661
553666662
553666663
553666664
553666665
553666666
553666667
553666668
553666669
5536666610
5536666611
5536666612
5536666613
5536666614
5536666615
5536666616
5536666617
5536666618
5536666619
5536666620
5536666621
5536666622
5536666623
5536666624
5536666625
5536666626
5536666627
5536666628
5536666629
5536666630
5536666631
5536666632
5536666633
5536666634
5536666635
5536666636
5536666637
5536666638
5536666639
5536666640
5536666641
5536666642
5536666643
5536666644
5536666645
5536666646
5536666647
5536666648
5536666649
5536666650
5536666651
5536666652
5536666653
5536666654
5536666655
5536666656
5536666657
5536666658
5536666659
5536666660
5536666661
5536666662
5536666663
5536666664
5536666665
5536666666
5536666667
5536666668
5536666669
55366666610
55366666611
55366666612
5

Table 2-5 summarizes the maximum simulated river temperature increases at River Monitoring Station 3 and the flows at which they occurred during the winter period (October 15 through May 15) for the years 2000 through 2006.

The limitations of the NPDES permit, dated June 9, 2003, for the plant-induced temperature increase at the downstream River Monitoring Station 3 during the summer period (May 16 through October 14) are shown in Table 2-4. Table 2-6 summarizes the maximum simulated river temperature increases at the station and the flows at which they occurred during the summer period for the years 2000 through 2006.

Table 2-5. Maximum Calculated River Temperature Increase at River Monitoring Station 3 During the NPDES Winter Period (October 15 through May 15)

Year	Day	Maximum Temperature Increase	Permit Limit	River Flow (cfs)	Exceeded 5°F/hour?
2006 ^(a)	March 12	6.03°F	13.4°F	2958	No
2005	February 10	12.91°F	13.4°F	1285	No
2004	February 2	12.9°F	13.4°F	1331	No
2003	January 25	13.16°F	13.4°F	1308	No
2002	January 23	12.7°F	13.4°F	1367	No
2001	December 21	12.67°F	13.4°F	1250	No
2000	November 26	12.6°F	13.4°F	1275	No

(a) Data through August 2006.

Sources: Normandeau 2001, 2002, 2003, 2004b, 2005; DeWald 2005a, 2006b

Exceedences occurred in each of the years between 2000 and 2004, but in each case were less than 1 hr in duration:

- On July 16 and 21, 2000, two 59-minute exceedences occurred (2.74°F and 0.03°F, respectively) when Vernon Dam went to minimum flow as a result of a loss of offsite power caused by a lightning strike (Normandeau 2001).
- On July 5, 2001, a 59-minute exceedence of 0.12°F occurred because plant operators did not shift to closed-cycle mode quickly enough to respond to changing river conditions.
- On October 5, 2002, a 60-minute exceedence of 0.05°F occurred because of unreliable automated input associated with new equipment (Normandeau 2003).

Plant and the Environment

1 **Table 2-6.** Maximum Calculated River Temperature Increase at River
 2 Monitoring Station 3 During the NPDES Summer Period (May 16
 3 through October 14)

5	Year	Day	Maximum Temperature Increase	Permit Limit	River Flow (cfs)	Exceeded 5°F/hour?
6	2006 ^(a)	August 15	2.94°F	3.0°F	3168	No
7	2005	July 1	1.97°F	2.0°F	6760	No
8	2004	July 6	2.1°F	2.0°F	3483	No
9	2003	September 19	2.16°F	2.0°F	2802	No
10	2002	October 5	2.05°F	2.0°F	1697	No
11	2001	July 5	2.12°F	2.0°F	3923	No
12	2000	July 16 ^(b)	2.74°F	2.0°F	6571	No

13 (a) Data through August 2006.

14 (b) July 21, 2000 was an exceedance but not the maximum exceedance for the year 2000.

15 Sources: Normandeau 2001, 2002, 2003, 2004b, 2005; DeWald 2005b, 2006c

- 17 • On September 19, 2003, an 11-minute exceedence of 0.16°F occurred because
 18 plant operators shifted operating parameters in anticipation of an increase in river
 19 flow (reported by the Wilder Hydroelectric Dam). The increase in river flow occurred,
 20 but not to the degree anticipated (Normandeau 2004b).
- 21 • On July 6, 2004, a 45-minute exceedence of 0.06°F occurred when the plant was
 22 brought back on-line after an outage caused by a transformer fire
 23 (Normandeau 2005).

26 There were no exceedences in 2005 or 2006 through August.

28 **Temperatures in the Connecticut River**

30 The monthly variation in river temperatures as measured at River Monitoring Stations 3
 31 (downstream) and 7 (upstream) over a 5-year period (2000 to 2004) are shown in Figures 2-12
 32 and 2-13, respectively. Over this period, monthly averages ranged from 34.5°F in January to
 33 75.5°F in July at River Monitoring Station 3 and from 33.4°F in February to 73.3°F in August at
 34 River Monitoring Station 7.

36 Figure 2-14 is a plot of the temperature difference in average monthly temperatures between
 37 River Monitoring Stations 7 and 3 (i.e., Station 3 minus Station 7) in 2000 through 2004. There
 38 is an increasing trend throughout the spring, peaking in May, with Station 3 having an average
 39 temperature that was 5.9°F higher than that at Station 7, with a decreasing trend throughout the




Figure 2-12. Seasonal Variation in Temperature at River Monitoring Station 3,
Located About 0.65 Miles Downstream of Vernon Dam (2000-2004)
(Data sources: Normandeau 2001, 2002, 2003, 2004b, 2005)




Figure 2-13. Seasonal Variation in Temperature at River Monitoring Station 7,
Located 4 Miles Upstream of VYNPS (2000-2004) (Data sources:
Normandeau 2001, 2002, 2003, 2004b, 2005)

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43

Plant and the Environment




Figure 2-14. Difference in Average Monthly Temperatures Between River Monitoring Stations 3 (downstream) and 7 (upstream) (Sources: Normandeau 2001, 2002, 2003, 2004b, 2005)

summer. In most months during this period, the average monthly temperatures at the downstream river monitoring station 3 were greater than those at the upstream river monitoring station 7. However, in September and December, the average monthly temperatures at Station 7 were higher than Station 3 (1.4°F and 0.4°F, respectively). The temperature difference between the stations was less than 1°F in January and March (Normandeau 2001, 2002, 2003, 2004b, 2005).

In June, July, and August 2002, temperature measurements were taken from thermistor stations along three bank-to-bank transects across Vernon Pool perpendicular to the river flow, as part of a study to characterize the circulation and distribution of heated water in the area between the VYNPS discharge structure and Vernon Dam (Figure 2-15; ASA 2004). Temperatures were measured at three depths at each of the three stations along each transect (Table 2-7). The June-July sampling period was chosen to represent expected conditions; August was chosen to represent low-flow, high-temperature conditions, usually considered the worst-case for potential impacts to aquatic biota.

The June-July measurements showed that temperature ranges were fairly similar along each transect between the VYNPS discharge structure and Vernon Dam: 67.1°F to 81.5°F at C stations, 67.3°F to 82.9°F at D stations, and 66.7°F to 81.9°F at E stations. Temperatures were generally lower at the F stations (67.1°F to 77.0°F), located upgradient of the VYNPS intake structure, during the same sampling period (Figure 2-15).




Figure 2-15. Locations of Thermistor Stations at Vernon Pool (Source: ASA 2004)

1 Plant and the Environment

2 **Table 2-7.** Total Water Depth and Temperature Sampling Depths
3 in Vernon Pool

4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37
	Station Total	Water Depth (ft)	Surface Depth (ft)	Middle Depth (ft)	Bottom Depth (ft)																												
	C1/C2	17	1	8.5	16																												
	C3/C4	17	1	8.5	16																												
	C5/C6	14	1	7.0	13																												
	D1/D2	20	1	10	19																												
	D3/D4	14.1	1	7.0	13																												
	D5/D6	23	1	11.5	22																												
	E1/E2	39	1	19.5	38																												
	E3/E4	13	1	6.5	12																												
	E5/E6	5	1	2.5	4																												
	F1/F2	13	1	6.5	12																												
	F3/F4	21	1	10.5	20																												

Source: ASA 2004

In the June-July sampling period, thermal stratification of the water column was highest (up to a 6.3°F difference across the thermocline) near the VYNPS discharge structure, and had a decreasing trend toward the dam. Measurements at the E stations near Vernon Dam showed little stratification of the water column; however, the diurnal variation in surface water temperature, due to fluctuations in river flow and the effects of solar heating, was as high as 1.8°F.

The August diurnal variation in temperature due to fluctuations in river flow and the effects of solar heating was most pronounced at the surface (upper 1 ft) in Vernon Pool, with the highest variation (3.6°F) occurring near the VYNPS discharge structure (Station C1/C2); diurnal variation was less pronounced at the upstream location (Station F), with a variation of about 1.5°F at the surface.

There was little spatial variation in temperature across the bank-to-bank transects in Vernon Pool during the August sampling period. Although temperatures were slightly higher near the VYNPS discharge structure, thermistor temperatures were within about 1.8°F of each other across a single transect at any given time. The average temperature difference between the upstream River Monitoring Station 7 and the downstream River Monitoring Station 3 during the August sampling period was 2.9°F (ASA 2004).

1 In 2004, river temperatures of VYNPS averaged about 42.9°F in April, 57.3°F in May, and
2 65.7°F in June, while at the downstream monitoring Station 3 they averaged about 43.3°F in
3 April, 59.5°F in May, and 67.5°F in June. Average daily temperatures at the Vernon Dam
4 fishway from mid May through the end of June ranged from 55.5°F(May 27) to 70.6°F (June 15)
5 (Normandeau 2005).

7 **Copper, Iron, and Zinc in the Connecticut River**

9 As part of the NPDES permit monitoring program, the VYNPS collects monthly grab samples
10 from the Connecticut River at the discharge structure and at River Monitoring Stations 3 and 7
11 for total copper, zinc, and iron analyses.

13 In 2004, total copper concentrations ranged from <0.002 to 0.135 mg/L at Station 7, 0.003 to
14 0.011 mg/L at NPDES Outfall 1, and 0.001 to 0.123 mg/L at Station 3, with the highest
15 concentration (0.135 mg/L) occurring at Station 7 in March. Total iron concentrations ranged
16 from 0.10 to 117 mg/L at Station 7, 0.178 to 0.569 mg/L at NPDES Outfall 1, and 0.147 to
17 2.42 mg/L at Station 3, with the highest concentration (0.425 mg/L) occurring at Station 7 in
18 March. Total zinc concentrations ranged from 0.004 to 0.425 mg/L at Station 7, <0.003 to
19 0.041 mg/L at NPDES Outfall 1, and 0.004 to 0.159 mg/L at Station 3, with the highest
20 concentration (0.425 mg/L) occurring at Station 7 in March (Normandeau 2005).

22 It is likely that the higher concentrations in metals occurring at the upstream location (Station 7)
23 relative to the plant's discharge location and the downstream Station 3 relate to the
24 configuration of the sampling location. The station is located in shallow water (less than one
25 foot deep) with a mud substrate that may be disturbed by wave action on occasion, thus
26 creating suspended particulates that may contribute to the higher results at that station
27 (Normandeau 2005).

29 **2.2.3.2 Groundwater**

31 An inventory of potential sources of groundwater contamination within the source protection
32 area (defined as a 500-ft radius) of each potable water supply well at the VYNPS is provided in
33 source water protection plans for each well (Entergy 2005d). The protection plans delineate
34 management practices to reduce the potential risk of contamination of these wells and outline
35 emergency response protocols for spills or other contamination events occurring within the
36 source protection area.

38 VYNPS has several sewage treatment and disposal systems (leach fields, landfarm, and septic
39 spreading field) that discharge to the subsurface under an Indirect Discharge Permit (ID-9-0036)
40 issued by the VDEC. Systems regulated under the permit are: Main (North) System,
41 Construction Office Building (South) System, New Office Building System, New Warehouse
42 System, Governor Hunt House System, and Gatehouse #1 System. These systems have a
43 combined total operation design capacity of 14,347 gallons per day (gpd) and a maximum

Plant and the Environment

1 design capacity of 26,297 gpd (VDEC 2005c). Regular (biannual) monitoring of groundwater
2 quality around these systems is required by the permit. Groundwater levels are also monitored.
3 Because the river-to-effluent flow ratio is extremely large at the VYNPS, Connecticut River
4 water quality monitoring is not required by the Indirect Discharge Permit.

5
6 Groundwater is also monitored in the area of a former underground storage tank (UST), known
7 as the No. 2 fuel oil release area, just west of the turbine building (Figure 2-3). This area is the
8 site of a 1999 petroleum release from a former 10,000-gal No. 2 fuel oil UST, which resulted in
9 the contamination of soil and groundwater in the surficial aquifer (SVE 1999). Contaminants
10 released include tetrachloroethylene (PCE) and a suite of fuel compounds (including benzene,
11 toluene, ethylbenzene, and xylene [BTEX] and naphthalene). Monitoring has shown the extent
12 of contamination to be fairly limited, although low levels (below drinking water standards) of
13 some volatile organic compounds (VOCs) were detected in the Construction Office Building well
14 (also known as the "COB" well) in 1999, located about 750 ft south of the release area. Free
15 product was found in one of the adjacent monitoring wells and recovered using sorbent pads
16 (SVE 1999).

17
18 Monitoring wells near the release area were sampled on a quarterly basis from 1999 to 2002,
19 and have been sampled annually since 2002. Over this period, four monitoring wells (located
20 between the former UST site and the turbine building) have consistently had levels of petroleum
21 hydrocarbons exceeding Vermont's Primary Groundwater Quality Standards (PGQS), including
22 naphthalene (at concentrations up to 1300 µg/L; PGQS = 20 µg/L), 1,2,4-trimethylbenzene
23 (at concentrations up to 640 µg/L; PGQS = 5 µg/L); and 1,3,5-trimethylbenzene (at
24 concentrations up to 240 µg/L; PGQS = 4 µg/L). PCE was also detected in adjacent wells with
25 concentrations up to 24 µg/L (PGQS = 5 µg/L). Contaminant concentrations in these wells were
26 generally lower in 2005 than in previous years (Entergy 2006m).

27
28 Free product (i.e., light nonaqueous-phase liquid) monitoring and recovery continues on an
29 as-needed basis. In 2005, free product, on the order of a few milliliters, was removed from four
30 of the wells adjacent to the release area (Entergy 2006m).

32 **2.2.4 Air Quality**

34 **2.2.4.1 Climate and Meteorology**

36 The climate in southeastern Vermont is characterized as a highly variable continental climate,
37 exhibiting a large range of diurnal and annual temperatures, significant differences in climate
38 parameters between the same seasons in different years, and considerable diversity from place
39 to place. Climate is heavily influenced by topography and distances to large bodies of water,
40 primarily Lake Champlain and the Atlantic Ocean (Vermont State Climatologist 2006). Three
41 climatological divisions have been defined for the State: Western, Northeastern, and
42 Southeastern. VYNPS lies within the Southeastern Division, which is defined roughly as a

Plant and the Environment

portion of land adjacent to the south-flowing Connecticut River. Topography variations within the Southeastern Division range from the Wantastiquet Mountain east of Brattleboro, Vermont, with an elevation of 1351 ft (411 m) MSL to lowland areas along the Connecticut River near Northfield, Massachusetts (south of Vernon approximately 3 mi), with an elevation of 175 ft (53 m) MSL (Entergy 2006a). The average elevation within Vernon is 315 ft (96 m) MSL. The elevation at VYNPS is approximately 250 ft (76 m) MSL.

The predominating direction of wind throughout the State is from the west with some seasonal variation; north to northwesterly during the winter months and south-southwesterly during the summer months. However, notwithstanding these broad state-wide trends, predominating wind directions at the local level are also greatly influenced by topography. Thus, in the vicinity of the VYNPS, the predominating wind direction generally parallels the long axis of the north-south trending Connecticut River Valley. Wind roses developed for Westover Air Reserve Base,^(a) due south of VYNPS, show the prevailing wind directions to be generally north or south, depending on the season, with an annual average wind speed of 19.1 knots (21.98 mph) (Entergy 2006o).

Weather systems in Vermont are influenced by air masses entering the State from three principal directions: cold, dry air from the North American Subartic region; warm, moist air from the Gulf of Mexico and other subtropical waters; and cool, damp air from the North Atlantic Ocean. Weather patterns are highly variable in both short and long time frames. Biweekly fluctuations of weather from fair to cloudy or stormy conditions, with abrupt changes in temperature, moisture, sunshine, wind direction, and wind speed are common, and monthly weather "averages" are typically the result of wide variations of each measured parameter throughout the month.

As documented by the National Climate Data Center (NCDC), average temperatures vary according to elevation, slope, and local features such as urban heat islands. Diurnal fluctuations of temperature range from 20 to 30°F, with the greatest fluctuations observed in the southern portion of the State (including the area containing the VYNPS) (NCDC 2006b). Temperature records from Vernon over the period 1951 to 1960 revealed an annual average of 13 days with temperatures above 90°F and 175 days with temperatures below 32°F (Entergy 2006o).

Precipitation occurs throughout the State throughout the year, with precipitation in the Southeastern Division most influenced by weather systems originating in the North Atlantic Ocean. Freezing rain can occur throughout the State, but is least likely to occur in the Southeastern Division. Summer thunderstorms, however, are very possible at VYNPS and represent the most significant precipitation event. Snowfall totals vary considerably with elevation and also vary considerably from year to year. Blizzards involving very heavy winds

(a) Westover Air reserve Base is located in Chicopee, Massachusetts, approximately 60 mi due south of Vernon, and also within the Connecticut River Valley.

Plant and the Environment

1 and heavy snow totals within the Southeastern Division are generally the result of exceptionally
2 low pressure weather systems moving into the State from the North Atlantic ("nor'easters"). On
3 average, the southern portion of the State near Lake Champlain can expect to receive 60 in. of
4 snow each winter. Snowfall records for Vernon show snow occurring in all months except June
5 through September, with monthly averages as high as 16.4 in. and annual amounts averaging
6 60 in. However, annual totals have been as high as 118 in. (Entergy 2006o).

7
8 Other severe weather events are uncommon in the State, but have occurred in the past,
9 including within the Southeastern Division. Over the period December 1995 through December
10 2005, the NCDC recorded 46 incidents of severe weather: 22 instances of severe winds
11 associated with thunderstorms, 17 instances of flooding or flash flooding, 4 instances of hail,
12 two tornadoes (F1 and F2 strengths), and one instance of damaging lightning. Over this period,
13 property damage from severe weather throughout Windham County was estimated at \$2.707 M.
14 There were no weather-related fatalities over this period (NCDC 2006c). Based on the Index of
15 Tornado Damage Potential, Entergy places the probability of a tornado striking the VYNPS as
16 small (Entergy 2006o).

2.2.4.2 Air Quality Impacts

20 The entire State of Vermont is currently in attainment of primary and secondary standards for all
21 six of the criteria pollutants for which National Ambient Air Quality Standards (NAAQS) have
22 been established^(a). VYNPS, located in Windham County, lies within the Vermont Intrastate Air
23 Quality Control Region (AQCR) 221. Other Vermont counties within AQCR 221 include
24 Bennington, Caledonia, Essex, Lamoille, Orange, Orleans, and Washington. AQCR 221 is also
25 comprised of counties in New Hampshire and Massachusetts. Air quality in a given area is a
26 function of the emission sources within the area, the atmospheric conditions (climate and
27 meteorology), features of the area (primarily size and topography), and the nature and amount
28 of pollutants transported from outside the area. The influence of each local pollutant emission
29 source on ambient air quality depends primarily on such factors as the type, rate, frequency,
30 duration, and exit conditions (primarily thermal energy and exit velocity) of the emissions and
31 the specific locations of each source within the area.

32
33 The Air Pollution Control Division (APCD) of the Vermont Agency of Natural Resources,
34 Department of Environmental Conservation (VDEC) has primary responsibility for regulating air
35 emission sources within the State of Vermont. APCD also monitors the ambient air quality for

(a) Criteria Pollutants include carbon monoxide (CO), sulfur dioxide (SO₂), nitrogen dioxide (NO₂), ozone (O₃), lead (Pb), and particulate matter with aerodynamic diameters <10 microns and <2.5 microns (PM₁₀ and PM_{2.5}). Criteria pollutants are used to establish NAAQS. Primary standards are those necessary to protect public health. Secondary standards preserve the general welfare and quality of life.

1 conformance with the NAAQS at various monitoring stations throughout the State. The
2 monitoring station closest to VYNPS is located in Brattleboro where only PM₁₀ was monitored in
3 2004 (VDEC 2006b).

4
5 The VYNPS has a number of stationary sources of criteria pollutants, including external
6 combustion sources such as comfort heat boilers and one used oil furnace and internal
7 combustion engines (ICEs) (diesel) on emergency generators. Emission calculations and
8 emission inventory reports for calendar years 2001 through 2005 demonstrate that all of these
9 stationary sources qualify as insignificant sources with respect to their emission potentials
10 (VYNPS 2001, 2002, 2003a, 2004, 2005, 2006e; Entergy 2006n). The VYNPS is correctly
11 classified as a minor source with respect to its potential to emit (PTE) criteria pollutants and/or
12 hazardous air pollutants (HAPs) and is therefore not required to secure a Title V operating
13 permit for any of its stationary emission sources^(a). Documentation submitted to the
14 VDEC/APCD claims exempt status for VYNPS (Entergy 1995) and VDEC/APCD concurs
15 (VDEC 1995). Documentation showing the annual hours of operation of the emergency power
16 generators demonstrates their continued eligibility for exempt status as emergency generators
17 (VYNPS 2006a through d).

18
19 Used oil generated at VYNPS is consumed onsite for energy recovery (comfort heating). One
20 oil burner is in service at the radioactive waste storage facility (the North Warehouse) and
21 operates only during the heating season. Management of used oil, including its incineration in
22 used oil burners, is the responsibility of the Hazardous Waste Coordinator. Sources of oil for
23 this burner include used oil recovered from vacuum pump maintenance and repair activities,
24 excess new diesel fuel remaining after quality control sampling/testing of the emergency
25 generators' "day tanks," and used crankcase oil from maintenance of the emergency
26 generators^(b). Used oil sources categorically excluded from consumption in the used oil burner
27 include any oils recovered from electrical equipment (transformers, oil-filled circuit breakers and
28 switches) or oil from any offsite source.

29
30 Used oil sampling and management protocols are established in written operating procedures
31 and call for comprehensive analyses of oil for the presence of radionuclides as well as other
32 hazardous chemicals and critical physical parameters such as flash point (VYNPS 2003b) to

(a) According to 40 CFR 70.2, a "major source" is any stationary source or collection of stationary sources within contiguous or adjacent areas and under common control whose PTE is equal to or greater than 10 tons per year of any hazardous air pollutant (HAP), 25 tons per year of any combination of HAPs, or 100 tons per year of any air pollutant, including fugitive dust. (Additional elements are added to this definition in nonattainment areas for ozone, CO, and PM₁₀.)

(b) To ensure reliability, diesel fuel for emergency generators is sampled monthly and analyzed for critical chemical and physical properties (VYNPS 2003b).

Plant and the Environment

ensure proper operation of the burner and to preclude the atmospheric release of hazardous constituents. Likewise, operation of the used oil burner is also addressed in written operating procedures. These procedures require the operator to ensure that the required preliminary sampling of oil has been completed and that the burner is operated correctly. Procedures for used oil management and for used oil burner operations have been summarized by facility personnel (Entergy 2006g).

Vermont air quality regulations define hazardous air contaminants (HACs)^(a). There is very little potential for releases of HACs from VYNPS as a result of routine facility operation. However, some water treatment chemicals present in the cooling tower contain Vermont-listed HACs, and there is the potential for their release to the atmosphere as cooling tower drift^(b). Details regarding such releases are discussed in Section 2.1.3.

Sections 101(b)(1), 110, 169A(a)(2), and 301(a) of the Clean Air Act as amended (42 U.S.C. 7401(b), 7410, 7491(a)(2), 7601(a)) established Mandatory Class I Federal Areas where visibility is an important value^(c). There is one Mandatory Class I Federal Area in Vermont, the Lye Brook Wilderness Area, a 12,430-ac parcel maintained by the U.S. Forest Service and located approximately 35 mi northwest of VYNPS. The closest Class I areas in New Hampshire include the 5552-ac Great Gulf Wilderness Area, approximately 130 mi northeast of VYNPS, and the 27,380-ac Presidential Range – Dry River Wilderness Areas located approximately 120 mi northeast of VYNPS, all managed by the U.S. Forest Service. There are no Class I Areas in Massachusetts close to VYNPS^(d). Given the locations of the Class I areas, their distances from the VYNPS, prevailing wind directions, and the limited potential of the facility's stationary sources to emit criteria pollutants that could impact visibility, there is little likelihood that activities at the facility can adversely impact visibility in any of these Class I areas.

(a) A comprehensive listing of HACs is contained in Appendix B of the Vermont Air Quality Regulations (adopted December 31, 2003). Appendix C establishes air quality standards for HACs that display, or are suspected of, carcinogenicity (Category I HACs), for HACs believed to cause chronic systemic toxicity due to long-term exposure (Category II HACs), and for HACs believed to cause short-term irritant effects (Category III HACs).

(b) Cooling tower drift is the result of the entrainment of cooling water droplets in the air being exhausted from a wet counter-flow-designed cooling tower such as the one being operated by VYNPS.

(c) See also federal regulations at 40 CFR 81 et seq.

(d) Additional information about the Class I areas within this region can be found on the USDA Forest Service website: <http://www.fs.fed.us/r6/aq/natarm/r9/class1r9.htm>.

1 **2.2.5 Aquatic Resources**

2 **2.2.5.1 Description of the Aquatic Resources in the Vicinity of VYNPS**

3 The principal aquatic resource in the vicinity of the VYNPS is the Connecticut River, which is the
4 source and receiving water body for the plant's cooling system. VYNPS is located on the
5 western shoreline of the Connecticut River in Windham County, 0.75 mi upstream of the Vernon
6 Dam, which is located at RM 142. The area upstream of the Vernon Dam is known as Vernon
7 Pool. Vernon Pool covers 2250 ac (at full-pond elevation of 220.13 ft behind the Vernon Dam)
8 and extends upstream to Bellows Falls Dam at RM 174. Maximum water depth at Vernon Dam
9 is 40 ft (Entergy 2006a). The Connecticut River near Vernon Dam is about 0.5 mi wide (AEC
10 1972). The minimum sustained discharged flow from the Vernon Dam is 1250 cfs, or the pool
11 inflow, if the river flow is less than 1250 cfs. Average daily flow is about 10,500 cfs with an
12 average annual flow rate of $3.3 \times 10^{11} \text{ ft}^3$ (Entergy 2006a). During 2004, the lowest daily river
13 discharge at Vernon Dam was 1757 cfs and the highest was 50,618 cfs. Monthly flow rate
14 averages ranged from 3,967 cfs in October to 23,570 cfs in April (Normandeau 2005).

15 Yearly river water temperatures upstream of VYNPS vary from 32 to 84°F with daily variations
16 rarely exceeding 2°F. Winter water temperatures average 35°F, and summer temperatures
17 average between 70 to 77°F (Entergy 2006a). During 2004, the monthly average daily river
18 temperatures upstream of VYNPS ranged from a low of 32.5°F in February to 72.7°F in July.
19 The lowest daily river temperature was 32.4°F on February 22, while the highest daily river
20 temperature was 76.4°F on August 5 (Normandeau 2005). Between the summer seasons of
21 1998 to 2002, ambient river temperatures never exceeded 80°F (Normandeau 2004a).

22 The transmission lines within the scope of the license renewal review are the Coolidge
23 115/345-kV and Chestnut Hill 115-kV lines. The Coolidge 115/345-kV transmission line
24 associated with VYNPS crosses several streams and rivers including the Black River, Williams
25 River, Chase Brook, Potash Brook, Trout Brook, Middle Branch Williams River, Howe Brook,
26 Stiles Brook, Mill Brook, Grassy Brook, West River, Stickney Brook, Flalladay Brook, Whetstone
27 Creek, Ames Hill Brook, and Broad Brook. The only river crossed by the Chestnut Hill 115-kV
28 transmission line is the Connecticut River. In addition, the upper reach of an unnamed tributary
29 of the Connecticut River is located within the Chestnut Hill transmission line right-of-way.
30 Transmission line ROW maintenance activities in the vicinity of stream and river crossings
31 employ methods to minimize erosion and shoreline disturbance while encouraging vegetative
32 cover.

33 A number of physical and chemical stresses have caused major changes and modifications to
34 the aquatic resources within the Connecticut River. These include dam construction and
35 operation; urban, industrial, and agricultural contaminants; and land-use changes. Water
36 withdrawal from the Connecticut River for municipal, agricultural, and industrial activities is
37 minimal. There are no reported water availability issues concerning the river (Entergy 2006a).

Plant and the Environment

The major industrial use of the river is by the 12 hydroelectric dams. Three dams, Vernon (RM 142), Turners Falls (RM 123), and Holyoke (RM 86) are located downstream of VYNPS. The Connecticut River is also used for recreation, tourism, and conservation (e.g., the Silvio O. Conte National Fish and Wildlife Refuge).

Over 180 species of phytoplankton have been collected in the vicinity of VYNPS. The most abundant phytoplankton species include several species of green algae (*Microspora stagnorum*, *Pediastrum* spp., and *Scenedesmus* spp.); yellow-green algae (*Tribonema bomycinum*, *Dinopryon cylindricum*, and *Ceratium hirudinella*); and diatoms (*Melosira varians*, *Tabellaria* spp., *Fragillaria crotensis*, and *Asterionella formosa*). Phytoplankton densities were highest in August through October (AEC 1972). Diatoms dominate the phytoplankton during most of the year (Aquatec 1978).

About 160 species of wetland and aquatic vascular plants were collected from Vernon Pool during preoperational studies (AEC 1972). Among the more abundant species collected from two marshes located near the plant were common marsh bedstraw (*Galium palustre*), hybrid cattail (*Typha glauca*), fringed sedge (*Carex crinita*), stalked bulrush (*Scirpus pedicellatus*), calamus (*Acorus calamus*), water horsetail (*Equisetum fluviatile*), and dotted smartweed (*Polygonum punctatum*) (AEC 1972).

Over 75 species of zooplankton were identified during preoperational and early postoperational studies. The zooplankton community density and diversity were highest in June through October, with rotifers, cladocerans, and unidentified nauplii (the first larval stage of crustaceans) being common (AEC 1972).

Over 200 macroinvertebrate taxa have been collected during studies associated with VYNPS (Aquatec 1990). The macroinvertebrate community near VYNPS is dominated by dipterans (true flies), caddisflies, and mayflies. Other groups of macroinvertebrates commonly collected included oligochaetes (aquatic worms), molluscs (mostly fingernail clams and snails), crustaceans, hydras, and flatworms (AEC 1972; Normandeau 2005). Few freshwater mussel species are expected to occur in the area of VYNPS due to impounded habitat conditions created by the Vernon Dam. Mussel species that have been collected include the triangle floater (*Alasmidonta undulata*) and Eastern elliptio (*Elliptio complanata*); both are common to abundant within the Connecticut River (Nadeau and Victoria 2003). Also collected were *Ligumia* sp. (probably *L. nasuta*, the Eastern pondmussel) and *Lampsilis* sp. (probably *L. radiata*, the Eastern lampmussel). Dams have been generally responsible for large losses of mussel habitat within the Connecticut River (Kart et al. 2004). No zebra mussels (*Dreissena polymorpha*) or Asiatic clams (*Corbicula fluminea*) have been collected in the area of VYNPS (Normandeau 2005).

Vernon Dam creates a lentic (lake-like) condition above the dam and a lotic (flowing) condition below the dam. The Vernon Dam was constructed in 1907. A fish ladder was constructed at Vernon Dam in 1981. Prior to that time, the dam was a barrier to fish movement. A

Plant and the Environment

downstream fish conduit was first operated in 1991 (Normandeau 2004a). Both warmwater and coolwater fish exist above and below Vernon Dam. Fish are routinely sampled upstream and downstream of Vernon Dam as part of the NPDES monitoring requirements. Samples are collected by electroshocking in May, June, September, and October (VANR 2006).

Over 60 species of fish, including 14 migratory species, have been reported from the Connecticut River (Connecticut River Atlantic Salmon Commission 1998). Thirty-one fish species were collected near VYNPS during preoperational studies. The most commonly collected species were smallmouth bass (*Micropterus dolomieu*), white sucker (*Catostomus commersoni*), yellow perch (*Perca flavescens*), rock bass (*Ambloplites rupestris*), walleye (*Sander vitreus*), white perch (*Morone americana*), common carp (*Cyprinus carpio*), bluegill (*Lepomis macrochirus*), and other sunfish. Recreational fishing occurs mostly for white perch, yellow perch, smallmouth bass, and largemouth bass (*Micropterus salmoides*) (AEC 1972). There are no commercial fisheries near the VYNPS (Entergy 2006a).

Between 1991 and 2004, 33 species of fish have been collected in electroshocking samples from upstream and downstream of Vernon Dam. Among the 28 species collected upstream of Vernon Dam, the predominant species collected were yellow perch (35.6 percent), bluegill (19.5 percent), pumpkinseed (*L. gibbosus*) (9.2 percent), spottail shiner (*Notropis hudsonius*) (8.6 percent), largemouth bass (6.7 percent), and white sucker (4.7 percent). Migratory species that were collected upstream of Vernon Dam included American eel (*Anguilla rostrata*) (0.2 percent), American shad (*Alosa sapidissima*) (0.7 percent), gizzard shad (*Dorosoma cepedianum*) (<0.01 percent), and sea lamprey (*Petromyzon marinus*) (0.3 percent) (Normandeau 2005). Among the 33 species collected downstream of Vernon Dam, the most numerous species included smallmouth bass (27.2 percent), spottail shiner (17.7 percent), American shad (10.9 percent), rock bass (8.1 percent), white sucker (7.5 percent), fallfish (*Semotilus corporalis*) (6.2 percent), and bluegill (6.1 percent). In addition to the American shad, other migratory species that were collected downstream of Vernon Dam included American eel (0.8 percent), Atlantic salmon (*Salmo salar*) (<0.01 percent), blueback herring (*Alosa aestivalis*) (<0.01 percent), gizzard shad (0.1 percent), and sea lamprey (0.5 percent) (Normandeau 2005). The fish community near the VYNPS has remained relatively stable based on the results of sampling that has been conducted since 1968 (Entergy 2006a). The major differences that have been observed since preoperational years are primarily due to the addition of fish passage facilities at the dams, which has allowed migratory species to become reestablished in the area.

Fish consumption guidelines for fish from the Connecticut River have been established due to high levels of mercury (Vermont and New Hampshire) or polychlorinated biphenyls (PCBs) (Massachusetts) found in some species. The guidelines are established for the general public and for a more restrictive group that includes pregnant women, women who may become pregnant, nursing mothers, and children. For Massachusetts, the general public are advised against eating channel catfish (*Ictalurus punctatus*), white catfish (*Ameiurus catus*), American eel, and yellow perch, while the more restrictive groups are advised not to eat any fish from the

Plant and the Environment

Connecticut River (Massachusetts Office of Health and Human Services 2006). The Vermont guidelines suggest no more than nine meals per month for the general public and no more than two to three meals a month for the more restrictive group for most fish species, while fewer meals per month are advised for one or both groups for walleye, smallmouth bass, largemouth bass, northern pike (*Esox lucius*), chain pickerel (*E. niger*), American eel, and yellow perch (VDH 2001). For New Hampshire, the general public are advised to limit themselves to four meals per month for most species while the more restrictive group should have only one meal per month. These limits also apply to bass and pickerel species, although only fish 12 in. or less should be consumed. For Atlantic salmon, adults 16 and older can eat 4 oz per month, while those under 16 and women from the restrictive group are advised against eating Atlantic salmon (NHFGD undated).

The Connecticut River Atlantic Salmon Commission establishes annual schedules for the passage of migratory fish species for a number of dams on the Connecticut River (FWS 2006a). The 2006 schedule for upstream fish passage operations at Vernon Dam was May 15 through July 15 and September 15 through November 15 for Atlantic salmon and May 15 through July 15 for American shad and blueback herring. The schedule for downstream fish passage operations for Vernon Dam was April 1 through June 15 for salmon smolts, October 15 through December 31 for salmon adults, June 1 through July 31 for adult shad, and September 1 through November 15 for juvenile shad (FWS 2006a).

Table 2-8 summarizes the passage of migratory fish species at Vernon Dam between 1981 and 2006. Prior to 1981, the lack of a fish passage facility at Vernon Dam prevented migratory species from moving into Vernon Pool. To illustrate how migrating species disperse throughout the mainstem of the Connecticut River, Table 2-9 presents the numbers of migratory fish species that have passed Holyoke, Turners Falls, Vernon, and Bellows Fall Dams during 2004 and 2005.

Atlantic Salmon

Prior to damming of the Connecticut River watershed, Atlantic salmon spawning runs occurred as far upstream as Beecher Falls (near the Vermont-Canadian border, about RM 370) (NHFGD 2005). Spawning runs mostly occur in the spring, but a small number also migrate upriver in the early fall. Those that return in the spring spend the summer in deep, cold pools of their natal streams before spawning in fall (Connecticut River Atlantic Salmon Commission 1998). The optimal temperature range for migratory adults is 57.2 to 68°F (Krisweb.com undated). Since restoration efforts have begun, Atlantic salmon have reached as far upstream as the Ammonoosuc River, downstream of the Ryegate Dam (RM 273) (FWS undated). Spawning habitat primarily occurs in the Connecticut River tributaries, including the West River (which is crossed by the Coolidge transmission line) (Gephard and McMenemy 2004). Artificial

Plant and the Environment

Table 2-8. Summary of Migratory Fish Passage at Vernon Dam, 1981 Through 2006

Year	Atlantic Salmon	American Shad	Blueback Herring	Gizzard Shad	Sea Lamprey	Striped Bass
1981 to 1985	2.4 ^(a) (0-8)	784 (9-2597)	31.4 (7-56)	0.0	428 (5-1257)	2.6 (0-11)
1986 to 1990	5.6 (0-10)	3932 (982-10,894)	39.4 (0-94)	2.2 (0-7)	423 (205-667)	0.0
1991 to 1995	7.8 (5-13)	18,091 (2681-37,197)	112.6 (10-383)	7.6 (0-14)	680 (509-750)	0.6 (0-1)
1996 to 2000	7.6 (4-12)	8032 (1548-18,844)	3.8 (0-11)	25 (0-114)	4098 (836-16,438)	1 (0-5)
2001 to 2005	1.8 (0-4)	638 (167-1744)	0.0	1 (0-4)	4176 (2210-8119)	0.2 (0-1)
2006	4.0	133.0	0.0	0.0	2895.0	0.0

(a) Mean number (range).

Source: VDFW 2006a

Table 2-9. Summary of Migratory Fish Passage at Holyoke, Turners Falls, Vernon, and Bellows Falls Dams, 2004 and 2005^(a)

Year	Atlantic Salmon	American Shad	Blueback Herring	Gizzard Shad	Sea Lamprey	Striped Bass
2005						
Holyoke	132 (15) ^(b)	116,511	534	126	28,134	226
Turners Falls	5	1500	2	0	17,798	2
Vernon	5	167	0	0	3586	0
Bellows Falls	3	3	0	0	229	0
2004						
Holyoke	46 (6)	191,555	151	279	59,461	256
Turners Falls	1	2092	43	0	8229	9
Vernon	1	653	0	1	3668	0
Bellows Falls	1	0	0	0	0	0

(a) Only observed fish are counted, therefore the numbers presented do not represent all returns.

(b) Number in parentheses are those that were released above Holyoke Dam, the remainder were removed for the captive broodstock program.

Sources: FWS 2004, 2005b

Plant and the Environment

1 barriers (e.g., dams and faulty culverts) and natural barriers (e.g., waterfalls >10 ft high) pose
2 problems for adults migrating to their spawning areas (Kart et al. 2004). Most returning Atlantic
3 salmon are captured for broodstock, although about 10 percent are released upstream of
4 Holyoke Dam to spawn naturally (Connecticut River Atlantic Salmon Commission 1998).
5 Optimal spawning temperature is 41 to 46.4°F (Krisweb.com undated). Spawning habitat
6 consists of coarse, clean gravel stretches that are at least 6 to 9 ft long and 3 ft wide with water
7 depths of 1 to 2 ft. Self-sustaining populations of Atlantic salmon do not currently occur within
8 the Connecticut River watershed, and are therefore dependent on a multi-state stocking effort
9 (Kart et al. 2004). Juvenile Atlantic salmon have been stocked in streams as far north as the
10 Nulhegan River, Vermont, about 350 river miles above the mouth of the Connecticut River
11 (FWS undated).

12
13 Adults that do not die after spawning will overwinter in the river before migrating back to sea.
14 Salmon fry emerge from their nests in May or June. The young (parr) Atlantic salmon inhabit
15 streams for 1 to 3 years (Kart et al. 2004) inhabiting cool, swift-flowing streams with riffles and
16 gravel-cobble substrates. As they mature, they will also use slower-moving waters with pools
17 and vegetation (NHFGD 2005). Optimal range for parr survival is 32.9 to 68°F (Krisweb.com
18 undated). Most parr undergo physiological changes (smoltification) for adaptation for ocean life;
19 however, some parr will become sexually mature before smoltification and are capable of
20 fertilizing the eggs of returning females (Henry and Cragg-Hine 2003). The smolts outmigrate
21 from the river and post-smolts migrate to feeding areas in the North Atlantic during late spring
22 and summer (Kart et al. 2004). The optimal temperature range for migrating smolts is 44.6 to
23 57.7°F (Krisweb.com undated). Atlantic salmon spend at least 1 year in the ocean before
24 returning to spawn (NHFGD 2005).

25
26 Outmigrating adults and smolts are subject to turbine mortality as they move downstream and
27 pass the hydroelectric dams on the Connecticut River. They also can experience extended
28 residency in impoundments (which can cause physiological stress or increased predatory
29 pressure to smolts), and are susceptible to diseases through contact with commercial
30 aquaculture salmon in estuary and marine habitats. Low water pH due to acid deposition
31 appears to be detrimental to outmigrating smolts, while water temperature fluctuations in the
32 Atlantic Ocean over the past 10 years may be contributing to reduced adult salmon returns
33 throughout much of their range (Kart et al. 2004). Annual spawning runs in the Connecticut
34 River have numbered in the hundreds, but more recently have declined to less than one
35 hundred. Spawning run declines have been occurring throughout the species' range; thus, the
36 decline is thought to be due to marine conditions (Gephard and McMenemy 2004). There is a
37 no-take policy for Atlantic salmon in the Connecticut River (NHFGD 2005).

38
39 **American Shad**

40
41 The goal for the restoration of the American shad in the Connecticut River is to have a return of
42 2 million shad at the mouth of the river, a passage of 1 million at Holyoke Dam, 850,000 at
43 Turners Falls, and 750,000 at Vernon Dam (Shad Studies Subcommittee 1992). To date, the

maximum return occurred in 1992 with a river estimate of 1.63 million and the count at Holyoke Dam estimated at 720,000. Counts have generally been less than 50 percent of these numbers in the succeeding years (FWS 2005c). Table 2-10 provides counts for American shad at Holyoke, Turners Falls, and Vernon Dams.

The American shad is reasonably secure within the Connecticut River as long as access to spawning and nursery habitats is not obstructed (Kart et al. 2004). However, annual spawning runs into the Vermont-New Hampshire portion of the Connecticut River have noticeably declined since the peak years of the early 1990s. This may be attributable to the inefficiency of the fishways at Turners Falls and, in some years, high spring discharges from Vernon Dam. Turbine mortality of outmigrating adults and juveniles is also a factor. Habitat modifications due to the impoundments and improvements in striped bass (*Morone saxatilis*) stocks have increased predatory pressure on clupeids and are also likely to contribute to the decline in abundance. Additionally, excessive commercial harvests within estuaries and the Atlantic seaboard also jeopardize shad stocks (Kart et al. 2004). The American shad occurs upstream in the Connecticut River to at least Bellows Falls (RM 174), although a few fish have passed above this dam. It has also been observed in the West River (enters the Connecticut River at RM 149) (Kart et al. 2004). Bellows Falls is thought to be the historic upstream range of the American shad prior to the construction of the hydroelectric dams in the Connecticut River (FWS undated). Although American shad can climb the fish ladder at Turners Falls, the ladder is thought to be too long for many individuals, causing them to tire and not pass farther upstream (Castro-Santos et al. 2005). In some years, <1 percent pass Turners Falls Dam (Castro-Santos et al. 2005). Between 1997 and 2002, only 2.45 percent of the American shad that passed Holyoke Dam passed Turners Falls Dam, while 73.3 percent that passed Turners Falls Dam passed Vernon Dam (Gephard and McMenemy 2004). Dam passage facilities on the Connecticut River that allow upriver displacement have resulted in higher adult American shad mortality, large decreases in repeat spawners, and decreases in the mean size and age of adults. The loss in larger repeat-spawning females could account for a 14 percent reduction in the annual recruitment to the American shad population in the river (Leggett et al. 2004).

American shad spawning occurs in well-oxygenated areas in broad flats and shallow water. Spawning substrates vary but water velocities need to be sufficient to minimize sedimentation (Kart et al. 2004). Spawning occurs at a temperature range of 46.4 to 78.8°F with peak activity at 57.2 to 69.8°F (O'Leary and Kynard 1986). Repeat spawning individuals in the Connecticut River has been reported at 63 percent (MacKenzie et al. 1985). High flow rates during the spawning season (late May and June) prolong the development of eggs, and turbulent June flows can promote unfavorable feeding conditions for first-feeding larvae that can reduce American shad larval survival. Both factors can reduce year-class strength (Savoy et al. 2004). The fecundity of first-time spawners has been reported to average 256,000 eggs per female, with a lifetime fecundity per female average 384,000 eggs. However, many eggs are not fertilized and, additionally, fertilized egg mortality is high (e.g., only 5 to 19 percent of fertilized

Plant and the Environment

Table 2-10. American Shad Counts at Holyoke, Turners Falls, and Vernon Dams from 1981 Through 2005

Year	River Estimate	Holyoke Dam	Turners Falls Dam	Vernon Dam
1981	910,000	380,000	200 (<0.1) ^(a)	97 (48.5) ^(b)
1982	940,000	290,000	11 (<0.1)	9 (81.8)
1983	1,570,000	530,000	12,705 (2.4)	2597 (20.4)
1984	1,230,000	500,000	4333 (0.9)	335 (7.7)
1985	730,000	480,000	3855 (0.8)	833 (21.6)
1986	750,000	350,000	17,858 (5.1)	982 (5.5)
1987	590,000	280,000	18,959 (6.8)	3459 (18.2)
1988	650,000	290,000	15,787 (5.4)	1370 (8.7)
1989	980,000	354,000	9511 (2.7)	2953 (31.0)
1990	820,000	363,788	27,908 (7.7)	10,868 (38.9)
1991	1,200,000	520,000	54,656 (10.5)	37,197 (68.1)
1992	1,630,000	720,000	60,089 (8.3)	31,155(51.8)
1993	750,000	340,000	10,221 (3.0)	3652 (35.7)
1994	330,000	181,000	3729 (2.1)	2681 (71.9)
1995	300,000	190,000	18,369 (9.7)	15,771 (85.9)
1996	670,000	280,000	16,192 (5.8)	18,844 (116.4)
1997	660,000	300,000	9216 (3.1)	7475 (81.1)
1998	640,000	320,000	10,527 (3.3)	7239 (68.8)
1999	480,000	190,000	6751 (3.6)	5309 (78.6)
2000	428,000	230,000	2590 (1.1)	1548 (59.8)
2001	740,000	270,000	1540 (0.6)	1666 (108.2)
2002	687,000	370,000	2870 (0.8)	336 (11.7)
2003	527,000	290,000	NA ^(c)	267 (NA)
2004	531,000	192,000	2092 (1.1)	653 (31.2)
2005	NA	116,511	1500 (1.3)	167 (11.1)

(a) Number (Percent of Holyoke Dam count).

(b) Number (Percent of Turners Falls Dam count).

(c) NA = not available.

Sources: Aquatec 1990; Connecticut Atlantic Salmon Commission 2004; FWS 2005b,c,d, 2006d; Gephard and McMenemy 2004

1 eggs survive) (MacKenzie et al. 1985; Savoy et al. 2004). Maximum egg hatch and survival
2 occurs at a range of 59.9 to 78.8°F. Temperatures in excess of 80.1°F are unsuitable (O'Leary
3 and Kynard 1986). The eggs are nonadhesive and most drift in the current until they hatch
4 (NHFGD 2005). Substrate is a critical problem only in areas where silt or sand can smother
5 eggs that have settled to the bottom (Atlantic Salmon Marine Fisheries Commission 1999).

6
7 About 60 to 80 percent of newly hatched larvae die within 7 days after first-feeding begins
8 (Savoy et al. 2004). Nursery habitat for American shad is generally deep pools away from the
9 shoreline (Atlantic States Marine Fisheries Commission 1999). Larvae change into filter-feeding
10 juveniles in July through August (Savoy et al. 2004). Juvenile shad are found at water
11 temperatures of 50 to 87.8°F (O'Leary and Kynard 1986). Juvenile American shad form dense
12 schools and outmigrate to the ocean in late fall (October to November) and mature at sea (Kart
13 et al. 2004). Outmigration generally begins when water temperatures drop to 66.2°F, peak at
14 57.2 to 48.2°F, and end at 50 to 46.4°F (O'Leary and Kynard 1986). The lower lethal
15 temperature for American shad is 39.2°F with sublethal effects occurring at 42.8°F (O'Leary
16 and Kynard 1986). Average annual mortality of returning adults in the Connecticut River is
17 about 70 percent (MacKenzie et al. 1985).

18
19 **Blueback Herring**

20
21 Historically, the blueback herring may have occurred as far upstream in the Connecticut River
22 as Bellow Falls (Kart et al. 2004). Although blueback herring are currently common downstream
23 of Turners Falls Dam and below the first dams on most tributaries, they are in decline
24 throughout the watershed. Their numbers are low between Turners Falls Dam and Bellows
25 Falls Dam (Gephard and McMenemy 2004). The blueback herring and alewife (*Alosa*
26 *pseudoharengus*) are collectively referred to as river herring. Alewives rarely occur upstream of
27 the Holyoke Dam (Connecticut River Atlantic Salmon Commission 2004). Spawning success
28 and survival of juveniles and adults depends upon successful passage of the dams (FWS
29 undated). Between 1981 and 1992, upstream passage at Holyoke Dam (RM 86) averaged
30 433,000 blueback herrings. Their upstream passage has decreased significantly in recent
31 years (FWS undated, 2005c). The annual passage during the 1990s was 44,000, only 1939
32 were counted in 2002, and a few hundred in 2004. Due to significant declines in the blueback
33 herring population within the Connecticut River over the past 20 years, blueback herring are
34 rarely encountered in the Vermont-New Hampshire portion of the river (Kart et al. 2004). At
35 Vernon Dam, no blueback herring have been counted in more than 5 years (Table 2-5).

36
37 The blueback herring spawns in swift flowing waters over substrates such as gravel, sand,
38 detritus, and submersed aquatic vegetation (Kart et al. 2004). Spawning occurs between April
39 and July at water temperatures ranging from 57 to 81°F (Connecticut River Atlantic Salmon
40 Commission 2004). A female can produce around 200,000 eggs (Connecticut River Atlantic
41 Salmon Commission undated). The eggs are released in the water column, but they settle and
42 adhere to the substrate. Adults return to sea after spawning, while the young-of-the-year
43 migrate to the ocean in the fall (Kart et al. 2004; NHFGD 2005). Juveniles begin their

Plant and the Environment

1 outmigration when water temperatures drop to 69.8°F, peak at 59 to 57.2°F, and end at 50°F
2 (O'Leary and Kynard 1986). Fewer than 1 percent of the young-of-the-year survive to migrate
3 to sea as juveniles, while as many as 90 percent of adults die after spawning (FWS 2002a).
4 High mortality of outmigrating juveniles and adults is thought to occur due to turbine mortality
5 during dam passage. Additionally, improvements in striped bass stocks have increased
6 predatory pressure on clupeids (Kart et al. 2004). Other factors that may have contributed to a
7 decline in blueback herring throughout the Atlantic Coast include their use as bait for the striped
8 bass sport fishery and commercial harvest in the Atlantic Ocean (Gephard and McMenemy
9 2004).

10
11 **Gizzard Shad**
12

13 The gizzard shad is a relatively new addition to the Connecticut River, having been first
14 observed from the mouth of the river in 1980 (FWS undated). Their occurrence in the
15 Connecticut River is due to a natural northern range extension along the East Coast (Gephard
16 and McMenemy 2004). As the gizzard shad has not fully adapted to New England winters, they
17 can experience high mortalities during cold winters, which subsequently lowers spawning runs
18 (Gephard and McMenemy 2004). While still sparse, they are now found as far upstream as
19 Bellows Falls Dam. Fish passage facilities have benefitted the gizzard shad, although programs
20 are not directly aimed at increasing the gizzard shad. Spawning runs include both anadromous
21 and potamodromous individuals (Gephard and McMenemy 2004). The latter are those
22 individuals that overwinter in freshwater and subsequently migrate into smaller tributaries for
23 spawning and rearing. They spawn in late spring and early summer (FWS undated). Gizzard
24 shad spawning in a vernal pool was first documented in 1989 (Aquatec 1990).

25
26 **Sea Lamprey**
27

28 The sea lamprey was extirpated from Vermont about two centuries ago due to dams and
29 degradation of spawning and nursery habitats (e.g., from excessive siltation). Although not
30 designed to increase the sea lamprey population, retrofitting the dams with passage facilities
31 has restored the sea lamprey. It now spawns in the Connecticut River at least as far upstream
32 as Wilder Dam (RM 217) and in tributaries such as the West, Williams, Black, and White Rivers
33 (Kart et al. 2004). While parasitic at sea, the adult sea lamprey does not feed during its
34 freshwater spawning migration and is not a threat to other fishes in the river. It spawns over
35 substrates of sand, gravel, and rubble at depths of 1.5 to 2.0 ft (Kart et al. 2004). Adults die
36 after spawning (FWS undated). The larvae (called ammocoetes) burrow into rich organic
37 stream bottoms and filter-feed at the streambed surface (Kart et al. 2004). They remain in
38 freshwater for up to 10 years. After migrating to sea, they become parasitic, living in the ocean
39 for 1 to 2 years before initiating their spawning migrations (FWS undated).

American Eel

The American eel spawns in the fall within the Sargasso Sea (a 2 million square-mile area of the North Atlantic Ocean between the West Indies and the Azores); each female can produce 20 to 40 million eggs (FWS 2005a). Adults die after spawning (FWS undated). After hatching, larvae (leptocephali) drift on currents to coastal areas where they transform into glass eels and then to elvers, which migrate to inland waters where they can live as immature yellow eels for 10 to 25 or more years before maturing and returning to the sea to spawn (silver eels) (Kart et al. 2004; NHFGD 2005). The American eel is ubiquitous in Connecticut and Massachusetts, common to infrequent in southern Vermont/New Hampshire, and uncommon in the northern Connecticut River basin (FWS undated). The number of American eels has been decreasing coast-wide in recent years (FWS undated). Dams (even those with fish ladders designed for adult anadromous species) can block access of juveniles to their important rearing habitats (American Eel Plan Development Team 2000; FWS undated) and can cause a high rate of turbine mortality to adults outmigrating to the ocean. High commercial harvests of juveniles in coastal waters has also diminished population stocks (Kart et al. 2004; FWS 2005a).

Striped Bass

Although the striped bass is considered an anadromous species, they are also considered to be amphidromus within the Connecticut River watershed, as they will move into freshwater for purposes other than spawning (e.g., for feeding) (FWS undated). Spawning most often occurs in the estuary or tidal portion of rivers. A female can produce 0.5 to 3 million eggs (Connecticut River Atlantic Salmon Commission undated). While the striped bass has been reported as far upstream as Bellows Falls Dam (FWS undated); there is little evidence that they spawn in the river (Gephard and McMenemy 2004). The numbers and size of striped bass in the Connecticut River, particularly below Holyoke Dam, have been increasing in recent years due to coast-wide stock recovery. The population of striped bass along the Atlantic coast has increased from about 5 million in 1982 to more than 41 million since 1995 (Massachusetts Division of Marine Fisheries undated). As previously discussed, the increase in the striped bass population in the Connecticut River, as well as other watersheds along the Atlantic coast, appear to coincide with declines in American shad populations. They generally occur in the river between April and early July, although some may exist in the river year-round (Gephard and McMenemy 2004). Since the mid-1990s, an average of over 300,000 striped bass larger than 2.5 ft long have occurred in the Connecticut River from April through June (Savoy and Crecco 2004). Striped bass of this size are large enough to consume adult male and first-spawning female American shad. This many striped bass could account for the marked decrease in American shad and blueback herring populations in the Connecticut River (Savoy and Crecco 2004).

Plant and the Environment

1 **2.2.5.2 Threatened or Endangered Aquatic Species**

2
3 Few Federally or State-listed aquatic species are known to occur in the Connecticut River in the
4 southeastern Vermont-southwestern New Hampshire-northern Massachusetts area or in the
5 Connecticut River tributaries within the three Counties in which the VYNPS transmission lines of
6 concern occur (i.e., Windham and Windsor Counties, Vermont, and Cheshire County, New
7 Hampshire) (Table 2-11). The vicinity of VYNPS is encompassed within or upstream of the
8 range of two Federally endangered aquatic species, the dwarf wedgemussel (*Alasmidonta*
9 *heterodon*) and the shortnose sturgeon (*Acipenser brevirostrum*), respectively. No Federally
10 listed aquatic species are known from the tributaries of the Connecticut River that are crossed
11 by the transmission lines associated with VYNPS (FWS 2006d; NMFS 2006). The State-listed
12 brook floater (*Alasmidonta varicosa*) is known from the West River, a Connecticut River tributary
13 that is crossed by the Coolidge transmission line. The Federally and State-listed species are
14 discussed in the remainder of this section.

15
16 **Table 2-11.** Federally and Vermont-Listed Aquatic Species Potentially Occurring
17 in the Vicinity of VYNPS and Associated Transmission Lines

19	20	Scientific Name	Common Name	Federal Status ^(a)	State Status ^(a)	Habitat
Mussels						
22	23	<i>Alasmidonta heterodon</i>	dwarf wedgemussel	E	E	Large rivers in substrates of stable mud, silty sand, sand, or gravel.
25		<i>Alasmidonta varicosa</i>	brook floater	-	T	Small rivers in rocky or gravelly substrates and in sandy shoals.
Fish						
28	29	<i>Acipenser brevirostrum</i>	shortnose sturgeon	E	E	Large rivers; occasionally enters saltwater.

30 (a) E = endangered, T = threatened, - = not listed.

31 Sources: Kart et al. 2004; NHFGD 2005

32
33 **Shortnose Sturgeon**

35 The shortnose sturgeon was Federally listed as an endangered species on March 11, 1967.
36 The National Oceanic and Atmospheric Administration National Marine Fisheries Service
37 (NOAA Fisheries) is the lead agency for this species (FWS 2006b). A recovery plan for the
38 shortnose sturgeon has been prepared (NMFS 1998). Decreases in the shortnose sturgeon
39 were attributable to over-harvests, bycatch in the shad fishery, dams, and pollution
40 (Suckling 2006; FWS undated). It inhabits freshwater rivers, but occasionally enters saltwater

(NHFGD 2005). Where not blocked by dams or other barriers, the shortnose sturgeon is capable of migrating 124 mi upriver to spawn (NHFGD 2005). The historic range in the Connecticut River appears to be upstream to Turners Falls (RM 123) (Gephard and McMenemy 2004). Females reach sexual maturity at age 8 to 12 years, while males mature at age 6 to 10 (CDEP 2004a). The shortnose sturgeon spawns during mid- to late-spring in areas containing boulder, cobble, and gravel substrates at water depths of 10 m or less. Spawning occurs at water temperatures of 48.2 to 64.4°F (NHFGD 2005). Females only spawn every three to 5 years, while males may spawn every year (CDEP 2004a).

Two populations of shortnose sturgeon occur in the Connecticut River, a partially landlocked population between the Holyoke and Turners Falls Dam in Massachusetts, and the second population between Holyoke Dam and Long Island Sound, which is amphidromus (moving between fresh and salt water) (FWS undated; CDEP 2004a). The upper Connecticut River population ranged from about 197 to 714 fish in the 1976 to 1978 period (Suckling 2006). There were 47 to 98 spawning fish in 1992 and 1993, respectively. The lower Connecticut River population has increased from about 875 in the 1988 to 1993 time period to about 1800 in 2003 (Suckling 2006). The Holyoke Dam fish lift passes an average of about four shortnose sturgeon per year (NMFS 1998). The population downstream of the Turners Falls Dam is at least 20 mi downstream of VYNPS (Entergy 2006a).

Dwarf Wedgemussel

The dwarf wedgemussel was Federally listed as an endangered species on March 14, 1990. The U.S. Fish and Wildlife Service (FWS) Northeast Region (Region 5) is the lead region for this species (FWS 2006b). A recovery plan for the dwarf wedgemussel has been prepared (FWS 1993). The reported distribution of the dwarf wedgemussel in the Connecticut River basin includes Hampshire and Franklin Counties, Massachusetts; Cheshire and Sullivan Counties, New Hampshire; and Windham and Windsor Counties, Vermont (Entergy 2006a). It has been documented from Brattleboro and further north in Vermont, but not in the Vernon area (VANR 2005). The dwarf wedgemussel has been impacted by riparian disturbance, pollution and sedimentation, stream fragmentation, impoundments, and altered flows (FWS 1990; NHFGD 2005). Generally, areas immediately upstream of dams can have conditions (e.g., siltation and low dissolved oxygen levels) that are unsuitable for mussels, while areas immediately downstream of dams can have daily water level and temperature fluctuations that can stress mussels (FWS 1993). Thus, the dwarf wedgemussel would not be expected to be present in the vicinity of the VYNPS, including the thermal plume area.

Less than 55 populations of the dwarf wedgemussel remain throughout its range. Forty-one of these populations contain less than 50 individuals, with 32 populations having less than 10 individuals or are possibly extirpated. Only 8 or 9 populations have 50 to 1000 individuals, and only 4 populations have 10,000 to 100,000 individuals (NHFGD 2005). In recent surveys, no specimens were found in Vernon Pool between Bellows Falls Dam and Vernon Dam

Plant and the Environment

(NHFGD 2005). The closest occurrence to the VYNPS in the Connecticut River is near Rockingham, Vermont, just north of Bellows Falls Dam, 30 mi upstream of the site (NHFGD 2005; Entergy 2006a).

The small (generally \leq 1.5-in.) mussel inhabits primarily large rivers in substrates of stable mud, silty sand, sand, or gravel (CDEP 2004b; Kart et al. 2004). Water currents need to be sufficient to maintain the area free of surficial silt (Kart et al. 2004). Suitable fish hosts in the Connecticut River watershed for the glochidia of the dwarf wedgemussel include the tessellated darter (*Etheostoma olmstedi*), slimy sculpin (*Cottus cognatus*), and juveniles and parr of Atlantic salmon (Kart et al. 2004; NHFGD 2005). Healthy populations of tessellated darter and slimy sculpin in the Connecticut River and major tributaries such as the Ashuelot River contribute to the persistence of the dwarf wedgemussel (NHFGD 2005). Unlike many mussel species that may live 20 to 100 years, the dwarf wedgemussel only lives about 10 years. Thus, individuals must be constantly replaced to maintain viable populations (NYSDEC undated).

Brook Floater

Within Vermont, the State-threatened brook floater is currently known only from the West River (Kart et al. 2004). It occurs in small- and medium-sized streams to large rivers within rocky or gravel substrates and sandy shoals, often with rooted aquatic vegetation and in or adjacent to riffles and rapids (MDFW 1989; Kart et al. 2004; NHFGD 2005). The brook floater requires clean, well-oxygenated waters with moderate to high flows (NHFGD 2005). Suitable fish hosts for the glochidia of the brook floater include slimy sculpin, longnose dace (*Rhinichthys cataractae*), blacknose dace (*R. atratulus*), golden shiner (*Notemigonus crysoleucas*), pumpkinseed, yellow perch, and tessellated darter (Kart et al. 2004). Declines of the brook floater are due to dams and flow regulation, siltation, dredging, stream diversions and channelization, nutrient loading, and acid precipitation (MDFW 1989).

2.2.6 Terrestrial Resources

2.2.6.1 Description of Terrestrial Resources in the Vicinity of VYNPS

The 125-ac VYNPS site is located just west of the Connecticut River and within the Southern Vermont Piedmont, a region of low rolling foothills that are dissected by streams and rivers (Thompson and Sorenson 2005). The region is mostly forested, but small agricultural areas are interspersed among the hills and dominate the fertile floodplains. Sugar maple (*Acer saccharum*), American beech (*Fagus grandifolia*), ash (*Fraxinus spp.*), and yellow birch (*Betula alleghaniensis*) occur at the higher elevations, and oak (*Quercus spp.*) and pine (*Pinus spp.*) become common in the Connecticut River Valley and on many south-facing slopes. The VYNPS site and the surrounding region are within the Adirondack-New England Mixed

1 Forest–Coniferous Forest–Alpine Meadow Province of the Warm Continental Regime
2 Mountains Division of the Humid Temperate Domain, using Bailey's delineation of ecoregions of
3 North America (Bailey 1995, 1996, and 1998).

4
5 Common terrestrial vertebrate species in the region include wild turkey (*Meleagris gallopavo*),
6 white-tailed deer (*Odocoileus virginianus*), eastern cottontail (*Sylvilagus floridanus*), porcupine
7 (*Erethizon dorsatum*), eastern chipmunk (*Tamias striatus*), gray squirrel (*Sciurus carolinensis*), a
8 variety of other small mammals, and numerous songbirds (Thompson and Sorenson 2005).
9 Vernal pools provide habitat for salamanders, including red-backed salamander (*Plethodon*
10 *cinereus*) and spotted salamander (*Ambystoma maculatum*). Other species in the vicinity
11 include green frog (*Rana clamitans*), wood frog (*R. sylvatica*), spring peeper (*Pseudacris*
12 *crucifer*), red-spotted newt (*Notophthalmus viridescens*), Jefferson's salamander (*Ambystoma*
13 *jeffersonianum*), ruffed grouse (*Bonasa umbellus*), beaver (*Castor canadensis*), muskrat
14 (*Ondatra zibethicus*), mink (*Mustela vison*), black bear (*Ursus americanus*), moose (*Alces*
15 *alces*), snowshoe hare (*Lepus americanus*), and fisher (*Martes pennanti*) (VDFW 2006b).

16
17 About 35 ac (28 percent) of the VYNPS site currently is occupied by buildings and structures
18 (Entergy 2006a). Prior to construction of the station, the site was primarily pasture land with a
19 few mature trees (AEC 1972). The remainder of the site supports mowed grass and early
20 successional habitat (66 ac; 53 percent), mixed deciduous and coniferous woodland (20 ac;
21 16 percent), shrubland (3 ac; 2 percent); and wetland (1 ac; 1 percent). A band of riparian
22 vegetation parallels the western bank of the Connecticut River. About 1600 ft of the shoreline
23 near the intake and discharge structures consists of rip-rap through which shrubs and small
24 trees have grown. Mixed deciduous and coniferous riparian woodland parallels the river shore
25 upstream and downstream of the rip-rap area for the remainder of the VYNPS property. This
26 riparian woodland is up to 300 ft wide.

27
28 Eleven wetland areas have been delineated on the VYNPS site (SVE Associates 2005). All of
29 these wetlands are dominated by herbaceous species, were described as depressions or
30 swales, and are Vermont Category 3 wetlands, i.e., they are not considered significant for
31 providing wetland functions (Smith 2004; Lattrell 2004, 2005). The largest of these wetlands is
32 about 1.2 ac (0.5 ha), and was apparently affected by construction of stormwater retention
33 areas associated with a new parking area (Smith 2004). Dominant plant species found in site
34 wetlands include reed canary grass (*Phalaris arundinacea*), spike rush (*Eleocharis* spp.), field
35 horsetail (*Equisetum arvense*), dark green bulrush (*Scirpus atrovirens*), soft rush (*Juncus*
36 *effusus*), sedges (*Carex* spp.), and sensitive fern (*Onoclea sensibilis*) (Smith 2004; Lattrell 2004;
37 Lattrell 2005). In addition to the wetlands on the VYNPS site, there are several small marshes
38 located on the western shore of the Connecticut River upstream and downstream of the VYNPS
39 site (AEC 1972; Entergy 2006j). These marshes are dominated by common reed (*Phragmites*
40 *communis*).

41
42 A number of migrant waterfowl and other birds occur in wetlands and aquatic habitats adjacent
43 to the VYNPS site (Entergy 2006a). Migrant waterfowl species that occur in the area include

Plant and the Environment

1 mallard (*Anas platyrhynchos*), Canada goose (*Branta canadensis*), and American black duck
2 (*Anas rubripes*). Osprey (*Pandion haliaetus*) and bald eagle (*Haliaeetus leucocephalus*) forage
3 and roost along the Connecticut River and occasionally roost in large riparian trees on the
4 VYNPS site.

5 Several forested areas within the nearby 1401-ac Roaring Brook Wildlife Management Area are
6 considered important deer wintering areas (Entergy 2006a). Many of the natural communities
7 on the wildlife management area property are unique to Vermont and are more like those found
8 in Massachusetts (VDFW 2006b). The wildlife management area is located about 1 mi to the
9 west and south of VYNPS. It is mostly forested with a mixture of eastern hemlock (*Tsuga*
10 *canadensis*) and hardwood trees, especially white oak (*Quercus alba*) and red oak (*Q. rubra*),
11 which provide important food for many wildlife species.

12

13 **2.2.6.2 Threatened or Endangered Terrestrial Species**

14 Table 2-12 presents the scientific names, common names, listing status, and habitats of
15 Federally and State-listed terrestrial species that could occur in the vicinity of the VYNPS site
16 (Windham County, Vermont, and Cheshire County, New Hampshire). This information is also
17 presented for species that could occur on or in the vicinity of transmission lines associated with
18 VYNPS (VYNPS-to-Coolidge line in Windham and Windsor Counties, Vermont, and the
19 VYNPS-to-Chestnut Hill line in Windham County, Vermont, and Cheshire County, New
20 Hampshire).

21 The NRC contacted FWS to determine the presence of Federally listed threatened or
22 endangered species in the vicinity of VYNPS or associated transmission lines (NRC 2006b,
23 2006c). The FWS determined that the bald eagle was the only Federally listed species known
24 to occur in the vicinity of these facilities, and that bald eagles nest less than 1 mi downstream of
25 VYNPS (FWS 2006d). In addition, FWS determined that no impacts to the eagles are known to
26 occur at this site that could be attributed to VYNPS or its transmission lines, and that
27 preparation of a Biological Assessment or further consultation under Section 7 of the
28 Endangered Species Act is not required.

29 Entergy contacted the Vermont Agency of Natural Resources (VANR) to determine if important
30 natural habitats occurred on or in the vicinity of the VYNPS site (Tucker 2005). VANR provided
31 a list of State-listed species that are known to occur within 6 mi of the VYNPS site. These
32 species and others determined to occur or potentially occur in the project area are presented in
33 Table 2-12. Federally listed species with the potential to occur in the project area are discussed
34 in the remainder of this section. Included are Jesup's milk-vetch, northeastern bulrush, bald
35 eagle, and Indiana bat.

1 **Table 2-12.** Federally Listed and State-Listed Terrestrial Species Whose Ranges Include the
 2 VYNPS Site, Transmission Lines Within the Scope of License Renewal, and
 3 Vicinity

5	Scientific Name	Common Name	Federal Status ^(a)	State Status ^(a)	Habitat
Plants					
8	<i>Allium canadense</i>	wild garlic	NL	NH-E	Moist fields or open woods. Known to occur in Cheshire County, New Hampshire.
9	<i>Astragalus robbinsii</i> var. <i>jesupi</i>	Jesup's milk-vetch	E	VT-E	Connecticut River Valley. Confined to calcareous bedrock outcrops that are ice scoured annually. Nearest known population approximately 50 mi north of site. Known to occur in Windsor County, Vermont.
11	<i>Aureolaria virginica</i>	downy false-foxfoglove	NL	NH-T	Dry oak woods. Known to occur in Cheshire County, New Hampshire.
12	<i>Aureolaria pedicularia</i> var. <i>intercedens</i>	fern-leaved false-foxfoglove	NL	NH-E	Dry deciduous woods and clearings. In New Hampshire, it is found in partial to open canopy portions of oak-pine forest and woodlands on rocky slopes and ridges, outcrops, and summits. Known to occur in Cheshire County, New Hampshire.
15	<i>Cornus florida</i>	flowering dogwood	NL	VT-T	Mesic deciduous woods, on floodplains, slopes, bluffs, and in ravines. Found within 6 mi of VYNPS in Windham County, Vermont.
16	<i>Crotalaria sagittalis</i>	rattlebox	NL	VT-T	Sandy soils of open areas. Found within 6 mi of VYNPS in Windham County, Vermont.
17	<i>Fimbristylis autumnalis</i>	autumn fimbriстиlis	NL	VT-E	Moist to wet sands, peats, silts, or clays, primarily of disturbed, sunny ground such as seeps, ditches, savannas, stream banks, reservoir drawdowns, and pond shores. Found within 6 mi of VYNPS.

Plant and the Environment

Table 2-12. (contd)

	Scientific Name	Common Name	Federal Status ^(a)	State Status ^(a)	Habitat
5	<i>Galearis spectabilis</i>	showy orchis	NL	NH-T	Rich woods, primarily beech and maple woods with calcareous soils, and at the edges of swamps. Known to occur in Cheshire County, New Hampshire.
6	<i>Helianthemum bicknellii</i>	plains frostweed	NL	VT-T	Dry sandy or rocky soil in open woods, clearings, and grasslands. Found within 6 mi of VYNPS.
8	<i>Helianthus strumosus</i>	harsh sunflower	NL	VT-T	Openings or edges of woods. Found within 6 mi of VYNPS.
10	<i>Hypericum ascyron</i>	great St. John's-wort	NL	VT-T	Along streambanks, and in wet meadows and thickets. Found within 6 mi of VYNPS.
11	<i>Isoetes engelmannii</i>	Engelmann's quillwort	NL	VT-T	Open areas of shallow bodies of water; pond margins and ditches. Found within 6 mi of VYNPS.
12	<i>Isotria verticillata</i>	large whorled pogonia	NL	VT-T, NH-E	Acid woods and edges of fens. Found within 6 mi of VYNPS.
13	<i>Lechea mucronata</i>	hairy pinweed	NL	VT-E	Dry sandy soils in fields and open woods. Found within 6 mi of VYNPS.
14	<i>Lespedeza hirta</i>	hairy bush-clover	NL	VT-T	Dry sunny places and roadsides. Found within 6 mi of VYNPS.
15	<i>Rhexia virginica</i>	Virginia meadow-beauty	NL	VT-T	Wet sandy soil. Found within 6 mi of VYNPS.
16	<i>Potamogeton zosteriformis</i>	flatstem pondweed	NL	NH-T	Ponds and slow streams. Known to occur in Cheshire County, New Hampshire.
18	<i>Polygonatum biflorum</i> var. <i>commutatum</i>	giant Solomon's seal	NL	NH-E	Dry to moist sandy, loamy, or rocky soils in deciduous woods and thickets, usually in upland areas. Known to occur in Cheshire County, New Hampshire.

Table 2-12. (contd)

	Scientific Name	Common Name	Federal Status^(a)	State Status^(a)	Habitat
1 2	<i>Scirpus ancistrochaetus</i>	northeastern bulrush	E	VT-E	Alluvial meadows and small headwater or coastal plains ponds characterized by seasonally variable water levels. Known to occur in Windham County, Vermont.
3	<i>Solidago odora</i>	sweet goldenrod	NL	VT-T	Dry openings in sandy or rocky acid soil; open woods, thinly wooded slopes, thickets, and clearings. Found within 6 mi of VYNPS.
4	<i>Uvularia perfoliata</i>	perfoliate bellwort	NL	NH-E	Moist woodland and scrub. Known to occur in Cheshire County, New Hampshire.
5	<i>Viola lanceolata</i>	lance-leaved violet	NL	VT-T	Wet open places often along streams and ponds, especially in sandy soils. Found within 6 mi of VYNPS.
6 7	<i>Woodwardia virginica</i>	Virginia chain-fern	NL	VT-T	Swamps and wet woods. Found within 6 mi of VYNPS.
8					
9	Insects				
10	<i>Cicindela puritana</i>	puritan tiger beetle	E		Extirpated. Formerly sandy riverine beaches along the Connecticut River.
11					
12	Amphibians				
13 14	<i>Ambystoma jeffersonianum</i>	Jefferson's salamander	NL	VT-SC	Well-shaded deciduous forest with ponds and pools for breeding. Found within 6 mi of VYNPS.

Plant and the Environment

Table 2-12. (contd)

	Scientific Name	Common Name	Federal Status ^(a)	State Status ^(a)	Habitat
1 2	<i>Ambystoma opacum</i>	marbled salamander	NL	NH-E	Sandy and gravelly areas of mixed deciduous woodlands; low areas around ponds, swamps, and quiet streams during breeding season. Known to occur in Cheshire County, New Hampshire.
3 4	<i>Hemidactylum scutatum</i>	four-toed salamander	NL	VT-SC	Swamps, boggy streams, and wet, wooded, or open areas near ponds or quiet, mossy, or grassy/sedgy pools. Found within 6 mi of VYNPS.
5	<i>Bufo fowleri</i>	Fowler's toad	NL	VT-SC	Wooded areas, river valleys, floodplains, agricultural areas; usually in areas with deep friable soils. Breeds in shallow water of marshes and bodies of water lacking a strong current. Found within 6 mi of VYNPS.
6	Reptiles				
7 8	<i>Coluber constrictor</i>	eastern racer	NL	VT-T	Wide range of habitats including prairies, shrublands, woodlands, forests, stream sides, and semi-agricultural areas. Found within 6 mi of VYNPS.
9	<i>Clemmys guttata</i>	spotted turtle	NL	VT-E	Unpolluted, small, shallow bodies of water such as marshes, marshy pastures, bogs, fens, streams, swamps, ponds, and vernal pools surrounded by relatively undisturbed meadow or undergrowth. Found within 6 mi of VYNPS.

Table 2-12. (contd)

	Scientific Name	Common Name	Federal Status^(a)	State Status^(a)	Habitat
1	<i>Crotalus horridus</i>	timber rattlesnake	NL	NH-E	Mountainous or hilly deciduous or mixed deciduous-coniferous forest, often with rocky outcroppings, steep ledges, and rock slides. Known to occur in Cheshire County, New Hampshire.
2					
3		Birds			
4	<i>Haliaeetus leucocephalus</i>	bald eagle	T, PDL	VT-E	Large open bodies of water with adjacent trees. Nests along Connecticut River less than 1 mi downstream of VYNPS site. Migrates and winters through area. Known to occur in Windham and Windsor Counties, Vermont.
5					
6					
7		Mammals			
8	<i>Myotis sodalis</i>	Indiana bat	E	VT-E	Riparian, bottomland, and upland forest habitats. Possible occurrence in Windham and Windsor County, Vermont, and Cheshire County, New Hampshire.
9					

(a) NL = not listed, E=endangered, T = threatened, PDL = proposed for delisting, VT-E = listed as endangered in Vermont, VT-T = listed as threatened in Vermont, VT-SC = species of special concern in Vermont, NH-E = listed as endangered in New Hampshire, NH-T = listed as threatened in New Hampshire. Note that for State-listed species, mention is only made regarding occurrence in the State of listing.

Sources: DeGraff and Rudis 1986; Gleason and Cronquist 1991; FWS 2002b, 2006c; LaRoche 2005; VDFW 2005a,b; CBS 2006; EPA 2006b; NatureServe 2006

Jesup's Milk-Vetch

Jesup's milk-vetch (*Astragalus robbinsii* var. *jesupi*) was Federally listed as endangered in 1987. Critical habitat has not been designated for this species. The entire population of the species is thought to be less than 1000 individuals, and it is considered one of the rarest plants

Plant and the Environment

in New England; it is endemic to rock outcrops on the Connecticut River (Brackley 1989). Jesup's milk-vetch is a perennial herb, 20 to 60 cm tall, with blue-violet flowers that appear in late May or early June. The species has a 1.5- to 3.0-cm long seed pod with a conspicuous beak that can be used to distinguish the species.

Only three populations (one in Vermont, two in New Hampshire) are currently known for the Jesup's milk-vetch (Brackley 1989). All three occur along a 16-mi stretch of the Connecticut River about 50 mi upstream of VYNPS. The species is found primarily on partially shaded calcareous bedrock outcrops (primarily schist) that are ice-scoured annually. Most plants occur at the ice-scour line between barren rock and vegetated upper areas of the bank. Searches of other apparently suitable sites downstream to the Massachusetts border have failed to reveal additional populations of the species (Brackley 1989). None of the locations are in areas likely to be affected by operations of the VYNPS or its associated transmission lines.

Northeastern Bulrush

The northeastern bulrush (*Scirpus ancistrochaetus*) was Federally listed as endangered in 1991. Critical habitat has not been designated for this species. Thirty-three populations are currently known from seven eastern states. Two of these populations are located in Vermont (Windham County) and one in New Hampshire (Cheshire County). Most of these populations exist on private lands that are subject to habitat loss, modification, and degradation caused by residential and agricultural development (Copeyan 1993). Northeastern bulrush is a member of the sedge family (Cyperaceae) and is about 30 to 50 in. tall at maturity. Flowering occurs from mid-June to July, and fruit sets between July and September.

The northeastern bulrush is found in ponds, wet depressions, and shallow sinkholes within small (less than 1 ac) wetland complexes (Copeyan 1993). The single population in New Hampshire, observed in 1992, occurred on private land in northern Cheshire County in a drained beaver pond dominated by grasses and sedges. The two populations in Vermont are located in Windham County about 15 mi apart. In one of these populations, individuals occur in several small shallow ponds surrounded by emergent wetlands in an alluvial meadow of the Connecticut River. In the other site, plants occur along the edges of a beaver meadow in the zone of emergent vegetation. All sites are characterized by fluctuating water levels fed primarily by surface water runoff.

The northeastern bulrush is not known to occur on the VYNPS site or on either transmission line within the scope of license renewal.

Bald Eagle

The bald eagle (*Haliaeetus leucocephalus*) was Federally listed in 1967. It is currently listed as threatened in the conterminous U.S., but was proposed for delisting in 1999 (FWS 1999). Critical habitat has not been designated for this species. Drastic declines in the number of bald

1 eagles was linked to reproductive failure associated with widespread use of the insecticide
2 dichloro-diphenyl-trichloroethane (DDT). The 1972 ban of DDT for use in the United States was
3 pivotal in the recovery of the species.

4
5 The bald eagle ranges across much of North America. The species frequents estuaries, large
6 lakes, reservoirs, major rivers, and some coastal habitats. Fish form the bulk of its diet, but
7 waterfowl and carrion are also eaten. Bald eagles typically nest in trees near water, especially
8 in large trees along shorelines away from disturbance. Adults tend to use the same breeding
9 area for years and often use the same nest.

10
11 Bald eagles can occur in the VYNPS area throughout the year. VYNPS's location on the
12 Vernon Pool of the Connecticut River makes it ideal as a foraging and roosting area for eagles.
13 Eagles frequently roost on the large riparian trees along the site shoreline. Several bald eagles
14 were observed on or near the site during the NRC staff's site audit in May 2006. During the
15 winter, open water near the discharge canal could attract foraging eagles that would otherwise
16 leave the area.

17
18 There is also the potential for breeding of the bald eagle on or near the VYNPS site. For
19 several years, Vermont was the only state in the conterminous United States that did not have a
20 breeding pair of bald eagles (VDFW 2006c). However, in 2005, a bald eagle pair built a nest in
21 a large pine along the Connecticut River just downstream of Vernon Dam less than 1 mi from
22 VYNPS. The pair successfully hatched at least one young in this nest in April 2006
23 (VDFW 2006c), but by late May the eaglet had died (VDFW 2006d). Although there was
24 evidence of raccoon predation, the cause of death was not known (VDFW 2006d).

25
26 **Indiana Bat**

27
28 The Indiana bat (*Myotis sodalis*) was Federally listed as endangered in 1967. No critical habitat
29 has been designated for this species in the project area. The Indiana bat ranges across much
30 of the eastern United States (FWS 1983). Large hibernating populations occur in Indiana,
31 Missouri, and Kentucky. Most Indiana bats migrate seasonally between winter hibernacula and
32 summer ranges.

33
34 Suitable habitat for the Indiana bat consists of riparian, bottomland, and upland forest habitats
35 with trees that have crevices or exfoliating bark that can be used as roosting sites. Maternity
36 colonies are formed mostly in riparian and floodplain areas of small- to medium-sized streams
37 (FWS 1983). Optimum foraging habitat consists of streams lined on both sides with mature
38 trees that overhang the water, although other habitats are sometimes used.

39
40 Although there are no known records of the Indiana bat in either Windham or Windsor Counties,
41 Vermont, or Cheshire County, New Hampshire, there is a possibility that the species occurs

Plant and the Environment

within suitable habitat on or near the VYNPS site or transmission lines associated with the site. The summer range of this species includes the southern half of Vermont and the southwestern portion of New Hampshire (FWS 1983).

2.2.7 Radiological Impacts

A radiological environmental monitoring program (REMP) has been conducted around the VYNPS site since 1970. The objectives of the REMP are to provide an early indication of the appearance or accumulation of any radioactive material in the environment caused by the operation of the station, to provide assurance to regulatory agencies and the public that the station's environmental impact is known and within anticipated limits, to verify the adequacy and proper functioning of station effluent controls and monitoring systems, and to provide standby monitoring capability for rapid assessment of risk to the general public in the event of unanticipated or accidental releases of radioactive material (Entergy 2006b).

Each year, results of measurements of radiological releases are summarized in the VYNPS Annual Radioactive Effluent Release Report (e.g., Entergy 2006c). The limits for all radiological releases are specified in the ODCM (Entergy 2002c), and these limits are designed to meet Federal standards and requirements.

The REMP includes monitoring of the airborne pathway (air particulates and iodine), waterborne pathways (river water, groundwater, and river sediment), ingestion pathways (milk, silage, mixed grass, and fish), and direct radiation pathway (gamma dose on thermoluminescent dosimeter (TLD) locations) (Entergy 2006b). For trending purposes, radiological and direct radiation measurements are compared with past years. Sampling locations are chosen based on meteorological factors, preoperational planning, and results of land-use surveys. A number of locations, in areas very unlikely to be affected by plant operations, are selected as controls. The environmental monitoring reports over the last 5 years have been reviewed. The results indicate that the radiation and radioactivity in the environmental media monitored around the plant have been well within applicable regulatory limits (Entergy 2002a, 2003a, 2004a, 2005a, 2006b).

The Vermont Department of Health (VDH) has also been conducting radiological surveillance and monitoring around the VYNPS since 1971. The results are summarized in the annual State of Vermont, Vermont Yankee Nuclear Power Station Environmental Radiation Surveillance Reports (VDH 2002, 2003, 2004, 2005, 2006). The samples collected and the measurements made by VDH annually include:

- The direct gamma radiation emanations as measured by TLDs at the site boundary and various other locations around the site,
- The amount of radioactive particulates and radioactive iodine in air,

Plant and the Environment

- 1 • Water from wells and waterways surrounding the plant, and
- 2
- 3 • Various wild and cultivated vegetation, river bed sediments, and soils.
- 4

5 The VDH reports present long-term historical trends and in some cases compare the results
6 with background measurements. The 2005 report concludes that there are no significant
7 adverse health effects from operation of VYNPS to Vermonters (VDH 2006).

8 In addition to monitoring radioactivity in environmental media, Entergy annually assesses doses
9 to individuals from gaseous and liquid effluents (if any) at several locations based on effluent
10 release data and mathematical modeling methods approved by the NRC. Calculations are
11 performed using the plant effluent release data, onsite meteorological data, and appropriate
12 pathways identified in the ODCM. Radiation dose results for the 5-year period of 2001 through
13 2005 (Entergy 2002b, 2003b, 2004b, 2005b, 2006c) were reviewed. The results for 2005, which
14 were representative of the values for the other years, were as follows:

- 17 • The maximum annual whole body dose to an individual on the site boundary not
18 adjacent to the Connecticut River (called the maximally exposed individual, or MEI)
19 from all pathways including direct radiation was 13.5 mrem/yr. Over 99.9 percent of
20 this dose was due to direct radiation because of the individual's close proximity to
21 the plant. The main source of this direct radiation is the gamma radiation originating
22 in the turbine building. These gammas spread out radially from the turbine building.
23 Some of them directed towards the sky get scattered back to earth by the atoms in
24 the air, particulate matter suspended in the air, or the clouds before they reach the
25 MEI (by a process called skyshine). This dose is less than the EPA (40 CFR
26 Part 190) dose limit of 25 mrem/yr to the whole body of any member of the public
27 from the entire fuel cycle. It also meets NRC's dose limit in 10 CFR Part 20, which is
28 based on the EPA's limit. It is also below the 20 mrem/yr limit imposed on VYNPS
29 by the Vermont Department of Health (VDH 1977).
- 31 • The maximum annual dose to the thyroid, which was also the organ with the
32 maximum dose, of the MEI from all effluents was also 13.5 mrem. Similar to the
33 whole body dose, over 99.9 percent of the thyroid dose was due to the direct
34 radiation. This dose is less than the EPA (40 CFR Part 190) dose limit of 75 mrem/yr
35 to the thyroid of any member of the public from the entire fuel cycle. It also meets
36 NRC's dose limit in 10 CFR Part 20, which is based on the EPA limit.
- 38 • The direct radiation decreased rapidly with distance from the plant. For example,
39 TLDs, which measure the direct radiation, registered an annual average reading of
40 0.0094 milliRoentgen (mR)/hr at a location 210 m away from the center of the turbine
41 building on the site boundary in the west-southwest (WSW) direction. At 520 m
42 away from the center of the turbine building in the same direction, the average
43 annual TLD measurement was 0.0066 mR/hr. The average TLD measurements at

Plant and the Environment

control locations indicative of the background radiation in the vicinity of the plant were of 0.0063 mR/hr with a standard deviation of 0.00033 mR/hr. These results indicate that direct radiation from the plant went down to essentially zero at about 310 m from the site boundary in the WSW direction. Similar reductions in direct radiation measurements were observed for other directions.

These results confirm that VYNPS has been operating in compliance with all the Federal (Appendix I to 10 CFR Part 50, 10 CFR Part 20, and 40 CFR Part 190) regulations as well as the State of Vermont regulations (VDH 1977). In March 2006, the NRC issued a license amendment that allowed Entergy to increase the thermal power of VYNPS by 20 percent (to 1912 MW(t)). In the EA and the FONSI accompanying the license amendment (NRC 2006a), it is estimated that when the power increases by 20 percent, the direct radiation component of the MEI dose at the site boundary would increase by about 26 percent and would be about 18.6 mrem per year. Considering that over 99.9 percent of the individual's dose is from direct radiation, the whole body dose to the MEI is estimated to be about 18.7 mrem/yr.

In March of 2006, Entergy started the power uprate and completed it in May 2006. In May 2006, Entergy also installed new shielding (3-in.-thick steel) on top of the high-pressure turbine to cut down on the skyshine component of the direct radiation. Entergy staff measured the exposure rate at the site boundary before the uprate, after the uprate but before the new shield was installed, and after the installation of the shield. The results indicated that the exposure rates at the site boundary were 0.001313 mR/hr before the uprate, 0.002534 mR/hr after the uprate but before the shield was installed, and 0.001866 mR/hr after the shield was installed (Entergy 2006d). On an annual basis, the exposure rates were estimated to be 11.50 mR, 22.2 mR, and 16.35 mR, respectively, for the same conditions. Although not exactly correct, the exposure rate in terms of 1 mR/hr is often considered to be equivalent to a dose rate of 1 mrem/hr. Therefore, the measured values indicate that with the newly installed shield in place, the MEI dose at the site boundary will continue to satisfy both the Federal and State regulations.

In April 2006, Entergy was granted approval by the Vermont Public Service Board to construct a dry fuel storage facility onsite. Once constructed, some of the spent fuel that is currently in the spent fuel pool onsite will be moved to the dry storage facility. It is estimated that the dry storage facility will increase the annual dose received by the MEI by approximately 0.3 mrem (Entergy 2006g). All of this increase is expected to come from direct radiation. With this increase, the estimated whole body dose to the MEI would be approximately 19 mrem/yr, which would still be within the Federal and State limits.

Aside from the changes associated with the power uprate and the installation of the dry fuel storage facility, as discussed above and in Section 2.1.4, Entergy does not anticipate any significant changes to the radioactive effluent releases or exposures from VYNPS operations during the renewal period; therefore, the impacts on the environment are not expected to change.

1 **2.2.8 Socioeconomic Factors**

2

3 The staff reviewed the Entergy ER (Entergy 2006a) and information obtained from county, city,
4 and local economic development staff. The following sections describe the housing market,
5 community infrastructure, population, and economy in the region surrounding the VYNPS site.

6

7 **2.2.8.1 Housing**

8

9 VYNPS employs approximately 650 workers, the majority of whom live in Windham County,
10 Vermont (43 percent), and Cheshire County, New Hampshire (25 percent). The remainder are
11 located in Franklin County, Massachusetts (17 percent), and a number of other counties
12 (Table 2-13). Given the residential locations of VYNPS employees, the most significant impacts
13 of plant operations are likely to occur in Windham County, Cheshire County, and Franklin
14 County. The focus of the analysis in this SEIS is on the impacts of VYNPS operations in these
15 counties.

16

17 Entergy refuels VYNPS every 18 months. During refueling, approximately 700 to 900 additional
18 workers are employed for a 30-day period (Entergy 2006a). The majority of these workers
19 reside in the same communities as the permanent employees at the plant.

20

21 The number of housing units and housing vacancies in Windham County, Cheshire County, and
22 Franklin County are shown in Table 2-14. In Windham County, the total number of housing
23 units grew at an annual rate of 0.5 percent over the period 1990 to 2000, while the number of
24 occupied units grew at an average annual rate of 1.2 percent over the same period. With an
25 annual average population growth rate of 0.6 percent during this period, there was a slight
26 decline (-1.0 percent) in the annual rate of growth in the number of vacant units during this
27 period. In Cheshire County, housing market trends were similar to those in Windham County.
28 Annual growth in housing in Cheshire County was 0.5 percent between 1990 and 2000, with
29 slightly larger growth in the number of occupied housing units (0.9 percent). In Franklin County,
30 annual growth in housing between 1990 and 2000 was 0.5 percent, with a slightly higher rate of
31 growth in occupied housing (0.6 percent). With annual population growth in Cheshire County
32 and Franklin County at 0.5 percent and 0.2 percent, respectively, the number of vacant units fell
33 in both counties, by -2.3 percent in Cheshire County and by -1.1 percent in Franklin County.

34

35 The housing vacancy rate in 2000 was 32.0 percent in Windham County, 11.2 percent in
36 Cheshire County, and 7.7 percent in Franklin County. The high rates in Windham County and
37 Cheshire County are due primarily to the large number of seasonal homes in the region.

38

39

40

41

42

Plant and the Environment

Table 2-13. VYNPS Permanent Employee Residence Information by County and City

County and City^(a)	Percent of Total
WINDHAM COUNTY	
Brattleboro	14
Vernon	14
Guilford	3
Putney	2
Newfane	2
Others	8
Total Windham County	43
CHESTERFIELD COUNTY	
Hinsdale	6
Keene	5
West Chesterfield	3
Spofford	2
Others	9
Total Cheshire County	25
FRANKLIN COUNTY	
Greenfield	6
Others	11
Total Franklin County	17
Other Counties	15
Grand Total	100

(a) Addresses are for both unincorporated (counties) and incorporated (cities and towns) areas.
Source: Entergy 2006a

1
2 **Table 2-14.** Housing Units and Housing Units Vacant (Available) by County
3 During 1990 and 2000
4

	1990	2000	Average Annual Growth Rate 1990 to 2000
WINDHAM COUNTY			
Housing units	25796	27039	0.5
Occupied units	16264	18375	1.2
Vacant units	9532	8664	-1.0
CHESHIRE COUNTY			
Housing units	30350	31876	0.5
Occupied units	25856	28299	0.9
Vacant units	4494	3577	-2.3
FRANKLIN COUNTY			
Housing units	30394	31939	0.5
Occupied units	27640	29466	0.6
Vacant units	2754	2473	-1.1
Source: USCB 2006a			

19
20 **2.2.8.2 Public Services**
21

22 **Water Supply**
23

24 Water supplied by public water systems in Windham County, Cheshire County, and Franklin
25 County comes from both surface water and groundwater sources (Table 2-15). Currently, there
26 are six water suppliers within 10 mi of VYNPS, with the Brattleboro system providing 68 percent
27 of total capacity (Entergy 2004c). Large parts of the three counties do not have access to public
28 water systems and use groundwater and springs as their primary water source. More than 50
29 wells within a mile of VYNPS supply water for domestic and farm use. All the water supply
30 systems within 10 mi of the plant have additional capacity to meet new water demands (Entergy
31 2004c).

32
33 VYNPS withdraws water from the Connecticut River for plant service and fire protection at a rate
34 of 18,400 gpm, and from wells located onsite at a maximum rate of 35 gpm (Section 2.2.2).
35 The plant does not use groundwater from local municipal systems. Fire protection for the plant
36 is provided by the Town of Vernon Fire Department (Town of Vernon 2006).
37
38

1
2 Plant and the Environment
3

4 **Table 2-15.** Major County Public Water Supply Systems in 2004
5

Water System	Source	Maximum Capacity (million gpd)
WINDHAM COUNTY		
Brattleboro	Surface water	3
Brattleboro	Groundwater	3.2
CHESHIRE COUNTY		
Hinsdale	Groundwater	1
Winchester	Groundwater	0.6
FRANKLIN COUNTY		
Northfield	Groundwater	0.2
Bernardston	Groundwater	1.1

14 Source: Entergy 2004c
15

16 **Education**
17

18 VYNPS is located in the Windham Southeast Supervisory Union School District, which is one of
19 four school districts serving Windham County. In 2004, the district had 9 schools, with a total
20 enrollment of 3106 students, and employed 48 teachers (Standard and Poors 2006).
21

22 Expenditures in the district are currently \$14,738 per student compared to \$13,408 for Vermont
23 as a whole (Public School Review 2006). The only school located in the town of Vernon is the
24 Vernon Elementary School, which had 228 students and 10 teachers in 2004 (Public School
25 Review 2006). Student enrollment in the district, together with expenditures per student and the
26 number of teachers in the district, have remained stable over the 2000 to 2004 period (Standard
27 and Poors 2006; Public School Review 2006).

28 In 2004, Windham County had an additional 20 private schools, with an enrollment of
29 2114 students (Private School Review 2006).
30

31 **Transportation**
32

33 Access to VYNPS is via State Highway 142, approximately 0.8 mi west of the plant. The
34 highway runs north-south in the vicinity of the plant, generally following the route of the
35 Connecticut River. Access to the plant itself is provided via two intersections on Highway 142
36 and Governor Hunt Road. Interstate I-91 and U.S. Highway 5 run north-south through the
37 county, connecting Brattleboro with Greenfield to the south, while Highway 9 connects
38 Brattleboro with Bennington to the west, and Keene to the east in New Hampshire. Highway 30

links Brattleboro with other towns to the northwest. Most VYNPS employees traveling from the northern and western parts of the county use these roads to reach the site (Entergy 2006a).

Two segments of Highway 142 for which traffic counts are available were assessed in the ER. Moderate increases in traffic have occurred between 1992 and 2002 to the north of the plant on Highway 142, with increases in commuter and commercial traffic, while traffic has been relatively stable south of the plant on Highway 142 over the same period (Entergy 2006a).

2.2.8.3 Offsite Land Use

VYNPS is located in the town of Vernon, Vermont, in Windham County. The town of Vernon occupies 19.4 mi². The 2000 Census reported Vernon's population to be 2119, and the town receives approximately \$1 million in property tax revenue (Entergy 2006a). Land use in the town has changed little over the last 20 to 30 years. From 1970 to 1990, approximately 425 ac of forest were converted to nonforested land, and 260 ac were developed for other land uses. The VYNPS site is currently surrounded by the Connecticut River on the east, by farm and pasture land mixed with wooded areas on the north and south, and by the town of Vernon on the west (Entergy 2004c). The nearest homes are situated along the Governor Hunt Road just to the west of the site, and the Vernon Elementary School is west of Highway 4, approximately 1500 ft from the reactor building (Entergy 2004c). The town of Vernon has no zoning ordinances, subdivision ordinances, or development review board. The town did approve the 2003 Town Plan, which outlines the community's plan for future growth and development (Entergy 2006a).

The town of Vernon derives significant revenue from VYNPS. Property taxes paid by Entergy make up approximately 40 percent of the town of Vernon's General Fund, which is utilized for police, fire, roads, and other town services. Entergy's State Electric Generation Education Tax payment covers approximately a third of the Vernon School District's budget. This funding enables the town of Vernon and Windham County to maintain lower tax rates than would otherwise be needed to fund the current level of public infrastructure and services for the county and local government (Entergy 2006a).

Windham County occupies roughly 789 mi², and its population increased from 41,588 to 44,284 between 1990 and 2004. The average annual population growth rate between the 2000 and 2003 censuses was 0.1 percent (Entergy 2006a). The major land uses within the county consist of woodland (56 percent), cropland (29 percent), pasture land (8 percent), and other uses (7 percent) (Entergy 2006a). Conversion of land to development is less intense in the county as compared to State-wide trends, with growth being associated with a recreational facility and resort and vacation home development. According to the 2002 USDA Census of Agriculture, 397 farms were located in the county, which is a 3 percent increase since 1997 (USDA 2006b). Land acreage associated with farms increased 21 percent during this period to over 60,000 ac. The major farm commodities in Windham County are cattle and dairy products, and the major crops are hay and silage (Entergy 2006a). The Windham Regional Commission

Plant and the Environment

1 has drafted a new regional plan to assist the towns in southeastern Vermont in collectively
2 addressing regional land use, as well as environmental and socioeconomic issues (Windham
3 Regional Commission 2006).

4
5 Cheshire County, New Hampshire, has a total area of 729 mi². In 2003, the county had a
6 population of 75,965, with an average annual growth rate of 0.9 percent between the 2000 and
7 2003 censuses (Entergy 2006a). Cheshire County, located in the Monadnock region of
8 southwestern New Hampshire, has a mix of rural villages, urban settings, and forest and
9 agricultural land. Approximately 83 percent of the county is forested, and the acreage in farms
10 increased from 38,216 ac to 41,651 ac between 1987 and 1997, while the acreage in cropland
11 declined from 14,475 ac to 12,301 ac during that period (USDA 2006; University of New
12 Hampshire Cooperative Extension 2006). Cheshire County is one of three New Hampshire
13 counties that are partners in the Southwest Region Planning Commission, which serves to
14 promote sound decision making for the conservation and effective management of natural,
15 cultural, and economic resources (Southwest Regional Planning Commission 2006). It is also a
16 member of the Monadnock Economic Development Corporation, which strives to enhance the
17 industrial and business base of the area to improve the standard of living, quality of life, and
18 economic vitality of member communities (Monadnock Economic Development Corporation
19 2006).

21 Franklin County, Massachusetts, located approximately 4 mi south of the town of Vernon, has a
22 total area of 725 mi². In 2003, the county had a population of 72,204, with an annual average
23 growth rate of 0.3 percent between the 2000 and 2003 censuses (Entergy 2006a). The county
24 exists today only as an historical geographic region, and it has no county government. The
25 Franklin Regional Council of Governments provides regional and local planning, human
26 services advocacy and coordination, and municipal services to the 26 towns located in the
27 upper Connecticut River Valley in midwestern Massachusetts that make up Franklin County.
28 The area is one of the most rural regions in Massachusetts (Franklin Regional Council of
29 Governments 2006).

30
31 The nearest urban area within 10 mi of the site is the city of Brattleboro, Vermont
32 (2000 population, 12,005), which is located about 5 mi upriver. The remainder of this area is
33 rural, with approximately 75 to 80 percent of the area being wooded, and it contains several
34 small villages and towns with populations between 1000 and 4000 (Entergy 2006a). The area
35 between 10 mi and 25 mi of the site is predominately rural and has two urban centers with
36 2000 census populations of around 20,000 residents (Greenfield, Massachusetts, 18,168, and
37 Keene, New Hampshire, 22,563) (Entergy 2004c; AEC 1972).

38
39 The site area is host to a New England Central Railroad line that is approximately 0.5 mi west of
40 the plant at its closest approach. A former rail line right-of-way on the east side of the
41 Connecticut River is now owned by the State of New Hampshire and has been converted for
42 recreational use by the public. Canoeing and some sport fishing take place on Vernon Pond
43 and adjacent river areas; users are precluded from landing on station waterfront property. The

1 New England Electric Company has developed a series of small recreation areas along the
2 Connecticut River. There are no public water supply intakes located on the Connecticut River
3 downstream of VYNPS (AEC 1972; Entergy 2004c, 2006a). The town of Vernon manages the
4 J. Maynard Miller Town Forest, and the Vermont Fish and Game Department owns several
5 large forested areas (Town of Vernon 2003b, 2006).

7 **2.2.8.4 Visual Aesthetics and Noise**

9 The plant is located on a river terrace. The elevation of the site ranges from 220 ft to
10 approximately 280 ft above mean sea level, which helps shield some of the plant structures
11 from the public road on the west boundary where several residences are located. The plant is
12 periodically visible from the Hinsdale, New Hampshire, side of the river, and landscaping serves
13 to partially blend the site with the surrounding countryside (AEC 1972).

14 The reactor building, turbine building, stack, and meteorological towers are visible from Vermont
15 State Highway 142, which passes by the plant, and also from New Hampshire State Highway
16 119, on the other side of the river. The reactor building (~305 ft) has reinforced concrete side
17 walls, with the top 40 ft covered with a light grey metal siding. The turbine building (~90 ft) has
18 a structural steel frame covered with a light green corrugated metal siding. The tapered,
19 reinforced concrete stack is 318 ft high and has white strobe lights at the ~300-ft level (AEC
20 1972). The primary meteorological tower has a variable intensity red light at the top and steady
21 red lights at the mid-height level (Entergy 2006f).

22 The 50-ft cooling towers are not visible from Highway 142, though the plume is visible from
23 Vernon and Highway 119 in New Hampshire (AEC 1972). The aesthetic impacts associated
24 with cooling tower operations will not change significantly. The cooling towers will continue to
25 operate based on the flow rate and ambient temperature of the river. With the plant's uprated
26 power level, the dimensions of the plumes generated during the summer will increase by
27 approximately 328 ft in length, 65.6 ft to 98.4 ft in width, and up to 164 ft in height (NRC 2006a).

28 Three 345-kV transmission lines connect to the plant's 345-kV switchyard. Two of these lines
29 span the Connecticut River to the New Hampshire side in tandem with a 115-kV line. The third
30 345-kV line extends north from the plant. While the lines detract from the aesthetic appearance
31 of the area, the AEC staff noted that these lines do not appear obtrusive in the setting
32 (AEC 1972).

33 Noise from operation of the mechanical draft cooling towers may be a source of irritation to the
34 public during summer months and a minor irritant to nearby residences (AEC 1972). No
35 significant increase in noise is anticipated for cooling tower operation following the extended
36 power up-rate to approximately 120 percent of the original NRC-licensed power level
37 (Entergy 2005c). As a condition of the approval of the up-rate, the Vermont Public Service
38 Board required replacing 21 of the 22 125-horsepower (hp) cooling tower motor/fan units with
39 200-hp units and replacing the 8-bladed fans with 10-bladed fans, with one of the design criteria

Plant and the Environment

being that the motor/fan changes could not increase the cooling tower environmental noise level by more than 1 "A-weighted" decibel level (dBA); the A-weighted decibel scale being used better approximates the range of sensitivity of the human ear to sounds of different frequencies. After a series of sound-level tests, not only did the fan modifications comply with the requirement that the cooling tower noise level shall not increase by more than 1 dBA, but sound levels were generally the same or up to 1.2 dBA quieter than the baseline measurements (Entergy 2005c; NRC 2006a).

2.2.8.5 Demography

In 2000, 153,409 people lived within 20 mi of VYNPS, for a density of 122 persons/mi². This density translates to Category 4 (least sparse) (Entergy 2006a), using the measure of sparseness described in the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, Volumes 1 and 2 (NRC 1996, 1999)^(a). At the same time, there were 1,513,282 persons living within 50 mi of the plant, for a density of 193 persons/mi². The NRC sparseness and proximity matrix assigns a Category 4 rating (high density) for this measure as well. There are no growth control measures that would limit housing development in this area (Entergy 2006a).

Table 2-16 shows population trends for Windham County, Cheshire County, and Franklin County, the area in which the majority of VYNPS employees live. Annual average growth rates in the three counties show moderate growth during the 1990s and 1980s. The annual average growth rate for each State over the period 1990 to 2000 was 0.8 percent for Vermont, 1.1 percent for New Hampshire, and 0.5 percent for Massachusetts. Growth in each county is forecasted to continue at moderate levels over the period 2004 to 2032 (Entergy 2006a).

Transient Population

The transient population in the vicinity of the VYNPS site consists primarily of tourists visiting the various recreational areas in southern Vermont and seasonal residents of resorts and vacation home developments (Entergy 2006a). An estimated 35,265 tourists per day visit the southern Vermont area (Entergy 2006i).

Migrant Farm Labor

Although approximately 1900 seasonal or migrant workers are employed during the summer and fall months in the three-county area (USDA 2006b), the majority of agricultural laborers reside in the area (Entergy 2006a). Agriculture in the area is declining in importance with the development of recreation and summer residency in the area.

(a) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and its Addendum 1.

1 **Table 2-16.** Population Growth in Windham County, Cheshire County,
 2 and Franklin County, 1970 to 2032
 3

WINDHAM COUNTY		
Year	Population	Annual Growth Percent^(a)
1990	41588	— ^(b)
2000	44216	0.6
2003	44379	0.1
2032	48941	0.3
CHESHIRE COUNTY		
Year	Population	Annual Growth Percent^(a)
1990	70121	—
2000	73825	0.5
2003	75965	0.9
2032	96895	0.7
FRANKLIN COUNTY		
Year	Population	Annual Growth Percent^(a)
1990	70092	—
2000	71535	0.2
2003	72204	0.3
2032	77231	0.2

22 (a) Annual percent growth rate is calculated over the previous decade.
 23 (b) A dash indicates no data available.
 24 Source: Entergy 2006a

2.2.8.6 Economy

Employment and Income

In 2003, total employment in Windham County was 23,083 (USCB 2006b). Service industries dominate employment in the county and account for almost 50 percent of total employment (11,345 people employed). The largest employer within 10 mi of the plant is C&S Wholesale Grocers, which has 840 employees (Table 2-17). Manufacturing also plays an important part in the local economy, with almost 21 percent of county employment (4779 people). Wholesale and retail trade employs 17.3 percent (3995 people) of the county workforce. In Cheshire County, the services sector also provides the largest share of total county employment, with almost 43 percent (13,046 people), followed by wholesale and retail trade and manufacturing, both with approximately 20 percent of the county employed workforce. Employment in Franklin

Plant and the Environment

Table 2-17. Major Employment Facilities Within 10 mi of the VYNPS Site

Firm	Number of Employees
C&S Wholesale Grocers	840
Windham Southeast Supervisory Union (County School District)	800
Entergy Nuclear	600
United Natural Foods	487
Retreat Healthcare	430
World Learning/School for International Training	362
Brattleboro Memorial Hospital	276
Cersosimo Lumber	252
Chittenden Bank	250
Wal-Mart	220
FiberMark	200

County is also dominated by services (43 percent of county jobs, 13,624 people), with a similar share of total employment (21 percent) in wholesale and retail trade as Windham and Cheshire Counties. Employment in agriculture (8 percent of total county employment) and utilities (7 percent of county jobs) are relatively more important in Franklin County than in Windham County and Cheshire County.

In Windham County, personal income was \$1.5 billion in 2003 (in 2005 dollars), with a per capita income of \$33,079 (2005 dollars) (DOC 2006). In Cheshire County, personal income was \$2.5 billion and per capita income was slightly higher at \$33,485. In Franklin County, personal income was \$2.3 billion and per capita income was \$32,094.

Unemployment

In January 2006, unemployment in Windham County and Cheshire County was relatively low at 3.4 percent and 3.3 percent, respectively. In Franklin County it was somewhat higher, at 5 percent (DOL 2006). The unemployment rate for Vermont as a whole was 4.1 percent in January 2006; the New Hampshire rate was 3.8 percent, and the Massachusetts rate was 5.3 percent.

1 **Taxes**

2

3 Property taxes are paid by VYNPS to the town of Vernon and by the Entergy corporate office
 4 facility in Brattleboro to Brattleboro Township. The State also levies an electricity generation tax
 5 on the plant, in addition to State sales, franchise use, and excise taxes on VYNPS and the
 6 Entergy corporate office facility. Revenues are used by the town of Vernon and Brattleboro
 7 Township to fund local and county emergency management programs, public safety, local
 8 public schools, local government operations, local road maintenance, and the local library
 9 system.

10 The plant is a significant source of tax revenue for local government in Vernon. Over the period
 11 2003 to 2005, on average, approximately 65 percent (about \$1.2 million in 2005 dollars) of total
 12 tax revenues spent in the town of Vernon came from property taxes paid to the township by
 13 VYNPS (Table 2-18). In contrast, only about 1 percent (about \$0.2 million in 2005 dollars) of
 14 Brattleboro Township tax revenues, on average, over the period 2003 to 2005 came from
 15 Entergy. Revenues from VYNPS, from the Entergy facility in Brattleboro and from electricity
 16 generation taxes levied by the State constituted less than 1 percent of total State revenues in
 17 2005.

18

21 **Table 2-18. VYNPS Contribution to Vernon Tax Revenues**

22

23 Year	24 Total Tax Revenues (millions \$2005) ^(a)	24 TOWN OF VERNON	24 Percent of Total Tax Revenues
25 2003	25 1.7	25 1.2	25 69
26 2004	26 1.8	26 1.1	26 65
27 2005	27 2	27 1.2	27 60
28 BRATTLEBORO TOWNSHIP			
29 2003	29 25.8	29 0.2	29 1
30 2004	30 25.6	30 0.2	30 1
31 2005	31 22.4	31 0.2	31 1
32 VERMONT			
33 2003	33 1655	33 6.4	33 >1
34 2004	34 1827	34 6.5	34 >1
35 2005	35 2243	35 6.2	35 >1
(a) Sources: Town of Vernon 2003b, 2004; Town of Brattleboro 2006; USCB 2006c			
(b) Source: Entergy 2006l			

Plant and the Environment

Utility restructuring legislation has not been enacted in Vermont, making it difficult to predict the long-term impact of any such changes in the electricity industry in the State on VYNPS. Any changes in assessed valuation of plant property and equipment that may potentially occur could affect property tax payments to the townships and the county. However, any impacts on tax revenues as a result of restructuring would not occur as a direct result of license renewal.

2.2.9 Historic and Archaeological Resources

This section discusses the cultural background and the known historic and archaeological resources at the VYNPS site and in the surrounding area.

2.2.9.1 Cultural Background

The area in and around the VYNPS site has the potential for significant prehistoric and historic resources. The area around the Connecticut River is highly sensitive for archaeological material. Human occupation in this region roughly follows a standard chronological sequence for prehistory in the Eastern United States: Paleo-Indian Period (10000 BC to 7000 BC); Archaic Period (7000 BC to 1000 BC); Woodland Period (1000 BC to AD 1500). In general, the Paleo-Indian Period is characterized by highly mobile bands of hunters and gatherers. A typical Paleo-Indian site might consist of an isolated stone point or knife (of a style characteristic of the period) in an upland area along large river valleys or ancient lake beds. The Archaic Period represents a transition from a highly mobile existence to a more sedentary existence. It is a period of increased local resource exploitation (e.g., predominantly deer and small mammals, fish and other aquatic resources, nuts and seeds), more advanced tool development, and increased complexity in social organization. The Woodland Period is a continuation of the complexities begun during the Archaic Period with the introduction of ceramic technology. Pottery, the principal distinguishing feature between Archaic and Woodland Period sites, begins to appear in the archaeological record during this time. Generally, the Woodland people lived in small permanent or semipermanent settlements. The bow and arrow first appears during the Woodland time period.

The historic period in this region began with the arrival of the first European settlers in the mid-1500s. However, the earliest European settlement in Windham County was Fort Dummer, established in 1725 on the current site of Brattleboro, Vermont. The Native Americans living in the area were collectively known as the Abenaki. The Abenaki are divided into the eastern and western groups. Vermont was home to the western groups, which included the Sokokis, Squakheag, and the Winnipesaukees. The Fort Hill site, a Sokokis/Squakheag village located on the Connecticut River near the VYNPS, contains evidence of European influence.

European claims on the region began in 1687 when Native American groups first deeded some of the land in the Vernon area. The first permanent settler was Joseph Stebbins in 1740 (Cowie and Peterson 1991). In 1791, Vermont became the 14th State in the United States.

1 The first railroad arrived in the area in 1847 opening the State to further development. The
2 Vernon area had an agricultural focus, with several mills and sawmills.

3
4 Windham County has 75 sites listed on the *National Register of Historic Places* (NRHP). The
5 nearest NRHP-listed property is the Pond Road Chapel, located 3 mi south of VYNPS. There
6 are 17 National Historic Landmarks (NHLs) in Vermont. Two of the NHLs are located in
7 Windham County. The Naulakha site, the residence of Rudyard Kipling, is located 15 mi north
8 of VYNPS, and the Rockingham Meeting House is located roughly 36 mi to the north.

9
10 In addition, Vermont maintains a *State Register of Historic Places* (SRHP). The SRHP is kept
11 by the Vermont Division for Historic Preservation. The SRHP includes archaeological sites,
12 historic buildings, structures, and landscapes. The SRHP contains over 30,000 properties. The
13 VYNPS has a SRHP-listed site on its property. The Governor Hunt House is an eighteenth
14 century house once owned by Jonathan Hunt, who was elected Lieutenant Governor of
15 Vermont in 1794. The structure, built in the early 1780s, is owned by the VYNPS and is used as
16 a meeting facility. This is the only known historic property at VYNPS.

17
18 **2.2.9.2 Historic and Archaeological Resources at the VYNPS Site**

19
20 The VYNPS site occupies approximately 125 ac. No formal archaeological survey was
21 conducted at the VYNPS site prior to initial construction (AEC 1972). There is potential for
22 intact archaeological deposits within the undeveloped areas of the VYNPS site. The VYNPS is
23 located on the floodplain of the Connecticut River. As a result, there is the potential for deeply
24 buried archaeological material.

25
26 The Vermont Archaeological Society was contacted during initial planning for the power
27 station's construction (AEC 1972). Extensive subsurface excavation is reported to have taken
28 place prior to construction, but no intact archaeological deposits were identified. It is unclear
29 whether the excavations were directed by the Vermont Archaeological Society. There does not
30 appear to be any documentation of the investigations that took place prior to construction.

31
32 A considerable amount of the site was disturbed during construction. Aerial photographs from
33 construction are the only evidence of the extent of the disturbance. Two archaeological
34 investigations have been undertaken since the plant was constructed. These surveys examined
35 a 34-ac area on the northern and western end of the plant property and a 10-ac area on the
36 southeastern portion of the site. These investigations did not identify any intact subsurface
37 cultural remains. Two shovel tests on the western portion of the property uncovered historic
38 artifacts dating to the nineteenth century, but no subsurface features were associated with these
39 artifacts (Hanson 1991). The southern survey established that disturbance from construction
40 activities extends to roughly 3.5 ft below ground surface (Hartgen 2001).

Plant and the Environment

1 The Governor Hunt House was purchased in 1968 by the Vermont Yankee Power Corporation.
2 The house was restored to its original condition in 1990. An addition was added to the back of
3 the house to accommodate a meeting room for the plant. The house is open for interpretive
4 tours in the summer and by appointment.

5
6 A file search was conducted at both the New Hampshire State Historic Preservation Office
7 (SHPO) and the Vermont SHPO to determine if any archaeological sites were in close proximity
8 to the transmission lines associated with VYNPS. No archaeological sites were identified near
9 the Chestnut Hill transmission lines in New Hampshire (NHDHR 2006). However, areas were
10 identified as highly sensitive for cultural resources. The Vermont SHPO file search identified
11 one archaeological site in the vicinity of the Coolidge transmission line; this transmission line is
12 not owned by Entergy. The transmission line is owned by Vermont Electric Power Company,
13 and the NRC has no regulatory authority over that company. The site consists of several stone
14 waste flakes found on the bank of a river. The site's eligibility for listing on the *National Register*
15 of *Historic Places* has not been determined. The material appears to have been found within
16 roughly 1000 ft of the transmission line right-of-way but, given the location, it is difficult to
17 determine the site boundary. By letter dated October 30, 2006, the NRC staff informed Vermont
18 Electric Power Company of the existence of the site and provided information that can be used
19 by the company to find the documentation concerning the site at the Vermont SHPO.

20
21 Although no known sites of significance to Native Americans have been identified at the VYNPS
22 site, government-to-government consultation with the appropriate Federally recognized Native
23 American Tribes has been initiated (Appendix E).

2.2.10 Related Federal Project Activities and Consultations

27 The NRC staff reviewed the possibility that the activities of other Federal agencies might impact
28 the renewal of the OL for the VYNPS. Any such activities could result in cumulative
29 environmental impacts and the possible need for a Federal agency to become a cooperating
30 agency for the preparation of the SEISs.

32 Vernon Dam, located 0.75 mi downstream from the VYNPS, is licensed by the Federal Energy
33 Regulatory Commission (FERC) as Project No. 1094, as one of a series of dams constructed
34 on the Connecticut River for hydroelectric and flood control purposes. The Vernon Dam and
35 Hydroelectric Station is owned and operated by TransCanada and is currently undergoing
36 renovation (Entergy 2006a).

38 Federal facilities and lands located within 50 mi of the VYNPS include the Green Mountain
39 National Forest and North Springfield Lake in Vermont, U.S. Air Force Westover facility and
40 Fort Devens U.S. Army Military Reservation in Massachusetts, and the Wapack National

1 Wildlife Refuge in New Hampshire (NRC 2006a). Only the Green Mountain National Forest in
2 Vermont is closer than 25 mi. There are no Native American lands within 50 mi of the VYNPS
3 (Entergy 2006a).

4
5 After reviewing the Federal activities in the vicinity of the VYNPS, the NRC staff determined that
6 there are no known or reasonably foreseeable Federal project activities that would make it
7 desirable for another Federal agency to become a cooperating agency for preparing this SEIS.
8

9 The NRC is required under Section 102(c) of the National Environmental Policy Act (NEPA) to
10 consult with and obtain the comments of any Federal agency that has jurisdiction by law or
11 special expertise with respect to any environmental impact involved. The NRC has consulted
12 with the FWS and the NMFS regarding the presence of Federally listed and/or proposed
13 endangered or threatened species in relation to the VYNPS; the consultation correspondence is
14 included in Appendix E (Letter, August 10, 2006, M. J. Amaral, FWS; Letter, September 15,
15 2006, L. A. Chiarella, NMFS).

16

17 **2.3 References**

18
19 10 CFR Part 20. *Code of Federal Regulations*, Title 10, Energy, Part 20, "Standards for
20 Protection Against Radiation."

21
22 10 CFR Part 50. *Code of Federal Regulations*, Title 10, Energy, Part 50, "Domestic Licensing of
23 Production and Utilization Facilities."

24
25 10 CFR Part 54. *Code of Federal Regulations*, Title 10, Energy, Part 54, "Requirements for
26 Renewal of Operating Licenses for Nuclear Power Plants."

27
28 10 CFR Part 61. *Code of Federal Regulations*, Title 10, Energy, Part 61, "Licensing
29 Requirements for Land Disposal of Radioactive Waste."

30
31 10 CFR Part 71. *Code of Federal Regulations*, Title 10, Energy, Part 71, "Packaging and
32 Transportation of Radioactive Material."

33
34 40 CFR Part 190. *Code of Federal Regulations*, Title 40, Protection of Environment, Part 190,
35 "Environmental Radiation Protection Standards for Nuclear Power Operations."

36
37 40 CFR Part 81. *Code of Federal Regulations*, Title 40, Protection of Environment, Part 81,
38 "Designation of Areas for Air Quality Planning Purposes."

Plant and the Environment

1 American Eel Plan Development Team. 2000. "Interstate Fishery Management Plan for
2 American Eel (*Anguilla rostrata*).” Atlantic States Marine Fisheries Commission, Washington,
3 D.C. April 2000. Available URL: <http://www.asmfc.org/speciesDocuments/eel/fmps/eel/FMP.pdf> (Accessed July 26, 2006).

5
6 Applied Science Associates, Inc. (ASA). 2004. *Hydrothermal Modeling of the Cooling Water*
7 *Discharge from the Vermont Yankee Power Plant to the Connecticut River*. ASA
8 Report 02-088. (April 2004).

9
10 Aquatec Inc. (Aquatec). 1978. *Executive Summary 316 Demonstration Vermont Yankee*
11 *Nuclear Power Station – Biological, Hydrological & Engineering Information*. Aquatec Inc.,
12 South Burlington, Vermont. (March 1978).

13
14 Aquatec Inc. (Aquatec). 1990. *316 Demonstration Vermont Yankee Nuclear Power Station*
15 *Connecticut River Vernon, Vermont – Biological, Hydrological & Engineering Information*.
16 Aquatec Inc., South Burlington, Vermont. (June 1990).

17
18 Atlantic States Marine Fisheries Commission. 1999. "Amendment 1 to the Interstate Fishery
19 Management Plan for Shad & River Herring." Fishery Management Report No. 35. Atlantic
20 States Marine Fisheries Commission, Washington, D.C. April 1999. Available URL:
21 <http://www.asmfc.org/speciesDocuments/shad/fmps/shadam1.pdf> (Accessed April 7, 2006).

22
23 Bailey, R.G. 1995. *Description of the Ecoregions of the United States*. Misc. Publ. 1391.
24 U.S. Department of Agriculture, Forest Service, Washington, D.C.

25
26 Bailey, R.G. 1996. *Ecosystem Geography*. Springer-Verlag, New York, New York.

27
28 Bailey, R.G. 1998. *Ecoregions Map of North America—Explanatory Note*. Misc. Publ. 1548.
29 U.S. Department of Agriculture, Forest Service, Washington, D.C.

30
31 Betzdearborn. 2003. Label for Spectrus NX 1104, Slime control Agent; Industrial, March 28.
32 Available URL: <http://eddenet.pmra-arla.gc.ca/4.0/4.1.2.asp?regn=23805.00&page=238&uniqueid=6%2F15%2F2006+1%3A51%3A06+PM#search=%22Spectrus%20NX-1104%20%22> (Accessed October 3, 2006).

35
36 Brackley, F.E. 1989. *Jesup's Milk-Vetch Recovery Plan*. U.S. Fish and Wildlife Service,
37 Concord, New Hampshire. (November 1989).

38
39 Brattleboro Area Chamber of Commerce. 2006. "Key Businesses." Available URL:
40 http://www.brattleborochamber.org/business/key_business.php (Accessed May 2006).

41
42 Castro-Santos, T., A. Haro, and T. Sullivan. 2005. "American Shad Passage on the
43 Connecticut River: What We've Done, What We Know, What to Do?" Migratory Fish

- 1 Restoration Research Forum Abstracts - 2005. U.S. Fish and Wildlife Service, Connecticut
2 River Coordinator's Office, Sunderland, Massachusetts. Available URL:
3 http://www.fws.gov/r5crc/mig_fish_forum.html (Accessed April 7, 2006).
- 4
- 5 Connecticut Botanical Society (CBS). 2006. "Gallery of Connecticut Wildflowers." Available
6 URL: <http://www.ct-botanical-society.org/galleries/galleryindex.html> (Accessed July 19, 2006).
- 7
- 8 Connecticut Department of Environmental Protection (CDEP). 2004a. "Shortnose Sturgeon
9 *Acipenser brevirostrum*." Connecticut Department of Environmental Protection, Hartford,
10 Connecticut. Available URL: <http://dep.state.ct.us/burnatr/Wildlife/factshts/snsturg.htm>
11 (Accessed August 7, 2006).
- 12
- 13 Connecticut Department of Environmental Protection (CDEP). 2004b. "Dwarf Wedgemussel
14 *Alasmidonta heterodon*." Connecticut Department of Environmental Protection, Hartford,
15 Connecticut. Available URL: <http://dep.state.ct.us/burnatr/Wildlife/learn/fwmusl/dwwm.htm>
16 (Accessed May 12, 2006).
- 17
- 18 Connecticut River Atlantic Salmon Commission. 1998. "Strategic Plan for the Restoration of
19 Atlantic Salmon to the Connecticut River." Connecticut River Atlantic Salmon Commission,
20 Sunderland, Massachusetts. July 1998. Available URL: <http://www.fws.gov/r5crc/documents/strplan.pdf> (Accessed April 6, 2006).
- 21
- 22 Connecticut River Atlantic Salmon Commission. 2004. "Management Plan for River Herring in
23 the Connecticut River Basin." Connecticut River Atlantic Salmon Commission, Sunderland,
24 Massachusetts. October 2004. Available URL: http://www.fws.gov/r5crc/herring_plan.html
25 (Accessed April 6, 2006).
- 26
- 27 Connecticut River Atlantic Salmon Commission. Undated. "Connecticut River Striped Bass."
28 Connecticut River Atlantic Salmon Commission, Sunderland, Massachusetts. Available URL:
29 http://www.fws.gov/R5CRc/Fish/stripped_bass_fact_sheet.pdf (Accessed August 23, 2006).
- 30
- 31 Copeyan, C.K. 1993. *Northeastern Bulrush (Scirpus ancistrochaetus) Recovery Plan*.
32 U.S. Fish and Wildlife Service, Hadley, Massachusetts. (August 25, 1993).
- 33
- 34 Cowie, E.R., and J.B. Peterson. 1991. *Archaeological Phase II Evaluation Study of the
35 Route 142 Improvement Project, Vernon, Windham County, Vermont*.
- 36
- 37 DeGraff, R.M., and D.D. Rudis. 1986. *New England Wildlife: Habitat, Natural History, and
38 Distribution*. General Technical Report NE-108. U.S. Department of Agriculture, Forest
39 Service, Broomhall, Pennsylvania.
- 40
- 41 DeWald, L. 2005a. Letter from L. DeWald, Entergy, to Theresa Tanner, VDEC. Subject:
42 "Monthly NPDES Discharge Monitoring Report for February 2005." (March 7, 2005).
- 43

Plant and the Environment

- 1 DeWald, L. 2005b. Letter from L. DeWald, Entergy, to Theresa Tanner, VDEC. Subject:
2 "Monthly NPDES Discharge Monitoring Report for July 2005." (August 12, 2005).
- 3
- 4 DeWald, L. 2006a. Personal communication from L. DeWald, Entergy, to T. Patton, Argonne
5 National Laboratory. ML061730237. (May 24, 2006).
- 6
- 7 DeWald, L. 2006b. Letter from L. DeWald, Entergy, to Theresa Tanner, VDEC. Subject:
8 "Monthly NPDES Discharge Monitoring Report for March 2006." (April 11, 2006).
- 9
- 10 DeWald, L. 2006c. Letter from L. DeWald, Entergy, to Theresa Tanner, VDEC. Subject:
11 "Monthly NPDES Discharge Monitoring Report for August 2006." (September 11, 2006).
- 12
- 13 DeWald, L. 2006d. E-mail communication from L. DeWald, Entergy Nuclear Northeast,
14 Vernon, Vermont, to R. Emch, Nuclear Regulatory Commission, Washington, D.C., copy to
15 D.S. Miller and R. Kolpa, Argonne National Laboratory, Argonne, IL. (October 5, 2006).
- 16
- 17 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 1995.
18 Letter from D. Reed, Entergy Nuclear Northeast, Vernon, Vermont, to Vermont Air Pollution
19 Control Division, Waterbury, Vermont. Subject: "Vermont Yankee Operating Permit Opt-Out
20 Application." (November 9, 1995).
- 21
- 22 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy).
23 2002a. *2001 Annual Radiological Environmental Operating Report, Vermont Yankee Nuclear*
24 *Power Station.* Docket No. 50-271. Brattleboro, Vermont. (May 14, 2002).
- 25
- 26 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy).
27 2002b. *Annual 2001 Radioactive Effluent Release Report, Vermont Yankee Nuclear Power*
28 *Station.* Docket No. 50-271. Brattleboro, Vermont. (May 14, 2002).
- 29
- 30 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2002c.
31 *Vermont Yankee Nuclear Power Station Off-Site Dose Calculation Manual.* Revision 30.
32 Brattleboro, Vermont (October 2002). Included as attachment to Entergy Nuclear Northeast –
33 Vermont Yankee (Entergy). 2003. *Annual 2002 Radioactive Effluent Release Report, Vermont*
34 *Yankee Nuclear Power Station.* Docket No. 50-271. Brattleboro, Vermont. (May 14, 2003).
- 35
- 36 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy).
37 2003a. *2002 Annual Radiological Environmental Operating Report, Vermont Yankee Nuclear*
38 *Power Station.* Docket No. 50-271. Brattleboro, Vermont. (May 9, 2003).
- 39
- 40 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy).
41 2003b. *Annual 2002 Radioactive Effluent Release Report, Vermont Yankee Nuclear Power*
42 *Station.* Docket No. 50-271. Brattleboro, Vermont. (May 7, 2003).
- 43

Plant and the Environment

- 1 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy).
2 2004a. *2003 Annual Radiological Environmental Operating Report, Vermont Yankee Nuclear*
3 *Power Station*. Docket No. 50-271. Brattleboro, Vermont. (May 7, 2004).
- 4 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy).
5 2004b. *Annual 2003 Radioactive Effluent Release Report, Vermont Yankee Nuclear Power*
6 *Station*. Docket No. 50-271. Brattleboro, Vermont. (May 7, 2004).
- 7 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2004c.
8 *Vermont Yankee Nuclear Power Station, Updated Final Safety Analysis Report, Revision 19*.
9 Docket No. 50-271. Brattleboro, Vermont. (November 1, 2004).
- 10 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy).
11 2005a. *2004 Annual Radiological Environmental Operating Report, Vermont Yankee Nuclear*
12 *Power Station*. Docket No. 50-271. Brattleboro, Vermont. (May 11, 2005).
- 13 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy).
14 2005b. *Annual 2004 Radioactive Effluent Release Report, Vermont Yankee Nuclear Power*
15 *Station*. Docket No. 50-271. Brattleboro, Vermont. (May 11, 2005).
- 16 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2005c.
17 *Extended Power Uprate Cooling Tower Pre & Post Modification Noise Test Report for Vermont*
18 *Yankee Nuclear Power Station*. Shaw, Stone Webster. 59029-RPT-05-001.
- 19 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy).
20 2005d. *Source Water Protection Plans for Entergy Nuclear Northeast*. (May 2005).
- 21 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy).
22 2005e. *Application for NPDES Permit Renewal 2006-2010*. (September 29, 2005).
- 23 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2005f.
24 *Nuclear Management Manual, Refrigerant Management Program, EN-MA-128, Revision 2*.
25 (June 29, 2005).
- 26 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy).
27 2006a. *Applicant's Environmental Report – Operating License Renewal Stage, Vermont*
28 *Yankee Nuclear Power Station*. Docket No. 50-271. Brattleboro, Vermont. (January 25, 2006).
- 29 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy).
30 2006b. *2005 Annual Radiological Environmental Operating Report, Vermont Yankee Nuclear*
31 *Power Station*. Docket No. 50-271. Brattleboro, Vermont. (May 15, 2006).
- 32

Plant and the Environment

1 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006c.
2 *Annual 2005 Radioactive Effluent Release Report, Vermont Yankee Nuclear Power Station.*
3 Docket No. 50-271. Brattleboro, Vermont. (May 15, 2006).

4
5 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy).
6 2006d. *DR-53 Location Exposure Rate Status – Pre-PowerUp, Pre and Post Shield – 3/4, 5/10*
7 *and 5/23 Data.* Prepared by SP Skibniowsky. NRC ADAMS Accession No. ML061730186.
8 (May 24, 2006).

9
10 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy).
11 *2006e. Vermont Yankee Nuclear Power Station License Renewal Application, Amendment 9,*
12 *Appendix E, Revision 2.* Entergy Nuclear Operations, Inc., Brattleboro, Vermont. (August 10,
13 2006).

14
15 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006f.
16 *Comments to Inquiries.* (May 25, 2006).

17
18 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy).
19 2006g. *Table 2 Summary of Site Boundary Direct Shine Doses and EPU Scaling Factors.*
20 Calculation Number: VYC-2298, Revision Number 0, Page 37 of 41. NRC Adams Accession
21 No. ML061730182.

22
23 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy).
24 2006h. *2005 Air Pollutant Emissions Inventory Report for Entergy Nuclear Vermont Yankee,*
25 *LLC.* Facility ID WM 2335. Letter report from L. DeWald and S. Wender IV, Entergy Nuclear
26 Northeast, Vernon, Vermont, to D. Riley, Vermont Agency of Natural Resources, Department of
27 Environmental Conservation, Air Pollution Control Division, Waterbury, Vermont. (January 26,
28 2006).

29
30 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006i.
31 *Used Oil Management and Furnace Operation; Summary for NRC License Renewal*
32 *Environmental Scoping Team.* No date on the document; however, received by NRC on
33 June 26.

34
35 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006j.
36 *Land Use Map.* Vernon, Vermont. (June 23, 2006).

37
38 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006k.
39 *Updated Final Safety Analysis Report, Revision 13.* (April 2003).

40
41 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006l.
42 *Vermont Yankee Nuclear Power Station License Renewal SEIS Information Needs.* ADAMS
43 Accession No. ML061730180.

Plant and the Environment

- 1 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy).
2 2006m. *2005 Annual Groundwater Monitoring Report, Entergy Nuclear Vermont Yankee, LLC*
3 SMS Site #99-2617. (January 23, 2006).
- 4 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy).
5 2006n. Letter report from L. DeWald and S. Wender, IV, Entergy Nuclear Northeast, Vermont,
6 Vermont, to D. Riley, Vermont Agency of Natural Resources, Department of Environmental
7 Conservation, Air Pollution Control Division, Waterbury, Vermont. Subject: "2005 Air Pollutant
8 Emission Inventory Report for Entergy Nuclear Vermont Yankee, LLC. Facility ID WM 2335.
9 (January 26, 2006).
- 10 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy).
11 2006o. *Updated Final Safety Analysis Report, Revision 17.* Section 2.3. (January 2006).
- 12 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006p.
13 *Entergy Nuclear Waste Minimization Plan.* (July 2006).
- 14 Franklin Regional Council of Governments. 2006. Available URL: <http://www.frcog.org>
15 (Accessed May 9, 2006).
- 16 Gephard, S., and J. McMenemy. 2004. "An Overview of the Program to Restore Atlantic
17 Salmon and Other Diadromous Fishes to the Connecticut River with Notes on the Current
18 Status of These Species in the River." In *The Connecticut River Ecological Study (1965-1973)*
19 *Revisited: Ecology of the Lower Connecticut River 1973-2003*, P.M. Jacobson, D.A. Dixon,
20 W.C. Leggett, B.C. Marcy, Jr., and R.R. Massengill, eds. American Fisheries Society,
21 Monograph 9, Bethesda, Maryland.
- 22 Gleason, H.A., and A. Cronquist. 1991. *Manual of Vascular Plants of Northeastern*
23 *United States and Canada.* Second Edition. New York Botanical Garden, Bronx, New York.
- 24 Hanson Engineers, Inc. 1991. *Phase I Cultural Resource Investigations – Vernon Vermont*
25 *Yankee Low Level Radioactive Waste Disposal Site.* Springfield, Illinois.
- 26 Hartgen Archaeological Associates, Inc. 2001. *Archaeological Sensitivity of Assessment for*
27 *the Proposed Gas Storage Area and Access Road.* Putney, Vermont.
- 28 Henry, K., and D. Cragg-Hine. 2003. "Ecology of the Atlantic Salmon." *Conserving Natura*
29 *2000 Rivers Ecology Series No. 7.* English Nature, Peterborough. Available URL:
30 <http://www.english-nature.org.uk/LIFEinUKRivers/publications/Salmon.pdf>
31 (Accessed August 23, 2006).
- 32 December 2006
- 33 2-91
- 34 Draft NUREG-1437, Supplement 30

Plant and the Environment

- 1 Kart, J., R. Regan, S.R. Darling, C. Alexander, K. Cox, M. Ferguson, S. Parren, K. Royar, and
2 B. Popp, eds. 2004. "Vermont's Wildlife Action Plan." Vermont Fish & Wildlife Department,
3 Waterbury, Vermont. Available URL: http://www.vtfishandwildlife.com/swg_cwcs_report.cfm
4 (Accessed August 22, 2006).
- 5
- 6 Krisweb.com. Undated. "Water Temperature and Gulf of Maine Atlantic Salmon." Klamath
7 Resource Information System. Available URL: http://www.krisweb.com/kriisheepscot/krisdb/html/krisweb/stream/temperature_sheepscot.htm (Accessed July 31, 2006).
- 9
- 10 LaRoche, W.A. 2005. Letter from W.A. LaRoche, Vermont Agency of Natural Resources, to
11 G.E. Tucker, FTN Associates, Ltd., Little Rock, Arkansas. (December 7, 2005).
- 12
- 13 Lattrell, W.A. 2004. Letter from W.A. Lattrell, Valley Environmental Services, Greenfield,
14 Massachusetts, to J. Goodell, SVE Associates, Brattleboro, Vermont. (May 5, 2004).
- 15
- 16 Lattrell, W.A. 2005. Letter from W.A. Lattrell, Valley Environmental Services, Greenfield,
17 Massachusetts, to J. Goodell, SVE Associates, Brattleboro, Vermont. (May 13, 2005).
- 18
- 19 Leggett, W.C., T.F. Savoy, and C.A. Tomichek. 2004. "The Impact of Enhancement Initiatives
20 on the Structure and Dynamics of the Connecticut River Population of American Shad." In *The
21 Connecticut River Ecological Study (1965-1973) Revisited: Ecology of the Lower Connecticut
22 River 1973-2003*, P.M. Jacobson, D.A. Dixon, W.C. Leggett, B.C. Marcy, Jr., and
23 R.R. Massengill, eds. American Fisheries Society Monograph 9, Bethesda, Maryland.
- 24
- 25 MacKenzie, C., L.S. Weiss-Glanz, and J.R. Moring. 1985. "Species Profiles: Life Histories and
26 Environmental Requirements of Coastal Fishes and Invertebrates (Mid-Atlantic) – American
27 Shad." U.S. Fish and Wildlife Service Biological Report 82 (11.37). U.S. Army Corps of
28 Engineers TR EL-82-4. Available URL: <http://www.nwrc.usgs.gov/wdb/pub/0156.pdf> (Accessed
29 August 22, 2006).
- 30
- 31 Massachusetts of Marine Fisheries. Undated. "Species Profiles > Striped Bass."
32 Massachusetts Division of Marine Fisheries, Boston, Massachusetts. Available URL:
33 <http://www.mass.gov/dfwele/dmf/recreationalfishing/striperbass.htm> (Accessed October 6,
34 2006).
- 35
- 36 Massachusetts Department of Fisheries and Wildlife (MDFW). 1989. "Massachusetts Rare and
37 Endangered Wildlife *Alasmidonta varicosa* Brook Floater." Massachusetts Department of
38 Fisheries and Wildlife, Natural Heritage and Endangered Species Program, Westborough,
39 Massachusetts. Available URL: <http://www.mass.gov/dfwele/dfw/nhesp/nhfacts/alavar.pdf>
40 (Accessed August 23, 2006).
- 41
- 42

Plant and the Environment

- 1 Massachusetts Office of Health and Human Services. 2006. "Public Health Fish Consumption
2 Advisory." Massachusetts Office of Health and Human Services, Boston, Massachusetts.
3 Available URL: <http://db.state.ma.us/dph/fishadvisory/SearchResults.asp?Action=WATER>
4 (Accessed April 7, 2006).
- 5
- 6 Monadnock Economic Development Corporation. 2006. "About Monadnock Economic
7 Development Corporation." Available URL: <http://www.monadnock-development.org/about.html> (Accessed May 18, 2006).
- 8
- 9
- 10 Nadeau, E.J., and J. Victoria. 2003. "A Guide to the Freshwater Mussels of Connecticut."
11 Connecticut Bureau of Natural Resources, Hartford, Connecticut. Available URL:
12 <http://dep.state.ct.us/burnatr/Wildlife/pdf/fwmusl.pdf> (Accessed August 23, 2006).
- 13
- 14 Nalco. 2006. Material Safety Data Sheet (MSDS) for Product H-550, Microbiocide. Available
15 URL: <http://www.nalco.com> (request access) (Accessed October 3, 2006).
- 16
- 17 National Climatic Data Center (NCDC). 2006a. "Vermont Climate Summary." U.S. Department
18 of Commerce. Available URL: <http://lwf.ncdc.noaa.gov/oa/climate/research/cag3/vt.html>
19 (Accessed September 12, 2006).
- 20
- 21 National Climate Data Center (NCDC). 2006b. "Climatological Data Annual Summary,
22 New England, 2004." Volume 116, Number 13, ISSN 0364-5339. National Oceanic and
23 Atmospheric Administration. Available URL: <http://www1.ncdc.noaa.gov/pub/orders/20E3F7BC-4D87-DAD4-A2AC-474579B6F16B.pdf> (Accessed March 29, 2006).
- 24
- 25
- 26 National Climate Data Center (NCDC). 2006c. "Storms Events." National Oceanic and
27 Atmospheric Administration. Available URL: <http://www4.ncdc.noaa.gov/cgi-win/wwcgi.dll?wwevent~storms> (Accessed March 30, 2006).
- 28
- 29
- 30 National Marine Fisheries Service (NMFS). 1998. "Final Recovery Plan for the Shortnose
31 Sturgeon *Acipenser brevirostrum*." U.S. Department of Commerce, National Oceanic and
32 Atmospheric Administration, National Marine Fisheries Service, Silver Spring, Maryland.
33 December 1998. Available URL: http://www.nmfs.noaa.gov/pr/pdfs/recovery/sturgeon_shortnose.pdf (Accessed July 20, 2006).
- 34
- 35
- 36 NatureServe. 2006. "NatureServe Explorer: An Online Encyclopedia of Life." NatureServe,
37 Arlington, Virginia. Available URL: <http://www.natureserve.org/explorer>
38 (Accessed July 19, 2006).
- 39

Plant and the Environment

1 New Hampshire Division of Historic Resources (NHDHR). 2006. E-mail correspondence
2 between E. Feighner, NHDHR, Concord, New Hampshire, and D. O'Rourke, Argonne National
3 Laboratory, Argonne, Illinois. Subject: "Transmission Lines Associated with Vermont Yankee
4 Nuclear Power Station." (July 12–13, 2006).

5
6 New Hampshire Fish and Game Department (NHFGD). 2005. "New Hampshire Wildlife Action
7 Plan." New Hampshire Fish and Game Department, Concord, New Hampshire. Available URL:
8 http://www.wildlife.state.nh.us/Wildlife/wildlife_plan.htm (Accessed August 22, 2006).

9
10 New Hampshire Fish and Game Department (NHFGD). Undated. "Is It Safe to Eat the Fish?"
11 New Hampshire Fish and Game Department, Concord, New Hampshire. Available URL:
12 http://www.wildlife.state.nh.us/Fishing/fish_consumption.htm (Accessed April 4, 2006).

13
14 New York State Department Environmental Conservation (NYSDEC). Undated. "Dwarf Wedge
15 Mussel Fact Sheet." New York State Department of Environmental Conservation, Albany, New
16 York. Available URL: <http://www.dec.state.ny.us/website/dfwmr/wildlife/endspec/dwmufs.html>
17 (Accessed August 7, 2006).

18
19 Normandeau Associates, Inc. (Normandeau). 2001. "Ecological Studies of the Connecticut
20 River, Vernon, Vermont." Report 30 (January–December 2000). (April 2001).

21
22 Normandeau Associates, Inc. (Normandeau). 2002. "Ecological Studies of the Connecticut
23 River, Vernon, Vermont." Report 31 (January–December 2001). (April 2002).

24
25 Normandeau Associates, Inc. (Normandeau). 2003. "Ecological Studies of the Connecticut
26 River, Vernon, Vermont." Report 32 (January–December 2002). (May 2003).

27
28 Normandeau Associates, Inc. (Normandeau). 2004a. "§316(a) Demonstration in Support of a
29 Request for Increased Discharge Temperature Limits at Vermont Yankee Nuclear Power
30 Station During May through October." Prepared for Entergy Nuclear Vermont Yankee, Vernon,
31 Vermont, by Normandeau Associates, Inc., Bedford, New Hampshire. (April 2004).

32
33 Normandeau Associates, Inc. (Normandeau). 2004b. "Ecological Studies of the Connecticut
34 River, Vernon, Vermont." Report 33 (January–December 2003). (May 2004).

35
36 Normandeau Associates, Inc. (Normandeau). 2005. "Ecological Studies of the Connecticut
37 River Vernon, Vermont." Report 34 January–December 2004. Prepared for Entergy Nuclear
38 Vermont Yankee, Vernon, Vermont, by Normandeau Associates, Inc., Bedford, New Hampshire.
39 (May 2005).

40
41 O'Leary, J.A., and B. Kynard. 1986. "Behavior, Length, and Sex Ratio of Seaward-Migrating
42 Juvenile American Shad and Blueback Herring in the Connecticut River." *Transactions of the*
43 *American Fisheries Society*, Vol. 115, pp. 529–536.

- 1 Private School Review. 2006. "Private Schools." Available URL:
2 http://www.privateschoolreview.com/public_schools/stateid/VT (Accessed May 2006).
- 3
- 4 Public School Review. 2006. "Public Schools." Available URL:
5 http://www.publicschoolreview.com/public_schools/stateid/VT (Accessed May 2006).
- 6
- 7 Savoy, T.F., and V.A. Crecco. 2004. "Factors Affecting the Recent Decline of Blueback Herring
8 and American Shad in the Connecticut River." In *The Connecticut River Ecological Study
9 (1965-1973) Revisited: Ecology of the Lower Connecticut River 1973-2003*, P.M. Jacobson,
10 D.A. Dixon, W.C. Leggett, B.C. Marcy, Jr., and R.R. Massengill, eds. American Fisheries
11 Society, Monograph 9, Bethesda, Maryland.
- 12
- 13 Savoy, T.F., V.A. Crecco, and B.C. Marcy, Jr. 2004. "American Shad Early Life History and
14 Recruitment in the Connecticut River: A 40-Year Summary." In *The Connecticut River
15 Ecological Study (1965-1973) Revisited: Ecology of the Lower Connecticut River 1973-2003*,
16 P.M. Jacobson, D.A. Dixon, W.C. Leggett, B.C. Marcy, Jr., and R.R. Massengill, eds.
17 American Fisheries Society, Monograph 9, Bethesda, Maryland.
- 18
- 19 Shad Studies Subcommittee. 1992. "A Management Plan for American Shad in the
20 Connecticut River Basin." U.S. Fish and Wildlife Service, Connecticut River Coordinator's
21 Office, Sunderland, Massachusetts. February 4. Available URL:
22 http://www.fws.gov.r5crc/shad_plan.html (Accessed April 7, 2006).
- 23
- 24 Smith, W.W. 2004. Letter from W.W. Smith, Valley Environmental Services, Greenfield,
25 Massachusetts, to J. Goodell, SVE Associates, Brattleboro, Vermont. (November 1, 2004).
- 26
- 27 Southwest Regional Planning Commission. 2006. Available URL: <http://www.swRPC.org>
28 (Accessed March 13, 2006).
- 29
- 30 Standard and Poors. 2006. "SchoolMatters." Available at <http://www.schoolmatters.com/>
31 (Accessed May, 2006).
- 32
- 33 Suckling, K. 2006. "Measuring the Success of the Endangered Species Act: Recovery Trends
34 in the Northeastern United States." Center for Biological Diversity, Tucson, Arizona. Available
35 URL: http://www.esasuccess.org/reports/ne_species/study/Measuring-the-Success-of-the-ESA.pdf (Accessed April 11, 2006).
- 36
- 37
- 38 SVE Associates. 1999. *Site Investigation Report – VT Yankee Nuclear Power Plant, Vernon*
39 *VT*. (November 15, 1999).
- 40
- 41 SVE Associates. 2005. *Wetlands Locations Map, Energy Nuclear Vermont Yankee, LLC,*
42 *Vernon, Vermont*. Brattleboro, Vermont. (June 2, 2005).
- 43

Plant and the Environment

- 1 Thompson, E.H., and E.R. Sorenson. 2005. *Wetland, Woodland, Wildland – A Guide to the*
2 *Natural Communities of Vermont.* Published by the Nature Conservancy and the Vermont
3 Department of Fish and Wildlife. Distributed by the University Press of New England, Lebanon,
4 New Hampshire.
- 5
- 6 Town of Brattleboro. 2006. "Town of Brattleboro, VT." Available URL:
7 <http://www.brattleboro.org/index.asp> (Accessed July 2006).
- 8
- 9 Town of Vernon. 2003a. *Town Plan.* Vernon, Vermont.
- 10
- 11 Town of Vernon. 2003b. "Vernon, Vermont, 2003." Vernon Town and School District Annual
12 Report. (June 30, 2003).
- 13
- 14 Town of Vernon. 2004. "Vernon, Vermont, 2004." Vernon Town and School District Annual
15 Report . (June 30, 2004).
- 16
- 17 Town of Vernon. 2006. "Vernon Selectboard Meeting." Available URL:
18 <http://sover.net/~vernontc/home.html> (Accessed May 9, 2006).
- 19
- 20 Tucker, G.E. 2005. Letter from G.E. Tucker, FTN Associates, Ltd., Little Rock, Arkansas, to
21 T. Torti, Vermont Agency of Natural Resources, Waterbury, Vermont. (September 15, 2005).
- 22
- 23 U.S. Atomic Energy Commission (AEC). 1972. *Final Environmental Statement Related to the*
24 *Operation of the Vermont Yankee Nuclear Power Station, Vermont Yankee Nuclear Power*
25 *Corporation.* Docket No. 50-271. Directorate of Licensing, Washington, D.C. (July 1972).
- 26
- 27 U.S. Census Bureau (USCB). 2006a. "American Fact Finder." U.S. Census Bureau,
28 Washington, D.C. Available URL: <http://factfinder.census.gov/> (Accessed May 2006).
- 29
- 30 U.S. Census Bureau (USCB). 2006b. "County Business Patterns." U.S. Census Bureau,
31 Washington, D.C. Available URL: <http://www.census.gov/epcd/cbp/view/cbpview.html>
32 (Accessed May 2006).
- 33
- 34 U.S. Census Bureau (USCB). 2006c. "Census of Governments." U.S. Census Bureau,
35 Washington, D.C. Available URL: <http://www.census.gov/gov/www/index>
36 (Accessed May 2006).
- 37
- 38 U.S. Department of Agriculture (USDA). 2006a. "U.S. Census of Agriculture, 1987, 1992,
39 1997." Available URL: <http://agcensus.mannlib.cornell.edu/> (Accessed March 22, 2006).
- 40
- 41 U.S. Department of Agriculture (USDA). 2006b. "Census of Agriculture, 2002." National
42 Agricultural Statistics Service, Washington, D.C. Available URL:
43 <http://www.nass.usda.gov/census/census97/vol1/vol1pubs.htm> (Accessed May 2006).

- 1 U.S. Department of Commerce (DOC). 2006. "Local Area Personal Income." Bureau of
2 Economic Analysis. Available URL: <http://www.bea.doc.gov/bea/regional/reis/>
3 (Accessed May 2006).
- 4 U.S. Department of Labor (DOL). 2006. "Local Area Unemployment Statistics." Bureau of
5 Labor Statistics. Available URL: <ftp://ftp.bls.gov/pub/time.series/la/> (Accessed May 2006).
- 6 U.S. Environmental Protection Agency (EPA). 2006a. "Fact Sheet: Complying With the
7 Section 608 Refrigerant Recycling Rule." March 8. Available URL:
8 <http://www.epa.gov/ozone/title6/608/608fact.html> (Accessed on July 6, 2006).
- 9 U.S. Environmental Protection Agency (EPA). 2006b. "Endangered Species Protection
10 Program Databases." Available URL: <http://www.epa.gov/espp/database.htm>
11 (Accessed July 19, 2006).
- 12 U.S. Environmental Protection Agency (EPA). 2006c. "NPDES Water Permit Program in New
13 England." Available URL: <http://www.epa.gov/region1/npdes/index.html> (Accessed October 2,
14 2006).
- 15 U.S. Fish and Wildlife Service (FWS). 1983. *Indiana Bat Recovery Plan*. Rockville, Maryland.
16 (October 14, 1983).
- 17 U.S. Fish and Wildlife Service (FWS). 1990. "Endangered and Threatened Wildlife and Plants;
18 Determination of Endangered Status for the Dwarf Wedge Mussel." *Federal Register*, Vol. 55,
19 No. 50, pp. 9447–9451.
- 20 U.S. Fish and Wildlife Service (FWS). 1993. "Dwarf Wedge Mussel (*Alasmidonta heterodon*)
21 Recovery Plan." U.S. Fish and Wildlife Service, Region 5, Hadley, Massachusetts. Available
22 URL: <http://www.fws.gov/northeast/nyfo/es/dwm.pdf> (Accessed April 11, 2006).
- 23 U.S. Fish and Wildlife Service (FWS). 1999. "Endangered and Threatened Wildlife and Plants;
24 Proposed Rule to Remove the Bald Eagle in the Lower 48 States from the List of Endangered
25 and Threatened Wildlife." *Federal Register*, Vol. 64, pp. 36454–36464. Washington, D.C.
26 (July 6, 1999).
- 27 U.S. Fish and Wildlife Service (FWS). 2001. "Shortnose Sturgeon Habitat Model." U.S. Fish
28 and Wildlife Service, Gulf of Maine Coastal Program, Falmouth, Maine. July. Available URL:
29 http://www.fws.gov/r5gomp/gom/habitatstudy/metadata/shortnose_sturgeon_model.htm
30 (Accessed July 20, 2006).
- 31
- 32
- 33
- 34
- 35
- 36
- 37
- 38
- 39
- 40
- 41
- 42

Plant and the Environment

1 U.S. Fish and Wildlife Service (FWS). 2002a. "The Natural History of the River Herrings (*Alosa*
2 *pseudoharengus* and *Alosa aestivalis*)." U.S. Fish and Wildlife Service, Central New England
3 Fishery Resources Office, Nashua, New Hampshire. Available URL:
4 <http://www.fws.gov/r5cneafp/herring.htm> (Accessed April 7, 2006).

5
6 U.S. Fish and Wildlife Service (FWS). 2002b. "Endangered Species – State and County
7 Listings." Northeast Region Ecological Services, Hadley, Massachusetts. Available URL:
8 <http://www.fws.gov/northeast/endangered/> (Accessed May 11, 2006).

9
10 U.S. Fish and Wildlife Service (FWS). 2004. "2004 Connecticut River Migratory Fish Counts."
11 U.S. Fish and Wildlife Service, Connecticut River Coordinator's Office, Sunderland,
12 Massachusetts. December. Available URL: <http://www.fws.gov/r5crc/Fish/old04.html>
13 (Accessed April 6, 2006).

14
15 U.S. Fish and Wildlife Service (FWS). 2005a. "American Eel *Anguilla rostrata*." U.S. Fish and
16 Wildlife Service, Northeast Region, Hadley, Massachusetts. April. Available URL:
17 <http://www.fws.gov/northeast/ameel/ameelfactsht.final.pdf> (Accessed April 12, 2006).

18
19 U.S. Fish and Wildlife Service (FWS). 2005b. "2005 Connecticut River Migratory Fish Counts."
20 U.S. Fish and Wildlife Service, Connecticut River Coordinator's Office, Sunderland,
21 Massachusetts. December. Available URL: <http://www.fws.gov/r5crc/Fish/old05.html>
22 (Accessed April 6, 2006).

23
24 U.S. Fish and Wildlife Service (FWS). 2005c. "Connecticut River Migratory Fish Counts, 1967-
25 2005." U.S. Fish and Wildlife Service, Connecticut River Coordinator's Office, Sunderland,
26 Massachusetts. December. Available URL: <http://www.fws.gov/r5crc/Fish/oldcts.html>
27 (Accessed August 8, 2006).

28
29 U.S. Fish and Wildlife Service (FWS). 2006a. "Fish Passage Schedule." U.S. Fish and Wildlife
30 Service, Connecticut River Coordinator's Office, Sunderland, Massachusetts. Available URL:
31 http://www.fws.gov/r5crc/Habitat/fish_passage_schedule.htm (Accessed April 6, 2006).

32
33 U.S. Fish and Wildlife Service (FWS). 2006b. "Species Information Threatened and
34 Endangered Animals and Plants." U.S. Fish and Wildlife Service, Washington, D.C. Available
35 URL: <http://www.fws.gov/endangered/wildlife.html> (Accessed August 23, 2006).

36
37 U.S. Fish and Wildlife Service (FWS). 2006c. "Natural Resources in the Connecticut River
38 Watershed – Federally Endangered or Threatened Species." Available URL:
39 <http://www.fws.gov/r5soc/EndThrSp.htm#HL> (Accessed May 22, 2006).

40
41 U.S. Fish and Wildlife Service (FWS). 2006d. Letter from M.J. Amaral, U.S. Fish and Wildlife
42 Service, Concord, New Hampshire, to R. Franovich, U.S. Nuclear Regulatory Commission,
43 Rockville, Maryland. (August 10, 2006).

Plant and the Environment

1 U.S. Fish and Wildlife Service (FWS). 2006d. Data from M. Grander, U.S. Fish and Wildlife
2 Service, Sunderland, Massachusetts, to W. Vinikour, Argonne National Laboratory, Argonne,
3 Illinois. (May 24, 2006).

4
5 U.S. Fish and Wildlife Service (FWS). Undated. "Fish Facts." U.S. Fish and Wildlife Service,
6 Connecticut River Coordinator's Office, Sunderland, Massachusetts. Available URL:
7 <http://www.fws.gov/r5crc/Fish/facts.html> (Accessed April 6, 2006).

8
9 U.S. National Marine Fisheries Service (NMFS). 2006. Letter from L. A. Chiarella, U.S.
10 National Marine Fisheries Service, Gloucester, Massachusetts, to R. Franovich, U.S. Nuclear
11 Regulatory Commission, Rockville, Maryland. (September 15, 2006).

12
13 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement*
14 *for License Renewal of Nuclear Plants*. NUREG-1437, Vols. 1 and 2, Washington, D.C.

15
16 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement*
17 *for License Renewal of Nuclear Plants, Main Report*, "Section 6.3 – Transportation, Table 9.1,
18 Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants, Final
19 Report." NUREG-1437, Vol. 1, Addendum 1, Washington, D.C.

20
21 U.S. Nuclear Regulatory Commission (NRC). 2006a. *Vermont Yankee Nuclear Power Station*
22 – *Final Environmental Assessment and Finding of No Significant Impact Related to the*
23 *Proposed License Amendment to Increase the Maximum Power Level*. Docket No. 50-271.
24 Washington, D.C. (January 20, 2006).

25
26 U.S. Nuclear Regulatory Commission (NRC). 2006b. Letter from R. Franovich, U.S. Nuclear
27 Regulatory Commission, Rockville, Maryland, to M. Moriarity, U.S. Fish and Wildlife Service,
28 Hadley, Massachusetts. (May 5, 2006).

29
30 U.S. Nuclear Regulatory Commission (NRC). 2006c. Letter from R. Franovich, U.S. Nuclear
31 Regulatory Commission, Rockville, Maryland, to M. Moriarity, U.S. Fish and Wildlife Service,
32 Concord, New Hampshire. (July 21, 2006).

33
34 U.S. Nuclear Regulatory Commission (NRC). 2006d. Memorandum and Order, Docket No.
35 50-271-LR. (September 22, 2006).

36
37 University of New Hampshire Cooperative Extension. 2006. "Cheshire County Profile."
38 Available URL: <http://extension.unh.edu/Counties/Cheshire/CHCProf.htm>
39 (Accessed March 22, 2006).

Plant and the Environment

1 Vermont Agency of Natural Resources (VANR). 2005. Letter from W.A. Laroche, Vermont
2 Agency of Natural Resources, Department of Fish and Wildlife, Waterbury, Vermont, to
3 G.E. Tucker, FTN Associates, Ltd., Little Rock, Arkansas. Subject: "Information on the
4 Environmental Issues and Informational Needs to Be Addressed in the Permit Application for
5 Renewal of the Current Operating License." (December 7, 2005).

6
7 Vermont Agency of Natural Resources (VANR). 2006. *Final Amended Discharge Permit*
8 #3-1199. Vermont Agency of Natural Resources, Department of Environmental Conservation,
9 Wastewater Management Division, Waterbury, Vermont. (March 2006).

10
11 Vermont Department of Environmental Conservation (VDEC). 1995. Letter from R. Valentini, VTEC,
12 VT DEC/APCD, to G.D. Weyman, Vermont Yankee Nuclear Power Station. Subject:
13 "Concurrence in Approval of the VYNPS Title V Permit Opt-Out Application."
14 (November 20, 1995).

15
16 Vermont Department of Environmental Conservation (VDEC). 2003. *National Pollutant*
17 *Discharge Elimination System Permit Number VT0000264 (VDEC Permit No. 3-1199)*.
18 Wastewater Management Division. (June 9, 2003).

19
20 Vermont Department of Environmental Conservation (VDEC). 2005a. *Renewal of Permit*
21 3-1199. Permit renewal with letter from C. Fowler, VDEC, to L. DeWald, Entergy.
22 (September 30, 2005).

23
24 Vermont Department of Environmental Conservation (VDEC). 2005b. Letter from C. Dunn,
25 Vermont Department of Environmental Conservation, Air Pollution Control Division, to
26 L. DeWald, Entergy Northeast (Vermont Yankee). Subject: "Acknowledging Payment of
27 Registration Fee and Certificate of Registration." (May 4, 2005).

28
29 Vermont Department of Environmental Conservation (VDEC). 2005c. *Indirect Discharge*
30 *Permit No. 9-0036*. Permit with letter from J.J. Akielaszek, VDEC, to B. Williams, Entergy.
31 (December 14, 2005).

32
33 Vermont Department of Environmental Conservation (VDEC). 2006a. *Final Amended*
34 *Discharge Permit #3-1199*. Amended permit with letter from B.D. Kooiker, VDEC, to
35 L. DeWald, Entergy. (March 30, 2006).

36
37 Vermont Department of Environmental Conservation (VDEC). 2006b. "2005 Annual Report on
38 Air Quality State of Vermont." Available URL: <http://www.anr.state.vt.us/air/Monitoring/htm/2005AnnualReport.htm> (Accessed March 29, 2006).

38
39 Vermont Department of Environmental Conservation (VDEC). 2006c. "Vermont Air Pollution
40 Point Source Database; Facility Emissions by Pollutant for 2004 (in tons)." Available URL:

1 <http://www.anr.state.vt.us/air/Planning/docs/rptFacEmissionsTotal2004.pdf>
2 (Accessed March 29, 2006).

3
4 Vermont Department of Environmental Conservation (VDEC). 2006d. "Air Pollution Control in
5 Vermont; Air Pollution from Motor Vehicles in Vermont." Pamphlet. Available URL:
6 <http://www.anr.state.vt.us/air/MobilSources/docs/pollution.pdf> (Accessed March 29, 2006).

7
8 Vermont Department of Fish and Wildlife (VDFW). 2005a. "Endangered and Threatened Plants
9 of Vermont." Nongame and Natural Heritage Program. April 23, 2005. Available URL:
10 http://www.vtfishandwildlife.com/library/Reports_and_documents/nongame_and_Natural_Heritage/Rare_Threatened_and_Endangered_Species/Endangered%20_and_Threatened_Plants_of_Vermont-April_2005.pdf (Accessed on May 22, 2006).

11
12 Vermont Department of Fish and Wildlife (VDFW). 2005b. "Endangered and Threatened
13 Animals of Vermont." Nongame and Natural Heritage Program. April 23, 2005. Available URL:
14 http://www.vtfishandwildlife.com/library/Reports_and_documents/nongame_and_Natural_Heritage/Rare_Threatened_and_Endangered_Species/Endangered_and_Threatened_Animals_of_Vermont-April_2005.pdf (Accessed on May 22, 2006).

15
16 Vermont Department of Fish and Wildlife (VDFW). 2006a. "Connecticut River Anadromous
17 Fisheries Restoration and Management. Fish Passage Operation." Vermont Fish and Wildlife
18 Department Annual Report. Project F-34-R-*. Period Covered: July 1, 2005 to June 30, 2006.
19 Vermont Fish and Wildlife Department, Waterbury, Vermont.

20
21 Vermont Department of Fish and Wildlife (VDFW). 2006b. "Roaring Brook Wildlife
22 Management Area." Available URL: <http://www.vtfishandwildlife.com/library/Maps/Wildlife%20Management%20Areas/Springfield%20District/Roaring%20Brook%20WMA.pdf> (Accessed May 11, 2006).

23
24 Vermont Department of Fish and Wildlife (VDFW). 2006c. "Vermont Has Its First Bald Eagle
25 Nest." Available URL: <http://www.cvps.com/eagles/documents/eaglereleaseMay12006.pdf>
26 (Accessed July 19, 2006).

27
28 Vermont Department of Fish and Wildlife (VDFW). 2006d. "Conn. River Eagle Nest Fails, but
29 Six Young Eagles Are Growing at Fish & Wildlife's Dead Creek Wildlife Management Area.
30 Available URL: http://www.cvps.com/eagles/documents/eaglet_loss.pdf
31 (Accessed July 19, 2006).

32
33 Vermont Department of Health (VDH). 1977. "Chapter 3 – Radiological Health." In
34 *Radiological Health Statute and Regulations, Regulation Part 5*. Available URL:
35 <http://healthvermont.gov/enviro/rad/Radiological%20Health.pdf> (Accessed on July 20, 2006).

Plant and the Environment

1 Vermont Department of Health (VDH). 2001. "Vermont Fish Advisory." Vermont Department of
2 Health, Burlington, Vermont. January. Available URL:
3 <http://leahy.senate.gov/issues/environment/mercury/fishmercury.pdf> (Accessed April 6, 2006).

4
5 Vermont Department of Health (VDH). 2002. *State of Vermont, Environmental Radiation*
6 *Surveillance Report*. 2001 Summary. Office of Occupational & Radiological Health, Burlington,
7 Vermont. NRC ADAMS Accession Number ML061780093.

8
9 Vermont Department of Health (VDH). 2003. *State of Vermont, Environmental Radiation*
10 *Surveillance Report*. 2002 Summary. Office of Radiological Health. Burlington, Vermont. NRC
11 ADAMS Accession Number ML061770612.

12
13 Vermont Department of Health (VDH). 2004. *State of Vermont, Environmental Radiation*
14 *Surveillance Report*. 2003 Summary. Office of Radiological Health, Burlington, Vermont. NRC
15 ADAMS Accession Number ML061770606.

16
17 Vermont Department of Health (VDH). 2005. *State of Vermont, Environmental Radiation*
18 *Surveillance Report*. 2004 Summary. Office of Radiological Health. Burlington, Vermont. NRC
19 ADAMS Accession Number ML061770589.

20
21 Vermont Department of Health (VDH). 2006. *State of Vermont, Vermont Yankee Nuclear*
22 *Power Station, Environmental Radiation Surveillance Report*. 2005 Summary. Office of
23 Radiological Health, Burlington, Vermont. NRC ADAMS Accession Number ML061770593.

24
25 Vermont State Climatologist. 2006. "Weather and Climate in Vermont." Available URL:
26 http://www.uvm.edu/~ldupigny/sc/climate_vermont.html (Accessed March 27, 2006).

27
28 Vermont Water Resources Board (VWRB). 2006. *Vermont Water Quality Standards*. Adopted
29 January 25.

30
31 Vermont Yankee Nuclear Power Station (VYNPS). 2001. *VY Air Emissions Recordkeeping –*
32 *2001*.

33
34 Vermont Yankee Nuclear Power Station (VYNPS). 2002. *VY Air Emissions Recordkeeping –*
35 *2002*.

36
37 Vermont Yankee Nuclear Power Station (VYNPS). 2003a. *VY Air Emissions Recordkeeping –*
38 *2003*.

39
40 Vermont Yankee Nuclear Power Station (VYNPS). 2003b. *Monthly Analysis Data for the Main*
41 *Fuel Oil Storage Tank for 2000 and 2003*. Summary data for samples taken from December
42 2000 through January 2003.

Plant and the Environment

- 1 Vermont Yankee Nuclear Power Station (VYNPS). 2004. *VY Air Emissions Recordkeeping –*
2 *2004*.
- 3
- 4 Vermont Yankee Nuclear Power Station (VYNPS). 2005. *VY Air Emissions Recordkeeping –*
5 *2005*.
- 6
- 7 Vermont Yankee Nuclear Power Station (VYNPS). 2006a. *Entergy Vermont Yankee Five Year*
8 *PM History for DG-1-1A, Diesel Generator.* (April 27, 2006).
- 9
- 10 Vermont Yankee Nuclear Power Station (VYNPS). 2006b. *Entergy Vermont Yankee Five Year*
11 *PM History for DG-1-1B, Diesel Generator.* (April 27, 2006).
- 12
- 13 Vermont Yankee Nuclear Power Station (VYNPS). 2006c. *Entergy Vermont Yankee Five Year*
14 *PM History for P-40-1A, Diesel Driven Fire Pump.* (April 27, 2006).
- 15
- 16 Vermont Yankee Nuclear Power Station (VYNPS). 2006d. *Entergy Vermont Yankee Five Year*
17 *PM History for DG-3-1A, Security Lighting Diesel Generator.* Includes John Deere diesel engine
18 and Kohler generator. (April 27, 2006).
- 19
- 20 Vermont Yankee Nuclear Power Station (VYNPS). 2006e. *Nameplate Ratings for House Heat*
21 *Boilers.* No date on document; however, received by NRC on June 26.
- 22
- 23 Windham Regional Commission. 2006. *Draft Windham Regional Plan.*

3.0 Environmental Impacts of Refurbishment

Environmental issues associated with refurbishment activities are discussed in the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, Volumes 1 and 2 (NRC 1996, 1999).^(a) The GEIS includes a determination of whether the analysis of the environmental issues could be applied to all plants and whether additional mitigation measures would be warranted. Issues are then assigned a Category 1 or a Category 2 designation. As set forth in the GEIS, Category 1 issues are those that meet all of the following criteria:

- (1) The environmental impacts associated with the issue have been determined to apply either to all plants or, for some issues, to plants having a specific type of cooling system or other specified plant or site characteristics.
- (2) A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to the impacts (except for collective off-site radiological impacts from the fuel cycle and from high-level waste and spent fuel disposal).
- (3) Mitigation of adverse impacts associated with the issue has been considered in the analysis, and it has been determined that additional plant-specific mitigation measures are likely not to be sufficiently beneficial to warrant implementation.

For issues that meet the three Category 1 criteria, no additional plant-specific analysis is required in this draft Supplemental Environmental Impact Statement (SEIS) unless new and significant information is identified.

Category 2 issues are those that do not meet one or more of the criteria for Category 1 and, therefore, additional plant-specific review of these issues is required.

License renewal actions may require refurbishment activities for the extended plant life. These actions may have an impact on the environment that requires evaluation, depending on the type of action and the plant-specific design. Environmental issues associated with refurbishment that were determined to be Category 1 issues are listed in Table 3-1.

Environmental issues related to refurbishment considered in the GEIS for which these conclusions could not be reached for all plants, or for specific classes of plants, are Category 2 issues. These are listed in Table 3-2.

(a) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and its Addendum 1.

Environmental Impacts of Refurbishment

Table 3-1. Category 1 Issues for Refurbishment Evaluation

ISSUE–10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections
SURFACE-WATER QUALITY, HYDROLOGY, AND USE (FOR ALL PLANTS)	
Impacts of refurbishment on surface-water quality	3.4.1
Impacts of refurbishment on surface-water use	3.4.1
AQUATIC ECOLOGY (FOR ALL PLANTS)	
Refurbishment	3.5
GROUNDWATER USE AND QUALITY	
Impacts of refurbishment on groundwater use and quality	3.4.2
LAND USE	
Onsite land use	3.2
HUMAN HEALTH	
Radiation exposures to the public during refurbishment	3.8.1
Occupational radiation exposures during refurbishment	3.8.2
SOCIOECONOMICS	
Public services: public safety, social services, and tourism and recreation	3.7.4; 3.7.4.3; 3.7.4.4; 3.7.4.6
Aesthetic impacts (refurbishment)	3.7.8

Environmental issues related to refurbishment considered in the GEIS for which these conclusions could not be reached for all plants, or for specific classes of plants, are Category 2 issues. These are listed in Table 3-2.

The potential environmental effects of refurbishment actions would be identified, and the analysis would be summarized within this section, if such actions were planned. Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy), indicated that it has performed an integrated plant assessment evaluating structures and components pursuant to Title 10, Part 54, Section 54.21, of the *Code of Federal Regulations* (10 CFR 54.21) to identify activities that are necessary to continue operation of VYNPS during the requested 20-year period of extended operation. These activities include replacement of certain components as well as new inspection activities and are described in the Environmental Report (ER) (Entergy 2006).

The integrated plant assessment that Entergy conducted under 10 CFR Part 54 did not identify the need to undertake any major refurbishment or replacement actions to maintain the functionality of important systems, structures, and components during the VYNPS license renewal period. Therefore, refurbishment is not considered in this draft SEIS.

Environmental Impacts of Refurbishment

Table 3-2. Category 2 Issues for Refurbishment Evaluation

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections	10 CFR 51.53 (c)(3)(ii) Subparagraph
TERRESTRIAL RESOURCES		
Refurbishment impacts	3.6	E
THREATENED OR ENDANGERED SPECIES (FOR ALL PLANTS)		
Threatened or endangered species	3.9	E
AIR QUALITY		
Air quality during refurbishment (nonattainment and maintenance areas)	3.3	F
SOCIOECONOMICS		
Housing impacts	3.7.2	I
Public services: public utilities	3.7.4.5	I
Public services: education (refurbishment)	3.7.4.1	I
Offsite land use (refurbishment)	3.7.5	I
Public services, transportation	3.7.4.2	J
Historic and archaeological resources	3.7.7	K
ENVIRONMENTAL JUSTICE		
Environmental justice	Not addressed ^(a)	Not addressed ^(a)
(a) Guidance related to environmental justice was not in place at the time the GEIS and the associated revision to 10 CFR Part 51 were prepared. If an applicant plans to undertake refurbishment activities for license renewal, environmental justice must be addressed in the applicant's ER and the U.S. Nuclear Regulatory Commission (NRC) staff's environmental impact statement.		

3.1 References

- 10 CFR Part 51. *Code of Federal Regulations*, Title 10, Energy, Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions."
- 10 CFR Part 54. *Code of Federal Regulations*, Title 10, Energy, Part 54, "Requirements for Renewal of Operating Licenses for Nuclear Power Plants."
- Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006. *Applicant's Environmental Report – Operating License Renewal Stage, Vermont Yankee Nuclear Power Station*. Docket No. 50-271. Brattleboro, Vermont. (January 25, 2006).
- U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*. NUREG-1437, Vols. 1 and 2, Washington, D.C.
- U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Main Report*, "Section 6.3 – Transportation, Table 9.1, Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants, Final Report." NUREG-1437, Vol. 1, Addendum 1, Washington, D.C.

1 **4.0 Environmental Impacts of Operation**

2

3

4 Environmental issues associated with operation of a nuclear power plant during the renewal
5 term are discussed in the *Generic Environmental Impact Statement for License Renewal of*
6 *Nuclear Plants* (GEIS), NUREG-1437, Volumes 1 and 2 (NRC 1996, 1999).^(a) The GEIS
7 includes a determination of whether the analysis of the environmental issues could be applied to
8 all plants and whether additional mitigation measures would be warranted. Issues are then
9 assigned a Category 1 or a Category 2 designation. As set forth in the GEIS, Category 1 issues
10 are those that meet all of the following criteria:

- 11
- 12 (1) The environmental impacts associated with the issue have been determined to apply
13 either to all plants or, for some issues, to plants having a specific type of cooling system
14 or other specified plant or site characteristics.
- 15
- 16 (2) A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to
17 the impacts (except for collective offsite radiological impacts from the fuel cycle and from
18 high-level waste and spent fuel disposal).
- 19
- 20 (3) Mitigation of adverse impacts associated with the issue has been considered in the
21 analysis, and it has been determined that additional plant-specific mitigation measures
22 are likely not to be sufficiently beneficial to warrant implementation.

23

24 For issues that meet the three Category 1 criteria, no additional plant-specific analysis is
25 required unless new and significant information is identified.

26

27 Category 2 issues are those that do not meet one or more of the criteria for Category 1, and,
28 therefore, additional plant-specific review of these issues is required.

29

30 This chapter addresses the issues related to operation during the renewal term that are listed in
31 Table B-1 of Title 10, Part 51, of the *Code of Federal Regulations* (10 CFR Part 51), Subpart A,
32 Appendix B, and are applicable to the Vermont Yankee Nuclear Power Station (VYNPS).
33 Section 4.1 addresses issues applicable to the VYNPS cooling system. Section 4.2 addresses
34 issues related to transmission lines and onsite land use. Section 4.3 addresses the radiological
35 impacts of normal operation, and Section 4.4 addresses issues related to the socioeconomic
36 impacts of normal operation during the renewal term. Section 4.5 addresses issues related to
37 groundwater use and quality, while Section 4.6 discusses the impacts of renewal-term
38 operations on threatened and endangered species. Section 4.7 addresses potential new
39 information that was raised during the scoping period, and Section 4.8 discusses cumulative

(a) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and its Addendum 1.

Environmental Impacts of Operation

1 impacts. The results of the evaluation of environmental issues related to operation during the
2 renewal term are summarized in Section 4.9. Category 1 and Category 2 issues that are not
3 applicable to VYNPS because they are related to plant design features or site characteristics
4 not found at VYNPS are listed in Appendix F.

4.1 Cooling System

8 Category 1 issues in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, that are applicable to
9 VYNPS cooling system operation during the renewal term are listed in Table 4-1. Entergy
10 Nuclear Vermont Yankee, LLC And Entergy Nuclear Operations, Inc. (Entergy) stated in its
11 Environmental Report (ER) (Entergy 2006a) that it is not aware of any new and significant
12 information associated with the renewal of the VYNPS operating license (OL). The
13 U.S. Nuclear Regulatory Commission (NRC) staff has not identified any new and significant
14 information during its independent review of the Entergy ER, the site visit, the scoping process,
15 or the evaluation of other available information (e.g., potential impacts associated with the
16 extended power uprate) (NRC 2006a). Therefore, the NRC staff concludes that there are no
17 impacts related to these issues beyond those discussed in the GEIS. For all of the issues, the
18 NRC staff concluded in the GEIS that the impacts would be SMALL, and additional
19 plant-specific mitigation measures are not likely to be sufficiently beneficial to warrant
20 implementation.

21
22 A brief description of the NRC staff's review and the GEIS conclusions, as codified in 10 CFR
23 Part 51, Table B-1, for each of these issues follows:

- 24
- 25 • Altered current patterns at intake and discharge structures. Based on information in
26 the GEIS, the Commission found that

27
28 Altered current patterns have not been found to be a problem at operating
29 nuclear power plants and are not expected to be a problem during the license
30 renewal term.

31
32 The NRC staff has not identified any new and significant information during its
33 independent review of the Entergy ER, the site visit, the scoping process, or the
34 evaluation of other available information. Therefore, the NRC staff concludes that there
35 would be no impacts of altered current patterns during the renewal term beyond those
36 discussed in the GEIS.

- 37
- 38 • Temperature effects on sediment transport capacity. Based on information in the
39 GEIS, the Commission found that

Environmental Impacts of Operation

Table 4-1. Category 1 Issues Applicable to the Operation of the VYNPS Cooling System
During the Renewal Term

ISSUE-10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Section
SURFACE WATER QUALITY, HYDROLOGY, AND USE	
Altered current patterns at intake and discharge structures	4.2.1.2.1
Temperature effects on sediment transport capacity	4.2.1.2.3
Scouring caused by discharged cooling water	4.2.1.2.3
Eutrophication	4.2.1.2.3
Discharge of chlorine or other biocides	4.2.1.2.4
Discharge of sanitary wastes and minor chemical spills	4.2.1.2.4
Discharge of other metals in wastewater	4.2.1.2.4
Water-use conflicts (plants with once-through cooling systems)	4.2.1.3
AQUATIC ECOLOGY	
Accumulation of contaminants in sediments or biota	4.2.1.2.4
Entrainment of phytoplankton and zooplankton	4.2.2.1.1
Cold shock	4.2.2.1.5
Thermal plume barrier to migrating fish	4.2.2.1.6
Distribution of aquatic organisms	4.2.2.1.6
Premature emergence of aquatic insects	4.2.2.1.7
Gas supersaturation (gas bubble disease)	4.2.2.1.8
Low dissolved oxygen in the discharge	4.2.2.1.9
Losses from predation, parasitism, and disease among organisms	4.2.2.1.10
Stimulation of nuisance organisms	4.2.2.1.11
AQUATIC ECOLOGY (PLANTS WITH COOLING-TOWER-BASED HEAT DISSIPATION SYSTEMS)	
Entrainment of fish and shellfish in early life stages	4.3.3
Impingement of fish and shellfish	4.3.3
Heat shock	4.3.3
TERRESTRIAL RESOURCES	
Cooling tower impacts on crops and ornamental vegetation	4.3.4
Cooling tower impacts on native plants	4.3.5.1
HUMAN HEALTH	
Microbiological organisms (occupational health)	4.3.6
Noise	4.3.7

Environmental Impacts of Operation

These effects have not been found to be a problem at operating nuclear power plants and are not expected to be a problem during the license renewal term.

The NRC staff has not identified any new and significant information during its independent review of the Entergy ER, the site visit, the scoping process, or the evaluation of other available information. Therefore, the NRC staff concludes that there would be no impacts of temperature effects on sediment transport capacity during the renewal term beyond those discussed in the GEIS.

- Scouring caused by discharged cooling water. Based on information in the GEIS, the Commission found that

Scouring has not been found to be a problem at most operating nuclear power plants and has caused only localized effects at a few plants. It is not expected to be a problem during the license renewal term.

The NRC staff has not identified any new and significant information during its independent review of the Entergy ER, the site visit, the scoping process, or the evaluation of other available information. Therefore, the NRC staff concludes that there would be no impacts of scouring caused by discharged cooling water during the renewal term beyond those discussed in the GEIS.

- Eutrophication. Based on information in the GEIS, the Commission found that

Eutrophication has not been found to be a problem at operating nuclear power plants and is not expected to be a problem during the license renewal term.

The NRC staff has not identified any new and significant information during its independent review of the Entergy ER, the site visit, the scoping process, or the evaluation of other available information. Therefore, the NRC staff concludes that there would be no impacts of eutrophication during the renewal term beyond those discussed in the GEIS.

- Discharge of chlorine or other biocides. Based on information in the GEIS, the Commission found that

Effects are not a concern among regulatory and resource agencies, and are not expected to be a problem during the license renewal term.

Environmental Impacts of Operation

1 However, the staff did receive a comment during the scoping process concerning the
2 presence of biocides in cooling water drift, providing potentially new and significant
3 information on this issue. The staff's evaluation of this information is presented in
4 Section 4.7.

5 The NRC staff has not identified any new and significant information during its
6 independent review of the Entergy ER, the site visit, the scoping process, or the
7 evaluation of other available information, including the National Pollutant Discharge
8 Elimination System (NPDES) permit for VYNPS, or discussion with the Vermont
9 Department of Environmental Conservation (VDEC). During the scoping process, the
10 NRC staff received a comment concerning the potential impact on human health from
11 the presence of biocides in the cooling tower drift. The staff examined this concern to
12 determine if it represents new and significant information. The staff's evaluation is
13 provided in Section 4.7. The NRC staff, based on the evaluation in Section 4.7,
14 concludes that there would be no impacts of discharge of chlorine or other biocides
15 during the renewal term beyond those discussed in the GEIS.

- 16
- 17 • Discharge of sanitary wastes and minor chemical spills. Based on information in the
18 GEIS, the Commission found that

19

20 Effects are readily controlled through the NPDES permit (in the case of
21 VYNPS, issued by the State of Vermont), an Indirect Discharge Permit, and
22 periodic modifications, if needed, and are not expected to be a problem
23 during the license renewal term.

24

25 The NRC staff has not identified any new and significant information during its
26 independent review of the Entergy ER, the site visit, the scoping process, or the
27 evaluation of other available information, including the NPDES permit for VYNPS, or
28 discussion with the VDEC. Therefore, the NRC staff concludes that there would be no
29 impacts of discharges of sanitary wastes and minor chemical spills during the renewal
30 term beyond those discussed in the GEIS.

- 31
- 32 • Discharge of other metals in wastewater. Based on information in the GEIS, the
33 Commission found that

34

35 These discharges have not been found to be a problem at operating nuclear
36 power plants with cooling-tower-based heat dissipation systems and have
37 been satisfactorily mitigated at other plants. They are not expected to be a
38 problem during the license renewal term.

39

40 The NRC staff has not identified any new and significant information during its
41 independent review of the Entergy ER, the site visit, the scoping process, or the

Environmental Impacts of Operation

1 evaluation of other available information, including the NPDES permit for VYNPS, or
2 discussion with the VDEC. Therefore, the NRC staff concludes that there would be no
3 impacts of discharges of other metals in wastewater during the renewal term beyond
4 those discussed in the GEIS.

- 5
- 6 • Water-use conflicts (plants with once-through cooling systems). Based on
7 information in the GEIS, the Commission found that

8 These conflicts have not been found to be a problem at operating nuclear
9 power plants with once-through heat dissipation systems.

10 The NRC staff has not identified any new and significant information during its
11 independent review of the Entergy ER, the site visit, the scoping process, or the
12 evaluation of other available information, including the NPDES permit for VYNPS, or
13 discussion with the VDEC. Therefore, the NRC staff concludes that there would be no
14 impacts of water-use conflicts for plants with once-through cooling systems during the
15 renewal term beyond those discussed in the GEIS.

- 16
- 17 • Accumulation of contaminants in sediments or biota. Based on information in the
18 GEIS, the Commission found that

19 Accumulation of contaminants has been a concern at a few nuclear power
20 plants but has been satisfactorily mitigated by replacing copper alloy
21 condenser tubes with those of another metal. It is not expected to be a
22 problem during the license renewal term.

23 The NRC staff has not identified any new and significant information during its
24 independent review of the Entergy ER, the site visit, the scoping process, or the
25 evaluation of available information. Therefore, the NRC staff concludes that there would
26 be no impacts of accumulation of contaminants in sediments or biota during the renewal
27 term beyond those discussed in the GEIS.

- 28
- 29 • Entrainment of phytoplankton and zooplankton. Based on information in the GEIS,
30 the Commission found that

31 Entrainment of phytoplankton and zooplankton has not been found to be a
32 problem at operating nuclear power plants and is not expected to be a
33 problem during the license renewal term.

34 The NRC staff has not identified any new and significant information during its
35 independent review of the Entergy ER, the site visit, the scoping process, the review of
36 monitoring programs, or the evaluation of other available information. Therefore, the

Environmental Impacts of Operation

1 NRC staff concludes that there would be no problems associated with the entrainment of
2 phytoplankton and zooplankton during the renewal term beyond those discussed in the
3 GEIS.

- 4
- 5 • Cold shock. Based on information in the GEIS, the Commission found that

6

7 Cold shock has been satisfactorily mitigated at operating nuclear plants with
8 once-through cooling systems, has not endangered fish populations or been
9 found to be a problem at operating nuclear power plants with cooling towers
10 or cooling ponds, and is not expected to be a problem during the license
11 renewal term.

12

13 The NRC staff has not identified any new and significant information during its
14 independent review of the Entergy ER, the site visit, the scoping process, or the
15 evaluation of other available information. Therefore, the staff concludes that there are
16 no impacts of cold shock during the renewal term beyond those discussed in the GEIS.

- 17
- 18 • Thermal plume barrier to migrating fish. Based on information in the GEIS, the
19 Commission found that

20

21 Thermal plumes have not been found to be a problem at operating nuclear
22 power plants and are not expected to be a problem during the license
23 renewal term.

24

25 The NRC staff has not identified any new and significant information during its
26 independent review of the Entergy ER, the site visit, the scoping process, or the
27 evaluation of other available information. During the course of the NRC staff review, a
28 number of comments were raised by members of the public and public interest groups
29 on the impact of the thermal plume during license renewal from VYNPS on migratory fish
30 species in the Connecticut River. The staff examined the information provided in the
31 comments as well as other sources to determine if it represents new and significant
32 information. The staff's evaluation is provided in Section 4.7. The NRC staff, based on
33 the evaluation in Section 4.7, concludes that there would be no impacts of thermal plume
34 barriers on migrating fish during the renewal term beyond those discussed in the GEIS.

- 35
- 36 • Distribution of aquatic organisms. Based on information in the GEIS, the
37 Commission found that

38

39 Thermal discharge may have localized effects but is not expected to affect
40 the larger geographical distribution of aquatic organisms.

Environmental Impacts of Operation

The NRC staff has not identified any new and significant information during its independent review of the Entergy ER, the site visit, the scoping process, the review of monitoring programs, or the evaluation of other available information. Therefore, the NRC staff concludes that there would be no impacts on the distribution of aquatic organisms during the renewal term beyond those discussed in the GEIS.

- Premature emergence of aquatic insects. Based on information in the GEIS, the Commission found that

Premature emergence has been found to be a localized effect at some operating nuclear power plants but has not been a problem and is not expected to be a problem during the license renewal term.

The NRC staff has not identified any new and significant information during its independent review of the Entergy ER, the site visit, the scoping process, or the evaluation of other available information. Therefore, the NRC staff concludes that there would be no impacts on premature emergence of aquatic insects during the renewal term beyond those discussed in the GEIS.

- Gas supersaturation (gas bubble disease). Based on information in the GEIS, the Commission found that

Gas supersaturation was a concern at a small number of operating nuclear power plants with once-through cooling systems but has been satisfactorily mitigated. It has not been found to be a problem at operating nuclear power plants with cooling towers or cooling ponds and is not expected to be a problem during the license renewal term.

The NRC staff has not identified any new and significant information during its independent review of the Entergy ER, the site visit, the scoping process, or the evaluation of other available information. Therefore, the NRC staff concludes that there would be no impacts of gas supersaturation during the renewal term beyond those discussed in the GEIS.

- Low dissolved oxygen in the discharge. Based on information in the GEIS, the Commission found that

Low dissolved oxygen has been a concern at one nuclear power plant with a once-through cooling system but has been effectively mitigated. It has not been found to be a problem at operating nuclear power plants with cooling towers or cooling ponds and is not expected to be a problem during the license renewal term.

Environmental Impacts of Operation

1 The NRC staff has not identified any new and significant information during its
2 independent review of the Entergy ER, the site visit, the scoping process, the review of
3 monitoring programs, or the evaluation of other available information. Therefore, the
4 NRC staff concludes that there would be no impacts of low dissolved oxygen during the
5 renewal term beyond those discussed in the GEIS.

- 6
- 7 • Losses from predation, parasitism, and disease among organisms exposed to
8 sublethal stresses. Based on information in the GEIS, the Commission found that

9

10 These types of losses have not been found to be a problem at operating
11 nuclear power plants and are not expected to be a problem during the license
12 renewal term.

13

14 The NRC staff has not identified any new and significant information during its
15 independent review of the Entergy ER, the site visit, the scoping process, or the
16 evaluation of other available information. Therefore, the NRC staff concludes that there
17 would be no impacts of losses from predation, parasitism, and disease among
18 organisms exposed to sublethal stresses during the renewal term beyond those
19 discussed in the GEIS.

- 20
- 21 • Stimulation of nuisance organisms. Based on information in the GEIS, the
22 Commission found that

23

24 Stimulation of nuisance organisms has been satisfactorily mitigated at the
25 single nuclear power plant with a once-through cooling system where
26 previously it was a problem. It has not been found to be a problem at
27 operating nuclear power plants with cooling towers or cooling ponds and is
28 not expected to be a problem during the license renewal term.

29

30 The NRC staff has not identified any new and significant information during its
31 independent review of the Entergy ER, the site visit, the scoping process, or the
32 evaluation of other available information. Therefore, the NRC staff concludes that there
33 would be no impacts from stimulation of nuisance organisms during the renewal term
34 beyond those discussed in the GEIS.

- 35
- 36 • Entrainment of fish and shellfish in early life stages (cooling-tower-based heat
37 dissipation). Based on information in the GEIS, the Commission found that

38

39 Entrainment of fish has not been found to be a problem at operating nuclear
40 power plants with this type of cooling system and is not expected to be a
41 problem during the license renewal term.

Environmental Impacts of Operation

VYNPS has the capability to operate using once-through or closed-cycle cooling or an intermediate condition called the hybrid mode. For closed-cycle cooling, the issue of entrainment is considered a Category 1 issue, not requiring a site-specific analysis but rather a determination of whether or not there is new and significant information that calls into question the conclusions of the staff's GEIS. However, since VYNPS does employ once-through cooling, at least for a portion of the year, the issue of entrainment does require a site-specific analysis as a Category 2 issue. The analysis is presented in Section 4.1.2 of this document and provides a site-specific assessment of impact for the issue of entrainment for the station cooling system under closed-cycle, hybrid, and once-through modes of operation.

- Impingement of fish and shellfish (cooling-tower-based heat dissipation). Based on information in the GEIS, the Commission found that

The impingement of fish and shellfish has not been found to be a problem at operating nuclear power plants with this type of cooling system and is not expected to be a problem during the license renewal term.

VYNPS has the capability to operate using once-through or closed-cycle cooling or an intermediate condition called the hybrid mode. For closed-cycle cooling, the issue of impingement is considered a Category 1 issue, not requiring a site-specific analysis but rather a determination of whether or not there is new and significant information that calls into question the conclusions of the staff's GEIS. However, since VYNPS does employ once-through cooling, at least for a portion of the year, the issue of impingement does require a site-specific analysis as a Category 2 issue. The analysis is presented in Section 4.1.3 of this document and provides a site-specific assessment of impact for the issue of impingement for the station cooling system under closed-cycle, hybrid, and once-through modes of operation.

- Heat shock (cooling-tower-based heat dissipation). Based on information in the GEIS, the Commission found that

Heat shock has not been found to be a problem at operating nuclear power plants with this type of cooling system and is not expected to be a problem during the license renewal term.

VYNPS has the capability to operate using once-through or closed-cycle cooling or an intermediate condition called the hybrid mode. For closed-cycle cooling, the issue of heat shock is considered a Category 1 issue, not requiring a site-specific analysis but rather a determination of whether or not there is new and significant information that calls into question the conclusions of the staff's GEIS. However, since VYNPS does employ once-through cooling, at least for a portion of the year, the issue of heat shock does require

Environmental Impacts of Operation

1 a site-specific analysis as a Category 2 issue. The analysis is presented in Section 4.1.4 of
2 this document and provides a site-specific assessment of impact for the issue of heat shock
3 for the station cooling system under closed-cycle, hybrid, and once-through modes of
4 operation.

- 5
- 6 • Cooling tower impacts on crops and ornamental vegetation. Based on information in
7 the GEIS, the Commission found that

8

9 Impacts from salt drift, icing, fogging, or increased humidity associated with
10 cooling tower operation have not been found to be a problem at operating
11 nuclear power plants and are not expected to be a problem during the
12 renewal term.

13

14 The NRC staff has not identified any new and significant information during its
15 independent review of the Entergy ER, the staff's site visit, the scoping process, or the
16 evaluation of other available information. Therefore, the NRC staff concludes that there
17 are no cooling tower impacts on crops and ornamental vegetation during the renewal
18 term beyond those discussed in the GEIS.

- 19
- 20 • Cooling tower impacts on native plants. Based on information in the GEIS, the
21 Commission found that

22

23 Impacts from salt drift, icing, fogging, or increased humidity associated with
24 cooling tower operation have not been found to be a problem at operating
25 nuclear power plants and are not expected to be a problem during the license
26 renewal term.

27

28 The NRC staff has not identified any new and significant information during its
29 independent review of the Entergy ER, the staff's site visit, the scoping process, or the
30 evaluation of other available information. Therefore, the NRC staff concludes that there
31 are no cooling tower impacts on native vegetation during the renewal term beyond those
32 discussed in the GEIS.

- 33
- 34 • Microbiological organisms (occupational health). Based on information in the GEIS,
35 the Commission found that

36

37 Occupational health impacts are expected to be controlled by continued
38 application of accepted industrial hygiene practices to minimize worker
39 exposures.

40

41 The NRC staff has not identified any new and significant information during its
42 independent review of the Entergy ER, the staff's site visit, the scoping process, or the

Environmental Impacts of Operation

evaluation of other available information. Therefore, the NRC staff concludes that there are no impacts of microbiological organisms during the renewal term beyond those discussed in the GEIS.

- Noise. Based on information in the GEIS, the Commission found that

Noise has not been found to be a problem at operating plants and is not expected to be a problem at any plant during the license renewal term.

The NRC staff has not identified any new and significant information during its independent review of the Entergy ER, the site visit, the scoping process, or the evaluation of other available information. Therefore, the NRC staff concludes that there would be no impacts of noise during the renewal term beyond those discussed in the GEIS.

The Category 2 issues related to cooling system operation during the renewal term that are applicable to VYNPS are discussed in the sections that follow and are listed in Table 4-2.

Table 4-2. Category 2 Issues Applicable to the Operation of the VYNPS Cooling System During the Renewal Term

ISSUE-10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Section	10 CFR Part 51.53(a)(3)(ii) Subparagraph	SEIS Section
SURFACE WATER QUALITY, HYDROLOGY, AND USE			
Water use conflicts (plants with cooling ponds or cooling towers using make-up water from a small river with low flow)	4.3.2.1 4.4.2.1	A	4.1.1
AQUATIC ECOLOGY			
Entrainment of fish and shellfish in early life stages	4.2.2.1.2	B	4.1.2
Impingement of fish and shellfish	4.2.2.1.3	B	4.1.3
Heat shock	4.2.2.1.4	B	4.1.4
HUMAN HEALTH			
Microbiological organisms (public health) (plants using lakes or canals, or cooling towers or cooling ponds that discharge to a small river)	4.3.6	G	4.1.5

1 **4.1.1 Water Use Conflicts (Make-Up from a Small River)**

2
3 For power plants with cooling ponds or cooling towers using make-up water from a small river
4 with low flow, i.e., less than $3.15 \times 10^{12} \text{ ft}^3/\text{yr}$ threshold value in 10 CFR 51.53(3)(ii)(A), water
5 use conflicts are considered a Category 2 issue that requires plant-specific assessment before
6 license renewal.

7
8 Cooling water withdrawn from the Connecticut River (at Vernon Pool) can be circulated through
9 the VYNPS system in one of three modes of operation, including closed-cycle, open-cycle
10 (once-through cooling), or hybrid-cycle. Category 2 applies to the VYNPS because the
11 Connecticut River has an average daily flow of about 10,500 cubic feet per second (cfs)
12 ($3.3 \times 10^{11} \text{ ft}^3/\text{yr}$), based on flows measured from 1944 to 1988 (Entergy 2006a) and about
13 11,101 cfs ($3.5 \times 10^{11} \text{ ft}^3/\text{yr}$), based on flows measured from 2000 to 2005 (Normandeau 2001,
14 2002, 2003, 2004b, 2005; DeWald 2006). Vernon Pool is an approximately 25-mi long, 2250-ac
15 impoundment created by the construction of the Vernon Dam, less than a mile downstream of
16 the plant. The dam facility, owned and operated by TransCanada, is required to maintain a
17 minimum sustained flow of 1250 cfs. The surface elevation of the pool fluctuates as much as
18 8 ft due to operations at upstream and downstream dams and runoff inflow. The maximum
19 depth of the pool near Vernon Dam is about 40 ft (Entergy 2006a).

20
21 According to the ER, 5000 gpm (11.1 cfs) of the 360,000 gpm (802.1 cfs) of water withdrawn
22 from the Connecticut River for condenser cooling would be lost to evaporation (as an upper
23 bound). This loss represents a reduction in flow of less than 0.10 percent of the average daily
24 flow. It also represents a reduction in flow of 0.37 percent of the low median monthly flow
25 (3050 cfs)^(a), 0.73 percent of the flow under drought conditions (1523 cfs)^(b), and 0.89 percent of
26 the minimum sustained flow requirement for Vernon Dam (1250 cfs). These values are well
27 below the Vermont Water Quality Standards criterion of 5 percent for Class B Water
28 Management Type 1 waters (constituting aquatic biota, wildlife, and aquatic habitat). Thus,
29 impacts to the flow of the Connecticut River through Vernon Pond due to consumptive water
30 use are not considered significant.

31
32 The NRC staff independently reviewed the Entergy ER, visited the site, and reviewed the
33 VYNPS NPDES permit, and other reports and has evaluated the consumptive water use

(a) Low median monthly flow is the median monthly flow for the month having the lowest median monthly flow (Vermont Water Quality Standards, Section 1-01.B.24).

(b) Drought flow is referred to as 7Q10 in Vermont Water Quality Standards, Section 3-01.C.1.b, and is the 7-day average low flow over a 10-year return period, adjusted to nullify any effects of artificial flow regulation, that has a 10 percent chance of occurring in a given year.

Environmental Impacts of Operation

associated with VYNPS operations (due to evaporative water loss). Based on this information, the staff concludes that the potential impacts of water use conflicts are SMALL and no additional mitigation is warranted.

4.1.2 Entrainment of Fish and Shellfish in Early Life Stages

For plants with once-through cooling systems, the entrainment of fish and shellfish in early life stages into cooling water systems associated with nuclear power plants is considered a Category 2 issue, which requires a site-specific assessment before license renewal. VYNPS operates in a closed-cycle mode part of the year during which time entrainment is categorized as a Category 1 issue. The hybrid-cycle mode, not discussed in the GEIS (NRC 1996), is neither defined as a Category 1 or 2 issue. Conservatively, for VYNPS, the NRC staff considered entrainment as a Category 2 issue providing a site-specific analysis of entrainment for the entire year under all three operating modes. To perform this assessment, the NRC staff reviewed the applicant's ER (Entergy 2006a) and related documents, including the Clean Water Act (CWA) Section 316 demonstrations (Aquatec 1978, 1990; Normandieu 2004), and visited the VYNPS site. The staff also reviewed the applicant's State of Vermont NPDES Permit No. VT0000264, issued on June 9, 2003, and in force until March 31, 2006 (VDEC 2003); the Final Amended NPDES Permit No. VT0000264, issued on March 30, 2006 (VDEC 2006a); the fact sheet related to the amendment of the NPDES permit (VDEC 2006b); and the application for the NPDES permit renewal (Entergy 2005a).

Section 316(b) of the CWA requires that the location, design, construction, and capacity of the cooling water intake structures reflect the best technology available for minimizing adverse environmental impacts (Title 33, Section 1326, of the *United States Code* (33 USC 1326)). Entrainment of fish and shellfish into the cooling water system is a potential adverse environmental impact that can be minimized by use of the best available technology.

On July 9, 2004, the EPA published a final rule in the *Federal Register* (EPA 2004) that addresses cooling water intake structures at existing power plants, such as VYNPS, where flow levels exceed a minimum threshold value of 50 million gpd. The rule is Phase II in the EPA's development of CWA 316(b) regulations that establish national requirements applicable to the location, design, construction, and capacity of cooling water intake structures at existing facilities that exceed the threshold value for water withdrawals. The national requirements, which are implemented through the NPDES permits, minimize the adverse environmental impacts associated with the continued use of the intake systems. Licensees are required to demonstrate compliance with the Phase II performance standards at the time of renewal of their NPDES permit. As part of the NPDES renewal, licensees may be required to alter the intake structure, redesign the cooling system, modify station operation, or take other mitigative measures to comply with this regulation. The new performance standards are designed to significantly reduce entrainment losses due to water withdrawals associated with cooling water

Environmental Impacts of Operation

1 intake structures used for power production. Any additional site-specific mitigation required as a
2 result of the 316(b) Phase II reviews at VYNPS would result in less impact from entrainment
3 during the license renewal period.

4
5 The VYNPS withdraws a maximum of 518 million gpd (360,000 gpm or 802 cfs) during once-
6 through operation to a minimum of 14.4 million gpd (10,000 gpm or 22 cfs) during closed-cycle
7 operation. During 2004, the monthly average daily river discharge at Vernon Dam ranged from
8 3967 cfs in October to 23,570 cfs in April. The lowest daily discharge was 1757 cfs on July 7,
9 while the highest daily flow was 50,618 cfs on April 2 (Normandeau 2005). The VYNPS
10 operates in a closed- or hybrid-cycle mode during the warmer months of the year and, at times,
11 may also operate these modes during the cooler months.

12
13 Entrained fish eggs and larvae experience thermal stress and mechanical and hydraulic forces
14 during transport through a plant's cooling system. In a study of the Haddam Neck Plant, a
15 nuclear plant with once-through cooling that formerly operated on the lower Connecticut River,
16 Marcy (2004c (1976c) and references cited therein) found mechanical damage to be the main
17 cause of entrainment mortality, while thermal shock was responsible for only about 20 percent
18 of the mortality. While some entrainment survival occurs, 100 percent mortality is normally
19 assumed as a conservative estimate of entrainment losses for all operational modes. When
20 ichthyoplankton are at their peak in the Connecticut River (e.g., late spring through early
21 summer), VYNPS is generally operating in an open-cycle or hybrid mode. The NPDES permit
22 requires larval fish sampling to be done weekly during this period (Normandeau 2005).

23
24 The portion of Vernon Pool near VYNPS was found not to be a good fish spawning area due to
25 daily water level fluctuations, a steep shoreline, and a silty sand substrate. Therefore, the
26 amount of ichthyoplankton entrained in the area would be expected to be limited. Overall,
27 densities of ichthyoplankton near the VYNPS intake were <1 fish/m³, which were much lower
28 than densities in littoral areas estimated by Aquatec (1990). For example, minnow densities
29 near the VYNPS intake were <0.6 larvae/m³, whereas densities in shallow, slow-moving
30 nearshore areas were as high as 3000/m³ (Aquatec 1990). Monitoring results indicate that
31 larval fish densities are low in the VYNPS area and the impact of entrainment has been minimal
32 (Entergy 2006a).

33
34 Table 4-3 presents some of the results of entrainment collections that have been made in the
35 Connecticut River in the vicinity of the VYNPS intake since 1988. Entrainment collections at
36 VYNPS are generally made from early May through early to mid July each year, as dictated by
37 the NPDES permit. In general, the common warmwater species that are resident within Vernon
38 Pool were predominant in entrainment collections. These included the spottail shiner (*Notropis*
39 *hudsonius*), white perch (*Morone americana*), and centrarchids. No Atlantic salmon (*Salmo*
40 *salar*) and only one American shad (*Alosa sapidissima*) have been collected in entrainment
41 samples.

Environmental Impacts of Operation

Table 4-3. Percentages (and Numbers) of Fish Eggs and Larvae Entrained at VYNPS

Species	Collection Period			
	1988 and 1990-1997	2001	2003	2004
Common carp (<i>Cyprinus carpio</i>)	0.3 (18) ^(a)	0.2 (3)	2.2 (27)	0.5 (5)
Spottail shiner (<i>Notropis hudsonius</i>)	0.03 (2)	57.9 (978)	71.6 (875)	25.4 (269)
<i>Notropis</i> spp.	49.6 ^(b) (2850)	0.0 (0)	0.0 (0)	0.0 (0)
Cyprinidae	13.7 ^(b) (788)	0.0 (0)	0.0 (0)	0.0 (0)
White sucker (<i>Catostomus commersoni</i>)	0.02 (1)	37.9 (640)	0.2 (2)	1.0 (11)
White perch (<i>Morone americana</i>)	20.7 (1191)	1.8 (31)	14.6 (178)	3.4 (36)
Sunfish (<i>Lepomis</i> spp.)	10.9 (628)	1.8 ^(c) (31)	8.2 ^(c) (100)	68.7 (726)
Largemouth bass (<i>Micropterus salmoides</i>)	0.07 (4)	0.0 ^(d) (0)	0.0 ^(d) (0)	0.0 (0)
Yellow perch (<i>Perca flavescens</i>)	4.2 (244)	0.1 (2)	3.2 (39)	0.5 (5)
Walleye (<i>Sander vitreus</i>)	0.14 (8)	0.1 (2)	0.1 (1)	0.2 (2)
Other species (including unidentifiable fishes)		0.1 ^(e) (2)	0.0 (0)	0.3 ^(e) (3)
Total	100 (5747)	100 (1690)	100 (1222)	100 (1057)

(a) The percentage and the total number collected followed by the number entrained in parentheses for each species during the collection period.

(b) Based on entrainment sample identifications done in the subsequent years and fish species known from lower Vernon Pool, most individuals identified as only *Notropis* spp. or Cyprinidae were probably spottail shiners.

(c) Listed as Centrarchidae and therefore may also include some largemouth bass.

(d) See footnote (c). Likely some largemouth bass eggs and larvae were entrained.

(e) Other species comprised almost entirely of the tessellated darter (*Etheostoma olmstedii*).

Sources: Normandeau 1999; VYNPS and Normandeau 2002; Entergy and Normandeau 2004; Normandeau 2005

To interpret the impacts of entrainment on the fish community, entrainment losses must be compared to the distribution, abundance, and life cycles of the populations and species that occur near VYNPS. The ultimate impact of entrainment losses must be evaluated in terms of a system's resiliency (i.e., environmental stability, productivity, population compensation, and ecological and economic importance of the individual species) (Noguchi et al. 1985). When assessing the significance of entrainment, entrainment losses need to be weighed against the losses that occur from natural mortality of fish eggs and larvae. For example, the survival from egg to adult for the American shad is about 0.001 percent (Marcy 2004b (1976b)). Based on riverine and entrainment collections of resident and anadromous fish, which have been ongoing since before VYNPS began commercial operations (e.g., Aquatec 1978, 1990; Entergy and Normandeau 2004; Normandeau 2005), the applicant stated that no observable adverse impacts to any fish species or to the overall fish community of Vernon Pool due entrainment by VYNPS has been demonstrated (Entergy 2006a).

Based on the results of the extensive sampling program conducted by the applicant, and the utilization of the closed- or hybrid-cycle mode during much of the spawning season, the NRC staff has determined that the potential impacts of entrainment of fish and shellfish by VYNPS during the 20-year renewal period would be SMALL and no additional mitigation is warranted. However, under the provisions of the CWA 316(b) Phase II regulations, the VDEC may impose further restrictions or require modifications to the cooling system to reduce the impact of entrainment.

4.1.3 Impingement of Fish and Shellfish

For power plants with once-through cooling systems, the impingement of fish and shellfish on screens associated with plant cooling systems is considered a Category 2 issue, which requires a site-specific assessment before license renewal. VYNPS operates in a closed-cycle mode part of the year, during which time impingement is categorized as a Category 1 issue. The hybrid-cycle mode, not discussed in the GEIS (NRC 1996), is neither defined as a Category 1 or 2 issue. Conservatively, for VYNPS, the NRC staff considered impingement as a Category 2 issue providing a specified analysis of impingement for the entire year under all three operating modes. To perform this evaluation, the NRC staff reviewed the applicant's ER (Entergy 2006a) and related documents, including the Clean Water Act (CWA) Section 316 demonstrations (Aquatec 1978, 1990; Normandeau 2004), and visited the VYNPS site. The staff also reviewed the applicant's State of Vermont NPDES Permit No. VT0000264, issued on June 9, 2003, and in force until March 31, 2006 (VDEC 2003); the Final Amended NPDES Permit No. VT0000264, issued on March 30, 2006 (VDEC 2006a); the fact sheet related to the amendment of the NPDES permit (VDEC 2006b); and the application for the NPDES permit renewal (Entergy 2005a).

Impacts of existing cooling water systems, including the impacts of impingement, are regulated under the provisions of the CWA as described in Section 4.1.2. Section 4.1.2 also includes a

Environmental Impacts of Operation

1 discussion of Section 316(b) requirements, which are also relevant to impingement. The new
2 performance standards are designed to significantly reduce impingement losses resulting from
3 plant operation. Any site-specific mitigation would result in less impact due to continued plant
4 operation.

5 As part of the NPDES requirements, VYNPS is required to monitor fish impingement. Routine
6 impingement sampling is conducted at VYNPS from April 1 through June 15 and from August 1
7 through October 31. Additionally, limits are established by the State of Vermont for the number
8 of American shad and Atlantic salmon (*Salmo salar*) that can be impinged. The impingement
9 limit for Atlantic salmon is set at 0.1 percent of the estimated smolt-equivalents (estimated
10 number of smolts from a population that successfully emigrate from a specified area) migrating
11 past VYNPS. If this limit is exceeded, the plant must run in a closed cycle until June 15. The
12 American shad impingement limit is set at one impinged shad for each adult shad that passes
13 the Vernon Dam fishway and/or is transported by State or Federal fisheries personnel upstream
14 of Vernon Dam (Aquatec 1990). Impingement numbers below those established for the two
15 anadromous fish species are considered by the Environmental Advisory Committee (comprised
16 of the Vermont Department of Environmental Conservation, Vermont Department of Fish and
17 Wildlife, New Hampshire Department of Environmental Services, New Hampshire Department
18 of Fish and Game, Massachusetts Department of Environmental Protection, Massachusetts
19 Division of Fish and Wildlife, and the U.S. Fish and Wildlife Service (FWS) Coordinator of the
20 Connecticut River Anadromous Fish Program) to be impingement losses that are not adverse to
21 the populations of these species (Entergy 2006a). To date, the NPDES limits established for
22 Atlantic salmon and American shad have not been exceeded.

23 During the initial 316 demonstration (Aquatec 1978), an average of 23 fish per day were
24 impinged during 685 days of once-through operation. The fish passages at Turners Falls and
25 Vernon Dam were not in place until the early 1980s, therefore no Atlantic salmon or American
26 shad were impinged during this period. Between 1981 and 1989, 26 fish were impinged per day
27 (Aquatec 1990). Over 80 percent were small sunfishes, rock bass, minnows, and yellow perch.
28 During this period, 59 juvenile Atlantic salmon and only one American shad were impinged
29 (Aquatec 1990).

30 Table 4-4 presents some of the results of impingement collections that have been made at
31 VYNPS since 1988. Impingement collections at VYNPS are generally made from April 1
32 through June 15 and August 1 through October 31 each year, as dictated by NPDES permit
33 stipulations. In general, the common warmwater species that are resident within Vernon Pool
34 were predominant in impingement collections. These included sunfish, rock bass, and yellow
35 perch. The numbers of American shad and Atlantic salmon impinged at VYNPS were lower
36 than the yearly NPDES permit limits set for these species. For example, 25 American shad and
37 9 Atlantic salmon were impinged in 2001. The permit limits were set at 1666 American shad and
38 231 Atlantic salmon (VYNPS and Normandeau 2002). In 2003, 13 American shad and 28
39 Atlantic salmon were impinged, while the permit limits for the year were set at 1140 and 364,
40 41 42

Environmental Impacts of Operation

Table 4-4. Percentages (and Numbers) of Fish Species Impinged at VYNPS^(a)

Species	Collection Period			
	1988 and 1990-1997	2001	2003	2004
Sea lamprey (<i>Petromyzon marinus</i>)	0.9 (130) ^(b)	34.4 (241)	0.2 (2)	0.0 (0)
American shad (<i>Alosa sapidissima</i>)	2.6 (387)	3.6 (25)	1.1 (13)	30.8 (73)
Atlantic salmon (<i>Salmo salar</i>)	1.4 (202)	1.3 (9)	2.5 (28)	0.0 (0)
Chain pickerel (<i>Esox niger</i>)	0.2 (31)	0.4 (3)	1.0 (11)	0.8 (2)
Golden shiner (<i>Notemigonus crysoleucas</i>)	1.1 (161)	2.1 (15)	0.6 (7)	0.4 (1)
Spottail shiner (<i>Notropis hudsonius</i>)	7.7 (1139)	0.3 (2)	0.8 (9)	2.1 (5)
Yellow bullhead (<i>Ameiurus natalis</i>)	1.5 (227)	0.0 (0)	3.4 (39)	0.4 (1)
Rock bass (<i>Ambloplites rupestris</i>)	10.8 (1599)	4.7 (33)	9.5 (108)	9.7 (23)
Pumpkinseed (<i>Lepomis gibbosus</i>)	5.8 (853)	1.7 (12)	14.2 (162)	2.5 (6)
Bluegill (<i>Lepomis macrochirus</i>)	19.9 (2937)	28.7 (201)	32.6 (372)	28.3 (67)
Unidentified sunfish (<i>Lepomis</i> spp.)	20.1 (2967)	0.0 (0)	0.0 (0)	0.0 (0)
Smallmouth bass (<i>Micropterus dolomieu</i>)	1.9 (279)	1.0 (7)	2.4 (27)	3.8 (9)
Largemouth bass (<i>Micropterus salmoides</i>)	0.9 (134)	0.6 (4)	5.1 (58)	1.3 (3)
Black crappie (<i>Pomoxis nigromaculatus</i>)	0.01 (1)	1.7 (12)	11.0 (126)	4.2 (10)
Yellow perch (<i>Perca flavescens</i>)	15.2 (2247)	18.3 (128)	15.0 (171)	8.4 (20)
Other species (including unidentifiable fishes)	28.3 (4184)	1.1 (8)	0.8 (9)	7.2 (17)
Totals	100 (14,778)	100 (700)	100 (1142)	100 (237)

(a) Data presented represent a portion of the impingement data collected at this facility.

(b) The percent of total number impinged followed by the total number impinged in parentheses for each species during the collection period.

Sources: Normandeau 1999, 2005; VYNPS and Normandeau 2002; Entergy and Normandeau 2004;

Environmental Impacts of Operation

1 respectively (Entergy and Normandeau 2004). In 2004, 73 American shad and no Atlantic
2 salmon were impinged. The NPDES permit impingement limits for 2004 were set at 1005
3 American shad and 252 Atlantic salmon (Normandeau 2005).

4
5 No observable adverse impacts to any fish species or to the overall fish community of Vernon
6 Pool due impingement at VYNPS has been demonstrated, based on riverine and impingement
7 collections of resident and anadromous fish, which have been ongoing since before VYNPS
8 began commercial operations (Aquatec 1978, 1990; Entergy and Normandeau 2004;
9 Normandeau 2005; Entergy 2006a).

10
11 Based on the results of the extensive sampling program conducted by the applicant, and the
12 utilization of closed- or hybrid-cycle modes during much of the year, the NRC staff has
13 determined that the potential impacts of impingement of fish and shellfish by VYNPS during the
14 20-year renewal period would be SMALL and no additional mitigation is warranted. However,
15 under the provisions of the CWA 316(b) Phase II regulations, the VDEC may impose further
16 restrictions or require modifications to the cooling system to reduce the impact of impingement.
17

18 **4.1.4 Heat Shock**

19
20 Heat shock can be defined as acute thermal stress caused by exposure to a sudden elevation
21 of water temperature that adversely affects the metabolism and behavior of fish and can lead to
22 death. Heat shock is most likely to occur when an off-line unit returns to service or when a
23 station has a discharge canal. For plants with once-through cooling systems, the impacts of
24 heat shock are listed as a Category 2 issue and require plant-specific evaluation before license
25 renewal. Impacts on fish and shellfish resources resulting from heat shock are a Category 2
26 issue because of continuing concerns about acute thermal-discharge impacts and the possible
27 need to modify thermal discharges in the future in response to changing environmental
28 conditions (NRC 1996). VYNPS operates in a closed-cycle mode part of the year during which
29 time heat shock is categorized as a Category 1 issue. The hybrid-cycle mode, not discussed in
30 the GEIS (NRC 1996), is neither defined as a Category 1 or 2 issue. Conservatively, for
31 VYNPS, the NRC staff considered heat shock as a Category 2 issue, providing a specified
32 analysis of heat shock for the entire year under all three operating modes.

33
34 Information considered by the NRC staff during its assessment includes (1) the type of cooling
35 system (e.g., once-through, closed-cycle, or cooling lake) and (2) evidence of CWA
36 Section 316(a) variance or equivalent State documentation. To perform this evaluation, the
37 NRC staff reviewed the applicant's ER (Entergy 2006a) and related documents, including the
38 Clean Water Act (CWA) Section 316 demonstrations (Aquatec 1978, 1990; Normandeau 2004),
39 and visited the VYNPS site. The staff also reviewed the applicant's State of Vermont NPDES
40 Permit No. VT0000264, issued on June 9, 2003, and in force until March 31, 2006
41 (VDEC 2003); the Final Amended NPDES Permit No. VT0000264, issued on March 30, 2006

Environmental Impacts of Operation

1 (VDEC 2006a); the fact sheet related to the amendment of the NPDES permit (VDEC 2006b);
2 and the application for the NPDES permit renewal (Entergy 2005a).

3
4 For coldwater species, which are generally stenothermal, the physiological effects from
5 temperature are often the main factors controlling their distribution. Ambient temperatures of
6 80.6°F often exceed the lethal temperature of coldwater species (Cherry et al. 1975). When
7 Connecticut Yankee, a nuclear power plant with once-through cooling that formerly operated on
8 the Lower Connecticut River was operational, most fish left the discharge canal when
9 temperatures reached about 95°F, but some would return even after a temperature drop of only
10 1.8°F (Marcy 2004a (1976a)). There was no indication that the fish that inhabited the discharge
11 canal during the warmer seasons suffered any mortality due to increased water temperatures
12 (Marcy 2004a (1976a)). Fish were able to leave the area as temperatures approached their
13 upper limits of tolerance. However, some species such as pumpkinseed, white perch, golden
14 shiner, white catfish (*Ameiurus catus*), and brown bullhead (*A. nebulosus*) were collected in the
15 discharge canal at a temperature of 104°F, while the common carp and spottail shiner were
16 collected at a maximum canal temperature of 102.6°F (Marcy 2004a (1976a)).

17
18 For the initial 316 demonstration (Aquatec 1978), brown trout (*Salmo trutta*) were held in live
19 cages in the VYNPS discharge plume. All of the fish were able to survive 10 days of rapidly and
20 widely fluctuating temperatures of 15°F or more within 10 minutes when ambient temperatures
21 did not exceed 60°F, which is generally the temperature that occurs in the October 15 to
22 May 15 period when VYNPS operates in an open cycle. American eels can survive short-term
23 thermal shocks, as demonstrated by individuals having apparently survived elevated
24 Connecticut Yankee discharge channel temperatures of 104°F (American Eel Plan
25 Development Team 2000).

26
27 Near the VYNPS discharge, heated effluent during the warmer summer months is about 80 to
28 90°F, with a very infrequent worst-case maximum of around 100°F (Normandeau 2004).
29 Table 4-5 summarizes thermal preferences and tolerances for several of the more common
30 warmwater species that are resident in the VYNPS area.

31
32 The NRC staff has determined that the potential for heat shock during the renewal term is
33 unlikely because of the design, location, and operation of VYNPS. The station discharges via a
34 shoreline surface discharge to the Connecticut River, a relatively large body of water. Vernon
35 Pool contains sufficient thermal refugia for fish even during the late summer or early fall when
36 there is high ambient river water temperatures. Station operation historically has resulted in a
37 gradual increase in cooling water discharge temperatures during power ascension, thereby
38 avoiding a rapid and possibly lethal increase in water temperatures. Similar operating
39 procedures are expected during the renewal term. Finally, heat shock has not been a problem
40 historically at VYNPS. No instances of heat shock-related mortality to fish in Vernon Pool have
41 been reported during the past years of commercial operation. Again, it is unlikely that heat
42 shock-related mortalities would occur during the renewal term. Therefore, the NRC staff has

Environmental Impacts of Operation

Table 4-5. Thermal Preferences and Tolerances of Warmwater Species That Occur in the VYNPS Area

	Species	Thermal Preference	Spawning Temperature	Upper Tolerance Limit
4	Common carp (<i>Cyprinus carpio</i>)	68°F	65-68°F	96°F
5	White sucker (<i>Catostomus commersoni</i>)	57°F	50°F	82°F
6	Bluegill (<i>Lepomis macrochirus</i>)	60-80°F	67°F	92.8°F
7	Pumpkinseed (<i>Lepomis gibbosus</i>)	60-80°F	68°F	95°F
8	Largemouth bass (<i>Micropterus salmoides</i>)	79-81°F	66°F	90.5°F
9	Smallmouth bass (<i>Micropterus dolomieu</i>)	68-0°F	62°F	90.5°F
10	Walleye (<i>Sander vitreus</i>)	77°F	50°F	84°F
11	Yellow perch (<i>Perca flavescens</i>)	63°F	45-50°F	91.4°F
12	Sources: AEC 1972; Marcy 2004a (1976a)			

determined that the impact related to heat shock to fish and shellfish during the renewal term would be SMALL and no additional mitigation is warranted.

4.1.5 Microbiological Organisms (Public Health)

The effects of microbiological organisms on human health are listed as a Category 2 issue and require plant-specific evaluation before license renewal for those plants with closed-cycle cooling on a small river. The average annual flow of the Connecticut River near the VYNPS site is $3.3 \times 10^{11} \text{ ft}^3/\text{yr}$ (Entergy 2006a), which is less than the $3.15 \times 10^{12} \text{ ft}^3/\text{yr}$ threshold value specified in 10 CFR 51.53(c)(3)(ii)(G) for thermal discharge to a small river. Hence, the NRC staff considers the Connecticut River to be a small river, and the effects of its discharge on microbiological organisms must be addressed for VYNPS.

The Category 2 designation is based on the magnitude of the potential public-health impacts associated with thermal enhancement of the enteric pathogens *Salmonella* spp. and *Shigella* spp., the *Pseudomonas aeruginosa* bacterium, thermophilic fungi, *Legionella* spp. bacteria, and

1 pathogenic strains of the free-living amoebae *Naegleria* and *Acanthamoeba* spp. (NRC 1999).
2 Thermophilic microorganisms can have optimum growth at temperatures of 122°F or more, a
3 maximum temperature tolerance of up to 158°F, and a minimum tolerance of about 68°F
4 (Deacon 2003). However, thermal preferences and tolerances differ among the various
5 microorganisms and environmental conditions. *P. aeruginosa* has an optimum temperature for
6 growth of 98.6°F and can tolerate a temperature as high as 107.6°F (Todar 2004). A water
7 temperature range of 90 to 105°F provides ideal conditions for *Legionella* spp. bacterial growth
8 (CDC 2005). *Salmonella* spp. can thrive at temperatures between 40 and 140°F (Kendall
9 2006). Populations of the pathogenic amoeba *Naegleria fowleri* can be enhanced in thermally
10 altered water bodies at temperatures ranging from 95 to 106°F or higher, but this organisms is
11 rarely found in water cooler than 95°F, as indicated by studies reviewed and coordinated by
12 Tyndall et al. (1989).

13
14 No public swimming areas occur in the Connecticut River between Brattleboro and Vernon, and
15 the incidence of swimming and diving activities near VYNPS is low (Entergy 2006a).
16 Recreational uses near the plant include fishing and boating. Entergy employees and
17 contractors also perform sampling in the river. These activities create a potential for human
18 exposure to microbiological organisms. The ambient temperatures of the Connecticut River
19 near the VYNPS site vary from near freezing (approximately 32°F) in the winter to a maximum
20 84°F in the summer (Entergy 2006a). Between 1998 to 2002, ambient river temperatures never
21 exceed 80°F (Normandeau 2004). Therefore, ambient river conditions are not likely to support
22 the proliferation of pathogenic organisms of concern. As discussed in Section 4.1.4, average
23 summer temperatures at the downstream monitoring station do not average more than 2°F
24 above ambient. In addition, water temperatures at the downstream monitoring station are not to
25 exceed 85°F (Entergy 2006b). Based the small area of maximum water temperatures near the
26 point of discharge (80 to 90°F, with an infrequent worst-case of 100°F (Normandeau 2004)),
27 coupled with the dilution provided by the Connecticut River, thermophilic
28 microorganisms are not expected to cause any appreciable public health risk. No reported
29 cases of *Naegleria fowleri* or amoebic meningoencephalitis or other water-borne illnesses have
30 been reported in the vicinity of VYNPS (Entergy 2006a).

31
32 Based on the evaluation presented above, thermophilic microbiological organisms are not likely
33 to occur as a result of VYNPS discharges to the Connecticut River. The NRC staff concludes
34 that impacts on public health from thermophilic microbiological organisms from continued
35 operation of VYNPS during the license renewal period would be SMALL, and no additional
36 mitigation is warranted.

37 **4.2 Transmission Lines**

38
39 The Final Environmental Statement (FES) for VYNPS (AEC 1972) describes two transmission
40 lines that were built to connect VYNPS with the transmission system. The transmission lines,

Environmental Impacts of Operation

as well as their ownership and responsibilities for their maintenance, are described in Section 2.1.7 of this Supplemental Environmental Impact Statement (SEIS). The 2-mi-long Chestnut Hill 115-kV transmission line connects to the Vermont-New Hampshire transmission grid, while the 50-mi-long Coolidge 345-kV transmission line connects to the New England transmission grid (AEC 1972). The Chestnut Hill line has a 300-ft right-of-way, and the Coolidge line has a 200-ft right-of-way.

Vegetation control along the Coolidge and Chestnut Hill transmission lines in Vermont is accomplished through the use of hand-applied herbicides and mechanical clearing. Procedures are in place to ensure that vegetation management along rights-of-way is carried out in a manner to protect local water bodies and aquatic organisms that could be adversely impacted from herbicide application in the immediate vicinity of stream and river crossings. Herbicides that are used comply with Federal and State regulations and are applied by licensed applicators. No herbicides are used in maintaining the right-of-way of the Chestnut Hill transmission line in New Hampshire.

Category 1 issues in 10 CFR Part 51, Subpart A, Appendix B, Table B-1, that are applicable to VYNPS transmission lines are listed in Table 4-6. Entergy stated in its ER that it is not aware of

Table 4-6. Category 1 Issues Applicable to the VYNPS Transmission Lines During the Renewal Term

ISSUE–10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections
TERRESTRIAL RESOURCES	
Power line right-of-way management (cutting and herbicide application)	4.5.6.1
Bird collisions with power lines	4.5.6.2
Impacts of electromagnetic fields on flora and fauna (plants, agricultural crops, honeybees, wildlife, livestock)	4.5.6.3
Floodplains and wetlands on power line right-of-way	4.5.7
AIR QUALITY	
Air quality effects of transmission lines	4.5.2
LAND USE	
Onsite land use	4.5.3
Power line rights-of-way	4.5.3

any new and significant information associated with the renewal of the VYNPS operating license (OL) (Entergy 2006a). The NRC staff has not identified any new and significant information during its independent review of the Entergy ER, the site visit, the scoping process, or its evaluation of other information. Therefore, the NRC staff concludes that there would be no

Environmental Impacts of Operation

1 impacts related to these issues beyond those discussed in the GEIS (NRC 1999). For all of
2 those issues, the NRC staff concluded in the GEIS that the impacts are SMALL, and additional
3 plant-specific mitigation measures are not likely to be sufficiently beneficial to warrant
4 implementation.

5 A brief description of the NRC staff's review and GEIS conclusions, as codified in Table B-1, for
6 each of these issues follows:

- 7
- 8 • Power line right-of-way management (cutting and herbicide application). Based on
9 information in the GEIS, the Commission found that

10

11 The impacts of right-of-way maintenance on wildlife are expected to be of
12 small significance at all sites.

13

14 The NRC staff has not identified any new and significant information during its
15 independent review of the Entergy ER, the site visit, the scoping process, consultation
16 with the U.S. Fish and Wildlife Service (FWS) and the Vermont Agency of Natural
17 Resources (VANR), or its evaluation of other information. Therefore, the NRC staff
18 concludes that there would be no impacts of power line right-of-way maintenance during
19 the renewal term beyond those discussed in the GEIS.

- 20
- 21 • Bird collisions with power lines. Based on information in the GEIS, the Commission
22 found that

23

24 Impacts are expected to be of SMALL significance at all sites.

25

26 The NRC staff has not identified any new and significant information during its
27 independent review of the Entergy ER, the site visit, the scoping process, consultation
28 with the FWS and VANR, or its evaluation of other information. Therefore, the NRC staff
29 concludes that there would be no impacts of bird collisions with power lines during the
30 renewal term beyond those discussed in the GEIS.

- 31
- 32 • Impacts of electromagnetic fields on flora and fauna (plants, agricultural crops,
33 honeybees, wildlife, livestock). Based on information in the GEIS, the Commission
34 found that

35

36 No significant impacts of electromagnetic fields on terrestrial flora and fauna
37 have been identified. Such effects are not expected to be a problem during
38 the license renewal term.

39

40 The NRC staff has not identified any new and significant information during its
41 independent review of the Entergy ER, the site visit, the scoping process, or its

Environmental Impacts of Operation

1 evaluation of other information and public comments on the draft SEIS. Therefore, the
2 NRC staff concludes that there would be no impacts of electromagnetic fields on flora
3 and fauna during the renewal term beyond those discussed in the GEIS.

- 4
- 5 • Floodplains and wetlands on power line rights-of-way. Based on information in the
6 GEIS, the Commission found that

7

8

9 Periodic vegetation control is necessary in forested wetlands underneath
10 power lines and can be achieved with minimal damage to the wetlands. No
11 significant impact is expected at any nuclear power plant during the license
12 renewal term.

13

14 The NRC staff has not identified any new and significant information during its
15 independent review of the Entergy ER, the site visit, the scoping process, consultation
16 with the FWS and VANR, or and its evaluation of other information. Therefore, the NRC
17 staff concludes that there would be no impacts of power line rights-of-way on floodplains
18 and wetlands during the renewal term beyond those discussed in the GEIS.

- 19
- 20 • Air quality effects of transmission lines. Based on the information in the GEIS, the
21 Commission found that

22

23 Production of ozone and oxides of nitrogen is insignificant and does not
24 contribute measurably to ambient levels of these gases.

25

26 The NRC staff has not identified any new and significant information during its
27 independent review of the Entergy ER, the site visit, the scoping process, or its
28 evaluation of other information. Therefore, the NRC staff concludes that there would be
29 no air quality impacts of transmission lines during the renewal term beyond those
30 discussed in the GEIS.

- 31
- 32 • Onsite land use. Based on the information in the GEIS, the Commission found that

33

34 Projected onsite land use changes required during ... the renewal period
35 would be a small fraction of any nuclear power plant site and would involve
36 land that is controlled by the applicant.

37

38 The NRC staff has not identified any new and significant information during its
39 independent review of the Entergy ER, the site visit, the scoping process, or its
40 evaluation of other information. Therefore, the NRC staff concludes that there would be
41 no onsite land-use impacts during the renewal term beyond those discussed in the
42 GEIS.

- 1 • Power line rights-of-way. Based on information in the GEIS, the Commission found
2 that

4 Ongoing use of power line rights-of-way would continue with no change in
5 restrictions. The effects of these restrictions are of small significance.

7 The NRC staff has not identified any new and significant information during its
8 independent review of the ER, the site visit, the scoping process, or its evaluation of
9 other information. Therefore, the NRC staff concludes that there would be no impacts of
10 power line rights-of-way on land use during the renewal term beyond those discussed in
11 the GEIS.

13 There is one Category 2 issue related to transmission lines, and another issue related to
14 transmission lines is being treated as a Category 2 issue. These issues are listed in Table 4-7
15 and are discussed in Sections 4.2.1 and 4.2.2.

17 **4.2.1 Electromagnetic Fields – Acute Effects**

19 Based on the GEIS, the Commission found that electric shock resulting from direct access to
20 energized conductors or from induced charges in metallic structures has not been found to be a
21 problem at most operating plants and generally is not expected to be a problem during the
22 license renewal term. However, site-specific review is required to determine the significance of
23 the electric shock potential along the portions of the transmission lines that are within the scope
24 of this SEIS.

26 **Table 4-7. Category 2 and Uncategorized Issues Applicable to the VYNPS Transmission
27 Lines During the Renewal Term**

29 ISSUE–10 CFR Part 51, Subpart A, 30 Appendix B, Table B-1	GEIS Sections	10 CFR 51.53(c)(3)(ii) Subparagraph	SEIS Section
HUMAN HEALTH			
32 Electromagnetic fields, acute effects 33 (electric shock)	4.5.4.1	H	4.2.1
34 Electromagnetic fields, chronic effects	4.5.4.2	NA ^(a)	4.2.2
(a) Not addressed.			

37 In the GEIS (NRC 1996), the NRC staff found that without a review of the conformance of each
38 nuclear plant transmission line with National Electrical Safety Code (NESC) (IEEE 2002)
39 criteria, it was not possible to determine the significance of the electric shock potential.
40 Evaluation of individual plant transmission lines is necessary because the issue of electric
41 shock safety was not addressed in the licensing process for some plants. For other plants, land

Environmental Impacts of Operation

use in the vicinity of transmission lines may have changed, or power distribution companies may have chosen to upgrade line voltage. To comply with 10 CFR 51.53(c)(3)(ii)(H), the applicant must provide an assessment of the impact of the proposed action on the potential shock hazard from the transmission lines if the transmission lines that were constructed for the specific purpose of connecting the plant to the transmission system do not meet the recommendations of the NESC for preventing electric shock from induced currents.

Both transmission lines associated with VYNPS were constructed in accordance with NESC and industry guidance in effect at that time. The transmission facilities are maintained to ensure continued compliance with current standards. Since the lines were constructed, a new criterion has been added to the NESC for power lines with voltages exceeding 98 kV. This criterion states that the minimum clearance for a line must limit induced currents due to static effects to 5 mA.

Entergy (2006a) has reviewed the transmission lines for compliance with this criterion. Vermont Electric Power Company, Inc. (VELCO) indicated that the Coolidge line has not operated in excess of 212°F, which is within its original design specifications which assumed an eventual 345-kV line, and that the line meets the current NESC clearance standards (Entergy 2006c). Northeast Utilities indicated that the Chestnut Hill line also only operates within its design limits and meets current NESC clearance standards (Entergy 2006c). No induced shock hazard to the public should occur, since the lines are operating within original design specifications and meet current NESC clearance standards.

The NRC staff has reviewed the available information, including the applicant's evaluation and computational results. Based on this information, the NRC staff evaluated the potential impacts for electric shock resulting from operation of VYNPS and its associated transmission lines. It is the NRC staff's conclusion that the potential impacts from electric shock during the renewal period would be SMALL and no additional mitigation is warranted.

4.2.2 Electromagnetic Fields – Chronic Effects

In the GEIS, the chronic effects of 60-Hz electromagnetic fields from power lines were not designated as Category 1 or 2, and will not be until a scientific consensus is reached on the health implications of these fields.

The potential for chronic effects from these fields continues to be studied and is not known at this time. The National Institute of Environmental Health Sciences (NIEHS) directs related research through the U.S. Department of Energy (DOE). The report by NIEHS (1999) contains the following conclusion:

The NIEHS concludes that ELF-EMF (extremely low frequency-electromagnetic field) exposure cannot be recognized as entirely safe because of weak scientific evidence that

exposure may pose a leukemia hazard. In our opinion, this finding is insufficient to warrant aggressive regulatory concern. However, because virtually everyone in the United States uses electricity and therefore is routinely exposed to ELF-EMF, passive regulatory action is warranted such as continued emphasis on educating both the public and the regulated community on means aimed at reducing exposures. The NIEHS does not believe that other cancers or noncancer health outcomes provide sufficient evidence of a risk to currently warrant concern.

This statement is not sufficient to cause the NRC staff to change its position with respect to the chronic effects of electromagnetic fields. The NRC staff considers the GEIS finding of "Not Applicable" still appropriate and will continue to follow developments on this issue.

4.3 Radiological Impacts of Normal Operations

Category 1 issues in 10 CFR Part 51, Subpart A, Appendix B, Table B-1, that are applicable to VYNPS in regard to radiological impacts are listed in Table 4-8. Entergy stated in its ER (Entergy 2006a) that it is not aware of any new and significant information associated with the renewal of the VYNPS OL. The extended power uprate that took place in early 2006 and the construction of the new dry fuel storage facility, which is expected to be completed in 2006, have been considered by the NRC in its evaluation of the radiological impacts, and the impacts have been determined to be within the envelope established in the GEIS. The NRC staff has not identified any new and significant information during its independent review of the ER, the site visit, the scoping process, or the evaluation of other available information. Therefore, the NRC staff concludes that there would be no impacts related to these issues beyond those discussed in the GEIS. For these issues, the NRC staff concluded in the GEIS that the impacts are SMALL and that additional plant-specific mitigation measures are not likely to be sufficiently beneficial to warrant implementation.

Table 4-8. Category 1 Issues Applicable to Radiological Impacts of Normal Operations During the Renewal Term

ISSUE-10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections
HUMAN HEALTH	
Radiation exposures to public (license renewal term)	4.6.2
Occupational radiation exposures (license renewal term)	4.6.3

Environmental Impacts of Operation

1 A brief description of the NRC staff's review and the GEIS conclusions, as codified in Table B-1,
2 for each of these issues follows:

- 3
- 4 • Radiation exposures to the public (license renewal term). Based on information in
5 the GEIS, the Commission found that

6

7 Radiation doses to the public will continue at current levels associated with
8 normal operations.

9

10 The NRC staff has not identified any new and significant information during its
11 independent review of the Entergy ER, the site visit, the scoping process, or the
12 evaluation of other available information. Therefore, the NRC staff concludes that there
13 would be no impacts of radiation exposures to the public during the renewal term beyond
14 those discussed in the GEIS.

- 15
- 16 • Occupational radiation exposures (license renewal term). Based on information in
17 the GEIS, the Commission found that

18

19 Projected maximum occupational doses during the license renewal term are
20 within the range of doses experienced during normal operations and normal
21 maintenance outages, and would be well below regulatory limits.

22

23 The NRC staff has not identified any new and significant information during its
24 independent review of the Entergy ER, the site visit, the scoping process, or the
25 evaluation of other available information. Therefore, the NRC staff concludes that there
26 would be no impacts of occupational radiation exposures during the renewal term
27 beyond those discussed in the GEIS.

28

29 There are no Category 2 issues related to radiological impacts of routine operations.

31 **4.4 Socioeconomic Impacts of Plant Operations During 32 the License Renewal Period**

33

34 Category 1 issues in 10 CFR Part 51, Subpart A, Appendix B, Table B-1, that are applicable to
35 socioeconomic impacts during the renewal term are listed in Table 4-9. Entergy stated in its ER
36 (Entergy 2006a) that it is not aware of any new and significant information associated with the
37 renewal of the VYNPS OL. The staff has not identified any new and significant information
38 during its independent review of the Entergy ER, the staff's site visit, the scoping process, or its
39 evaluation of other available information. Therefore, the staff concludes that there are no
40 impacts related to these issues beyond those discussed in the GEIS (NRC 1996). For these

Table 4-9. Category 1 Issues Applicable to Socioeconomics During the Renewal Term

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections
SOCIOECONOMICS	
Public services: public safety, social services, and tourism and recreation	4.7.3; 4.7.3.3; 4.7.3.4; 4.7.3.6
Public services: education (license renewal term)	4.7.3.1
Aesthetic impacts (license renewal term)	4.7.6
Aesthetic impacts of transmission lines (license renewal term)	4.5.8

issues, the staff concluded in the GEIS that the impacts are SMALL and additional plant-specific mitigation measures are not likely to be sufficiently beneficial to warrant implementation.

A brief description of the staff's review and the GEIS conclusions, as codified in Table B-1, for each of these issues follows:

- Public services: public safety, social services, and tourism and recreation. Based on information in the GEIS, the Commission found that

Impacts to public safety, social services, and tourism and recreation are expected to be of small significance at all sites.

The NRC staff has not identified any new and significant information during its independent review of the Entergy ER, the staff's site visit, the scoping process, or the evaluation of other available information. Therefore, the NRC staff concludes that there are no impacts on public safety, social services, and tourism and recreation during the renewal term beyond those discussed in the GEIS.

- Public services: education (license renewal term). Based on information in the GEIS, the Commission found that

Only impacts of small significance are expected.

The NRC staff has not identified any new and significant information during its independent review of the Entergy ER, the site visit, the scoping process, or the evaluation of other available information. Therefore, the NRC staff concludes that there are no impacts on education during the renewal term beyond those discussed in the GEIS.

Environmental Impacts of Operation

- 1 • Aesthetic impacts (license renewal term). Based on information in the GEIS, the
2 Commission found that

3 No significant impacts are expected during the license renewal term.

4 The NRC staff has not identified any new and significant information during its
5 independent review of the Entergy ER, the site visit, the scoping process, or the
6 evaluation of other available information. Therefore, the NRC staff concludes that there
7 would be no aesthetic impacts during the renewal term beyond those discussed in the
8 GEIS.

- 9 • Aesthetic impacts of transmission lines (license renewal term). Based on information
10 in the GEIS, the Commission found that

11 No significant impacts are expected during the license renewal term.

12 The NRC staff has not identified any new and significant information during its
13 independent review of the Entergy ER, the site visit, the scoping process, or the
14 evaluation of other available information. Therefore, the NRC staff concludes that there
15 would be no aesthetic impacts of transmission lines during the renewal term beyond
16 those discussed in the GEIS.

17 Table 4-10 lists the Category 2 socioeconomic issues, which require plant-specific analysis, and
18 environmental justice, which was not addressed in the GEIS.

19 **Table 4-10.** Environmental Justice and GEIS Category 2 Issues Applicable to
20 Socioeconomics During the Renewal Term

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections	10 CFR 51.53(c)(3)(ii) Subparagraph	SEIS Section
SOCIOECONOMICS			
Housing impacts	4.7.1	I	4.4.1
Public services: public utilities	4.7.3.5	I	4.4.2
Offsite land use (license renewal term)	4.7.4	I	4.4.3
Public services, transportation	4.7.3.2	J	4.4.4
Historic and archaeological resources	4.7.7	K	4.4.5
Environmental Justice	Not addressed ^(a)	Not addressed ^(a)	4.4.6

(a) Guidance related to environmental justice was not in place at the time the GEIS and the associated revision to 10 CFR Part 51 were prepared. Therefore, environmental justice must be addressed in the NRC staff's SEIS.

1 **4.4.1 Housing Impacts During Operations**

2
3 In determining housing impacts, the applicant chose to follow Appendix C of the GEIS
4 (NRC 1996), which presents a population characterization method that is based on two factors,
5 “sparseness” and “proximity” (GEIS Section C.1.4 (NRC 1996)). Sparseness measures
6 population density within 20 mi of the site, and proximity measures population density and city
7 size within 50 mi. Each factor has categories of density and size (GEIS Table C.1), and a
8 matrix is used to rank the population category as low, medium, or high (GEIS Figure C.1).

9
10 In 2000, there were 153,409 people living within 20 mi of VYNPS, for a density of
11 122 persons/mi². This density translates to Category 4 (least sparse), using the GEIS measure
12 of sparseness (Entergy 2006a). At the same time, there were 1,513,282 persons living within
13 50 mi of the plant, for a density of 193 persons/mi². The NRC sparseness and proximity matrix
14 assigns a Category 4 rating (high density) for this measure as well. There are no growth
15 controls that would limit housing development in this area (Entergy 2006a).

16
17 10 CFR Part 51, Subpart A, Appendix B, Table B-1, states that impacts on housing availability
18 are expected to be of small significance at plants located in a high-population area where
19 growth-control measures are not in effect. The VYNPS site is located in a high-population area,
20 and Windham County, Cheshire County, and Franklin County are not subject to growth-control
21 measures that would limit housing development. Based on the NRC criteria, Entergy expects
22 housing impacts to be SMALL during continued operations (Entergy 2006a).

23
24 SMALL impacts result when no discernible change in housing availability occurs, changes in
25 rental rates and housing values are similar to those occurring State-wide, and no housing
26 construction or conversion is required to meet new demand (NRC 1996). The GEIS assumes
27 that an additional staff of 60 permanent workers might be needed during the license renewal
28 period to perform routine maintenance and other activities.

29
30 The housing vacancy rate in 2000 was 32.0 percent in Windham County, 11.2 percent in
31 Cheshire County, and 7.7 percent in Franklin County. If these vacancy rates continue, small
32 increases in the number of workers at the plant during the license renewal period would mean
33 no new housing construction would be required.

34
35 The NRC staff reviewed the available information relative to housing impacts and Entergy's
36 conclusions. Based on this review, the NRC staff concludes that the impact on housing during
37 the license renewal period would be SMALL and no additional mitigation is warranted.

38
39 **4.4.2 Public Services: Public Utility Impacts During Operations**

40
41 Impacts on public utility services are considered SMALL if there is little or no change in the
42 ability of the system to respond to the level of demand, thus there is no need to add capital

Environmental Impacts of Operation

facilities. Impacts are considered MODERATE if overtaxing of service capabilities occurs during periods of peak demand. Impacts are considered LARGE if existing levels of service (e.g., water or sewer services) are substantially degraded and additional capacity is needed to meet ongoing demands for services. The GEIS indicates that, in the absence of new and significant information to the contrary, the only impacts on public utilities that could be significant are impacts on public water supplies (NRC 1996).

Analysis of impacts on the public water supply system considered both plant demand and plant-related population growth. Section 2.2.2 describes the VYNPS-permitted withdrawal rate and actual use of water.

The NRC staff has reviewed the available information, including permitted and actual water-use rates at VYNPS, water supply capacities for the major water supply systems in Windham County, Cheshire County, and Franklin County, and expected population growth. Based on this information, the NRC staff concludes that the potential impacts of VYNPS operation during the license renewal period would be SMALL. During the course of its evaluation, the NRC staff considered mitigation measures for continued operation of VYNPS. Based on this evaluation, the staff determined that mitigation measures in place at VYNPS are appropriate and no additional mitigation is warranted.

4.4.3 Offsite Land Use During Operations

Offsite land use during the license renewal term is a Category 2 issue (10 CFR Part 51, Subpart A, Appendix B, Table B-1). Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, notes that "significant changes in land use may be associated with population and tax revenue changes resulting from license renewal."

Section 4.7.4 of the GEIS defines the magnitude of land-use changes as a result of plant operation during the license renewal term as follows:

SMALL – Little new development and minimal changes to an area's land-use pattern.

MODERATE – Considerable new development and some changes to the land-use pattern.

LARGE – Large-scale new development and major changes in the land-use pattern.

Tax revenue can affect land use because it enables local jurisdictions to provide the public services (e.g., transportation and utilities) necessary to support development. Section 4.7.4.1 of the GEIS states that the assessment of tax-driven land-use impacts during the license renewal term should consider (1) the size of the plant's payments relative to the community's total revenues, (2) the nature of the community's existing land-use pattern, and (3) the extent to which the community already has public services in place to support and guide development. If

Environmental Impacts of Operation

1 the plant's tax payments are projected to be small relative to the community's total revenue, tax-
2 driven land-use changes during the plant's license renewal term would be SMALL, especially
3 where the community has pre-established patterns of development and has provided adequate
4 public services to support and guide development. Section 4.7.2.1 of the GEIS states that if tax
5 payments by the plant owner are less than 10 percent of the taxing jurisdiction's revenue, the
6 significance level would be SMALL. If the plant's tax payments are projected to be medium to
7 large relative to the community's total revenue, new tax-driven land-use changes would be
8 MODERATE. If the plant's tax payments are projected to be a dominant source of the
9 community's total revenue, new tax-driven land-use changes would be LARGE. This would be
10 especially true where the community has no pre-established pattern of development or has not
11 provided adequate public services to support and guide development.

12
13 Property taxes are paid by VYNPS to the town of Vernon and the Entergy corporate office
14 facility in Brattleboro to Brattleboro Township. Property taxes paid by VYNPS to the town of
15 Vernon approximate 65 percent (about \$1.2 million in 2005 dollars) of total township tax
16 revenue, which is utilized for police, fire, public works, roads, and other town services.
17 Entergy's State Electric Generation Education Tax payment covers approximately a third of the
18 Vernon School District's budget. In contrast, only 1 percent (about \$0.2 million in 2005 dollars)
19 of Brattleboro Township revenues, on average, over the period 2003 to 2005 came from
20 Entergy. Revenues from VYNPS, the Entergy facility and electricity generation taxes levied by
21 the State constitute less than 1 percent of total State revenues in 2005. These payments
22 represent a significant, positive impact on the condition of Vernon, while a small, positive impact
23 on the fiscal conditions of the township and State.

24
25 Because no refurbishment or new construction activities are associated with the license
26 renewal, no additional sources of plant-related tax payments are expected that could further
27 influence land use in the town, township, or State. The continued collection of property taxes
28 from VYNPS will result in moderate indirect tax-driven land-use pattern changes through lower
29 local property taxes and the current level of public infrastructure and services (Entergy 2006a).
30 This source of revenue allows the town and local school district to keep tax rates below the
31 levels they would otherwise have in order to fund the higher levels of public infrastructure and
32 services and educational facilities and staffing.

33
34 Windham County's average annual population growth rate between the 2000 and 2003
35 censuses was 0.1 percent, while Cheshire County's rate was 0.9 percent, and Franklin County's
36 rate was 0.3 percent (Section 2.2.8.3). These three counties are rural with growing areas of
37 recreational development. The GEIS assumes that an additional 60 permanent workers might
38 be needed during the license renewal period to perform routine maintenance and other
39 activities; thus, land-use changes from VYNPS population-related growth would be negligible.
40 The town of Vernon did approve the 2003 Town Plan, which outlines the community's plan for
41 future growth and development (Entergy 2006a); land use has changed little over the last 20 to
42 30 years. All three counties are members of regional planning commissions.

Environmental Impacts of Operation

No major plant refurbishment or construction activities have been identified as necessary to support the continued operation of the VYNPS beyond the end of the existing operating license term (Entergy 2006a). Because it is anticipated there will be no increase in the assessed value of VYNPS due to refurbishment-related improvements or normal maintenance, annual property taxes from VYNPS to the town of Vernon and Brattleboro Township might remain relatively constant throughout the license renewal period. Since utility restructuring legislation has not been enacted in Vermont, the long-term impact of any such changes in the electricity industry in the State on VYNPS is difficult to predict. Any changes to the VYNPS tax rates due to the restructuring would be independent of license renewal.

VYNPS will continue to be a significant source of tax revenue for the town of Vernon. However, despite having this significant income source since plant construction in the early 1970s, Vernon has not nor expects to experience large land use changes. VYNPS environs continue to remain largely rural, and annual population growth rates for the three-county region have recently averaged between 0.1 to 0.9 percent (Entergy 2006a). The criteria in the GEIS (Section C.4.1.5.2), results in the assignment of an impact level of MODERATE when tax levels are greater than 10 percent. However, the case study assumed a certain level of refurbishment. As no major refurbishment activities are planned at Vermont Yankee to support license renewal, no new sources of plant-related tax payments are expected that could significantly affect land use in the three-county region. Based on the aforementioned information derived from the applicant, the NRC staff's site visit, the scoping process, discussions with Vernon officials and regional land-use planning agency personnel, and other public sources, the staff concluded that tax-related land-use impacts are likely to be SMALL and no additional mitigation is warranted.

4.4.4 Public Services: Transportation Impacts During Operations

Table B-1, 10 CFR Part 51, states: "Transportation impacts (level of service) of highway traffic generated ... during the term of the renewed license are generally expected to be of small significance. However, the increase in traffic associated with additional workers and the local road and traffic control conditions may lead to impacts of moderate or large significance at some sites." All applicants are required by 10 CFR 51.53(c)(3)(ii)(J) to assess the impacts of highway traffic generated by the proposed project on the level of service of local highways during the term of the renewed license.

Given the small number of additional workers required during the renewal period, there would be no significant additional impacts to the transportation network in the vicinity of the VYNPS site. Therefore, the staff concluded that transportation impacts during operation are likely to be SMALL and no additional mitigation is warranted.

1 **4.4.5 Historic and Archaeological Resources**

2
3 The National Historic Preservation Act (NHPA) requires that Federal agencies take into account
4 the effects of their undertakings on historic properties. The historic preservation review process
5 mandated by Section 106 of the NHPA is outlined in regulations issued by the Advisory Council
6 on Historic Preservation at 36 CFR Part 800. Renewal of an OL is an undertaking that could
7 potentially affect historic properties. Therefore, according to the NHPA, the NRC is to make a
8 reasonable effort to identify historic properties in the areas of potential effects. If no historic
9 properties are present or affected, the NRC is required to notify the State Historic Preservation
10 Office (SHPO) before proceeding. If it is determined that historic properties are present, the
11 NRC is required to assess and resolve possible adverse effects of the undertaking.

12
13 Entergy contacted the Vermont SHPO on September 15, 2005, regarding preparation of its
14 application for license renewal (Entergy 2006a). The NRC contacted the Vermont SHPO and
15 the Advisory Council on Historic Preservation on May 8, 2006, and the appropriate Federally
16 recognized Native American Tribes in the region on May 10, 2006. These letters are available
17 in Appendix E.

18
19 A search of the Vermont SHPO files for the region around the VYNPS shows that the region is
20 highly sensitive for archaeological remains. While no prehistoric archaeological sites have been
21 identified on the VYNPS property, the Governor Hunt House is a historically significant property
22 owned and managed by the plant operator. The area around the house has the potential to
23 contain buried remains associated with the Governor Hunt House. Additionally, the VYNPS
24 property is located on the floodplain of the Connecticut River, which has the potential to contain
25 deeply buried archaeological deposits.

26
27 Continued operation of VYNPS would likely protect any archaeological sites present within the
28 VYNPS site boundary by protecting those lands from development and providing secured
29 access. However, because there is the potential for cultural resources to be present at the site,
30 the applicant should take care during normal operations and maintenance activities related to
31 operations not to inadvertently affect cultural resources. To avoid such adverse impacts,
32 environmental review procedures have been put in place at VYNPS regarding undertakings that
33 involve land disturbing activities in undisturbed surface and subsurface areas as well as
34 modifications to historic structures (i.e., Governor Hunt House). These procedures include
35 contacting the SHPO to establish the actions necessary to protect known or as of yet
36 undiscovered cultural resources before an action is allowed to occur.

37
38 The archaeological site in close proximity to the Coolidge transmission line has the potential to
39 be impacted by right-of-way maintenance activities. However, the site's location adjacent to a
40 river makes any impacts to the site unlikely. VELCO's procedures consider minimization of
41 erosion and bank destabilization along rivers and wetlands, which could further protect the site.
42 These procedures would likely protect the archaeological site from impact. Similarly, the areas

Environmental Impacts of Operation

1 sensitive for archaeological remains along the Chestnut Hill line are along waterways, which are
2 protected by current maintenance procedures, thereby minimizing the potential for impacts to
3 previously unidentified archaeological remains.

Based on this analysis of cultural resources, the NRC staff concludes that the impact of license renewal would be **SMALL** and that further mitigation is not necessary. While the area is highly sensitive for cultural resources and a historic property is on the VYNPS site (i.e., Governor Hunt House), the procedures are adequate to protect cultural resources at the plant. Therefore, daily operations at the VYNPS during the license renewal period would likely have a **SMALL** impact on cultural resources. The potential for impacts to cultural resources along the transmission lines is considered **SMALL**.

4.4.6 Environmental Justice

Environmental justice refers to a Federal policy that requires that Federal agencies identify and address, as appropriate, disproportionately high and adverse human health or environmental effects of its actions on minority^(a) or low-income populations. The memorandum accompanying Executive Order 12898 (59 FR 7629) directs Federal executive agencies to consider environmental justice under the National Environmental Policy Act of 1969 (NEPA). The Council on Environmental Quality (CEQ) has provided guidance for addressing environmental justice (CEQ 1997). Although the Executive Order is not mandatory for independent agencies, the NRC has voluntarily committed to undertake environmental justice reviews. Specific guidance is provided in NRC Office of Nuclear Reactor Regulation Office Instruction LIC-203, *Procedural Guidance for Preparing Environmental Assessments and Considering Environmental Issues Rev. 1* (NRC 2004a). In 2004, the Commission issued a final *Policy Statement on the Treatment of Environmental Justice Matters in NRC Regulatory and Licensing Actions* (NRC 2004b).

The scope of the review as defined in NRC guidance (NRC 2004a) includes identification of impacts on minority and low-income populations, the location and significance of any environmental impacts during operations on populations that are particularly sensitive, and information pertaining to mitigation. It also includes an evaluation of whether these impacts are likely to be disproportionately high and adverse.

(a) The NRC guidance for performing environmental justice reviews defines “minority” as American Indian or Alaskan Native; Asian; Native Hawaiian or other Pacific Islander; Black races; or Hispanic ethnicity. “Other” races and multiracial individuals may be considered as separate minorities (NRC 2004a).

Environmental Impacts of Operation

1 The NRC staff looks for minority and low-income populations within a 50-mi radius of the site.
2 For the NRC staff's review, a minority population exists in a census block group^(a) if the
3 percentage of each minority and aggregated minority category within the census block group
4 exceeds the corresponding average minority percentage in Vermont, New Hampshire, and
5 Massachusetts by 20 percentage points, or if the percentage of minorities within a census block
6 group is at least 50 percent. A low-income population exists if the percentage of low-income
7 population within a census block group exceeds the corresponding average percentage of low-
8 income population in the three states by 20 percentage points, or if the percentage of low-
9 income population within a census block group is at least 50 percent.

10 For the VYNPS review, the NRC staff examined the geographic distribution of minority and
11 low-income populations within 50 mi of the site, employing data from the 2000 census
12 (USCB 2006).

13 Figures 4-1 and 4-2 show the distribution of census block groups for the minority and low-
14 income populations, respectively.

15 There are no census block groups in Vermont or New Hampshire within the 50-mi region that
16 exceed the NRC thresholds defining minority populations. A number of block groups in
17 Massachusetts within the 50-mi region exceeded the NRC thresholds. These are located to the
18 south of VYNPS in Springfield and Northampton, and to the southeast of the site in Worcester,
19 Leominster, and Fitchburg. The majority of the census block groups exceeding the thresholds
20 defining a low-income population are located in the same communities to the south and
21 southeast of the site containing minority populations. Additional low-income population block
22 groups are located in Greenfield, Adams, and Pittsfield, Massachusetts, in Bennington,
23 Vermont, and in Keene, New Hampshire.

24 With the locations of minority and low-income populations identified, the NRC staff proceeded to
25 evaluate whether any of the environmental impacts of the proposed action could affect these
26 populations in a disproportionately high and adverse manner. Based on staff guidance

(a) A census block group is a combination of census blocks, which are statistical subdivisions of a census tract. A census block is the smallest geographic entity for which the U.S. Census Bureau (USCB) collects and tabulates decennial census information. A census tract is a small, relatively permanent statistical subdivision of counties delineated by local committees of census data users in accordance with USCB guidelines for the purpose of collecting and presenting decennial census data. Census block groups are subsets of census tracts (USCB 2006).

Environmental Impacts of Operation




Figure 4-1. Geographic Distribution of Minority Populations (shown in shaded areas) Within 50 mi of VYNPS Site Based on Census Block Group Data




Figure 4-2. Geographic Distribution of Low-Income Populations (shown in shaded areas)
Within 50 mi of the VYNPS Site Based on Census Block Group Data

Environmental Impacts of Operation

(NRC 2004a), air, land, and water resources within about 50 mi of the VYNPS site were examined. Within that area, a few potential environmental impacts could affect human populations; all of these were considered SMALL for the general population.

The pathways through which the environmental impacts associated with VYNPS license renewal can affect human populations are discussed in each associated section. The NRC staff evaluated whether minority and low-income populations could be disproportionately affected by these impacts. The NRC staff found no unusual resource dependencies or practices, such as subsistence agriculture, hunting, or fishing, through which the populations could be disproportionately high and adversely affected. In addition, the NRC staff did not identify any location-dependent disproportionately high and adverse impacts affecting these minority and low-income populations. The NRC staff concludes that offsite impacts from VYNPS to minority and low-income populations would be SMALL and no additional mitigation is warranted.

4.5 Groundwater Use and Quality

The Category 1 issue in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, that is applicable to VYNPS groundwater use and quality is listed in Table 4-11. Entergy stated in its ER (Entergy 2006a) that it is not aware of any new or significant information associated with the renewal of the VYNPS OL. The NRC staff has not identified any new and significant information during its independent review of the Entergy ER, the site visit, the scoping process, or the evaluation of other available information. Therefore, the NRC staff concludes that there are no impacts related to this issue beyond those discussed in the GEIS. For the issue, the NRC staff concluded in the GEIS that the impact would be SMALL and additional mitigative measures are not likely to be sufficiently beneficial to warrant implementation.

**Table 4-11. Category 1 Issue Applicable to Groundwater Use and Quality
During the Renewal Term**

ISSUE-10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections
GROUNDWATER USE AND QUALITY	
Groundwater use conflicts (potable and service water; plants that use <100 gpm)	4.8.1.1

A brief description of the NRC staff's review and the GEIS conclusions, as codified in 10 CFR Part 51, Table B-1, follows:

- Groundwater-use conflicts (potable and service water; plants that use <100 gpm).
Based on information in the GEIS, the Commission found that

Plants using less than 100 gpm are not expected to cause any groundwater-use conflicts.

As discussed in Section 2.2.2, VYNPS groundwater use is less than 100 gpm. The NRC staff has not identified any new and significant information during its independent review of the Entergy ER, the site visit, the scoping process, or the evaluation of other available information. Therefore, the NRC staff concludes that there would be no groundwater-use conflicts during the renewal term beyond those discussed in the GEIS.

The Category 2 issue related to groundwater use and quality during the renewal term is listed in Table 4-12. This issue requires a plant-specific analysis.

Table 4-12. Category 2 Issue Applicable to Groundwater Use and Quality During the Renewal Term

ISSUE-10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Section	10 CFR Part 51.53(a)(3)(ii)	SEIS Section
GROUNDWATER USE AND QUALITY			
Groundwater-use conflicts (plants using cooling towers withdrawing make-up water from a small river)	4.8.1.3 4.4.2.1	B	4.5

4.5.1 Groundwater-Use Conflicts (Make-Up from a Small River)

The issue of groundwater-use conflicts applies to VYNPS because it withdraws water from the Connecticut River (Vernon Pool), an approximately 25-mi-long, 2250-ac impoundment created by the construction of Vernon Dam on the Connecticut River, and such withdrawals can potentially impact recharge rates to local groundwater resources. The dam facility, owned and operated by TransCanada, is required to maintain a minimum sustained inflow of 1250 cfs. The surface elevation of Vernon Pool fluctuates as much as 8 ft due to operations at upstream and downstream dams and runoff inflow.

The Connecticut River has an average daily flow of about 10,500 ft³/s (3.3×10^{11} ft³/yr), based on flows measured from 1944 to 1988 (Entergy 2006a), and about 11,101 ft³/s (3.5×10^{11} ft³/yr), based on flows measured from 2000 to 2005 (Normandeau 2001, 2002, 2003, 2004b, 2005; DeWald 2006). The maximum consumptive loss due to cooling tower evaporation is estimated to be 5000 gpm (11.1 ft³/s) (AEC 1972). This represents a reduction in flow of less than 0.10 percent of the average daily flow. It also represents a reduction in flow of 0.37 percent of

Environmental Impacts of Operation

the low median monthly flow (3050 ft³/s), 0.73 percent of the flow under drought conditions (1523 ft³/s), and 0.89 percent of the minimum sustained flow requirement for Vernon Dam (1250 ft³/s). These values are well below the Vermont Water Quality Standards criterion of 5 percent for Vermont Class B waters (Section 4.1.1). Because impacts to the flow in the Connecticut River due to consumptive use are not considered significant, the NRC staff concludes that impacts to groundwater use would also be SMALL and no additional mitigation is warranted.

4.6 Threatened or Endangered Species

Threatened or endangered species are listed as a Category 2 issue in 10 CFR Part 51, Subpart A, Appendix B, Table B-1. This issue is listed in Table 4-13.

This issue requires consultation with appropriate agencies to determine whether threatened or endangered species are present and whether they or their critical habitat would be adversely affected by continued operation of the nuclear plant during the license renewal term. The presence of threatened or endangered species or their critical habitat in the vicinity of the VYNPS site is discussed in Sections 2.2.5.5 and 2.2.6.2.

Table 4-13. Category 2 Issue Applicable to Threatened or Endangered Species During the Renewal Term

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Section	10 CFR Part 51.53(c)(3)(ii) Subparagraph	SEIS Section
THREATENED OR ENDANGERED SPECIES (FOR ALL PLANTS)			
Threatened or endangered species	4.1	E	4.6

The NRC contacted FWS to determine the presence of Federally listed threatened or endangered species in the vicinity of VYNPS or associated transmission lines (NRC 2006b, 2006d). The FWS determined that the bald eagle was the only Federally listed species known to occur in the vicinity of these facilities, and that bald eagles nest less than one mile downstream of VYNPS (FWS 2006). In addition, FWS determined that no impacts to the eagles are known to occur at this site that could be attributed to VYNPS or its transmission lines, and that preparation of a biological assessment or further consultation under Section 7 of the Endangered Species Act is not required.

The NRC also contacted the U.S. National Marine Fisheries Service (NMFS) to determine the presence of Federally listed threatened and endangered species in the vicinity of VYNPS (NRC 2006c). The NMFS determined that no Federally listed or proposed threatened or endangered species or designated critical habitat for listed species under the jurisdiction of NMFS are known

1 to exist in the project area. Therefore, the NMFS concluded that no further consultation
2 pursuant to section 7 of the Endangered Species Act is required (NMFS 2006).
3

4 **4.6.1 Aquatic Species**

5 The FWS (2005) did not list any Federally listed or proposed threatened or endangered aquatic
6 species under FWS jurisdiction that occur within the VYNPS area, and the proposed project
7 would not adversely affect Federally listed species under FWS jurisdiction. However, the
8 Federally listed (endangered) dwarf wedgemussel (*Alasmidonta heterodon*) and shortnose
9 sturgeon (*Acipenser brevirostrum*) are reported to inhabit the Connecticut River. As discussed
10 in Section 2.2.5, no specimens of the dwarf wedgemussel have been found in Vernon Pool
11 between Bellows Falls Dam (river mile (RM) 174) and Vernon Dam (RM 142) in recent surveys.
12 The closest occurrence in the Connecticut River is near Rockingham, Vermont, just north of
13 Bellows Falls Dam, over 30 mi upstream of VYNPS (NHFGD 2005; Entergy 2006a).

14
15 The VYNPS cooling water intake and discharge are closely monitored under the NPDES
16 program. The NPDES permit limits are reviewed on a regular basis to ensure the protection of
17 aquatic biota. This includes the tessellated darter, slimy sculpin, and Atlantic salmon smolts
18 that serve as hosts for the glochidia of the dwarf wedgemussel. The tessellated darter is
19 common throughout the Connecticut River watershed (Hartel et al. 1996). The slimy sculpin is
20 well distributed throughout the Connecticut River watershed (NHFGD 2005), although it has not
21 been collected in river or impingement samples associated with VYNPS (Normandeau 2005).
22 Atlantic salmon smolts are also common throughout the Connecticut River due to stocking
23 programs. Few smolts are annually impinged at VYNPS (Normandeau 2005), and they have
24 not been impinged at numbers above those allowed by the NPDES permit (Section 4.1.3).
25 Therefore, potential indirect impacts to the dwarf wedgemussel due to operational effects on
26 their host fish species would be negligible.

27
28 Known populations of the shortnose sturgeon in the Connecticut River occur downstream of the
29 Turners Falls Dam (RM 123) in Massachusetts. This area is about 20 mi downstream of
30 VYNPS (Entergy 2006a; NMFS 2006). As shortnose sturgeon spawning can occur over a
31 range of water temperatures (48.2 to 64.4 °F) (NHFGD 2005), the thermal discharge would have
32 no noticeable impact to shortnose sturgeon inhabiting the Connecticut River below the Turners
33 Fall Dam. Therefore, impacts associated with the operation of VYNPS, located 20 mi upstream,
34 are too far removed to adversely affect this species.

35
36 There are no plans to conduct refurbishment or construction activities at VYNPS. Therefore, the
37 NRC staff has concluded that continued operation of the plant during the license renewal term
38 will have no effect of the dwarf wedgemussel or the shortnose sturgeon. Thus, it is the NRC
39 staff's finding that the impacts on threatened or endangered aquatic species from an additional
40 20 years of operation of VYNPS would be SMALL and no additional mitigation is warranted.
41

Environmental Impacts of Operation

4.6.2 Terrestrial Species

FWS (2006) stated that, except for the bald eagle (*Haliaeetus leucocephalus*), no other Federally listed or proposed threatened or endangered species under FWS jurisdiction are known to occur within the VYNPS area and the areas of transmission lines within the scope of license renewal, and that operations during the license renewal term would not adversely affect Federally listed species under FWS jurisdiction. They concluded that preparation of a biological assessment or further consultation under Section 7 of the Endangered Species Act (ESA) would not be required.

Bald eagles can occur in the VYNPS area throughout the year, are known to use the site for foraging and roosting, and nest less than 1 mi downstream of the site near the Vernon Dam. During the winter, open water near the discharge canal could attract foraging eagles that would otherwise leave the area. This close proximity to the site increases the potential for interactions between the bald eagle and VYNPS, but adverse effects are not considered likely. The bald eagle may benefit from the maintenance of open water near the plant's discharge during the winter, as this may provide additional foraging opportunities for the species.

Transmission lines pose a potential collision hazard to migrant and resident bird species, including the bald eagle. In the GEIS, the NRC assessed the impacts of transmission lines on avian populations (NRC 1996). The NRC concluded that mortality resulting from bird collisions with transmission lines associated with an additional 20 years of operation would be of SMALL significance (see Section 4.2). This conclusion was based on (1) no indication in the existing literature that collision mortality is high enough to result in population-level impacts, and (2) the lack of known instances where nuclear power plant lines affect large numbers of individuals in local areas. Continued operation of VYNPS and operation and maintenance of the VYNPS-to-Coolidge and VYNPS-to-Chestnut Hill transmission lines during the license renewal period are not likely to adversely affect the bald eagle.

The Indiana bat is not known to occur at the VYNPS site or along associated transmission lines, but potential habitat occurs within the project area. It should be noted, however, that this species is difficult to detect without conducting specialized surveys, and such surveys of the site and vicinity have not been conducted. License renewal and continued operations of VYNPS are not likely to adversely affect the Indiana bat for several reasons. No refurbishment is considered necessary during the license renewal period at the VYNPS site (Entergy 2006a), and, therefore, significant land disturbance during that period is not considered likely. However, any activities during the renewal period that could result in land disturbance would undergo a predisturbance evaluation and consideration of impacts on threatened and endangered species. Vegetation management within the transmission line rights-of-way (ROWs) prevents the establishment of large trees within the ROWs that could be used by the Indiana bat. Only dangerous trees in the border zone of the ROWs are removed during routine vegetation management. This greatly limits the likelihood that a tree used by Indiana bats for roosting or

1 nursery habitat would be affected. On the basis of these considerations, continued operation of
2 VYNPS during the license renewal period would not be expected to adversely affect the Indiana
3 bat.

4
5 The two Federally listed plant species, Jesup's milk-vetch and northeastern bulrush, are not
6 expected to be adversely affected by VYNPS license renewal. Jesup's milk-vetch occurs only in
7 an area along the Connecticut River approximately 50-mi upstream of the VYNPS site. The site
8 is not affected by VYNPS operations nor by operation and maintenance of the transmission
9 lines within the scope of license renewal. Although not known to occur within either of the
10 transmission line corridors, the northeastern bulrush occurs in wetlands of both counties
11 traversed by transmission lines within the scope of license renewal. ROW maintenance is not
12 expected to adversely affect this species because herbicides are not used by maintenance
13 crews near wetlands and any hand-clearing of vegetation would increase the openness of
14 habitats, which should benefit this species. Surveys conducted prior to any land disturbance on
15 the VYNPS site, as required by site environmental review procedures, would ensure that any
16 previously undetected populations of this species could be avoided.
17

18 Continued operations and transmission line maintenance during the license renewal term are
19 not expected to adversely affect State-listed threatened or endangered species (Table 2-11).
20 No refurbishment is considered necessary during the license renewal period at the VYNPS site
21 (Entergy 2006a), and, therefore, significant land disturbance during that period is not considered
22 likely. However, environmental review procedures in place at VYNPS ensure the consideration
23 of impacts on threatened and endangered species of any activities that could result in land
24 disturbance. Maintenance procedures for transmission line ROWs limits vegetation clearing to
25 that needed to ensure line safety, and cutting and herbicide use near wetlands or stream
26 crossings (where many of the State-listed species are found) is limited (cutting) or prohibited
27 (herbicide). State-listed species adapted to more open habitats could benefit from transmission
28 line maintenance practices that maintain openings.
29

30 In conclusion, it is the NRC staff's finding that the impact on threatened or endangered
31 terrestrial species of an additional 20 years of operation of VYNPS and the VYNPS-to-Coolidge
32 and VYNPS-to-Chestnut Hill transmission line would be SMALL and no additional mitigation is
33 warranted.
34

35 **4.7 Evaluation of New and Potentially Significant 36 Information on Impacts of Operations During the 37 Renewal Term**

38

39 During the scoping period, comments indicated concern about the effects of biocides present in
40 the cooling tower drift during the license renewal period. This issue is discussed in
41 Section 4.7.1. Concerns were also expressed during the scoping period suggesting that

Environmental Impacts of Operation

1 thermal discharges to the Connecticut River from the VYNPS during the renewal period would
2 adversely affect migratory fish species. This issue is discussed in Section 4.7.2.
3

4 4.7.1 Evaluation of Potential New and Significant Information Concerning 5 Biocides in Cooling Water Drift

7 As discussed in Section 2.3.1, water treatment chemicals that contain Vermont-listed hazardous
8 air contaminants (HACs) are in use in the circulating water system. Releases of Category III
9 HACs to the atmosphere are the result of biocides (Nalco H-550 and Spectrue NX-1104) being
10 present in "drift" from the cooling tower.^(a) For all of the Category III HACs involved, the
11 calculated releases were substantially below the respective action levels (both expressed as
12 lb/8-hr period): 0.002 vs. 0.025 for dodecylguanidine, 0.001 vs. 2330 for ethyl alcohol, 0.001 vs.
13 4120 for isopropyl alcohol, and 0.015 vs. 340 for glutaraldehyde.

14
15 VYNPS has discontinued the use of Nalco H-550 (DeWald 2006) but will continue to use
16 Spectrue NX-1104. Entergy has requested approval for a number of additional water treatment
17 chemicals in its application to the State for a new NPDES permit (Entergy 2005e). If approval
18 for use is granted through the issuance of a new NPDES, and in accordance with air pollution
19 regulations, Entergy will identify the HACs present in each of the approved chemicals and will
20 ensure that all subsequent annual reports to the State regarding HAC releases include
21 calculations for each HAC for which there is the potential for release to the atmosphere as drift
22 from the cooling tower (DeWald 2006). The operating conditions of the cooling tower are not
23 expected to change significantly, and, therefore, the drift rate can be expected to remain
24 generally the same as was reported for calendar year 2005.

25
26 Drift from the cooling tower has the potential to contain such HACs; thus, such drift constitutes a
27 release to the atmosphere. A member of the public at the June 07, 2006 public scoping
28 meeting expressed concern over exposure to a specific HAC, glutaraldehyde, known to be
29 present in one of the biocides formerly in use. The most recent data indicates that the amount
30 of glutaraldehyde released to the atmosphere was well below the state action level. Further,
31 the facility has indicated that it has discontinued the use of this particular biocide, so the
32 potential for future releases of glutaraldehyde from the use of that biocide has been eliminated.

33
34 Beyond the concern expressed in the comment, however, the NRC staff realizes that there is a
35 broader issue regarding the potential for release of other HACs contained in water treatment
36 chemicals in cooling tower drift. The staff determined the facility is aware of the potential for
37 such releases and has performed the necessary calculations and made the required emission
38 reports to the State regarding the releases of HACs from the cooling towers. Data discussed

(a) Cooling tower drift is the result of the entrainment of cooling water droplets in the air being exhausted from a wet counter-flow-designed cooling tower such as the one being operated by VYNPS.

above indicate that all of the HACs present in the cooling water were released in drift at concentrations well below the state action levels. Because cooling tower operating conditions are not expected to change in the foreseeable future, the drift rate is expected to remain essentially unchanged, and equilibrium concentrations of water treatment chemicals are expected to be low. Consequently, even though there may be changes to the water treatment chemicals used in the future, the magnitudes of releases of such chemicals in cooling tower drift can be expected to remain relatively small. Further, it is expected that cooling tower drift will fall to the ground in the immediate vicinity of the cooling tower; thus, pathways of exposures to the general public do not practically exist.

For the reasons stated above, the concerns expressed during the scoping period do not represent information that would be considered new and significant relative to HACs released in cooling tower drift, as the impacts resulting from their release due to continued operation of VYNPS are SMALL.

4.7.2 Evaluation of Potential New and Significant Information Concerning Thermal Discharges to the Connecticut River

During the scoping period, the NRC staff received comments from members of the public and public interest groups suggesting that thermal discharges to the Connecticut River from the VYNPS during the renewal period would adversely affect migratory fish species. In particular, concerns were raised that thermal discharges from VYNPS' cooling system would affect both the spawning migration and outmigration of juveniles and post-spawning adults for American shad and Atlantic salmon. It was suggested that upstream movement of adults of both species could be disrupted or denied by the thermal plume in the vicinity of the VYNPS. Fish could become confused by the elevated temperature at the entrance to the Vernon Dam fish ladder or water temperatures could be above the avoidance limits for the species. Conversely, during downstream movement, fish could be delayed due to avoidance of the thermal plume. Concerns were expressed that any delays in outmigration could result in physiological changes to individuals that may ultimately affect their survival during the transition from a freshwater to a marine environment. Also, it was believed that delayed outmigration could result in American shad acclimatizing to warmer water temperatures and then experiencing cooler ambient river temperatures near or at their lower tolerance limit as they resume downstream movement.

It has been suggested that thermal plumes could constitute a barrier to migrating fish if the thermal mixing zone covers all or a substantial cross sectional area of the river and/or exceeds thermal tolerance limits. Conversely, impacts from thermal plumes are considered to be of small significance if fish migrations are not blocked and populations of aquatic organisms in the vicinity of the plant are not reduced (NRC 1999). As thermal plume barriers have not been observed to be a problem at any existing nuclear power plant, the NRC staff determined that thermal plume barriers to migrating fish are classified as a Category 1 issue (NRC 1996). In the 1980s, a study, known as Project SAVE (Save Available Vermont Energy) was conducted at

Environmental Impacts of Operation

VYNPS to evaluate the effects of thermal discharge, impingement, and entrainment on aquatic resources (Aquatec 1990). As part of Project SAVE, migration of anadromous species was evaluated. No correlation was found between the operation of VYNPS and the size of the American shad run through the Vernon Dam fishway. Also, no large exclusionary areas to American shad were found as a result of plant operations (Aquatec 1990). As most American shad move in the lower half of the water column (Witherell and Kynard 1990), they are unlikely to be deterred by a surface discharge thermal plume at the surface (NRC 1996). As no statistical differences were observed in American shad counts at Vernon Dam before, during, and following power outages at VYNPS, it was concluded that upstream migration of shad was not affected by thermal discharges from the plant (Normandeau 2004).

Similarly, no blockages of adult Atlantic salmon past Vernon Dam due to VYNPS operations were observed during Project SAVE (Aquatec 1990). Seventy-five percent of the adult Atlantic salmon that passed Turners Falls Dam passed the Vernon Dam fishway; while radiotelemetry studies of smolts revealed that downstream movement into and through the VYNPS thermal plume occurred without any observed delays (Aquatec 1990). Most Atlantic salmon smolt migration past VYNPS is completed by early June. Therefore, downstream migration past the VYNPS is completed before the upper limit for feeding of 72.5°F or 7-day upper limit for survival of 82°F is exceeded (Normandeau 2004). Atlantic salmon smolts migrating past VYNPS would not be subjected to elevated temperatures for more than 12 hr, and could avoid the warmest waters by swimming around or under the plume (Normandeau 2004).

American shad comprised 0.7 percent of electroshocking catches above Vernon Dam between 1991 and 2002; while no Atlantic salmon were collected. During these years, only two American shad larvae were collected in ichthyoplankton samples collected near the VYNPS intake (Normandeau 2004). As discussed in Section 4.1.3, impingement of American shad and Atlantic salmon at VYNPS has always been well below annual limits stipulated in the NPDES permit. These results imply that these species do not frequent lower Vernon Pool; therefore, suggesting that the thermal plume from VYNPS does not delay movements of American shad or Atlantic salmon or function as an attraction to these species.

Upstream passage of American shad has been very successful at Vernon Dam. For example, between 1995 and 2002, counts of American shad at the Vernon Dam fishway were over 71 percent of those counted at the Turners Falls Dam fishway. In comparison, counts at Turners Falls Dam were only 3.6 percent of those at Holyoke Dam (Normandeau 2004). This supports the finding that VYNPS operations have a minimal impact on American shad migrations, especially in comparison to passage problems at Turners Falls Dam. Similarly, most adult Atlantic salmon that pass Turners Falls Dam have been found to pass Vernon Dam, with most continuing on to be counted at Bellows Falls Dam. Section 2.2.5 provides further discussion on migratory fish species passage at these dams.

As discussed in Section 2.2.5, the decreases in American shad that have been observed in the Connecticut River since the early 1990s have not been confined to the river, but have been observed throughout the Atlantic coast. Recovery of the striped bass population has likely increased predatory pressure on American shad. This factor coupled with excessive commercial harvests within the estuaries and Atlantic Ocean are believed to be primarily responsible for decreases in this species of shad. Similarly, spawning run declines of Atlantic salmon have occurred throughout the range of the species. As discussed in Section 2.2.5, this decline is thought to be due to impacts that occur while the Atlantic salmon is in the sea.

Overall, none of the observed changes in fish community composition or distribution in over 30 years of study of the aquatic resources in lower Vernon Pool and upper Turners Falls Pool can be reasonably attributed to operations of VYNPS (Normandeau 2004). Modeling of thermal discharges from VYNPS indicated that most of the eastern half of Vernon Pool near Vernon Dam would experience minimal elevated temperatures (Swanson et al. 2005) therefore preventing the establishment of a thermal barrier to in- or out- migration. Also, solar radiation contributes to much of the difference in river temperatures between the monitoring station upstream of VYNPS and the monitoring station downstream of Vernon Dam (Normandeau 2004). The highest temperatures that outmigrating fish would experience would be in the immediate area of Vernon Dam near the fishways. It would only take a short time (e.g., minutes to seconds) for them to pass through this area. When the fishways are operational, temperature differentials are well within thermal tolerance limits of the migratory species. The NPDES permit for VYNPS contains operational and temperature limits to protect water quality and minimize impacts to aquatic biota. No observable adverse impacts to any fish species or to the overall fish community of Vernon Pool due to thermal discharges from VYNPS have been demonstrated since VYNPS began commercial operations (Aquatec 1978, 1990; Entergy and Normandeau 2004; Normandeau 2005; Entergy 2006a). For example, neither decreases in the growth rates of resident fish species nor delays in movement of migratory species due to the VYNPS thermal plume have been observed (Aquatec 1990; Normandeau 2004).

For the reasons stated above, the concerns expressed during the scoping period do not represent information that would be considered new and significant or call into question the NRC staff's conclusions that impacts on the migration of fish from continued operation of VYNPS are SMALL.

4.8 Cumulative Impacts

The NRC staff considered potential cumulative impacts in its environmental analysis of operations of VYNPS. For the purposes of this analysis, past actions are those related to the resources at the time of the plant licensing and construction, present actions are those related to the resources at the time of current operation of the power plant, and future actions are considered to be those that are reasonably foreseeable through the end of plant operation, which would include the 20-year license renewal term. Therefore, the analysis considers

Environmental Impacts of Operation

1 potential impacts through the end of the current license term as well as the 20-year renewal
2 license term. The geographical area over which past, present, and future actions would occur is
3 dependent on the type of action considered and is described below for each impact area.

4
5 The impacts of the proposed action, as described in Sections 4.1 through 4.6, are combined
6 with other past, present, and reasonably foreseeable future actions regardless of what agency
7 (Federal or non-Federal) or person undertakes such other actions. These combined impacts
8 are defined as "cumulative" in 40 CFR 1508.7 and include individually minor but collectively
9 significant actions taking place over a period of time. It is possible that an impact that may be
10 SMALL by itself could result in a MODERATE or LARGE impact when considered in
11 combination with the impacts of other actions on the affected resource. Likewise, if a resource
12 is regionally declining or imperiled, even a SMALL individual impact could be important if it
13 contributes to or accelerates the overall resource decline.

14 **4.8.1 Cumulative Impacts on Aquatic Resources**

15
16 For the purposes of this analysis, the geographic area considered for cumulative impacts
17 resulting from operation of the cooling system at VYNPS is primarily the portion of the
18 Connecticut River between Turners Falls Dam (RM 123) and Vernon Pool up to Brattleboro,
19 Vermont (RM 149), although the entire Connecticut River was also considered, especially in
20 regard to migratory fish species. As discussed in Section 4.1, the NRC staff found no new and
21 significant information to indicate that the conclusion regarding any of the Category 1 issues
22 related to the cooling system at VYNPS is inconsistent with the conclusions in the GEIS (NRC
23 1996). Additionally, the NRC staff determined that none of the Category 2 issues related to the
24 cooling system (i.e., entrainment, impingement, and thermal shock) would have greater than a
25 SMALL impact on aquatic resources. The transmission line right-of-way maintenance activities
26 in the vicinity of stream and river crossings employ procedures to minimize erosion and
27 shoreline disturbance while encouraging vegetative cover. Therefore, impacts from the
28 transmission lines associated with the VYNPS would have a negligible impact on aquatic
29 resources near VYNPS.

30
31
32 The cumulative impacts of past actions have resulted in the existing water quality and aquatic
33 resource conditions near VYNPS. The major changes and modifications within the Connecticut
34 River that have resulted in the greatest impacts on aquatic resources include physical and
35 chemical stresses and introduced species. The physical and chemical stresses include urban,
36 industrial, and agricultural contaminants (e.g., nutrients, toxic chemicals, sediment); land-use
37 changes (e.g., residential, agricultural, and industrial development); acid rain and
38 channelization; and dams and associated impoundments (Center for the Environment 2004;
39 Connecticut River Watershed Council undated; Field 2005). These stresses can affect fish,
40 benthic macroinvertebrates, and plankton populations; cause a loss of habitat; and contaminate
41 fish, which leads to restrictions on human consumption. Dam construction began in the 1800s
42 and resulted in the reduction of the distribution and/or extirpation of migratory species within the

Environmental Impacts of Operation

1 Connecticut River. Upstream passage restoration began in the 1970s, and downstream
2 passage restoration began in the 1980s (Boubee and Haro 2003). In addition to dams blocking
3 fish movement, both migratory and resident fishes could be damaged or killed by turbine
4 passage. For example, various estimates of mortality for the American shad range from 1 to
5 10 percent to as high as 90 percent (Savoy et al. 2004). Other than the hydroelectric dams, no
6 significant diversions of water pose a threat to migratory fishes (Gephard and McMenemy
7 2004). Thermal plumes from other power plants along the Connecticut River can affect aquatic
8 species, particularly migratory fishes (AEC 1972).

9
10 The river water supply is adequate to meet the needs of VYNPS for cooling purposes under all
11 flow conditions. The NRC staff, while preparing this assessment, assumed that other industrial,
12 commercial, or public installations could be located in the general vicinity of VYNPS prior to the
13 end of VYNPS operations. Any discharge of water by such facilities into the Connecticut River
14 would be regulated by the VANR. They set discharge limits considering the overall or
15 cumulative impact of all other regulated activities in the area. Compliance with the CWA and its
16 NPDES permit minimizes the cumulative impacts that VYNPS would have on aquatic resources.
17 Continued operation of VYNPS would require renewed discharge permits from the VANR, which
18 would address changing requirements so that cumulative water quality objectives would be
19 served.

20
21 The VYNPS is located within a reach of the Connecticut River, which serves as a migratory
22 corridor that links spawning and rearing habitats for several migratory fish species, including the
23 anadromous American shad, Atlantic salmon, blueback herring, sea lamprey, and the
24 catadromous American eel (VANR 2005). All of these species were extirpated from some or
25 most of the river as a result of dams. However, since the construction of fish ladders at the
26 dams, these species have been undergoing restoration as part of the Anadromous Fish
27 Restoration Program, which is a cooperative effort among the States of Connecticut,
28 Massachusetts, New Hampshire, and Vermont, as well as the U.S. Bureau of Sport Fisheries
29 and Wildlife and the U.S. Bureau of Commercial Fisheries (Entergy 2006a). The increased
30 abundance of striped bass in the estuary and lower reaches of the Connecticut River may be
31 partly responsible for the dramatic drop in the number of American shad and blueback herring
32 that have occurred in the Connecticut River (and other East Coast river systems) since 1992
33 (Savoy and Crecco 2004).

34
35 Future contributions to cumulative impacts to aquatic resources within the Connecticut River
36 would generally occur from those actions that currently cause impacts (e.g., human habitation,
37 urban and industrial development, agriculture, commercial, and recreational fisheries). The
38 potential also exists for the expansion of non-native species that already occur in the
39 Connecticut River, and for additional non-native species to become established within the river.
40 Among the species introduced into the Connecticut River (Connecticut River Atlantic Salmon
41 Commission 1998), those prevalent in the area near VYNPS include the rock bass, bluegill,
42 smallmouth bass, largemouth bass, common carp, white catfish, channel catfish, and walleye.

Environmental Impacts of Operation

The dwarf wedgemussel and shortnose sturgeon are the only Federally listed aquatic species that are reported from the Connecticut River in the area being considered for cumulative impacts. As mentioned in Section 2.2.5, past actions that have adversely affected these species have included siltation, impoundments, and contaminants. The introduction or spread of the zebra mussel (*Dreissena polymorpha*) or Asiatic clam (*Corbicula fluminea*) within the Connecticut River would have the potential to adversely affect the dwarf wedgemussel and other native mussel species. As discussed in Section 4.6.1, existing populations of the dwarf wedgemussel and shortnose sturgeon are too far removed from VYNPS for plant operations to contribute to the cumulative impacts that affect these species. Additionally, entrainment, impingement, and thermal discharges have only minimal localized impact on species that would be suitable hosts for the glochidia of the dwarf wedgemussel.

Because the aquatic resources of the Connecticut River are influenced by many controlling factors, the incremental contributions of VYNPS operations cannot be quantified precisely without additional investigations. It is likely, however, that VYNPS impacts are localized and have a minimal contribution to the cumulative impact on aquatic resources in the Connecticut River. The NRC staff concludes that the cumulative impact of continued operation of the VYNPS cooling system on aquatic resources in the Connecticut River would be SMALL and no additional mitigation is warranted. However, under the provisions of the CWA 316(b) Phase II regulations, the VDEC may impose further restrictions or require modifications to the cooling system to reduce the impacts on aquatic resources from entrainment and impingement.

In addition to the assessment above, the NRC contacted the NMFS to determine if any species needed to be evaluated under the essential fish habitat provisions of the Magnuson-Stevens Fishery Conservation and Management Act (NRC 2006c). The NMFS indicated that the Connecticut River and tributaries are designated essential fish habitat for Atlantic salmon; therefore, the NMFS instructed the NRC to evaluate the impact of the operation of VYNPS on the essential fish habitat of the Atlantic salmon (NMFS 2006). An assessment of the essential fish habitat for the Atlantic salmon, which is being provided to the NMFS for review, is included in Appendix E of this SEIS.

4.8.2 Cumulative Impacts on Terrestrial Resources

This section analyzes past, present, and future actions that could result in adverse cumulative impacts on terrestrial resources, including wildlife populations, upland habitat, wetlands, floodplains, and land use. For the purposes of this analysis, the geographic area that encompasses the past, present, and foreseeable future actions that could contribute to adverse cumulative impacts on terrestrial resources includes Windham County, Vermont, and Cheshire County, New Hampshire, which contain VYNPS and its associated transmission lines. VYNPS and its associated transmission lines occupy a very small percentage of the overall land area of the two counties (0.24 and 0.02 percent, respectively).

Past land-use changes include construction of the VYNPS facility and the VYNPS-to-Coolidge and VYNPS-to-Chestnut Hill transmission lines. While some expansion of commercial and residential development has occurred in the area since the station was built in the late 1960s, the area remains fairly rural and undeveloped. Continued operations during the license renewal term are not expected to result in a change in land use, development rates, or terrestrial habitat loss in the area.

As described in Section 2.2.6, several small wetland areas that are ranked by the State as Category 3 wetlands (i.e., they are not considered significant for providing wetland functions) are present on the site. In addition, some relatively undisturbed terrestrial habitats exist on the station (e.g., mixed and deciduous woodland and riparian habitat). No impacts to these wetland or terrestrial habitats are anticipated during the license renewal term, and any activities would be reviewed for impacts prior to implementation.

Four Federally listed threatened or endangered terrestrial species are listed for the two-county project area, but there is no critical habitat designated in either county (Section 2.2.6.2). The FWS determined that the bald eagle was the only Federally listed species known to occur in the vicinity of VYNPS facilities (FWS 2006). In addition, FWS determined that no impacts to the eagles are known to occur that could be attributed to VYNPS or its transmission lines.

On the basis of these considerations, the NRC staff concludes that the incremental contribution of VYNPS operations to cumulative impacts on terrestrial resources, including terrestrial threatened or endangered species, is SMALL, and that operations of VYNPS during the license renewal term would not result in a change to current levels of cumulative impact. No additional mitigation is warranted.

4.8.3 Cumulative Human Health Impacts

The radiological dose limits for protection of the public and workers have been developed by the EPA and the NRC to address the cumulative impact of acute and long-term exposure to radiation and radioactive material. These dose limits are codified in 40 CFR Part 190 and 10 CFR Part 20. For the purpose of this analysis, the area within a 50-mi radius region of interest (ROI) of the VYNPS site was included. There are no other operating nuclear fuel cycle facilities within the 50-mi ROI. The Yankee Rowe nuclear reactor, which is located about 30 mi to the west-southwest of VYNPS in Greenfield, Massachusetts, was permanently shut down on October 1, 1991. It is undergoing decommissioning. One other nuclear fuel-cycle facility, the 50-mi ROI of which intersects with the 50-mi ROI of VYNPS, is Haddam Neck nuclear power plant located approximately 90 mi south of VYNPS in East Hampton, Connecticut. This plant is also shut down and is currently undergoing decommissioning. A research and test reactor that was operated by Combustion Engineering for the U.S. Navy in Windsor, Connecticut

Environmental Impacts of Operation

(approximately 75 mi away from VYNPS), is also in final stages of decommissioning. Because of their distance and nonoperational status, these nuclear facilities are not expected to contribute to the cumulative impacts at or near the VYNPS.

As stated in Section 2.2.7, the owners of VYNPS have conducted a radiological environmental monitoring program (REMP) around the VYNPS site since 1970, with the results presented annually in the VYNPS Annual Radiological Environmental Operating Report (Entergy 2006d). In addition, the Vermont Department of Health, Division of Health Protection, has conducted an environmental surveillance program in the vicinity of VYNPS since 1971 (VDH 2006). Both the REMP and the State of Vermont VYNPS Surveillance Program measure radiation and radioactive materials from all sources, including VYNPS emissions, and thus consider cumulative radiological impacts. On the basis of an evaluation of results from both of these programs and considering the effects of the extended power uprate and the dry fuel storage facility onsite, the NRC staff concluded in Sections 2.2.7 and 4.3 that impacts of radiation exposure on the public and workers (occupational) from operation of VYNPS during the renewal term would be SMALL. The NRC staff is not aware of any plans or proposals for new nuclear facilities in the vicinity of VYNPS that would potentially contribute to cumulative radiological impacts. Therefore, the NRC staff concludes that future cumulative radiological impacts would be SMALL and no additional mitigation is warranted. The NRC and States of Vermont, New Hampshire, and Massachusetts would regulate any future actions in the vicinity of the VYNPS site that could contribute to cumulative radiological human health impacts.

The staff determined that the electric-field-induced currents from the VYNPS transmission lines are well below the National Electrical Safety Code (NESC) recommendations for preventing electric shock from induced currents. Therefore, the VYNPS transmission lines do not detectably affect the overall potential for electric shock from induced currents within the analysis area. With respect to chronic effects of electromagnetic fields, although the NRC staff considers the GEIS finding of "not applicable" to be appropriate in regard to VYNPS, the VYNPS transmission lines are not likely to detectably contribute to the regional exposure to extremely low frequency-electromagnetic fields (ELF-EMFs). The VYNPS transmission lines pass through a sparsely populated, rural area with very few residences or businesses close enough to the lines to have detectable ELF-EMFs. Therefore, the NRC staff has determined that the cumulative impacts of the continued operation of the VYNPS transmission lines will be SMALL and no additional mitigation is warranted.

4.8.4 Cumulative Socioeconomic Impacts

The continued operation of VYNPS is not likely to result in significant cumulative impacts for any of the socioeconomic impact measures assessed in Section 4.4 of this SEIS (public services, housing, and offsite land use). This is because operating expenditures, staffing levels, and local tax payments during renewal would be similar to those during the current license period.

When combined with the impact of other potential activities likely in the area surrounding the plant, socioeconomic impacts resulting from VYNPS license renewal would not produce an incremental change in any of the impact measures used. The NRC staff therefore determined that the impacts on employment, personal income, housing, local public services, utilities, and education occurring in the local socioeconomic environment as a result of license renewal activities, in addition to the impacts of other potential economic activity in the area, would be SMALL. The NRC staff determined that the impact on offsite land use would be SMALL because no refurbishment activities are planned at VYNPS and no new incremental changes to plant-related tax payments are expected that could influence land use by fostering considerable growth. The impacts of license renewal on transportation and environmental justice would also be SMALL. There are no reasonably foreseeable scenarios that would alter these conclusions in regard to cumulative impacts.

Although archaeological surveys at the VYNPS have failed to identify intact archaeological sites, and the potential exists for significant cultural resources to be present within the site boundaries due to its location on the Connecticut River floodplain, it does not appear likely that the proposed license renewal would adversely affect these resources. The applicant has indicated that no refurbishment or replacement activities, including additional land-disturbing activities, at the plant site (or along existing transmission corridors) are planned for the license renewal period (Entergy 2006a). Absent land-disturbing activities, continued operation of VYNPS would likely protect any cultural resources present within the VYNPS site boundary by protecting those lands from development and providing secured access. Prior to a ground-disturbing activity in an undisturbed area, it is expected the applicant would evaluate the potential for impacts on cultural resources in consultation with the SHPO and appropriate Native American Tribes, as required under Section 106 of the National Historic Policy Act; therfore, the contribution to a cumulative impact on cultural resources by continued operation of VYNPS during the license renewal period would be SMALL.

4.8.5 Cumulative Impacts on Groundwater Use and Quality

The geographic range of analysis for cumulative impacts on groundwater would encompass wells completed in the unconsolidated glacial and fluvial sediments making up the unconfined aquifer to a depth of about 30 to 70 ft and the underlying Ordovician gneiss and granitic intrusives of the Oliverian Plutonic and New Hampshire Plutonic Series (Entergy 2005b, Buckley 2006).

Groundwater in the region generally flows towards the Connecticut River, but fluctuates depending on precipitation and water level changes in the river. Well users in the vicinity rely on wells completed in the glacial deposits. Deeper wells, which go into the underlying bedrock, generally have lower yields (AEC 1972, Entergy 2004).

Environmental Impacts of Operation

VYNPS draws its potable water supply from four onsite wells completed at depths greater than 350 ft (as listed in Table 2-1). Based on usage in 2002 and 2003, the maximum demand for these wells is about 8.54 gpm, well below the Category 2 threshold of 100 gpm for groundwater use. The facility does not have plans for further groundwater development, either by increased pumping or installation of additional wells. Compared to regional water withdrawal rates and projected increases, VYPNS operational uses are considered inconsequential.

As described in Section 2.2.3.2, site exceedences of groundwater standards have included petroleum compounds. However, the areal extent of contamination remains on the facility's property, and various remedial activities (e.g., free product recovery) and monitoring systems are operating under State regulation. Therefore, the contamination does not contribute to offsite regional groundwater impacts. This is also true of discharges related to the plant's sewage treatment and disposal systems.

On the basis of actual and planned pumping rates and the fact that increasing groundwater extraction would require State approval, the NRC staff concludes that the plant's contribution to cumulative impacts on groundwater resources through water usage would be minor and no additional mitigation is warranted. On the basis of groundwater quality, the NRC staff concludes that the plant's contributions to cumulative impacts on the quality of local groundwater resources also would be inconsequential. As long as remediation and monitoring continue, where necessary, under State regulatory oversight, no additional mitigation is warranted.

4.8.6 Conclusions Regarding Cumulative Impacts

The NRC staff considered the potential impacts resulting from operation of VYNPS during the license renewal term and other past, present, and future actions in the vicinity of VYNPS. The NRC staff's determination is that the potential cumulative impacts resulting from VYNPS operation during the license renewal term would be SMALL.

4.9 Summary of Impacts of Operations During the Renewal Term

Neither Entergy nor the NRC staff is aware of information that is both new and significant related to any of the applicable Category 1 issues associated with VYNPS operation during the renewal term. Consequently, the NRC staff concludes that the environmental impacts associated with these issues are bounded by the impacts described in the GEIS. For each of these issues, the GEIS concluded that the impacts would be SMALL, and that additional plant-specific mitigation measures would not likely be sufficiently beneficial to warrant implementation.

1 Plant-specific environmental evaluations were conducted for 14 Category 2 issues applicable to
2 VYNPS operation during the renewal term as well as for environmental justice and chronic
3 effects of electromagnetic fields. For 13 issues and environmental justice, the NRC staff
4 concludes that the potential environmental impact of renewal term operations of VYNPS would
5 be of SMALL significance in the context of the standards set forth in the GEIS and no additional
6 mitigation is warranted. For Federally listed threatened and endangered species, the NRC
7 staff's conclusion is that the impact resulting from license renewal would be SMALL and that
8 further investigation is not warranted. In addition, the NRC staff determined that a consensus
9 has not been reached by appropriate Federal health agencies regarding chronic adverse effects
10 from electromagnetic fields.

11 Cumulative impacts of past, present, and reasonably foreseeable future actions were
12 considered, regardless of what agency (Federal or non-Federal) or person undertakes such
13 other actions. The NRC staff concluded that the impacts of continued operation of VYNPS
14 during the license renewal period would not result in significant cumulative impacts on
15 potentially affected resources.

18 **4.10 References**

19
20 10 CFR Part 20. *Code of Federal Regulations*, Title 10, Energy, Part 20, "Standards for
21 Protection Against Radiation."

22
23 10 CFR Part 51. *Code of Federal Regulations*, Title 10, Energy, Part 51, "Environmental
24 Protection Regulations for Domestic Licensing and Related Regulatory Functions."

25
26 40 CFR Part 190. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 190,
27 "Environmental Radiation Protection Standards for Nuclear Power Operations."

28
29 American Eel Plan Development Team. 2000. "Interstate Fishery Management Plan for
30 American Eel (*Anguilla rostrata*).” Atlantic States Marine Fisheries Commission, Washington,
31 D.C. April. Available URL: <http://www.asmfc.org/speciesDocuments/eel/fmps/eel/FMP.pdf>
32 (Accessed July 26, 2006).

33
34 Aquatec Inc. (Aquatec). 1978. *Executive Summary 316 Demonstration Vermont Yankee*
35 *Nuclear Power Station – Biological, Hydrological & Engineering Information*. Aquatec Inc.,
36 South Burlington, Vermont. (March 1978).

37
38 Aquatec Inc. (Aquatec). 1990. *316 Demonstration Vermont Yankee Nuclear Power Station*
39 *Connecticut River Vernon, Vermont – Biological, Hydrological & Engineering Information*.
40 Aquatec Inc., South Burlington, Vermont. (June 1990).

Environmental Impacts of Operation

- 1 Boubee, J., and A. Haro. 2003. "Downstream Migration and Passage Technologies for
2 Diadromous Fishes in the United States and New Zealand: Tales from Two Hemispheres."
3 Downstream Movement of Fish in the Murray-Darling Basin – Canberra Workshop. June.
4 Available URL: http://www.mdbc.gov.au/_data/page/509/Jacques_Boubee_&_Alex_Haro.pdf
5 (Accessed July 26, 2006).
- 6
- 7 Buckley, R.N. 2006. E-mail communication from R.N. Buckley, Entergy, to D.S. Miller, Argonne
8 National Laboratory. (May 30, 2006).
- 9
- 10 Center for the Environment. 2004. "Connecticut River." Mount Holyoke College, Center for the
11 Environment, South Hadley, Massachusetts. Available URL:
12 http://www.mtholyoke.edu/proj/cel/ref/place/natplaces/conn_river.shtml
13 (Accessed April 6, 2006).
- 14
- 15 Centers for Disease Control and Prevention (CDC). 2005. "Legionellosis: Legionnaires'
16 Disease (LD) and Pontiac Fever." Atlanta, Georgia. Available URL:
17 http://www.cdc.gov/ncidod/dbmd/diseaseinfo/legionellosis_g.htm (Accessed August 22, 2006).
- 18
- 19 Cherry, D.S., K.L. Dickson, and J. Cairns, Jr. 1975. "Temperatures Selected and Avoided by
20 Fish at Various Acclimation Temperatures." *Journal of Fisheries Research Board of Canada*,
21 Vol. 32, pp. 485–491.
- 22
- 23 Connecticut River Atlantic Salmon Commission. 1998. "Strategic Plan for the Restoration of
24 Atlantic Salmon to the Connecticut River." Connecticut River Atlantic Salmon Commission,
25 Sunderland, Massachusetts. July. Available URL:
26 <http://www.fws.gov/r5crc/documents/strplan.pdf> (Accessed April 6, 2006).
- 27
- 28 Connecticut River Watershed Council. Undated. "About the River." Connecticut River
29 Watershed Council, Greenfield, Massachusetts. Available URL:
30 http://www.ctriver.org/about_river/issues.html (Accessed July 31, 2006).
- 31
- 32 Council on Environmental Quality (CEQ). 1997. *Environmental Justice: Guidance Under the
33 National Environmental Policy Act*. Executive Office of the President, Washington, D.C.
- 34
- 35 Deacon, J. 2003. "The Microbial World: Thermophilic Microorganisms." The University of
36 Edinburgh, Institute of Cell and Molecular Biology, Edinburgh, United Kingdom. Available URL:
37 <http://helios.bto.ed.ac.uk/bto/microbes/thermo.htm> (Accessed August 22, 2006).
- 38
- 39 DeWald, L. 2006. Average Connecticut River Discharge (cfs) at Vernon Station for the Year
40 2005. L. DeWald, Entergy, to T. Patton, Argonne National Laboratory. (May 24, 2006).
- 41

Environmental Impacts of Operation

1 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2004.
2 *Vermont Yankee Nuclear Power Station, Updated Final Safety Analysis Report, Rev. 19.*

3
4 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2005a.
5 *Application for NPDES Permit Renewal 2006-2010.* Entergy Nuclear Operations, Inc., Vernon,
6 Vermont. (September 2005).

7
8 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2005b.
9 *Source Water Protection Plans for Entergy Nuclear Northeast.* (May 2005).

10
11 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006a.
12 *Applicant's Environmental Report – Operating License Renewal Stage, Vermont Yankee*
13 *Nuclear Power Station.* Docket No. 50-271. Brattleboro, Vermont. (January 25, 2006).

14
15 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006b.
16 *Vermont Yankee Nuclear Power Station License No. DPR-28 (Docket No. 50-271) License*
17 *Renewal Application, Amendment 6.* Entergy Nuclear Operations, Inc., Brattleboro, Vermont.
18 (July 2006).

19
20 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006c.
21 *Vermont Yankee Nuclear Power Station License Renewal Application, Amendment 9,*
22 *Appendix E, Revision 2.* Entergy Nuclear Operations, Inc., Brattleboro, Vermont. (August 10,
23 2006).

24
25 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006d.
26 *2005 Annual Radiological Environmental Operating Report, Vermont Yankee Nuclear Power*
27 *Station.* Docket No. 50-271. Brattleboro, Vermont. (May 15, 2006).

28
29 Entergy Nuclear Vermont Yankee, LLC and Normandeau Associates, Inc. (Entergy and
30 Normandeau). 2004. *Ecological Studies of the Connecticut River Vernon, Vermont.* Report 33.
31 Prepared for Entergy Nuclear Vermont Yankee, LLC. Vernon, Vermont, by Entergy Nuclear
32 Vermont Yankee, LLC and Normandeau Associates, Inc., Bedford, New Hampshire.
33 (May 2004).

34
35 Executive Order 12898. "Federal Actions to Address Environmental Justice in Minority and
36 Low-Income Populations." *Federal Register*, Vol. 59, No. 32, Washington, D.C.
37 (February 16, 1994).

Environmental Impacts of Operation

1 Field, J. 2005. "Impact of Channelization along the Northern Connecticut River, Vermont and
2 New Hampshire." In *River and Lake Restoration: Changing Landscapes*. 2005 UCOWR
3 Annual Conference, Portland, Maine. Universities Council on Water Resources, Carbondale,
4 Illinois. Available URL: <http://www.ucowr.siu.edu/proceedings/proceedings.htm>
5 (Accessed July 31, 2006).

6
7 Gephard, S., and J. McMenemy. 2004. "An Overview of the Program to Restore Atlantic
8 Salmon and Other Diadromous Fishes to the Connecticut River with Notes on the Current
9 Status of These Species in the River." In *The Connecticut River Ecological Study (1965-1973)*
10 *Revisited: Ecology of the Lower Connecticut River 1973-2003*, P.M. Jacobson, D.A. Dixon,
11 W.C. Leggett, B.C. Marcy, Jr., and R.R. Massengill, eds. American Fisheries Society,
12 Monograph 9, Bethesda, Maryland.

13
14 Hartel, K.E., D.B. Halliwell, and A.E. Launer. 1996. "An Annotated Working List of the Inland
15 Fishes of Massachusetts." Harvard University, Cambridge, Massachusetts. Available URL:
16 http://collections.oeb.harvard.edu/Fish/ma_fish/ma_fam.htm (Accessed July 27, 2006).

17
18 Institute of Electrical and Electronics Engineers, Inc. (IEEE). 2002. *National Electric Safety*
19 *Code*.

20
21 Kendall, P. 2006. "Bacterial Food-Borne Illness." Fact Sheet No. 9.300. Colorado State
22 University Cooperative Extension, Colorado State University, Fort Collins, Colorado. Available
23 URL: <http://www.ext.colostate.edu/pubs/foodnut/09300.html> (Accessed August 22, 2006).

24
25 Marcy, B.C., Jr. 2004a (1976a). "Fishes of the Lower Connecticut River and the Effects of the
26 Connecticut Yankee Plant." In *The Connecticut River Ecological Study (1965-1973) Revisited:*
27 *Ecology of the Lower Connecticut River 1973-2003*, P.M. Jacobson, D.A. Dixon, W.C. Leggett,
28 B.C. Marcy, Jr., and R.R. Massengill, eds. American Fisheries Society, Monograph 9,
29 Bethesda, Maryland.

30
31 Marcy, B.C., Jr. 2004b (1976b). "Planktonic Fish Eggs and Larvae of the Lower Connecticut
32 River and the Effect of the Connecticut Yankee Plant, Including Entrainment." In *The*
33 *Connecticut River Ecological Study (1965-1973) Revisited: Ecology of the Lower Connecticut*
34 *River 1973-2003*, P.M. Jacobson, D.A. Dixon, W.C. Leggett, B.C. Marcy, Jr., and
35 R.R. Massengill, eds. American Fisheries Society, Monograph 9, Bethesda, Maryland.

36
37 Marcy, B.C., Jr. 2004c (1976c). "Early Life History Studies of American Shad in the Lower
38 Connecticut River and the Effect of the Connecticut Yankee Plant." In *The Connecticut River*
39 *Ecological Study (1965-1973) Revisited: Ecology of the Lower Connecticut River 1973-2003*,
40 P.M. Jacobson, D.A. Dixon, W.C. Leggett, B.C. Marcy, Jr., and R.R. Massengill, eds. American
41 Fisheries Society, Monograph 9, Bethesda, Maryland.

Environmental Impacts of Operation

- 1 National Environmental Policy Act of 1969 (NEPA). 42 USC 4321, et seq.
- 2
- 3 National Institute of Environmental Health Sciences (NIEHS). 1999. *NIEHS Report on Health*
4 *Effects from Exposure to Power Line Frequency and Electric and Magnetic Fields*. Publication
5 No. 99-4493. Research Triangle Park, North Carolina.
- 6
- 7 New Hampshire Fish and Game Department (NHFGD). 2005. "New Hampshire Wildlife Action
8 Plan." New Hampshire Fish and Game Department, Concord, New Hampshire. Available URL:
9 http://www.wildlife.state.nh.us/Wildlife/wildlife_plan.htm (Accessed August 22, 2006).
- 10
- 11 Noguchi, L.S., D.L. Bimber, H.T. Tin, P.J. Mansfield, and D.J. Jude. 1985. "Field Distribution
12 and Entrainment of Fish Larvae and Eggs at the Donald C. Cook Nuclear Power Plant,
13 Southeastern Lake Michigan, 1980-1982." Special Report No. 116 of the Great Lakes
14 Research Division. Great Lakes and Marine Waters Center, The University of Michigan, Ann
15 Arbor, Michigan.
- 16
- 17 Normandeau Associates, Inc. (Normandeau). 1999. *Summary Report on the 1986-1997*
18 *Ecological Studies of the Connecticut River, Vernon, Vermont*. Prepared for Vermont Yankee
19 Nuclear Power Corporation, Vernon, Vermont, by Normandeau Associates, Inc., Drumore,
20 Pennsylvania. (April 22, 1999).
- 21
- 22 Normandeau Associates, Inc. (Normandeau). 2001. "Ecological Studies of the Connecticut
23 River, Vernon, Vermont." Report 30 (January-December 2000). (April 2001).
- 24
- 25 Normandeau Associates, Inc. (Normandeau). 2002. "Ecological Studies of the Connecticut
26 River, Vernon, Vermont." Report 31 (January-December 2001). (April 2002).
- 27
- 28 Normandeau Associates, Inc. (Normandeau). 2003. "Ecological Studies of the Connecticut
29 River, Vernon, Vermont." Report 32 (January-December 2002). (May 2003).
- 30
- 31 Normandeau Associates, Inc. (Normandeau). 2004a. "§316(a) Demonstration in Support of a
32 Request for Increased Discharge Temperature Limits at Vermont Yankee Nuclear Power
33 Station During May Through October." Prepared for Entergy Nuclear Vermont Yankee, Vernon,
34 Vermont, by Normandeau Associates, Inc., Bedford, New Hampshire. (April 2004).
- 35
- 36 Normandeau Associates, Inc. (Normandeau). 2004b. "Ecological Studies of the Connecticut
37 River, Vernon, Vermont." Report 33 (January-December 2003). (May 2004).
- 38
- 39 Normandeau Associates, Inc. (Normandeau). 2005. "Ecological Studies of the Connecticut
40 River, Vernon, Vermont." Report 34 (January-December 2004). Prepared for Entergy Nuclear
41 Vermont Yankee, Vernon, Vermont, by Normandeau Associates, Inc., Bedford, New Hampshire.
42 (May 2005).

Environmental Impacts of Operation

1 Savoy, T.F., and V.A. Crecco. 2004. "Factors Affecting the Recent Decline of Blueback Herring
2 and American Shad in the Connecticut River." In *The Connecticut River Ecological Study*
3 (1965-1973) Revisited: *Ecology of the Lower Connecticut River 1973-2003*, P.M. Jacobson,
4 D.A. Dixon, W.C. Leggett, B.C. Marcy, Jr., and R.R. Massengill, eds. American Fisheries
5 Society, Monograph 9, Bethesda, Maryland.

6
7 Swanson, C., H.-S. Kim, S. Subbayya, P. Hall, and J. Patel. 2005. *Hydrothermal Modeling of*
8 *the Cooling Water Discharge from the Vermont Yankee Power Plant to the Connecticut River*.
9 ASA Report 02-088. Prepared by Applied Sciences Associates, Inc., Narragansett, Rhode
10 Island, for Normandeau Associates, Inc., Bedford, New Hampshire. (April 1, 2005).

11
12 Todar, K. 2004. "*Pseudomonas aeruginosa*." Bacteriology at UW-Madison, Bacteriology 330
13 Home Page, University of Wisconsin-Madison, Department of Bacteriology, Madison,
14 Wisconsin. Available URL: <http://textbookofbacteriology.net/pseudomonas.html>
15 (Accessed August 22, 2006).

16
17 Tyndall, R.L., K.S. Ironside, P.L. Metler, E.L. Tan, T.C. Hazen, and C.B. Fliermans. 1989.
18 "Effect of Thermal Additions on the Density and Distribution of Thermophilic Amoebae and
19 Pathogenic *Naegleria fowleri* in a Newly Created Cooling Lake." *Applied and Environmental*
20 *Microbiology*, Vol. 55, No. 3, pp. 722-732.

21
22 U.S. Atomic Energy Commission (AEC). 1972. *Final Environmental Statement Related to*
23 *Operation of Vermont Yankee Nuclear Power Station*. Docket No. 50-271. U.S. Atomic Energy
24 Commission, Washington, D.C. (July 1972).

25
26 U.S. Census Bureau (USCB). 2006. "Glossary." Washington, D.C. Available URL:
27 <http://www.census.gov/main/www/glossary.html> (Accessed March 2006).

28
29 U.S. Environmental Protection Agency (EPA). 2004. "National Pollutant Discharge Elimination
30 System – Final Regulations to Establish Requirements for Cooling Water Intake Structures at
31 Phase II Existing Facilities: Final Rule." *Federal Register*, Vol. 69, No. 131, pp. 41575–41693.

32
33 U.S. Fish and Wildlife Service (FWS). 2005. Letter from M.J. Amaral, U.S. Fish and Wildlife
34 Service, Concord, New Hampshire, to G.E. Tucker, FTN Associates, Ltd., Little Rock, Arkansas.
35 Subject: "Information on the Presence of Federally Listed and/or Proposed Endangered or
36 Threatened Species in Relation to the Vermont Yankee Nuclear Power Station." (December 16,
37 2005).

38
39 U.S. Fish and Wildlife Service (FWS). 2006. Letter from M.J. Amaral, U.S. Fish and Wildlife
40 Service, Concord, New Hampshire, to R. Franovich, U.S. Nuclear Regulatory Commission,
41 Rockville, Maryland. (August 10, 2006).

Environmental Impacts of Operation

- 1 U.S. National Marine Fisheries Service (NMFS). 2006. Letter from L.A. Chiarella, U.S. National
2 Marine Fisheries Service , Gloucester, Massachusetts, to R. Franovich, U.S. Nuclear
3 Regulatory Commission, Rockville, Maryland. (September 15, 2006).
- 4
- 5 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement*
6 *for License Renewal of Nuclear Plants*. NUREG-1437, Vols. 1 and 2, Washington, D.C.
- 7
- 8 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement*
9 *for License Renewal of Nuclear Plants, Main Report*, "Section 6.3 – Transportation, Table 9.1,
10 Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants, Final
11 Report." NUREG-1437, Vol. 1, Addendum 1, Washington, D.C.
- 12
- 13 U.S. Nuclear Regulatory Commission (NRC). 2004a. *Procedural Guidance for Preparing*
14 *Environmental Assessments and Considering Environmental Issues*. Rev. 1. Appendix D to
15 *NRC Office Instruction LIC-203*. Washington, D.C. (May 24, 2004).
- 16
- 17 U.S. Nuclear Regulatory Commission (NRC). 2004b. "Policy Statement on the Treatment of
18 Environmental Justice Matters in NRC Regulatory and Licensing Actions." *Federal Register*,
19 Vol. 69, pp. 52040–52048. Washington, D.C. (August 24, 2004).
- 20
- 21 U.S. Nuclear Regulatory Commission (NRC). 2006a. *Vermont Yankee Nuclear Power Station*
22 – *Final Environmental Assessment and Finding of No Significant Impact Related to the*
23 *Proposed License Amendment to Increase the Maximum Reactor Power Level*. Docket
24 No. 50-271. Washington, D.C. (January 20, 2006).
- 25
- 26 U.S. Nuclear Regulatory Commission (NRC). 2006b. Letter from R. Franovich, U.S. Nuclear
27 Regulatory Commission, Rockville, Maryland, to M. Moriarity, U.S. Fish and Wildlife Service,
28 Hadley, Massachusetts. (May 5, 2006).
- 29
- 30 U.S. Nuclear Regulatory Commission (NRC). 2006c. Letter from R. Franovich, U.S. Nuclear
31 Regulatory Commission, Washington, D.C., to P. Kurkul, U.S. National Marine Fisheries
32 Service, Gloucester, Massachusetts. (May 5, 2006).
- 33
- 34 U.S. Nuclear Regulatory Commission (NRC). 2006d. Letter from R. Franovich, U.S. Nuclear
35 Regulatory Commission, Rockville, Maryland, to M. Moriarity, U.S. Fish and Wildlife Service,
36 Concord, New Hampshire. (July 21, 2006).
- 37
- 38 Vermont Agency of Natural Resources (VANR). 2005. Letter from W.A. Laroche, Vermont
39 Agency of Natural Resources, Department of Fish and Wildlife, Waterbury, Vermont, to
40 G.E. Tucker, FTN Associates, Ltd., Little Rock, Arkansas. Subject: "Information on the
41 Environmental Issues and Informational Needs to Be Addressed in the Permit Application for
42 Renewal of the Current Operating License." (December 7, 2005).

Environmental Impacts of Operation

1 Vermont Department of Environmental Conservation (VDEC). 2003. *Final Amended Discharge*
2 *Permit #3-1199*. Vermont Agency of Natural Resources, Department of Environmental
3 Conservation, Wastewater Management Division, Waterbury, Vermont. (June 9, 2003).

4
5 Vermont Department of Environmental Conservation (VDEC). 2006a. *Final Amended*
6 *Discharge Permit #3-1199*. Vermont Agency of Natural Resources, Department of
7 Environmental Conservation, Wastewater Management Division, Waterbury, Vermont.
8 (March 30, 2006).

9
10 Vermont Department of Environmental Conservation (VDEC). 2006b. *Amended National*
11 *Pollutant Discharge Elimination System (NPDES) Permit to Discharge to Waters of the United*
12 *States*. Fact sheet. Vermont Agency of Natural Resources, Department of Environmental
13 Conservation, Wastewater Management Division, Waterbury, Vermont. (March 2006).

14
15 Vermont Department of Health (VDH). 2006. *State of Vermont, Vermont Yankee Nuclear*
16 *Power Station, Environmental Radiation Surveillance Report, 2005 Summary*. Vermont
17 Department of Health, Office of Radiological Health, Burlington, Vermont. (April 10, 2006).

18
19 Vermont Yankee Nuclear Power Station and Normandeau Associates, Inc. (VYNPS and
20 Normandeau). 2002. *Ecological Studies of the Connecticut River Vernon, Vermont*. Report 31,
21 January-December 2001. Prepared for Vermont Yankee Nuclear Power Corporation,
22 Brattleboro, Vermont, by Vermont Yankee Nuclear Power Station, Brattleboro, Vermont, and
23 Normandeau Associates, Inc., Bedford, New Hampshire. (April 2002).

24
25 Witherwell, D.B., and B. Kynard. 1990. "Vertical Distribution of Adult American Shad in the
26 Connecticut River." *Transactions of the American Fisheries Society*, Vol. 119, pp. 151–155.

1 **5.0 Environmental Impacts of Postulated Accidents**

2

3

4 Environmental issues associated with postulated accidents are discussed in the *Generic*
5 *Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437,
6 Volumes 1 and 2 (NRC 1996, 1999).^(a) The GEIS includes a determination of whether the
7 analysis of the environmental issue could be applied to all plants and whether additional
8 mitigation measures would be warranted. Issues are then assigned a Category 1 or a
9 Category 2 designation. As set forth in the GEIS, Category 1 issues are those that meet all of
10 the following criteria:

- 11
- 12 (1) The environmental impacts associated with the issue have been determined to apply
13 either to all plants or, for some issues, to plants having a specific type of cooling
14 system or other specified plant or site characteristics.
- 15
- 16 (2) A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned
17 to the impacts (except for collective offsite radiological impacts from the fuel cycle
18 and from high-level waste and spent fuel disposal).
- 19
- 20 (3) Mitigation of adverse impacts associated with the issue has been considered in the
21 analysis, and it has been determined that additional plant-specific mitigation
22 measures are likely not to be sufficiently beneficial to warrant implementation.

23

24 For issues that meet the three Category 1 criteria, no additional plant-specific analysis is
25 required unless new and significant information is identified.

26

27 Category 2 issues are those that do not meet one or more of the criteria for Category 1, and,
28 therefore, additional plant-specific review of these issues is required.

29

30 This chapter describes the environmental impacts from postulated accidents that might occur
31 during the license renewal term.

32

33 **5.1 Postulated Plant Accidents**

34

35

36 Two classes of accidents are evaluated in the GEIS. These are design-basis accidents and
37 severe accidents, as discussed below.

38

39

(a) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all
references to the "GEIS" include the GEIS and Addendum 1.

Environmental Impacts of Postulated Accidents

5.1.1 Design-Basis Accidents

In order to receive U.S. Nuclear Regulatory Commission (NRC) approval to operate a nuclear power facility, an applicant for an initial operating license (OL) must submit a Safety Analysis Report (SAR) as part of its application. The SAR presents the design criteria and design information for the proposed reactor and comprehensive data on the proposed site. The SAR also discusses various hypothetical accident situations and the safety features that are provided to prevent and mitigate accidents. The NRC staff reviews the application to determine whether the plant design meets the Commission's regulations and requirements and includes, in part, the nuclear plant design and its anticipated response to an accident.

Design-basis accidents (DBAs) are those accidents that both the licensee and the NRC staff evaluate to ensure that the plant can withstand normal and abnormal transients, and a broad spectrum of postulated accidents, without undue hazard to the health and safety of the public. A number of these postulated accidents are not expected to occur during the life of the plant, but are evaluated to establish the design basis for the preventive and mitigative safety systems of the facility. The acceptance criteria for DBAs are described in Title 10, Part 50 and Part 100, of the *Code of Federal Regulations* (10 CFR Part 50 and 10 CFR Part 100).

The environmental impacts of DBAs are evaluated during the initial licensing process, and the ability of the plant to withstand these accidents is demonstrated to be acceptable before issuance of the OL. The results of these evaluations are found in license documentation such as the applicant's Final Safety Analysis Report (FSAR), the NRC staff's Safety Evaluation Report (SER), the Final Environmental Statement (FES), and Section 5.1 of this Supplemental Environmental Impact Statement (SEIS). A licensee is required to maintain the acceptable design and performance criteria throughout the life of the plant, including any extended-life operation. The consequences for these events are evaluated for the hypothetical maximally exposed individual; as such, changes in the plant environment will not affect these evaluations. Because of the requirements that continuous acceptability of the consequences and aging management programs be in effect for license renewal, the environmental impacts as calculated for DBAs should not differ significantly from initial licensing assessments over the life of the plant, including the license renewal period. Accordingly, the design of the plant relative to DBAs during the extended period is considered to remain acceptable, and the environmental impacts of those accidents were not examined further in the GEIS.

The Commission has determined that the environmental impacts of DBAs are of SMALL significance for all plants because the plants were designed to successfully withstand these accidents. Therefore, for the purposes of license renewal, DBAs are designated as a Category 1 issue in 10 CFR Part 51, Subpart A, Appendix B, Table B-1. The early resolution of the DBAs makes them a part of the current licensing basis of the plant; the current licensing basis of the plant is to be maintained by the licensee under its current license and, therefore,

Environmental Impacts of Postulated Accidents

under the provisions of 10 CFR 54.30, is not subject to review under license renewal. This issue, applicable to Vermont Yankee Nuclear Power Station (VYNPS), is listed in Table 5-1.

Table 5-1. Category 1 Issue Applicable to Postulated Accidents During the Renewal Term

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections
POSTULATED ACCIDENTS	
Design-basis accidents	5.3.2; 5.5.1

Based on information in the GEIS, the Commission found that

The NRC staff has concluded that the environmental impacts of design-basis accidents are of small significance for all plants.

Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy), stated in its Environmental Report (ER) (Entergy 2006) that it is not aware of any new and significant information associated with the renewal of the VYNPS OL. The NRC staff has not identified any new and significant information during its independent review of the Entergy ER, the site visit, the scoping process, or the evaluation of other available information. Therefore, the NRC staff concludes that there are no impacts related to DBAs beyond those discussed in the GEIS.

5.1.2 Severe Accidents

Severe nuclear accidents are those that are more severe than DBAs because they could result in substantial damage to the reactor core, regardless of offsite consequences. In the GEIS, the NRC staff assessed the impacts of severe accidents using the results of existing analyses and site-specific information to conservatively predict the environmental impacts of severe accidents for each plant during the renewal period.

Severe accidents initiated by external phenomena, such as tornadoes, floods, earthquakes, fires, and sabotage, traditionally have not been discussed in quantitative terms in FESs and were not specifically considered for the VYNPS site in the GEIS (NRC 1996). However, in the GEIS, the NRC staff did evaluate existing impact assessments performed by the NRC and by the industry at 44 nuclear plants in the United States and concluded that the risk from beyond-design-basis earthquakes at existing nuclear power plants is SMALL. Additionally, compliance with the NRC regulatory requirements under 10 CFR Part 73 provide reasonable assurance that the risk from sabotage is SMALL. Even if such events were to occur, the Commission would expect that resultant core damage and radiological releases would be no worse than those expected from internally initiated events. Based on the above, the Commission concludes that

Environmental Impacts of Postulated Accidents

the risk from sabotage and beyond design-basis earthquakes at existing nuclear power plants is small and additionally, that the risks from other external events, are adequately addressed by a generic consideration of internally initiated severe accidents.

Based on information in the GEIS, the Commission found that

The probability weighted consequences of atmospheric releases, fallout onto open bodies of water, releases to groundwater, and societal and economic impacts from severe accidents are small for all plants. However, alternatives to mitigate severe accidents must be considered for all plants that have not considered such alternatives.

Therefore, the Commission has designated mitigation of severe accidents as a Category 2 issue in 10 CFR Part 51, Subpart A, Appendix B, Table B-1. This issue, applicable to VYNPS, is listed in Table 5-2.

Table 5-2. Category 2 Issue Applicable to Postulated Accidents During the Renewal Term

ISSUE–10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Sections	10 CFR 51.53(c)(3)(ii) Subparagraph	SEIS Section
POSTULATED ACCIDENTS			
Severe accidents	5.3.3; 5.3.3.2; 5.3.3.3; 5.3.3.4; 5.3.3.5; 5.4; 5.5.2	L	5.2

The NRC staff has not identified any new and significant information with regard to the consequences from severe accidents during its independent review of the Entergy ER (Entergy 2006), the site visit, the scoping process, or the evaluation of other available information. Therefore, the NRC staff concludes that there are no impacts of severe accidents beyond those discussed in the GEIS. However, in accordance with 10 CFR 51.53(c)(3)(ii)(L), the NRC staff has reviewed severe accident mitigation alternatives (SAMAs) for VYNPS. The results of its review are discussed in Section 5.2.

5.2 Severe Accident Mitigation Alternatives

Section 51.53(c)(3)(ii)(L) requires that license renewal applicants consider alternatives to mitigate severe accidents if the staff has not previously evaluated SAMAs for the applicant's plant in an environmental impact statement (EIS) or related supplement or in an environmental assessment. The purpose of this consideration is to ensure that plant changes (i.e., hardware, procedures, and training) with the potential for improving severe accident safety performance

1 are identified and evaluated. SAMAs have not been previously considered for Vermont Yankee
2 Nuclear Power Station (VYNPS); therefore, the remainder of Chapter 5 addresses those
3 alternatives.

4 **5.2.1 Introduction**

5 This section presents a summary of the SAMA evaluation for VYNPS conducted by Entergy
6 Nuclear Generation Company (Entergy), and described in the ER, and the NRC's review of this
7 evaluation. The details of the review are described in the NRC staff evaluation that was
8 prepared with contract assistance from Information Systems Laboratories, Inc. The entire
9 evaluation for VYNPS is presented in Appendix G.

10 The SAMA evaluation for VYNPS was conducted with a four-step approach. In the first step
11 Entergy quantified the level of risk associated with potential reactor accidents using the
12 plant-specific probabilistic safety assessment (PSA) and other risk models.

13 In the second step Entergy examined the major risk contributors and identified possible ways
14 (SAMAs) of reducing that risk. Common ways of reducing risk are changes to components,
15 systems, procedures, and training. Entergy initially identified 302 potential SAMAs for VYNPS.
16 Entergy screened out 236 SAMAs from further consideration because they are not applicable at
17 VYNPS due to design differences, have already been implemented at VYNPS, or are addressed
18 by a similar SAMA. The remaining 66 SAMAs were subjected to further evaluation.

19
20 In the third step Entergy estimated the benefits and the costs associated with each of the
21 remaining SAMAs. Estimates were made of how much each SAMA could reduce risk. Those
22 estimates were developed in terms of dollars in accordance with NRC guidance for performing
23 regulatory analyses (NRC 1997). The cost of implementing the proposed SAMAs was also
24 estimated.

25 Finally, in the fourth step, the costs and benefits of each of the remaining SAMAs were
26 compared to determine whether the SAMA was cost-beneficial, meaning the benefits of the
27 SAMA were greater than the cost (a positive cost-benefit). Entergy found two SAMAs to be
28 potentially cost-beneficial (Entergy 2006c). However, in response to NRC staff inquiries
29 regarding estimated benefits for certain SAMAs and lower cost alternatives, four additional
30 potentially cost-beneficial SAMAs were identified (Entergy 2006c and 2006d).

31 The potentially cost-beneficial SAMAs do not relate to adequately managing the effects of aging
32 during the period of extended operation; therefore, they need not be implemented as part of
33 license renewal pursuant to 10 CFR Part 54. Entergy's SAMA analyses and the NRC's review
34 are discussed in more detail below.

35

Environmental Impacts of Postulated Accidents

5.2.2 Estimate of Risk

Entergy submitted an assessment of SAMAs for VYNPS as part of the ER (Entergy 2006a). This assessment was based on the most recent VYNPS PSA available at that time, a plant-specific offsite consequence analysis performed using the MELCOR Accident Consequence Code System 2 (MACCS2) computer program, and insights from the VYNPS Individual Plant Examination (IPE) (VYNPC 1993) and Individual Plant Examination of External Events (IPEEE) (VYNPC 1998).

The baseline core damage frequency (CDF) for the purpose of the SAMA evaluation is approximately 8.0×10^{-6} per year. This CDF is based on the risk assessment for internally-initiated events. Entergy did not include the contribution to risk from external events within the VYNPS risk estimates; however, it did account for the potential risk reduction benefits associated with external events by increasing the estimated benefits for internal events by a factor of 3.33. The breakdown of CDF by initiating event is provided in Table 5-3.

As shown in Table 5-3, events initiated by loss of offsite power, internal flooding, transients without the power conversion system, and loss of an AC bus are the dominant contributors to CDF. Although not separately reported, station blackout (SBO) sequences contribute 2.3×10^{-6} per year (about 29 percent of the total internal events CDF), while anticipated transient without scram (ATWS) sequences contribute 1.5×10^{-7} per year to CDF (about 2 percent of the total internal events CDF).

Entergy estimated the dose to the population within 80 km (50 mi) of the VYNPS site to be approximately 0.151 person-Sv (15.1 person-rem) per year. The breakdown of the total population dose by containment release mode is summarized in Table 5-4. Containment failures within the early time frame (less than 6 hours following event initiation) dominate the population dose risk at VYNPS.

The NRC staff has reviewed Entergy's data and evaluation methods and concludes that the quality of the risk analyses is adequate to support an assessment of the risk reduction potential for candidate SAMAs. Accordingly, the staff based its assessment of offsite risk on the CDFs and offsite doses reported by Entergy.

5.2.3 Potential Plant Improvements

Once the dominant contributors to plant risk were identified, Entergy searched for ways to reduce that risk. In identifying and evaluating potential SAMAs, Entergy considered insights from the plant-specific PSA, and SAMA analyses performed for other operating plants that have submitted license renewal applications. Entergy identified 302 potential risk-reducing improvements (SAMAs) to plant components, systems, procedures and training.

Environmental Impacts of Postulated Accidents

Table 5-3. VYNPS Core Damage Frequency

Initiating Event	CDF (Per Year)	% Contribution to CDF
Loss of offsite power	2.8×10^{-6}	35
Internal Flooding	1.4×10^{-6}	17
Transients without power conversion system	8.4×10^{-7}	11
Loss of AC Bus 3	7.9×10^{-7}	10
Loss of AC Bus 4	7.3×10^{-7}	9
Loss of DC bus 2	2.8×10^{-7}	4
Loss of DC bus 1	2.8×10^{-7}	3
Inadvertently opened relief valve	2.7×10^{-7}	3
Reactor trip	1.7×10^{-7}	2
Anticipated Transient Without Scram	1.5×10^{-7}	2
Loss of Coolant Accidents	7.3×10^{-8}	1
Stuck-open relief valve	6.5×10^{-8}	1
Total loss of service water	5.2×10^{-8}	1
Interfacing System LOCA	3.9×10^{-8}	<1
LOCA outside containment	3.4×10^{-8}	<1
Total CDF	8.0×10^{-6}	100

Table 5-4. Breakdown of Population Dose by Containment Release Mode

Containment Release Mode	Population Dose (Person-Rem¹ Per Year)	% Contribution
Early Containment Failure	12.8	85
Late Containment Failure	2.1	14
Containment Bypass	0.2	1
Intermediate Containment Failure	< 0.1	< 1
Intact Containment	negligible	negligible
Total	15.1	100

¹One person-Rem = 0.01 person-Sv

Environmental Impacts of Postulated Accidents

1 Entergy removed 236 SAMAs from further consideration because they are not applicable at
2 VYNPS due to design differences, have already been implemented at VYNPS, or are addressed
3 by a similar SAMA. A detailed cost-benefit analysis was performed for each of the 66 remaining
4 SAMAs.

5 The staff concludes that Entergy used a systematic and comprehensive process for identifying
6 potential plant improvements for VYNPS, and that the set of potential plant improvements
7 identified by Entergy is reasonably comprehensive and, therefore, acceptable.

8 **5.2.4 Evaluation of Risk Reduction and Costs of Improvements**

9
10 Entergy evaluated the risk-reduction potential of the remaining 66 SAMAs. The majority of the
11 SAMA evaluations were performed in a bounding fashion in that the SAMA was assumed to
12 completely eliminate the risk associated with the proposed enhancement.

13 Entergy estimated the costs of implementing the 66 candidate SAMAs through the application of
14 engineering judgement, and use of other licensees' estimates for similar improvements. The
15 cost estimates conservatively did not include the cost of replacement power during extended
16 outages required to implement the modifications, nor did they include contingency costs
17 associated with unforeseen implementation obstacles.

18 The staff reviewed Entergy's bases for calculating the risk reduction for the various plant
19 improvements and concludes that the rationale and assumptions for estimating risk reduction
20 are reasonable and somewhat conservative (i.e., the estimated risk reduction is similar to or
21 somewhat higher than what would actually be realized). Accordingly, the staff based its
22 estimates of averted risk for the various SAMAs on Entergy's risk reduction estimates.

23 The staff reviewed the bases for the applicant's cost estimates. For certain improvements, the
24 staff also compared the cost estimates to estimates developed elsewhere for similar
25 improvements, including estimates developed as part of other licensees' analyses of SAMAs for
26 operating reactors and advanced light-water reactors. The staff found the cost estimates to be
27 consistent with estimates provided in support of other plants' analyses.

28 The staff concludes that the risk reduction and the cost estimates provided by Entergy are
29 sufficient and appropriate for use in the SAMA evaluation.

30 **5.2.5 Cost-Benefit Comparison**

31 The cost-benefit analysis performed by Entergy was based primarily on NUREG/BR-0184 (NRC
32 1997) and was executed consistent with this guidance. NUREG/BR-0058 has recently been
33 revised to reflect the agency's revised policy on discount rates. Revision 4 of NUREG/BR-0058

Environmental Impacts of Postulated Accidents

1 states that two sets of estimates should be developed – one at three percent and one at seven
2 percent (NRC 2004). Entergy provided both sets of estimates (Entergy 2006a).

3
4 Entergy identified three potentially cost-beneficial SAMAs in the baseline analysis contained in
5 the ER (using a seven percent discount rate, and considering the combined impact of both
6 external events and uncertainties). The potentially cost-beneficial SAMAs are:

- 7
- 8 • SAMA 47 – shield injection system electrical equipment from potential water spray. This
9 SAMA involves installing shields in two locations to address the impacts of breaks in either
10 of the two locations.
 - 11 • SAMA 65 – modify procedures to allow operators to defeat the low reactor pressure
12 interlock circuitry that inhibits opening the LPCI or core spray injection valves following
13 sensor or logic failures that prevent all low pressure injection valves from opening.
 - 14 • SAMA 66 – install a bypass switch to allow operators to bypass the low reactor pressure
15 interlock circuitry that inhibits opening the LPCI or core spray injection valves following
16 sensor or logic failures that prevent all low pressure injection valves from opening.

17 In response to an RAI, Entergy provided a revised assessment based on a modified multiplier
18 for external events and a separate accounting of uncertainties (Entergy 2006c). The revised
19 baseline assessment resulted in identification of only one potentially cost-beneficial SAMA
20 (SAMA 65). When accounting for uncertainties, SAMA 66 was also potentially cost-beneficial.
21 (SAMA 47, which was marginally cost-beneficial in Entergy's original SAMA assessment, is not
22 cost-beneficial in the revised assessment.) However, in response to NRC staff inquiries
23 regarding estimated benefits for certain SAMAs and lower cost alternatives, four additional
24 potentially cost-beneficial SAMAs were identified (Entergy 2006c and 2006d):

- 25
- 26 • SAMA 63, control containment venting within a narrow pressure band.
 - 27 • New SAMA involving operator procedure revisions to provide additional space cooling to the
28 EDG room via the use of portable equipment.
 - 29 • New SAMA involving use of a portable generator to power the battery chargers.
 - 30 • New SAMA involving use of a portable generator to provide power to individual 125VDC motor
31 control centers (MCCs).

32 The staff concludes that, with the exception of the potentially cost-beneficial SAMAs discussed
33 above, the costs of the SAMAs evaluated would be higher than the associated benefits.

Environmental Impacts of Postulated Accidents

1 **5.2.6 Conclusions**

2
3 The staff reviewed Entergy's analysis and concluded that the methods used and the
4 implementation of those methods were sound. The treatment of SAMA benefits and costs
5 support the general conclusion that the SAMA evaluations performed by Entergy are reasonable
6 and sufficient for the license renewal submittal. Although the treatment of SAMAs for external
7 events was somewhat limited by the unavailability of an external event PSA, the likelihood of
8 there being cost-beneficial enhancements in this area was minimized by improvements that
9 have been realized as a result of the IPEEE process, and increasing the estimated SAMA
10 benefits for internal events by a multiplier to account for potential benefits in external events.
11 Based on its review of the SAMA analysis, the staff concurs with Entergy's identification of
12 areas in which risk can be further reduced in a cost-beneficial manner through the
13 implementation of all or a subset of potentially cost-beneficial SAMAs. Given the potential for
14 cost-beneficial risk reduction, the staff considers that further evaluation of these SAMAs by
15 Entergy is warranted. However, none of the potentially cost-beneficial SAMAs relate to
16 adequately managing the effects of aging during the period of extended operation. Therefore,
17 they need not be implemented as part of the license renewal pursuant to 10 CFR Part 54.

18
19 **5.3 References**

20
21 10 CFR Part 50. *Code of Federal Regulations*, Title 10, Energy, Part 50, "Domestic Licensing of
22 Production and Utilization Facilities."

23
24 10 CFR Part 51. *Code of Federal Regulations*, Title 10, Energy, Part 51, "Environmental
25 Protection Regulations for Domestic Licensing and Related Regulatory Functions."

26
27 10 CFR Part 54. *Code of Federal Regulations*, Title 10, Energy, Part 54, "Requirements for
28 Renewal of Operating Licenses for Nuclear Power Plants."

29
30 10 CFR Part 73. *Code of Federal Regulations*, Title 10, Energy, Part 73, "Physical Protection of
31 Plants and Materials."

32
33 10 CFR Part 100. *Code of Federal Regulations*, Title 10, Energy, Part 100, "Reactor Site
34 Criteria."

35
36 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006a.
37 *Applicant's Environmental Report – Operating License Renewal Stage, Vermont Yankee*
38 *Nuclear Power Station*. Docket No. 50-271. Brattleboro, Vermont. (January 25, 2006).

Environmental Impacts of Postulated Accidents

1 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006b.
2 *Vermont Yankee Nuclear Power Station License No. DPR-28 (Docket No. 50-271) License*
3 *Renewal Application, Amendment 7.* Entergy Nuclear Operations, Inc., Brattleboro, Vermont.
4 (August 1, 2006).

5
6 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006c.
7 *Vermont Yankee Nuclear Power Station License No. DPR-28 (Docket No. 50-271) License*
8 *Renewal Application, Amendment 13.* Entergy Nuclear Operations, Inc., Brattleboro, Vermont.
9 (September 19, 2006).

10
11 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006d.
12 *Vermont Yankee Nuclear Power Station License No. DPR-28 (Docket No. 50-271) License*
13 *Renewal Application, Amendment 18.* Entergy Nuclear Operations, Inc., Brattleboro, Vermont.
14 (October 20, 2006).

15
16 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006e.
17 *Vermont Yankee Nuclear Power Station License No. DPR-28 (Docket No. 50-271) License*
18 *Renewal Application, Amendment 21.* Entergy Nuclear Operations, Inc., Brattleboro, Vermont.
19 (November 6, 2006).

20
21 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement*
22 *for License Renewal of Nuclear Plants.* NUREG-1437, Vols. 1 and 2. Washington, D.C.

23
24 U.S. Nuclear Regulatory Commission (NRC). 1997. *Regulatory Analysis Technical Evaluation*
25 *Handbook.* NUREG/BR-0184, Washington, D.C.

26 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement*
27 *for License Renewal of Nuclear Plants, Main Report,* "Section 6.3 – Transportation, Table 9.1,
28 Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants, Final
29 Report." NUREG-1437, Vol. 1, Addendum 1, Washington, D.C.

30 U.S. Nuclear Regulatory Commission (NRC). 2004. *Regulatory Analysis Guidelines of the U.S.*
31 *Nuclear Regulatory Commission.* NUREG/BR-0058, Rev. 4, Washington, D.C.

32 Vermont Yankee Nuclear Power Corporation (VYNPC). 1993. Letter from James P. Pelletier,
33 VYNPS to U.S. Nuclear Regulatory Commission Document Control Desk. *Vermont Yankee*
34 *Response to Generic Letter 88-20: Report on the Individual Plant Examination for Severe*
35 *Accident Vulnerabilities - 10CFR 50-54 (f).* (December 21, 1993).

Environmental Impacts of Postulated Accidents

1 Vermont Yankee Nuclear Power Corporation (VYNPC). 1998. Letter from Don M. Leach,
2 VYNPS to NRC Document Control Desk. *Vermont Yankee Nuclear Power Station License No.*
3 *DPR-28 (Docket No. 50-271) Submittal of the Vermont Yankee Individual Plant Examination for*
4 *External Events (IPEEE) Report - Response to Generic Letter 88-20, Supplement 4.* (June 30,
5 1998).

6

1 6.0 Environmental Impacts of the Uranium 2 Fuel Cycle and Solid Waste Management

3
4
5 Environmental issues associated with the uranium fuel cycle and solid waste management are
6 discussed in the *Generic Environmental Impact Statement for License Renewal of Nuclear*
7 *Plants* (GEIS), NUREG-1437, Volumes 1 and 2 (NRC 1996, 1999).^(a) The GEIS includes a
8 determination of whether the analysis of the environmental issue could be applied to all plants
9 and whether additional mitigation measures would be warranted. Issues are then assigned a
10 Category 1 or a Category 2 designation. As set forth in the GEIS, Category 1 issues are those
11 that meet all of the following criteria:

- 12
- 13 (1) The environmental impacts associated with the issue have been determined to apply
14 either to all plants or, for some issues, to plants having a specific type of cooling system
15 or other specified plant or site characteristics.
 - 16 (2) A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to
17 the impacts (except for collective offsite radiological impacts from the fuel cycle and from
18 high-level waste (HLW) and spent fuel disposal).
 - 19 (3) Mitigation of adverse impacts associated with the issue has been considered in the
20 analysis, and it has been determined that additional plant-specific mitigation measures
21 are likely not to be sufficiently beneficial to warrant implementation.

22
23
24 For issues that meet the three Category 1 criteria, no additional plant-specific analysis is
25 required unless new and significant information is identified.

26
27 Category 2 issues are those that do not meet one or more of the criteria for Category 1, and,
28 therefore, additional plant-specific review of these issues is required.

29
30
31 This chapter addresses the issues that are related to the uranium fuel cycle and solid waste
32 management during the license renewal term that are listed in Table B-1 of Title 10, Part 51, of
33 the *Code of Federal Regulations* (10 CFR Part 51), Subpart A, Appendix B, and are applicable
34 to the Vermont Yankee Nuclear Power Station (VYNPS). The generic potential impacts of the
35 radiological and nonradiological environmental impacts of the uranium fuel cycle and
36 transportation of nuclear fuel and wastes are described in detail in the GEIS based, in part, on
37 the generic impacts provided in 10 CFR 51.51(b), Table S-3, "Table of Uranium Fuel Cycle

(a) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and its Addendum 1.

Fuel Cycle

Environmental Data," and in 10 CFR 51.52(c), Table S-4, "Environmental Impact of Transportation of Fuel and Waste to and from One Light-Water-Cooled Nuclear Power Reactor." The U.S. Nuclear Regulatory Commission (NRC) staff also addresses the impacts from radon-222 and technetium-99 in the GEIS.

6.1 The Uranium Fuel Cycle

Category 1 issues in 10 CFR Part 51, Subpart A, Appendix B, Table B-1, that are applicable to VYNPS from the uranium fuel cycle and solid waste management are listed in Table 6-1.

Table 6-1. Category 1 Issues Applicable to the Uranium Fuel Cycle and Solid Waste Management During the Renewal Term

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Section
URANIUM FUEL CYCLE AND WASTE MANAGEMENT	
Offsite radiological impacts (individual effects from other than the disposal of spent fuel and HLW)	6.1; 6.2.1; 6.2.2.1; 6.2.2.3; 6.2.3; 6.2.4; 6.6
Offsite radiological impacts (collective effects)	6.1; 6.2.2.1; 6.2.3; 6.2.4; 6.6
Offsite radiological impacts (spent fuel and HLW disposal)	6.1; 6.2.2.1; 6.2.3; 6.2.4; 6.6
Nonradiological impacts of the uranium fuel cycle	6.1; 6.2.2.6; 6.2.2.7; 6.2.2.8; 6.2.2.9; 6.2.3; 6.2.4; 6.6
Low-level waste storage and disposal	6.1; 6.2.2.2; 6.4.2; 6.4.3; 6.4.3.1; 6.4.3.2; 6.4.3.3; 6.4.4; 6.4.4.1; 6.4.4.2; 6.4.4.3; 6.4.4.4; 6.4.4.5; 6.4.4.5.1; 6.4.4.5.2; 6.4.4.5.3; 6.4.4.5.4; 6.4.4.6; 6.6
Mixed waste storage and disposal	6.4.5.1; 6.4.5.2; 6.4.5.3; 6.4.5.4; 6.4.5.5; 6.4.5.6; 6.4.5.6.1; 6.4.5.6.2; 6.4.5.6.3; 6.4.5.6.4; 6.6
Onsite spent fuel	6.1; 6.4.6; 6.4.6.1; 6.4.6.2; 6.4.6.3; 6.4.6.4; 6.4.6.5; 6.4.6.6; 6.4.6.7; 6.6
Nonradiological waste	6.1; 6.5; 6.5.1; 6.5.2; 6.5.3; 6.6
Transportation	6.1; 6.3.1; 6.3.2.3; 6.3.3; 6.3.4; 6.6, Addendum 1

1 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy) stated in
2 its Environmental Report (ER) (Entergy 2006) that it is not aware of any new and significant
3 information associated with the renewal of the VYNPS operating license (OL). The extended
4 power uprate granted in March 2006 and the construction of the new dry fuel storage facility,
5 which is expected to be completed in 2006, have been considered by the NRC in its evaluation
6 of the radiological impacts and the impacts have been determined to be within the boundaries
7 established in the GEIS. The NRC staff has not identified any new and significant information
8 during its independent review of the Entergy ER, the site visit, the scoping process, or the
9 evaluation of other available information. Therefore, the NRC staff concludes that there are no
10 impacts related to these issues beyond those discussed in the GEIS. For these issues, the
11 NRC staff concluded in the GEIS that the impacts are SMALL except for the collective offsite
12 radiological impacts from the fuel cycle and from HLW and spent fuel disposal, as discussed
13 below, and that additional plant-specific mitigation measures are not likely to be sufficiently
14 beneficial to be warranted.

15
16 A brief description of the NRC staff review and the GEIS conclusions, as codified in Table B-1,
17 10 CFR Part 51, for each of these issues follows:

- 18
19 • Offsite radiological impacts (individual effects from other than the disposal of spent fuel
20 and HLW). Based on information in the GEIS, the Commission found that

21
22 Offsite impacts of the uranium fuel cycle have been considered by the Commission in
23 Table S-3 of this Part (10 CFR 51.51(b)). Based on information in the GEIS, impacts on
24 individuals from radioactive gaseous and liquid releases, including radon-222 and
25 technetium-99, are small.

26
27 The NRC staff has not identified any new and significant information during its independent
28 review of the Entergy ER, the site visit, the scoping process, or the evaluation of other available
29 information. Therefore, the NRC staff concludes that there would be no offsite radiological
30 impacts of the uranium fuel cycle during the renewal term beyond those discussed in the GEIS.

- 31
32 • Offsite radiological impacts (collective effects). Based on information in the GEIS, the
33 Commission found that

34
35 The 100-year environmental dose commitment to the U.S. population from the fuel cycle,
36 HLW and spent fuel disposal excepted, is calculated to be about 14,800 person-rem, or
37 12 cancer fatalities, for each additional 20-year power reactor operating term. Much of
38 this, especially the contribution of radon releases from mines and tailing piles, consists
39 of tiny doses summed over large populations. This same dose calculation can
40 theoretically be extended to include many tiny doses over additional thousands of years
41 as well as doses outside the United States. The result of such a calculation would be
42 thousands of cancer fatalities from the fuel cycle, but this result assumes that even tiny

Fuel Cycle

1 doses have some statistical adverse health effect that will not ever be mitigated (e.g., no
2 cancer cure in the next thousand years), and that these doses projected over thousands
3 of years are meaningful. However, these assumptions are questionable. In particular,
4 science cannot rule out the possibility that there will be no cancer fatalities from these
5 tiny doses. For perspective, the doses are very small fractions of regulatory limits and
6 even smaller fractions of natural background exposure to the same populations.
7

8 Nevertheless, despite all the uncertainty, some judgment as to the regulatory NEPA
9 (National Environmental Policy Act) implications of these matters should be made and it
10 makes no sense to repeat the same judgment in every case. Even taking the
11 uncertainties into account, the Commission concludes that these impacts are acceptable
12 in that these impacts would not be sufficiently large to require the NEPA conclusion, for
13 any plant, that the option of extended operation under 10 CFR Part 54 should be
14 eliminated. Accordingly, while the Commission has not assigned a single level of
15 significance for the collective effects of the fuel cycle, this issue is considered
16 Category 1.
17

18 The NRC staff has not identified any new and significant information during its independent
19 review of the Entergy ER, the site visit, the scoping process, or the evaluation of other available
20 information. Therefore, the NRC staff concludes that there would be no offsite radiological
21 impacts (collective effects) from the uranium fuel cycle during the renewal term beyond those
22 discussed in the GEIS.
23

- 24 • Offsite radiological impacts (spent fuel and HLW disposal). Based on information in the
25 GEIS, the Commission found that

27 For the HLW and spent fuel disposal component of the fuel cycle, there are no current
28 regulatory limits for offsite releases of radionuclides for the current candidate repository
29 site. However, if we assume that limits are developed along the lines of the 1995
30 National Academy of Sciences (NAS) report, *Technical Bases for Yucca Mountain*
31 *Standards* (NAS 1995), and that in accordance with the Commission's Waste
32 Confidence Decision, 10 CFR 51.23, a repository can and likely will be developed at
33 some site which will comply with such limits, peak doses to virtually all individuals will be
34 100 mrem per year or less. However, while the Commission has reasonable confidence
35 that these assumptions will prove correct, there is considerable uncertainty since the
36 limits are yet to be developed, no repository application has been completed or
37 reviewed, and uncertainty is inherent in the models used to evaluate possible pathways
38 to the human environment. The NAS report indicated that 100 mrem per year should be
39 considered as a starting point for limits for individual doses, but notes that some
40 measure of consensus exists among national and international bodies that the limits
41 should be a fraction of the 100 mrem per year. The lifetime individual risk from the
42 100 millirem annual dose limit is about 3×10^{-3} .

1 Estimating cumulative doses to populations over thousands of years is more
2 problematic. The likelihood and consequences of events that could seriously
3 compromise the integrity of a deep geologic repository were evaluated by the
4 Department of Energy in the *Final Environmental Impact Statement: Management of*
5 *Commercially Generated Radioactive Waste*, October 1980 (DOE 1980). The
6 evaluation estimated the 70-year whole-body dose commitment to the maximum
7 individual and to the regional population resulting from several modes of breaching a
8 reference repository in the year of closure, after 1000 years, after 100,000 years, and
9 after 100,000,000 years. Subsequently, the NRC and other Federal agencies have
10 expended considerable effort to develop models for the design and for the licensing of a
11 HLW repository, especially for the candidate repository at Yucca Mountain. More
12 meaningful estimates of doses to population may be possible in the future as more is
13 understood about the performance of the proposed Yucca Mountain repository. Such
14 estimates would involve very great uncertainty, especially with respect to cumulative
15 population doses over thousands of years. The standard proposed by the NAS is a limit
16 on maximum individual dose. The relationship of potential new regulatory requirements,
17 based on the NAS report, and cumulative population impacts has not been determined,
18 although the report articulates the view that protection of individuals will adequately
19 protect the population for a repository at Yucca Mountain. However, the
20 U.S. Environmental Protection Agency's (EPA's) generic repository standards in 40 CFR
21 Part 191 generally provide an indication of the order of magnitude of cumulative risk to
22 population that could result from the licensing of a Yucca Mountain repository, assuming
23 the ultimate standards will be within the range of standards now under consideration.
24 The standards in 40 CFR Part 191 protect the population by imposing "containment
25 requirements" that limit the cumulative amount of radioactive material released over
26 10,000 years. Reporting performance standards that will be required by EPA are
27 expected to result in releases and associated health consequences in the range
28 between 10 and 100 premature cancer deaths, with an upper limit of 1000 premature
29 cancer deaths worldwide for a 100,000-metric tonne (MTHM) repository.

30
31 Nevertheless, despite all the uncertainty, some judgment as to the regulatory NEPA
32 implications of these matters should be made and it makes no sense to repeat the same
33 judgment in every case. Even taking the uncertainties into account, the Commission
34 concludes that these impacts are acceptable in that these impacts would not be
35 sufficiently large to require the NEPA conclusion, for any plant, that the option of
36 extended operation under 10 CFR Part 54 should be eliminated. Accordingly, while the
37 Commission has not assigned a single level of significance for the impacts of spent fuel
38 and HLW disposal, this issue is considered Category 1.

39
40 On February 15, 2002, based on a recommendation by the Secretary of the Department of
41 Energy, the President recommended the Yucca Mountain site for the development of a
42 repository for the geologic disposal of spent nuclear fuel and high-level nuclear waste. The

Fuel Cycle

1 U.S. Congress approved this recommendation on July 9, 2002, in Joint Resolution 87, which
2 designated Yucca Mountain as the repository for spent nuclear waste. On July 23, 2002, the
3 President signed Joint Resolution 87 into law; Public Law 107-200, 116 Stat. 735 (2002)
4 designates Yucca Mountain as the repository for spent nuclear waste. This development does
5 not represent new and significant information with respect to the offsite radiological impacts
6 from license renewal related to disposal of spent nuclear fuel and high-level nuclear waste.
7

8 The EPA developed Yucca-Mountain-specific repository standards, which were subsequently
9 adopted by the NRC in 10 CFR Part 63. In an opinion, issued July 9, 2004, the U.S. Court of
10 Appeals for the District of Columbia Circuit (the Court) vacated the EPA's radiation protection
11 standards for the candidate repository, which required compliance with certain dose limits over
12 a 10,000-year period. The Court's decision also vacated the compliance period in NRC's
13 licensing criteria for the candidate repository in 10 CFR Part 63. In response to the Court's
14 decision, the EPA issued its proposed revised standards to 40 CFR Part 197 on August 22,
15 2005 (70 FR 49014). In order to be consistent with the EPA's revised standards, the NRC
16 proposed revisions to 10 CFR Part 63 on September 8, 2005 (70 FR 53313).
17

18 Therefore, for the HLW and spent fuel disposal component of the fuel cycle, there is some
19 uncertainty with respect to regulatory limits for offsite releases of radioactive nuclides for the
20 current candidate repository site. However, prior to promulgation of the affected provisions of
21 the Commission's regulations, the NRC staff assumed that limits would be developed along the
22 lines of the 1995 NAS report, *Technical Bases for Yucca Mountain Standards*, and that in
23 accordance with the Commission's Waste Confidence Decision, 10 CFR 51.23, a repository that
24 would comply with such limits could and likely would be developed at some site.
25

26 Despite the current uncertainty with respect to these rules, some judgment as to the regulatory
27 NEPA implications of offsite radiological impacts of spent fuel and HLW disposal should be
28 made. The NRC staff concludes that these impacts are acceptable in that the impacts would
29 not be sufficiently large to require the NEPA conclusion that the option of extended operation
30 under 10 CFR Part 54 should be eliminated.
31

32 The NRC staff has not identified any new and significant information during its independent
33 review of the Entergy ER, the site visit, the scoping process, or the evaluation of other available
34 information. Therefore, the NRC staff concludes that there would be no offsite radiological
35 impacts related to spent fuel and HLW disposal during the renewal term beyond those
36 discussed in the GEIS.
37

- 38 • Nonradiological impacts of the uranium fuel cycle. Based on information in the GEIS, the
39 Commission found that

40
41 The nonradiological impacts of the uranium fuel cycle resulting from the renewal of an
42 operating license for any plant are found to be small.

1 The NRC staff has not identified any new and significant information during its independent
2 review of the Entergy ER, the site visit, the scoping process, or the evaluation of other available
3 information. Therefore, the NRC staff concludes that there would be no nonradiological impacts
4 of the uranium fuel cycle during the renewal term beyond those discussed in the GEIS.

- 5
- 6 • Low-level waste storage and disposal. Based on information in the GEIS, the
7 Commission found that

8

9 The comprehensive regulatory controls that are in place and the low public doses being
10 achieved at reactors ensure that the radiological impacts to the environment will remain
11 small during the term of a renewed license. The maximum additional onsite land that
12 may be required for low-level waste storage during the term of a renewed license and
13 associated impacts will be small. Nonradiological impacts on air and water will be
14 negligible. The radiological and nonradiological environmental impacts of long-term
15 disposal of low-level waste from any individual plant at licensed sites are small. In
16 addition, the Commission concludes that there is reasonable assurance that sufficient
17 low-level waste disposal capacity will be made available when needed for facilities to be
18 decommissioned consistent with NRC decommissioning requirements.

19

20 The NRC staff has not identified any new and significant information during its independent
21 review of the Entergy ER, the site visit, the scoping process, or the evaluation of other available
22 information. Therefore, the NRC staff concludes that there would be no impacts of low-level
23 waste storage and disposal associated with the renewal term beyond those discussed in the
24 GEIS.

- 25
- 26 • Mixed waste storage and disposal. Based on information in the GEIS, the Commission
27 found that

28

29 The comprehensive regulatory controls and the facilities and procedures that are in
30 place ensure proper handling and storage, as well as negligible doses and exposure to
31 toxic materials for the public and the environment at all plants. License renewal will not
32 increase the small, continuing risk to human health and the environment posed by mixed
33 waste at all plants. The radiological and nonradiological environmental impacts of
34 long-term disposal of mixed waste from any individual plant at licensed sites are small.
35 In addition, the Commission concludes that there is reasonable assurance that sufficient
36 mixed waste disposal capacity will be made available when needed for facilities to be
37 decommissioned consistent with NRC decommissioning requirements.

38

39 The NRC staff has not identified any new and significant information during its independent
40 review of the Entergy ER, the site visit, the scoping process, or the evaluation of other available
41 information. Therefore, the NRC staff concludes that there would be no impacts of mixed waste
42 storage and disposal associated with the renewal term beyond those discussed in the GEIS.

Fuel Cycle

- 1 • Onsite spent fuel. Based on information in the GEIS, the Commission found that

2 The expected increase in the volume of spent fuel from an additional 20 years of
3 operation can be safely accommodated onsite with small environmental effects through
4 dry or pool storage at all plants if a permanent repository or monitored retrievable
5 storage is not available.

6
7 The NRC staff has not identified any new and significant information during its independent
8 review of the Entergy ER, the site visit, the scoping process, or the evaluation of other available
9 information. Therefore, the NRC staff concludes that there would be no impacts of onsite spent
10 fuel associated with license renewal beyond those discussed in the GEIS.

- 11 • Nonradiological waste. Based on information in the GEIS, the Commission found that

12 No changes to generating systems are anticipated for license renewal. Facilities and
13 procedures are in place to ensure continued proper handling and disposal at all plants.

14
15 The NRC staff has not identified any new and significant information during its independent
16 review of the Entergy ER, the site visit, the scoping process, or the evaluation of other available
17 information. Therefore, the NRC staff concludes that there would be no nonradiological waste
18 impacts during the renewal term beyond those discussed in the GEIS.

- 19 • Transportation. Based on information contained in the GEIS, the Commission found that

20 The impacts of transporting spent fuel enriched up to 5 percent uranium-235 with
21 average burnup for the peak rod to current levels approved by the NRC up to
22 62,000 MWd/MTU and the cumulative impacts of transporting HLW to a single
23 repository, such as Yucca Mountain, Nevada, are found to be consistent with the impact
24 values contained in 10 CFR 51.52(c), Summary Table S-4, "Environmental Impact of
25 Transportation of Fuel and Waste to and from One Light-Water-Cooled Nuclear Power
26 Reactor." If fuel enrichment or burnup conditions are not met, the applicant must submit
27 an assessment of the implications for the environmental impact values reported in the
28 summary table.

29
30 VYNPS meets the fuel-enrichment and burnup conditions set forth in Addendum 1 to the GEIS.
31 The NRC staff has not identified any new and significant information during its independent
32 review of the Entergy ER, the site visit, the scoping process, or the evaluation of other available
33 information. Therefore, the NRC staff concludes that there would be no impacts of
34 transportation associated with license renewal beyond those discussed in the GEIS.

35
36 There are no Category 2 issues for the uranium fuel cycle and solid waste management.

1 6.2 References

- 2
3 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, "Environmental
4 Protection Regulations for Domestic Licensing and Related Regulatory Functions."
5
6 10 CFR Part 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, "Requirements for
7 Renewal of Operating Licenses for Nuclear Power Plants."
8
9 10 CFR Part 63. *Code of Federal Regulations*, Title 10, *Energy*, Part 63, "Disposal of
10 High-Level Radioactive Wastes in a Geologic Repository at Yucca Mountain, Nevada."
11
12 40 CFR Part 191. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 191,
13 "Environmental Radiation Protection Standards for Management and Disposal of Spent Nuclear
14 Fuel, High-Level and Transuranic Radioactive Waste."
15
16 40 CFR Part 197. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 197,
17 "Public Health and Environmental Radiation Protection Standards for Management and
18 Disposal for Yucca Mountain, Nevada."
19
20 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006.
21 *Applicant's Environmental Report – Operating License Renewal Stage, Vermont Yankee*
22 *Nuclear Power Station*. Docket No. 50-271. Brattleboro, Vermont. (January 25, 2006).
23
24 Joint Resolution Approving the Site at Yucca Mountain, Nevada, for the Development of a
25 Repository for the Disposal of High-Level Radioactive Waste and Spent Nuclear Fuel, pursuant
26 to the Nuclear Waste Policy Act of 1982. 2002. Public Law 107-200. 116 Stat. 735.
27
28 National Academy of Sciences (NAS). 1995. *Technical Bases for Yucca Mountain Standards*.
29 Washington, D.C.
30
31 National Environmental Policy Act (NEPA), as amended, 42 USC 4321, et. seq.
32
33 U.S. Department of Energy (DOE). 1980. *Final Environmental Impact Statement:*
34 *Management of Commercially Generated Radioactive Waste*. DOE/EIS-0046F.
35 Washington, D.C.
36
37 U.S. Environmental Protection Agency (EPA). 2005. "Public Health and Environmental
38 Radiation Protection Standards for Yucca Mountain, Nevada." *Federal Register*, Vol. 70,
39 No. 161, pp. 49014–49068. Washington, D.C. (August 22, 2005).
40
41 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement*
42 *for License Renewal of Nuclear Plants*. NUREG-1437, Vols. 1 and 2, Washington, D.C.

Fuel Cycle

- 1 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement*
2 *for License Renewal of Nuclear Plants, Main Report*, "Section 6.3 – Transportation, Table 9.1,
3 Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants, Final
4 Report." NUREG-1437, Vol. 1, Addendum 1, Washington, D.C.
- 5 U.S. Nuclear Regulatory Commission (NRC). 2005. "Implementation of a Dose Standard After
6 10,000 Years." *Federal Register*, Vol. 63, No. 173, pp. 53313–53320. Washington, D.C.
7 (September 28, 2005).
- 8

7.0 Environmental Impacts of Decommissioning

Environmental impacts from the activities associated with the decommissioning of any reactor before or at the end of an initial or renewed license are evaluated in the *Generic Environmental Impact Statement for Decommissioning of Nuclear Facilities: Supplement 1, Regarding the Decommissioning of Nuclear Power Reactors*, NUREG-0586, Supplement 1 (NRC 2002). The U.S. Nuclear Regulatory Commission (NRC) staff's evaluation of the environmental impacts of decommissioning presented in NUREG-0586, Supplement 1, identifies a range of impacts for each environmental issue.

The incremental environmental impacts associated with decommissioning activities resulting from continued plant operation during the renewal term are discussed in the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, Volumes 1 and 2 (NRC 1996, 1999).^(a) The GEIS includes a determination of whether the analysis of the environmental issue could be applied to all plants and whether additional mitigation measures would be warranted. Issues were then assigned a Category 1 or a Category 2 designation. As set forth in the GEIS, Category 1 issues are those that meet all of the following criteria:

- (1) The environmental impacts associated with the issue have been determined to apply either to all plants or, for some issues, to plants having a specific type of cooling system or other specified plant or site characteristics.
- (2) A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to the impacts (except for collective offsite radiological impacts from the fuel cycle and from high-level waste and spent fuel disposal).
- (3) Mitigation of adverse impacts associated with the issue has been considered in the analysis, and it has been determined that additional plant-specific mitigation measures are likely not to be sufficiently beneficial to warrant implementation.

For issues that meet the three Category 1 criteria, no additional plant-specific analysis is required unless new and significant information is identified.

Category 2 issues are those that do not meet one or more of the criteria for Category 1, and, therefore, additional plant-specific review of these issues is required. There are no Category 2 issues related to decommissioning.

(a) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and its Addendum 1.

Environmental Impacts of Decommissioning

7.1 Decommissioning

Category 1 issues in Table B-1 of Title 10, Part 51, of the *Code of Federal Regulations* (10 CFR Part 51), Subpart A, Appendix B, that are applicable to Vermont Yankee Nuclear Power Station (VYNPS) decommissioning following the renewal term are listed in Table 7-1. Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy) stated in its Environmental Report (ER) (Entergy 2006) that it is aware of no new and significant information regarding the environmental impacts of VYNPS license renewal. The NRC staff has not identified any new and significant information during its independent review of the Entergy ER, the site visit, the scoping process, or its evaluation of other available information. Therefore, the NRC staff concludes that there are no impacts related to these issues beyond those discussed in the GEIS. For all of these issues, the NRC staff concluded in the GEIS that the impacts are SMALL, and additional plant-specific mitigation measures are not likely to be sufficiently beneficial to be warranted.

Table 7-1. Category 1 Issues Applicable to the Decommissioning of VYNPS Following the Renewal Term

ISSUE—10 CFR Part 51, Subpart A, Appendix B, Table B-1	GEIS Section
DECOMMISSIONING	
Radiation doses	7.3.1; 7.4
Waste management	7.3.2; 7.4
Air quality	7.3.3; 7.4
Water quality	7.3.4; 7.4
Ecological resources	7.3.5; 7.4
Socioeconomic impacts	7.3.7; 7.4

A brief description of the NRC staff's review and the GEIS conclusions, as codified in Table B-1, for each of the issues follows:

- Radiation doses. Based on information in the GEIS, the Commission found that

Doses to the public will be well below applicable regulatory standards regardless of which decommissioning method is used. Occupational doses would increase no more than 1 man-rem caused by buildup of long-lived radionuclides during the license renewal term.

The NRC staff has not identified any new and significant information during its independent review of the Entergy ER, the site visit, the scoping process, or the

Environmental Impacts of Decommissioning

1 evaluation of other available information. Therefore, the NRC staff concludes that there
2 would be no radiation dose impacts associated with decommissioning following the
3 license renewal term beyond those discussed in the GEIS.

- 4
- 5 • Waste management. Based on information in the GEIS, the Commission found that

6

7 Decommissioning at the end of a 20-year license renewal period would generate
8 no more solid wastes than at the end of the current license term. No increase in
9 the quantities of Class C or greater than Class C wastes would be expected.

10

11 The NRC staff has not identified any new and significant information during its
12 independent review of the Entergy ER, the site visit, the scoping process, or the
13 evaluation of other available information. Therefore, the NRC staff concludes that there
14 would be no impacts from solid waste associated with decommissioning following the
15 license renewal term beyond those discussed in the GEIS.

- 16
- 17 • Air quality. Based on information in the GEIS, the Commission found that

18

19 Air quality impacts of decommissioning are expected to be negligible either at the
20 end of the current operating term or at the end of the license renewal term.

21

22 The NRC staff has not identified any new and significant information during its
23 independent review of the Entergy ER, the site visit, the scoping process, or the
24 evaluation of other available information. Therefore, the NRC staff concludes that there
25 would be no impacts on air quality associated with decommissioning following the
26 license renewal term beyond those discussed in the GEIS.

- 27
- 28 • Water quality. Based on information in the GEIS, the Commission found that

29

30 The potential for significant water quality impacts from erosion or spills is no
31 greater whether decommissioning occurs after a 20-year license renewal period
32 or after the original 40-year operation period, and measures are readily available
33 to avoid such impacts.

34

35 The NRC staff has not identified any new and significant information during its independent
36 review of the Entergy ER, the site visit, the scoping process, or the evaluation of other
37 available information. Therefore, the NRC staff concludes that there would be no impacts
38 on water quality associated with decommissioning following the license renewal term
39 beyond those discussed in the GEIS.

- 40
- 41 • Ecological resources. Based on information in the GEIS, the Commission found that

Environmental Impacts of Decommissioning

1 Decommissioning after either the initial operating period or after a 20-year
2 license renewal period is not expected to have any direct ecological impacts.
3

4 The NRC staff has not identified any new and significant information during its independent
5 review of the Entergy ER, the site visit, the scoping process, or the evaluation of other
6 available information. Therefore, the NRC staff concludes that there would be no impacts
7 on ecological resources associated with decommissioning following the license renewal
8 term beyond those discussed in the GEIS.
9

- 10 • Socioeconomic impacts. Based on information in the GEIS, the Commission found that
11

12 Decommissioning would have some short-term socioeconomic impacts. The
13 impacts would not be increased by delaying decommissioning until the end of a
14 20-year relicense period, but they might be decreased by population and
15 economic growth.
16

17 The NRC staff has not identified any new and significant information during its independent
18 review of the Entergy ER, the site visit, the scoping process, or its evaluation of other
19 available information. Therefore, the NRC staff concludes that there would be no
20 socioeconomic impacts associated with decommissioning following the license renewal term
21 beyond those discussed in the GEIS.
22

23 **7.2 References**

24
25 10 CFR Part 51. *Code of Federal Regulations*, Title 10, Energy, Part 51, "Environmental
26 Protection Regulations for Domestic Licensing and Related Regulatory Functions."
27

28 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006.
29 *Applicant's Environmental Report – Operating License Renewal Stage, Vermont Yankee*
30 *Nuclear Power Station*. Docket No. 50-271. Brattleboro, Vermont. (January 25, 2006).
31

32 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement*
33 *for License Renewal of Nuclear Plants*. NUREG-1437, Vols. 1 and 2, Washington, D.C.
34

35 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement*
36 *for License Renewal of Nuclear Plants, Main Report*, "Section 6.3 – Transportation, Table 9.1,
37 Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants, Final
38 Report." NUREG-1437, Vol. 1, Addendum 1, Washington, D.C.
39

40 U.S. Nuclear Regulatory Commission (NRC). 2002. *Generic Environmental Impact Statement*
41 *for Decommissioning of Nuclear Facilities: Supplement 1, Regarding the Decommissioning of*
42 *Nuclear Power Reactors*. NUREG-0586, Supplement 1, Washington, D.C.

1 **8.0 Environmental Impacts of Alternatives**

2

3

4 This chapter examines the potential environmental impacts associated with (1) denying the
5 renewal of the Vermont Yankee Nuclear Power Station (VYNPS) operating license (OL)
6 (i.e., the no-action alternative); (2) replacing VYNPS electric-generation capacity using electric-
7 generation sources other than VYNPS; (3) purchasing electric power from other sources to
8 replace power generated by VYNPS; and (4) a combination of generation and conservation
9 measures. In addition, other alternatives that were deemed unsuitable for replacement of power
10 generated by VYNPS are discussed.

11 The environmental impacts of alternatives are evaluated using the U.S. Nuclear Regulatory
12 Commission's (NRC's) three-level standard of significance – SMALL, MODERATE, or LARGE –
13 developed using the Council on Environmental Quality guidelines and set forth in the footnotes
14 to Table B-1 of Title 10, Part 51, of the *Code of Federal Regulations* (10 CFR Part 51),
15 Subpart A, Appendix B:

16 SMALL – Environmental effects are not detectable or are so minor that they will neither
17 destabilize nor noticeably alter any important attribute of the resource.

18 MODERATE – Environmental effects are sufficient to alter noticeably, but not to destabilize
19 important attributes of the resource.

20 LARGE – Environmental effects are clearly noticeable and are sufficient to destabilize
21 important attributes of the resource.

22 The impact categories evaluated in this chapter are the same as those used in the *Generic*
23 *Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS) NUREG-1437,
24 Volumes 1 and 2 (NRC 1996, 1999),^(a) with the additional impact category of environmental
25 justice and transportation.

26 **8.1 No-Action Alternative**

27 NRC regulations implementing the National Environmental Policy Act (NEPA), 10 CFR Part 51,
28 Subpart A, Appendix A(4), specify that the no-action alternative be discussed in an NRC
29 Environmental Impact Statement (EIS). For license renewal, the no-action alternative refers to
30 a scenario in which the NRC would not renew the VYNPS OL, and Entergy would then cease
31 plant operations by the end of the current OL and initiate decommissioning of the plant. Entergy
32 eventually would be required to shut down VYNPS and to comply with NRC decommissioning

1 (a) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all
2 references to the "GEIS" include the GEIS and its Addendum 1.

Alternatives

1 requirements in 10 CFR 50.82, whether or not the OL is renewed. If the VYNPS OL is renewed,
2 shutdown of the unit and decommissioning activities would not be avoided, but would be
3 postponed for up to an additional 20 years.

4
5 The environmental impacts associated with decommissioning under a license renewal or the no-
6 action alternative would be bounded by the discussion of impacts in Chapter 7 of the license
7 renewal GEIS (NRC 1996), Chapter 7 of this Supplemental Environmental Impact Statement
8 (SEIS), and the *Final Generic Environmental Impact Statement on Decommissioning of Nuclear*
9 *Facilities*, NUREG-0586, Supplement 1 (NRC 2002). The impacts of decommissioning after
10 60 years of operation are not expected to be significantly different from those that would occur
11 after 40 years of operation.

12
13 Impacts from the decision to permanently cease operations are not considered in NUREG-0586,
14 Supplement 1.^(a) Therefore, immediate impacts that occur between plant shutdown and the
15 beginning of decommissioning are considered here. These impacts would occur when the unit
16 shuts down regardless of whether the license is renewed or not and are discussed below, with
17 the results presented in Table 8-1. Plant shutdown would result in a net reduction in power
18 production capacity. The power not generated by VYNPS during the license renewal term
19 would likely be replaced by (1) power purchased from other electricity providers, (2) generation
20 alternatives other than VYNPS, (3) demand-side management (DSM) and energy conservation,
21 or (4) some combination of these options. The environmental impacts of these options are
22 discussed in Section 8.2.

23
24 • **Land Use**

25
26 In Chapter 4, the NRC staff concluded that the impact of continued plant operation on land
27 use would be SMALL. Onsite land use would not be affected immediately by the cessation
28 of operations. Plant structures and other facilities are likely to remain in place until
29 decommissioning. The transmission lines associated with VYNPS are expected to remain in
30 service after the plant stops operating. As a result, maintenance of the rights-of-way will
31 continue as before. Therefore, the NRC staff concludes that the impact on land use from
32 plant shutdown would be SMALL.

33
34 • **Ecology**

35
36 In Chapter 4, the NRC staff concluded that the ecological impact of continued plant
37 operation would be SMALL. Cessation of operations would be accompanied by a reduction
38 in cooling water flow and in the thermal plume from the plant. These changes would reduce

(a) Appendix J of NUREG-0586, Supplement 1, discusses the socioeconomic impacts of plant closure. The results of the analysis in Appendix J, however, were not incorporated into the analysis presented in the main body of the NUREG.

environmental impacts on terrestrial and aquatic species. The transmission lines associated with VYNPS are expected to remain in service after VYNPS stops operating. As a result, maintenance of the rights-of-way and subsequent impacts on the terrestrial ecosystem would continue as before. Therefore, the NRC staff concludes that the ecological impact from shutdown of the plant would be SMALL.

Table 8-1. Summary of Environmental Impacts of the No-Action Alternative

Impact Category	Impact	Comment
Land use	SMALL	Impact is expected to be SMALL because plant shutdown would not be expected to result in changes to onsite or offsite land use.
Ecology	SMALL	Impact is expected to be SMALL because aquatic impacts would be reduced from current levels, and terrestrial impacts are not expected because there would not be any changes in transmission line right-of-way maintenance practices.
Water use and quality – surface water	SMALL	Impact is expected to be SMALL because surface-water intake and discharges would be eliminated.
Water use and quality – groundwater	SMALL	Impact is expected to be SMALL because groundwater use would decrease.
Air quality	SMALL	Impact is expected to be SMALL because emissions related to plant operation and worker transportation would decrease.
Waste	SMALL	Impact is expected to be SMALL because generation of high-level waste would stop, and generation of low-level and mixed waste would decrease.
Human health	SMALL	Impact is expected to be SMALL because radiological doses to workers and members of the public, which are within regulatory limits, would be further reduced.
Socioeconomics	SMALL TO LARGE	Impacts are expected to range from SMALL to LARGE because the loss of overall employment would be relatively SMALL and the loss of tax revenues would be LARGE.
Transportation	SMALL	Impact is expected to be SMALL because the decrease in employment would reduce traffic.
Aesthetics	SMALL	Impact is expected to be SMALL because plant structures would remain in place and the visibility of plumes from the cooling towers would be eliminated.
Historic and archaeological resources	SMALL	Impact is expected to be SMALL because shutdown of the plant would not result in land disturbance.
Environmental justice	SMALL	Impact is expected to be SMALL because the loss of overall employment would be small.

Alternatives

1 • **Water Use and Quality – Surface Water**

2
3 In Chapter 4, the NRC staff concluded that the impact of continued plant operation on
4 surface-water use and quality would be SMALL. When the plant stops operating, there
5 would be an immediate reduction in the consumptive use of water because of the reduction
6 in cooling water flow and in the amount of heat rejected to the Connecticut River. Therefore,
7 the NRC staff concludes that the impact on surface-water use and quality from plant
8 shutdown would be SMALL.

9
10 • **Water Use and Quality – Groundwater**

11
12 In Chapter 4, the NRC staff concluded that the impact of continued plant groundwater use
13 on groundwater availability and quality would be SMALL. When the plant stops operating,
14 there would be a reduction in the use of water because cooling towers would no longer be
15 required and there would be reduced potable water consumption and sanitary use as the
16 size of the plant staff decreases. Therefore, the NRC staff concludes that the impact on
17 groundwater use and quality from shutdown of the plant would be SMALL.

18
19 • **Air Quality**

20
21 In Chapter 4, the NRC staff concluded that the impact of continued plant operation on air
22 quality would be SMALL. When the plant stops operating, there would be a reduction in
23 emissions from activities related to plant operation, such as worker transportation.
24 Therefore, the NRC staff concludes that the impact on air quality from shutdown of the plant
25 would be SMALL.

26
27 • **Waste**

28
29 The impacts of radioactive waste generated by continued plant operation are discussed in
30 Chapter 6. The impact of low-level and mixed waste from plant operation is characterized
31 as SMALL. When VYNPS stops operating, it would stop generating high-level waste (HLW),
32 and the generation of low-level and mixed waste associated with plant operation and
33 maintenance would be reduced. Therefore, the NRC staff concludes that the impact of
34 waste generated after shutdown of the plant would be SMALL.

35
36 • **Human Health**

37
38 In Chapter 4, the NRC staff concluded that the impacts of continued plant operation on
39 human health would be SMALL. After the cessation of operations, the amount of radioactive
40 material released to the environment in gaseous and liquid forms would be reduced.
41 Therefore, the NRC staff concludes that the impact of shutdown of the plant on human
42 health would be SMALL. In Chapter 5, the NRC staff concluded that the impacts of

1 accidents during operation would be SMALL. After shutdown, the variety of potential
2 accidents at the plant would be reduced to a limited set associated with fuel handling and
3 storage. Therefore, the NRC staff concludes that the impact of potential accidents following
4 shutdown of the plant would be SMALL.

5 • **Socioeconomics**

6 In Chapter 4, the NRC staff concluded that the socioeconomic impact of continued plant
7 operation would be SMALL. There would be immediate socioeconomic impacts associated
8 with the shutdown of the plant because of the reduction in the staff at the plant. There may
9 also be an immediate reduction in property tax revenues for Windham County, and this is
10 anticipated to be LARGE. The overall impact would depend on the state of the economy,
11 the net change in workforce at the plant, and the changes in local government tax receipts.
12 Appendix J of Supplement 1 to NUREG-0586 (NRC 2002) shows that the overall
13 socioeconomic impact of plant closure plus decommissioning could be greater than SMALL.
14 The NRC staff concludes that the socioeconomic impact of VYNPS shutdown on
15 employment would be SMALL because of the relatively small employment loss compared
16 with total employment in the economy of the surrounding area. Therefore, the NRC staff
17 concludes that the socioeconomic impacts of plant shutdown would range from SMALL to
18 LARGE. Impacts could be offset if new power-generating facilities are built at or near the
19 current site.

20 • **Transportation**

21 In Chapter 4, the NRC staff concluded that the impact of continued plant operation on
22 transportation would be SMALL. Cessation of operations would be accompanied by a
23 reduction of traffic in the vicinity of the plant. Most of the reduction would be associated with
24 a reduction in the plant workforce, but there also would be a reduction in shipment of
25 material to and from the plant. Therefore, the NRC staff concludes that the impact of plant
26 closure on transportation would be SMALL.

27 • **Aesthetics**

28 In Chapter 4, the NRC staff concluded that the aesthetic impact of continued plant operation
29 would be SMALL. Cessation of operations would be accompanied by the elimination of
30 visible plumes from the cooling towers. Plant structures and other facilities are likely to
31 remain in place until decommissioning. Therefore, the NRC staff concludes that the
32 aesthetic impact of plant closure would be SMALL.

33 • **Historic and Archaeological Resources**

34 In Chapter 4, the NRC staff concluded that the impacts of continued plant operation on
35 historic and archaeological resources would be SMALL. Onsite land use would not be
36

Alternatives

1 affected immediately by the cessation of operations. Plant structures and other facilities
2 would likely remain in place until decommissioning. The transmission line associated with
3 the project is expected to remain in service after the plant stops operating. As a result,
4 maintenance of the transmission line right-of-way would continue as before. Therefore, the
5 NRC staff concludes that the impact on historic and archaeological resources from plant
6 shutdown would be SMALL.
7

8 • **Environmental Justice**
9

10 In Chapter 4, the NRC staff concluded that the environmental justice impact of continued
11 operation of the plant would be SMALL. Continued operation of the plant would not have a
12 disproportionately high and adverse impact on minority and low-income populations.
13 Shutdown of the plant also would not have disproportionately high and adverse impacts on
14 minority and low-income populations resulting from the loss of employment opportunities at
15 the site or from secondary socioeconomic impacts (e.g., loss of patronage at local
16 businesses because the loss would be very minor in the context of the regional economy).
17 The NRC staff concludes that the environmental justice impact of plant shutdown is
18 expected to be SMALL. Any impact would be offset if new power-generating facilities are
19 built at or near the current site. See Appendix J to NUREG-0586, Supplement 1
20 (NRC 2002), for additional discussion of this impact.
21

22 **8.2 Alternative Energy Sources**
23

24 This section discusses the environmental impacts associated with developing alternative
25 sources of electric power to replace the power generated by VYNPS, assuming that the OL for
26 VYNPS is not renewed. The order of presentation of alternative energy sources does not imply
27 which alternative would be most likely to occur or to have the least environmental impacts. The
28 following power-generation alternatives are considered in detail:
29

- 30 • Coal-fired plant generation at an alternate site (Section 8.2.1),
31
32 • Natural-gas-fired plant generation at the VYNPS site and at an alternate site
33 (Section 8.2.2), and
34
35 • New nuclear power plant generation at an alternate site (Section 8.2.3).
36

37 The alternative of purchasing power from other sources to replace power generated at VYNPS
38 is discussed in Section 8.2.4. Other power-generation alternatives and conservation
39 alternatives considered by the NRC staff and found not to be reasonable replacements for
40 VYNPS are discussed in Section 8.2.5. Section 8.2.6 discusses the environmental impacts of a
41 combination of generation and conservation alternatives.
42

1 Each year, the Energy Information Administration (EIA), a component of the U.S. Department of
2 Energy (DOE), issues an Annual Energy Outlook. In its *Annual Energy Outlook 2006 with*
3 *Projections to 2030*, the EIA projects that more than 57 percent of new electric-generating
4 capacity between 2006 and 2030 will be coal-fired plants (EIA 2006). The amount of electricity
5 produced by coal-fired plants will rise slowly in the near future but will grow considerably
6 compared to other types of plants because of reliability and rising natural gas prices. Natural-
7 gas-fired plants accounted for 18 percent of the total supply in 2004, but the EIA predicts their
8 contribution to decline to 17 percent by 2030 (EIA 2006). A slight rise in the percentage of
9 natural-gas-fired plants in the near term is predicted due to new more efficient technologies, but
10 the rising cost of natural gas will eventually reduce this share. Renewable fuel technologies
11 such as wind, solar, and hydropower provided 9 percent of the total electricity consumed in
12 2004, and this is expected to rise to only 9.4 percent by 2030 (EIA 2006). Of the renewable
13 fuels, hydropower provides the most power at 6.8 percent in 2004 and is expected to fall to
14 5.1 percent in 2030 (EIA 2006). The drop in hydropower is due to the lack of new locations for
15 development. The share of power resulting from other renewable sources of power is expected
16 to rise from 2.2 percent in 2004 to 4.3 percent in 2030 due to technological advances and State
17 and Federal support (EIA 2006).

18
19 Nuclear plants currently provide 20 percent of the power in the United States (EIA 2006). New
20 nuclear plants are expected to be built partly due to Energy Policy Act of 2005 tax incentives.
21 By 2030, nuclear power is expected to drop to only 15 percent of the total power produced in
22 the United States (EIA 2006).

23
24 However, there has been an increased interest in constructing new nuclear power facilities, as
25 evidenced by the certification of four standard nuclear power plant designs and recent activities
26 involving the review of other plant designs and potential sites (see Section 8.2.3). The NRC has
27 also established the Office of New Reactors (NRO) to prepare for and manage future reactor
28 and site licensing applications (NRC 2006). In addition, the Energy Policy Act of 2005 contains
29 provisions to ensure that nuclear energy continues to be a major component of the nation's
30 energy supply. This Act also establishes a production tax credit for new nuclear power facilities.
31 Therefore, despite the EIA projection, a new nuclear plant alternative for replacing power
32 generated by VYNPS is considered in this SEIS.

33
34 VYNPS has a net electrical capacity of 650 MW(e) (Section 3.2.1; Entergy 2005). For the coal-
35 and natural-gas-fired plant alternatives, the NRC staff assumed construction of a 620-MW(e)
36 and a 608-MW(e) plant, respectively, which is consistent with Entergy's Environmental Report
37 (ER) (Entergy 2005). This assumption will understate the environmental impacts of replacing
38 the 650 MW(e) from VYNPS by about 5 to 6 percent. The applicant did not identify any specific
39 alternate sites in the ER for the coal-fired or natural-gas-fired plants; however, it was assumed
40 that a suitable location could be found in the region. For the new nuclear power plant
41 alternative, the NRC staff assumed the same capacity as VYNPS. Given the small size of the
42 VYNPS property, 125 acres, it was assumed that the coal-fired and nuclear power plant would

Alternatives

have to be constructed at an alternate location (Entergy 2006). Therefore, this SEIS only evaluates construction of a natural-gas-fired plant at the VYNPS site as well as the construction of all three power plant alternatives at an alternate site for the analysis of environmental impacts.

8.2.1 Coal-Fired Plant Generation

The coal-fired plant alternative is analyzed for a generic alternate site. Unless otherwise indicated, the assumptions and numerical values used are from the Entergy ER (Entergy 2006). The NRC staff reviewed the information in the Entergy ER and compared it with environmental impact information in the GEIS for license renewal. Although the OL renewal period is only 20 years, the impact of operating a coal-fired plant for 40 years is considered (as a reasonable projection of the operating life of a coal-fired plant). The NRC staff assumed that the VYNPS plant would remain in operation while the alternative coal-fired plant was constructed.

The NRC staff assumed the construction of one standard 620-MW(e) unit for a total capacity of 620 MW(e) as a potential replacement for VYNPS. The coal-fired plant would consume approximately 1.9 million tons/yr of pulverized bituminous coal with an ash content of approximately 8.2 percent (Entergy 2006). Entergy assumes a heat rate^(a) of 10,200 Btu/kWh and a capacity factor^(b) of 0.85 in its ER (Entergy 2006).

In addition to the impacts discussed below for a coal-fired plant at an alternate site, impacts would occur offsite as a result of the mining of coal and limestone. Impacts of mining operations would include an increase in fugitive dust emissions; surface-water runoff; erosion; sedimentation; changes in water quality; disturbance of vegetation and wildlife; disturbance of historic and archaeological resources; changes in land use; and impacts on employment.

The magnitude of these offsite impacts would largely be proportional to the amount of land affected by mining operations. In the GEIS, the NRC staff estimated that approximately 22,000 ac would be affected by the mining of coal and the disposal of the waste needed to support a 1000-MW(e) coal-fired plant during its operational life (NRC 1996). Proportionally less land would be affected by a 620-MW(e) plant. Partially offsetting this offsite land use would be the elimination of the need for uranium mining to supply fuel for VYNPS. In the GEIS, the NRC staff estimated that approximately 1000 ac would be affected for mining the uranium and processing it during the operating life of a 1000-MW(e) nuclear power plant.

(a) Heat rate is a measure of generating station thermal efficiency. In English units, it is generally expressed in British thermal units (Btu) per net kilowatt-hour (kWh). It is computed by dividing the total Btu content of the fuel burned for electric generation by the resulting kWh generation.

(b) The capacity factor is the ratio of electricity generated, for the period of time considered, to the energy that could have been generated at continuous full-power operation during the same period.

1 **8.2.1.1 Coal-Fired Plant with a Closed-Cycle Cooling System**

2

3 In this section, the NRC staff evaluates the impacts of a coal-fired plant located at an alternate
4 site that uses a closed-cycle cooling system. The impacts of a coal-fired plant using a once-
5 through cooling system are considered in Section 8.2.1.2.

6 The overall impacts of the coal-fired plant alternative are discussed in the following sections and
7 summarized in Table 8-2. The magnitude of impacts for an alternate site would depend on the
8 characteristics of the particular site selected.

10 • **Land Use**

11 In its ER, Entergy estimated that 1054 ac of land would be needed for construction of a coal-
12 fired plant at an alternate site. Entergy assumed use of the closed-cycle cooling system for
13 a coal-fired plant at an alternate site (see Table 8-2 for a discussion of the impacts of a coal-
14 fired plant using a closed-cycle cooling system). Additional land would likely be required for
15 construction of cooling towers.

16 The GEIS estimates that approximately 1700 ac would be needed for a 1000-MW(e) coal-
17 fired plant (NRC 1996). This estimate would be scaled down for the 620-MW(e) capacity of
18 the proposed coal-fired plant alternative (i.e., 1054 ac) at an alternate site. Additional land
19 might be needed for transmission lines and rail spurs, depending on the location of the
20 alternate site relative to the nearest intertie connection and rail line.

21 In the GEIS, the staff estimated that approximately 22 acres of land per MW(e) would be
22 affected for mining the coal and disposing of the waste to support a coal-fired plant during its
23 operational life (NRC 1996). Therefore, for the hypothetical 620 gross MW(e) plant utilized
24 in this analysis, it would take approximately 13,640 acres of land. Partially offsetting this
25 offsite land use would be the elimination of the need for uranium mining and processing to
26 supply fuel for VYNPS. In the GEIS, the staff estimated approximately 1 acre per MW(e)
27 would be affected for mining and processing the uranium during the operating life of a
28 nuclear power plant (NRC 1996). Therefore, for the hypothetical 620 gross MWe plant
29 utilized in this analysis, it would take approximately 620 acres of land.

30 Additional land would likely be needed at an alternate site for a transmission line to connect
31 to the existing grid and for a rail spur.

32 The waste produced by the coal-fired plant would be disposed of at an alternate site, and
33 would account for approximately 123.3 ac of land area over the 40-year plant life.

Alternatives

Table 8-2. Summary of Environmental Impacts of a Coal-Fired Plant Using Closed-Cycle Cooling at an Alternate Site

	Impact Category	Impact	Comments
5	Land use	MODERATE to LARGE	Impact would depend on the characteristics of the alternate site. Uses approximately 1054 ac for plant, offices, and parking. Additional land (amount dependent on site chosen) would be needed for a rail spur and a transmission line. Additional offsite land-use impact of 13,640 ac for mining coal and limestone.
6	Ecology	MODERATE to LARGE	Impact would depend on the characteristics of the land to be developed, surface-water body used for intake and discharge, and transmission line and rail spur routes. Impact on terrestrial ecology from cooling-tower drift. Some impingement and entrainment of aquatic organisms.
7	Water use and quality – surface water	SMALL to MODERATE	Impact would depend on the volume of water withdrawn and discharged and the characteristics of the surface-water body. Cooling-tower blowdown containing increased dissolved solids and intermittent low concentrations of biocides, as well as wastewater, would be released.
9	Water use and quality – groundwater	SMALL to MODERATE	Impact would depend on the volume of water withdrawn and discharged and the characteristics of the aquifers.
10	Air quality	MODERATE	Impact from fugitive dust and emissions from vehicles and equipment during construction would be MODERATE. Impact of operations on air quality during operations would be MODERATE with the following emissions expected: Sulfur oxides <ul style="list-style-type: none"> • 1238 tons/yr Nitrogen oxides <ul style="list-style-type: none"> • 472 tons/yr Particulates <ul style="list-style-type: none"> • 77 tons/yr of total suspended particulates • 18 tons/yr of PM₁₀ Carbon monoxide <ul style="list-style-type: none"> • 472 tons/yr Small amounts of mercury and other hazardous air pollutants and naturally occurring radioactive materials – mainly uranium and thorium. Pollution-control standards may vary, depending on location. Impact during construction would be MODERATE. Impact during operation would be MODERATE.

Table 8-2. (contd)

Impact Category	Impact	Comments
Waste	MODERATE	Waste would be generated and removed during construction. During operation, total waste volume would be about 222,227 tons/yr of ash and scrubber sludge, requiring approximately 123.3 ac for disposal during the 40-year life of the plant. Waste disposal constraints may vary.
Human health	SMALL	Impact is uncertain, but considered SMALL in the absence of more quantitative data.
Socioeconomics	SMALL to LARGE	Construction impact would depend on location, but could be LARGE if the plant is located in a rural area. Up to 1550 workers during the peak period of the 3-year construction period. Operation would result in a workforce of 124 full-time employees, which is a net loss of approximately 554 jobs, if the site is located in Windham County. Windham County's tax base would experience a loss and an additional reduction in employment if the alternate site is not located within the county. Employment impacts could be offset by other economic growth in the area.
Transportation	MODERATE to LARGE	Transportation impact associated with up to 1550 construction workers would be MODERATE. Impact associated with 124 plant workers during operation would be SMALL.
		For rail transportation of coal and lime, the impact is considered SMALL to LARGE, depending on location. Barge delivery would have SMALL impacts.
Aesthetics	MODERATE to LARGE	Impact would depend on the characteristics of the site, but could be MODERATE. Intermittent noise from construction, commuter traffic, and waste disposal; continuous noise from cooling towers and mechanical equipment; and rail transportation of coal and lime would result in MODERATE noise impacts. The impact could range from MODERATE to LARGE.
		Additional impact would result from construction and operation of the new transmission line and rail spur. Depending on the location of the site chosen, this impact could be LARGE.
Historic and archeological resources	SMALL to MODERATE	Impact would depend on the characteristics of the alternate site. A cultural resource inventory would be needed to identify, evaluate, and mitigate potential impacts of new plant construction.
Environmental justice	SMALL to MODERATE	Impact would depend on population distribution and makeup at the site.

Alternatives

The NRC staff concludes that this alternative would result in MODERATE to LARGE land-use impacts at an alternate site, depending particularly on the location and length of the transmission line and rail spur.

• Ecology

Locating a coal-fired plant at an alternate site would result in construction and operational impacts. Approximately 1054 ac of land would be converted to industrial use. Even assuming siting at a previously disturbed area, the impacts would affect ecological resources. Impacts could include impacts on threatened and endangered species, wildlife habitat loss, reduced productivity, habitat fragmentation, and a local reduction in biological diversity. Use of cooling makeup water from a nearby surface-water body could cause entrainment and impingement of fish and other aquatic organisms, and result in adverse impacts on aquatic resources. If needed, construction and maintenance of a transmission line and a rail spur also would have ecological impacts. There would be some additional impact on terrestrial ecology from drift from the cooling towers. Overall, the ecological impacts of constructing a coal-fired plant with a closed-cycle cooling system at an alternate site are considered to be MODERATE to LARGE.

• Water Use and Quality

Surface Water. At an alternate site, the impact on surface-water use and quality would depend on the volume of water needed for cooling makeup water, the discharge volume, and the characteristics of the receiving body of water. Intake from and discharge to any surface body of water would be regulated by the State of Vermont. The impacts would be SMALL to MODERATE and dependent on the receiving body of water.

Groundwater. Groundwater use is possible for a coal-fired plant at an alternate site if surface-water resources are limited for makeup and potable water. Groundwater withdrawal could require a permit. Impacts on groundwater use and quality of a coal-fired plant with a closed-cycle cooling system at an alternate site would be SMALL to MODERATE, depending on the volume of groundwater withdrawn and characteristics of the aquifer.

• Air Quality

The air quality impacts of coal-fired generation differ considerably from those of nuclear generation due to emissions of sulfur oxides (SO_x), nitrogen oxides (NO_x), particulate matter, carbon monoxide (CO), hazardous air pollutants such as mercury, and naturally occurring radioactive materials.

A new coal-fired plant located in Vermont would likely need a Prevention of Significant Deterioration (PSD) permit and an operating permit under the Clean Air Act (CAA). The

1 plant would need to comply with the new-source performance standards for such plants as
2 set forth in 40 CFR Part 60, Subpart D(a). The standards establish limits for particulate
3 matter and opacity (40 CFR 60.42(a)), sulfur dioxide (SO_2) (40 CFR 60.43(a)), and NO_x
4 (40 CFR 60.44(a)).

5
6 The U.S. Environmental Protection Agency (EPA) has various regulatory requirements for
7 visibility protection in 40 CFR Part 51, Subpart P, including a specific requirement for review
8 of any new major stationary source in an area designated as attainment or unclassified
9 under the CAA. All of Vermont has been classified as attainment or unclassified for criteria
10 pollutants (40 CFR 81.346).

11
12 Section 169A of the CAA establishes a national goal of preventing future and remedying
13 existing impairment of visibility in mandatory Class I Federal areas when impairment results
14 from man-made air pollution. The EPA issued a new regional haze rule in 1999 (*Federal*
15 *Register*, Volume 64, page 35714 (64 FR 35714); July 1, 1999 (EPA 1999)). The rule
16 specifies that for each mandatory Class I Federal area located within a State, the State must
17 establish goals that provide for reasonable progress toward achieving natural visibility
18 conditions. The reasonable progress goals must provide for an improvement in visibility for
19 the most-impaired days over the period of the implementation plan and ensure no
20 degradation in visibility for the least-impaired days over the same period
21 (40 CFR 51.308(d)(1)). If a coal-fired plant were located close to a mandatory Class I area,
22 additional air pollution control requirements could be imposed. Lye Brook Wilderness Area,
23 located about 35 mi northwest of VYNPS, is a Class I area where visibility is an important
24 value (40 CFR 81.431). Air quality in this area could be affected by a coal-fired plant at an
25 alternate site if the site chosen were located upwind of the wildlife refuge.

26
27 Anticipated impacts for particular pollutants that would result from a coal-fired plant at an
28 alternate site are as follows:

29
30 Sulfur oxides. A new coal-fired power plant would be subject to the requirements in Title IV
31 of the CAA. Title IV was enacted to reduce SO_2 and NO_x emissions, the two principal
32 precursors of acid rain, by restricting emissions of these pollutants from power plants.
33 Title IV caps aggregate annual power plant SO_2 emissions and imposes controls on SO_2
34 emissions through a system of marketable allowances. The EPA issues one allowance for
35 each ton of SO_2 that a unit is allowed to emit. New units do not receive allowances but are
36 required to have allowances to cover their SO_2 emissions. Owners of new units must
37 therefore acquire allowances from owners of other power plants by purchase or reduce SO_2
38 emissions at other power plants they own. Allowances can be banked for use in future
39 years. Thus, a new coal-fired power plant would not add to net regional SO_2 emissions,
40 although it might do so locally. Regardless, SO_2 emissions would be greater for the coal-
41 fired plant alternative than the proposed action.

Alternatives

1 Entergy estimates that by using wet limestone flue gas desulfurization to minimize SO_x
2 emissions (95 percent removal), the total annual stack emissions would be approximately
3 1238 tons of SO_x (Entergy 2006).

4
5 Nitrogen oxides. Section 407 of the CAA establishes technology-based emission limitations
6 for NO_x emissions. The market-based allowance system used for SO₂ emissions is not used
7 for NO_x emissions. A new coal-fired power plant would be subject to the new-source
8 performance standards for such plants at 40 CFR 60.44a(d)(1). This regulation, issued on
9 September 16, 1998 (63 FR 49453 (EPA 1998)), limits the discharge of any gases that
10 contain NO_x (expressed as nitrogen dioxide (NO₂)) in excess of 200 ng/J (1.6 lb/MWh) of
11 gross energy output, based on a 30-day rolling average.
12

13 Entergy estimates that by using NO_x burners with overfire air and selective catalytic
14 reduction (SCR) (95 percent reduction), the total annual NO_x emissions for a new coal-fired
15 power plant would be approximately 472 tons (Entergy 2006). This level of NO_x emissions
16 would be greater than under the proposed action.
17

18 Particulate matter. Entergy estimates that the total annual stack emissions would include
19 77 tons of filterable total suspended particulates and 18 tons of particulate matter (PM₁₀)
20 (40 CFR 50.6). Entergy assumes a design that minimizes air emissions through a
21 combination of boiler technology and post-combustion pollutant removal would be used for
22 control (Entergy 2005). Particulate emissions would be greater under the coal-fired plant
23 alternative than under the proposed action.
24

25 The construction of a coal-fired plant would generate fugitive dust. In addition, exhaust
26 emissions would come from vehicles and motorized equipment used during the construction
27 process.
28

29 Carbon monoxide. Entergy estimates that the total CO emissions would be approximately
30 472 tons/yr (Entergy 2006). This level of emissions is greater than that under the proposed
31 action.
32

33 Hazardous air pollutants, including mercury. In December 2000, the EPA issued regulatory
34 findings on emissions of hazardous air pollutants from electric utility steam-generating units
35 (EPA 2000a). The EPA determined that coal- and oil-fired electric utility steam-generating
36 units are significant emitters of hazardous air pollutants. The EPA found that coal-fired
37 power plants emit arsenic, beryllium, cadmium, chromium, dioxins, hydrogen chloride,
38 hydrogen fluoride, lead, manganese, and mercury (EPA 2000a). The EPA concluded that
39 mercury is the hazardous air pollutant of greatest concern. The EPA found that (1) there is
40 a link between the burning of coal and mercury emissions; (2) electric utility steam-
41 generating units are the largest domestic source of mercury emissions; and (3) certain
42 segments of the U.S. population (e.g., the developing fetus and subsistence fish-eating
43 populations) are believed to be at potential risk of adverse health effects due to mercury

1 exposures resulting from consumption of contaminated fish (EPA 2000a). Accordingly, on
2 March 15, 2005, the EPA issued the Clean Air Mercury Rule to permanently cap and reduce
3 mercury emissions from coal-fired power plants (EPA 2005).

4 Uranium and thorium. Coal contains uranium and thorium. Uranium concentrations are
5 generally in the range of 1 to 10 ppm. Thorium concentrations are generally about 2.5 times
6 greater than uranium concentrations (Gabbard 1993). One estimate is that in 1982, a
7 typical coal-fired plant released about 5.2 tons of uranium and 12.8 tons of thorium
8 (Gabbard 1993). The population dose equivalent from the uranium and thorium releases
9 and daughter products produced by the decay of these isotopes has been calculated to be
10 significantly higher than that from nuclear power plants (Gabbard 1993).

11 Carbon dioxide. A coal-fired plant would also have unregulated carbon dioxide (CO₂)
12 emissions that could contribute to global warming. The level of emissions from a coal-fired
13 plant would be greater than that under the proposed action.

14 Summary. The GEIS analysis did not quantify emissions from coal-fired power plants, but
15 implied that air impacts could be substantial. The GEIS also mentioned global warming
16 from unregulated CO₂ emissions and acid rain from SO_x and NO_x emissions as potential
17 impacts (NRC 1996). Adverse human health effects, such as cancer and emphysema, have
18 been associated with the products of coal combustion.

19 Siting a coal-fired power plant at an alternate site within the same air jurisdiction could result
20 in installing more or less stringent pollution control equipment to meet local applicable
21 requirements. Therefore, the NRC staff concludes that the impact on air quality would be
22 MODERATE.

23 • **Waste**

24 Waste would be generated during construction activities. During operations, coal
25 combustion generates waste in the form of ash, and equipment for controlling air pollution
26 generates additional ash and scrubber sludge. One 620-MW(e) coal-fired plant would
27 generate approximately 222,227 tons of this waste annually for 40 years (Entergy 2006).
28 The ash and scrubber sludge would be disposed of onsite, accounting for approximately
29 123.3 ac of land area over the 40-year plant life. Waste impacts on groundwater and
30 surface water could extend beyond the operating life of the plant if leachate and runoff from
31 the waste storage area occurs. Disposal of the waste could noticeably affect land use and
32 groundwater quality; however, with appropriate management and monitoring, the impact is
33 expected to be small to moderate. After closure of the waste site and revegetation, the land
34 could be available for other uses.

35 In May 2000, the EPA issued a "Notice of Regulatory Determination on Wastes from the
36 Combustion of Fossil Fuels" (EPA 2000b). The EPA concluded that some form of national
37

Alternatives

regulation is warranted to address coal combustion waste products because (1) the composition of these wastes could be dangerous to human health and the environment under certain conditions; (2) the EPA has identified 11 documented cases of proven damages to human health and the environment by improper management of these wastes in landfills and surface impoundments; (3) present disposal practices are such that, in 1995, these wastes were being managed in 40 to 70 percent of landfills and surface impoundments without reasonable controls in place, particularly in the area of groundwater monitoring; and (4) the EPA identified gaps in State oversight of coal combustion wastes. Accordingly, the EPA announced its intention to issue regulations for disposal of coal combustion waste under Subtitle D of the Resource Conservation and Recovery Act.

For all of the preceding reasons, the impact from waste generated from burning coal at an alternate site is considered MODERATE.

• Human Health

Worker risks associated with coal-fired plants result from fuel and limestone mining, from fuel and lime transportation, and from disposal of coal combustion waste. In addition, there are public risks from inhalation of stack emissions. Emission impacts can be widespread and health risks difficult to quantify. The coal-fired plant alternative also introduces the risk of coal-pile fires and attendant inhalation risks.

In the GEIS, the NRC staff stated that there could be human health impacts (cancer and emphysema) from inhalation of toxins and particulates, but it did not identify the significance of these impacts (NRC 1996). In addition, the discharges of uranium and thorium from coal-fired plants can potentially produce radiological doses in excess of those arising from nuclear power plant operations (Gabbard 1993).

Regulatory agencies, including the EPA and State agencies, establish air emission standards and requirements based on human health impacts. These agencies also impose site-specific emission limits as needed to protect human health. As discussed previously, the EPA has recently concluded that certain segments of the U.S. population (e.g., the developing fetus and subsistence fish-eating populations) are believed to be at potential risk of adverse health effects due to mercury exposures from sources such as coal-fired power plants. However, in the absence of more quantitative data, the NRC staff expects that the human health impact from radiological doses and inhalation of toxins and particulates generated by burning coal would be SMALL at an alternate site.

• Socioeconomics

Construction of a coal-fired plant and associated facilities would take approximately 3 years. The NRC staff assumed that construction would take place while VYNPS continues

1 operation and would be completed by the time VYNPS permanently ceases operations.
2 Estimates presented in the GEIS indicate that the workforce would be expected to vary
3 between 744 and 1550 workers during the 3-year construction period for a 620-MW(e) coal-
4 fired plant (NRC 1996). After construction, the local communities would be impacted by the
5 loss of the construction jobs, although this loss would be possibly offset by other growth
6 currently being projected for the area. Impacts on socioeconomics of operation of a coal-
7 fired plant would be SMALL.

8 Construction of a replacement coal-fired power plant at an alternate site would impact the
9 communities around VYNPS as they would experience the impact of the loss of jobs at
10 VYNPS. The communities around the new site would have to absorb the impacts of a
11 temporary workforce (approximately 1550 workers at the peak of construction) and a
12 permanent workforce of approximately 124 workers. In the GEIS, the NRC staff stated that
13 socioeconomic impacts at a rural site would be larger than at an urban site, because more
14 of the peak construction workforce would need to move to the area to work. Alternate sites
15 would need to be analyzed on a case-by-case basis, and socioeconomic impacts could
16 range from SMALL to LARGE.

17

- 18 • **Transportation**

19 Transportation-related impacts associated with a coal-fired plant at an alternate site would
20 be dependent on the site location. The impacts on transportation associated with
21
22 1550 commuting construction workers would likely be MODERATE. Transportation impacts
23 related to the commuting of an estimated 124 workers during operations would likely be
24 SMALL.

25 At an alternate site, coal and lime would probably be delivered by rail. At an alternate site,
26 impacts associated with rail transportation would depend on the site location and distance to
27 the existing rail line. Impacts associated with rail transportation at an alternate site could
28 range from SMALL to LARGE.

29

- 30 • **Aesthetics**

31 The coal-fired plant could be as much as 200 ft tall with cooling towers, stack, and coal piles
32 visible in daylight hours. The exhaust stack could be as much as 650 ft high. The plant and
33 associated stack would also be visible at night because of outside lighting. Visual impacts
34 of a new coal-fired plant could be mitigated by landscaping and color selection for buildings
35 that is consistent with the environment. Visual impact at night could be mitigated by
36 reduced use of lighting, provided that the lighting meets Federal Aviation Administration
37 (FAA) requirements (FAA 2000), and appropriate use of shielding. There could be a
38 significant impact if construction of a new transmission line and/or rail spur is needed. A

Alternatives

1 coal-fired plant at an alternate site would likely have a MODERATE to LARGE aesthetic
2 impact, depending on the site location chosen.

3
4 A coal-fired plant would introduce mechanical sources of noise that would be audible offsite.
5 Sources contributing to total noise produced by plant operation are classified as continuous
6 or intermittent. Continuous sources include the mechanical equipment associated with
7 normal plant operations, such as cooling towers. Intermittent sources include the equipment
8 related to coal handling, solid waste disposal, transportation related to coal and lime
9 delivery, use of outside loudspeakers, and the commuting of plant employees. These
10 impacts are considered to be MODERATE.

11
12 Noise impacts associated with rail delivery of coal and lime to a plant at an alternate site
13 would be most significant for residents living in the vicinity of the facility and along the rail
14 route. Although noise from passing trains significantly raises noise levels near the rail
15 corridor, the short duration of the noise reduces the impact. Nevertheless, given the
16 frequency of train transport and the many residents likely to be within hearing distance of the
17 rail route, the impact of noise on residents in the vicinity of the facility and the rail line are
18 considered MODERATE.

19
20 The aesthetic impact associated with the construction and operation of a new transmission
21 line and rail spur at an alternate site could be LARGE, depending on the location of the site
22 chosen. Overall, the NRC staff concludes that the aesthetic impact associated with locating
23 a coal-fired plant at an alternate site could be MODERATE to LARGE.

24
25 • **Historic and Archaeological Resources**

26
27 Before construction or any ground disturbance at an alternate site, studies would likely be
28 needed to identify, evaluate, and address mitigation of the potential impacts of new plant
29 construction on historic and archaeological resources. The studies would likely be needed
30 for all areas of potential disturbance at the proposed plant site and along associated
31 corridors where new construction would occur (e.g., roads, transmission corridors, rail lines,
32 or other rights-of-way). Other lands, if any, that are acquired to support the plant would also
33 likely need an inventory of cultural resources to identify and evaluate existing historic and
34 archaeological resources and possible mitigation of adverse effects from subsequent
35 ground-disturbing actions related to physical expansion of the plant site.

36
37 Historic and archaeological resources must be evaluated on a site-specific basis. The
38 impacts can generally be effectively managed under current laws and regulations, and as
39 such, the categorization of impacts at an alternate site could range from SMALL to
40 MODERATE, depending on what resources are present and whether mitigation is
41 necessary.

1 • **Environmental Justice**

2
3 Environmental justice impacts would depend on the site chosen and the nearby population
4 distribution. Construction activities would offer new employment possibilities. This could
5 affect housing availability and prices during construction, which could disproportionately
6 affect minority and low-income populations. Closure of VYNPS would result in a decrease
7 in employment of approximately 678 operating employees, possibly offset by general growth
8 in the area. Following construction, it is possible that the ability of local government to
9 maintain social services could be reduced at the same time as diminished economic
10 conditions reduce employment prospects for minority or low-income populations. Overall,
11 the impact is expected to be SMALL. Projected economic growth in the area and the ability
12 of minority and low-income populations to commute to other jobs outside the area could
13 mitigate any adverse effects.

14
15 The environmental justice impact at an alternate site would depend on the site chosen and
16 the nearby population distribution, and could range from SMALL to MODERATE.

17
18 **8.2.1.2 Coal-Fired Plant with a Once-Through Cooling System**

19
20 This section discusses the environmental impacts of constructing a coal-fired generation system
21 at an alternate site using once-through cooling. The impacts (SMALL, MODERATE, or LARGE)
22 of this option are the same as the impacts for a coal-fired plant using the closed-cycle system.
23 However, there are minor environmental differences between the closed-cycle and once-
24 through cooling systems. Table 8.3 summarizes these differences. The design and operation
25 of the intake would need to comply with performance standards of the EPA's 316(b) regulations
26 to minimize adverse impacts associated with water withdrawal, and heated discharges would
27 need to comply with 316(a) regulations.

28
29 **8.2.2 Natural-Gas-Fired Plant Generation**

30
31 The environmental impacts of the natural-gas-fired plant alternative are examined in this section
32 for both the VYNPS site and an alternate site. The NRC staff assumed that the plant would use
33 a closed-cycle cooling system (Section 8.2.2.1). In Section 8.2.2.2, the NRC staff also
34 evaluated the impacts of once-through cooling.

35
36 The existing switchyard, offices, and transmission line would be used for the gas-fired
37 alternative at the VYNPS site. For purposes of analysis, Entergy estimates that approximately
38 40 mi of buried gas supply pipeline would need to be constructed to connect to the existing
39 pipeline near Renfrew, Massachusetts (Tennessee Pipeline) (Entergy 2006).

40
41 If a new natural-gas-fired plant were built at an alternate site in Vermont to replace VYNPS,
42 construction of a new natural gas supply pipeline and a new transmission line could be needed.

Alternatives

Table 8-3. Summary of Environmental Impacts of Coal-Fired Plant Generation at an Alternate Site with Once-Through Cooling System

Impact Category	Change in Impacts from Closed-Cycle Cooling System
Land use	Impacts may be less (e.g., through elimination of cooling towers) or greater (e.g., if a reservoir is required).
Ecology	Impact would depend on ecology at the site. Possible impacts associated with entrainment of fish and shellfish in early life stages, impingement of fish and shellfish, and heat shock. No impact on terrestrial ecology from cooling tower drift.
Water use and quality-surface water	Increased water withdrawal leading to possible water-use conflicts; thermal load higher on receiving body of water than with closed-cycle cooling; no discharge of cooling tower blowdown.
Water use and quality-groundwater	No change
Air quality	No change
Waste	No change
Human health	No change
Socioeconomics	No change
Transportation	No change
Aesthetics	Less aesthetic impact because cooling towers would not be used.
Historic and archaeological resources	No change
Environmental justice	No change

In the GEIS, the NRC staff estimated disturbance of up to 2500 ac for construction of a 60-mi transmission line to an alternate site (NRC 1996).

The NRC staff assumed that a replacement natural-gas-fired plant would use combined-cycle technology (Entergy 2006). In a combined-cycle unit, hot combustion gases in a combustion turbine rotate the turbine to generate electricity. Waste combustion heat from the combustion turbine is routed through a heat-recovery boiler to make steam to generate additional electricity.

Entergy assumed a 608 MW(e) combined-cycle plant, as the gas-fired plant alternative at VYNPS (Entergy 2006). This capacity is approximately equivalent to the VYNPS total net capacity of 650 MW(e). Entergy estimates that the plant would consume approximately 26.9 billion ft³ of gas annually (Entergy 2006).

Unless otherwise indicated, the assumptions and numerical values used are from the Entergy ER (Entergy 2006). The NRC staff reviewed this information and compared it with environmental impact information in the GEIS. Although the OL renewal period is only 20 years, the impact of operating a natural-gas-fired plant for 40 years is considered (as a reasonable projection of the operating life of a natural-gas-fired plant).

8.2.2.1 Natural-Gas-Fired Plant with a Closed-Cycle Cooling System

The overall impacts of a natural-gas-fired plant with a closed-cycle cooling system are discussed in the following sections and summarized in Table 8-4. The extent of impacts at an alternate site would depend on the characteristics of the selected location of the plant site.

- **Land Use**

For siting a natural-gas-fired plant at VYNPS, existing facilities and infrastructure would be used to the extent practicable, limiting the amount of new construction that would be required. Specifically, the NRC staff assumed that a natural-gas-fired plant would use the existing switchyard, offices, and transmission line. Much of the land that would be used has been previously disturbed. At VYNPS, the NRC staff assumed that approximately 67 ac would be needed for the plant and associated infrastructure. (However, additional land would also be needed for construction of cooling towers for a closed-cycle cooling system.) There would be an additional impact of up to approximately 364 ac for construction of a 40-mile gas pipeline. Approximately 90 ac of already developed land at the VYNPS site is available (Entergy 2006).

For construction at an alternate site, the NRC staff assumed in the GEIS that 110 ac would be needed for a 1000-MW(e) plant and associated infrastructure (NRC 1996). This estimate would be scaled down for the 608-MW(e) capacity of the gas-fired plant alternative considered here (i.e., 67 ac). The additional amount of land impacted by the construction of a new transmission line and a gas pipeline is dependent on the site location chosen. The NRC staff assumed in the GEIS that approximately 2500 ac would be impacted for construction of a 60-mi transmission line (NRC 1996).

Regardless of where a gas-fired plant is built, additional land (approximately 3600 ac) would be required for natural gas wells and collection stations (NRC 1996). Partially offsetting these offsite land requirements would be the elimination of the need for uranium mining to supply fuel for VYNPS. In the GEIS (NRC 1996), the NRC staff estimated that approximately 1000 ac would be affected by the mining and processing of uranium during the operating life of a 1000-MW(e) nuclear power plant.

Overall, the NRC staff concludes that land-use impact for a gas-fired plant at the VYNPS site would be SMALL to MODERATE given the availability of previously developed and

Alternatives

Table 8-4. Summary of Environmental Impacts of a Natural-Gas-Fired Plant Using Closed-Cycle Cooling at the VYNPS Site and at an Alternate Site

		VYNPS Site		Alternate Site	
	Impact Category	Impact	Comments	Impact	Comments
7	Land use	SMALL to MODERATE	Impact would depend on the degree to which previously disturbed lands were utilized. Uses approximately 67 ac for plant site. Additional impact of up to approximately 364 ac for construction of 40-mi of underground gas pipeline. Additional land needed for cooling towers.	MODERATE to LARGE	Impact would depend on the characteristics of the alternate site. Uses approximately 110 ac for power block, cooling towers, offices, roads, and parking areas. Additional land would be needed for a new transmission line (amount dependent on site chosen) and for construction and/or upgrade of a gas pipeline.
8	Ecology	SMALL to MODERATE	Impact would depend on the characteristics of the land to be developed. Using developed areas at the current VYNPS site would reduce impacts on ecology. Impacts could occur with construction of a gas pipeline. Impact on terrestrial ecology from cooling-tower drift. Impact on aquatic ecology would be reduced from current levels because surface-water intake and thermal discharge would be reduced.	MODERATE to LARGE	Impact would depend on the characteristics of the land to be developed, surface-water body used for intake and discharge, and transmission and pipeline routes. Impact on terrestrial ecology from cooling-tower drift. Some impingement and entrainment of aquatic organisms.
9 10 11	Water use and quality – surface water	SMALL	Impact on surface water would be reduced from current level. Cooling-tower blowdown containing increased dissolved solids and intermittent low concentrations of biocides, as well as wastewater, would be released. Temporary erosion and sedimentation could occur in any streams crossed during pipeline construction.	SMALL to MODERATE	Impact would depend on volume of water withdrawn and discharged and characteristics of surface-water body. Cooling-tower blowdown containing increased dissolved solids and intermittent low concentrations of biocides, as well as wastewater, would be released. Temporary erosion and sedimentation could occur in streams crossed during pipeline construction.

Table 8-4. (contd)

Impact Category	VYNPS Site		Alternate Site	
	Impact	Comments	Impact	Comments
Water use and quality – groundwater	SMALL	Impact would be similar to current VYNPS operations if groundwater continues to be used for potable water use.	SMALL to MODERATE	Impact would depend on the location of the site, the volume of water withdrawn and discharged, and characteristics of the aquifer.
Air quality	MODERATE	Impact from fugitive dust and emissions from vehicles and equipment during construction would be SMALL. Impact of operations on air quality during operations would be MODERATE with the following emissions expected: Sulfur oxides <ul style="list-style-type: none">• 47.7 tons/yr Nitrogen oxides <ul style="list-style-type: none">• 153.1 tons/yr Carbon monoxide <ul style="list-style-type: none">• 32.2 tons/yr PM ₁₀ particulates <ul style="list-style-type: none">• 26.7 tons/yr Some hazardous air pollutants.	MODERATE	Same emissions as a natural-gas-fired plant at the VYNPS site, although pollution-control standards may vary depending on location. Impacts during construction would be SMALL. Impacts during operation would be MODERATE.
Waste	SMALL	Waste would be generated and removed during construction. Minimal waste from fuel consumption during operation.	SMALL	Same impact as a natural-gas-fired plant at the VYNPS site. Waste disposal constraints may vary.
Human health	SMALL	Human health risks associated with gas-fired plants may result from NO _x emissions, which are regulated. Impacts are expected to be SMALL.	SMALL	Same impact as a natural-gas-fired plant at the VYNPS site.

Alternatives

Table 8-4. (contd)

	Impact Category	VYNPS Site		Alternate Site	
		Impact	Comments	Impact	Comments
1	Socioeconomics	MODERATE	During construction, impact would be MODERATE. Less than 1550 additional workers during the peak of the 3-year construction period, followed by a reduction of the current VYNPS workforce from 678 to 124. Windham County would experience a reduced demand for goods and services as well as a loss in its tax base and employment, but this would be potentially offset by projected economic growth in the area. Impact during operation would be MODERATE.	MODERATE	Construction impact would depend on location, but could be MODERATE if the location is in a rural area. Up to 1550 additional workers during the peak of the 3-year construction period. Windham County would experience a loss in its tax base and employment if the plant is built outside of the county, but this would be potentially offset by projected economic growth in the area. Impact during operation would be MODERATE.
2 3	Transportation	MODERATE	Transportation impact associated with construction workers would be MODERATE, as 678 VYNPS workers and less than 1550 construction workers would be commuting to the site. Impact during operation would be SMALL as the number of commuters would be reduced to 124.	MODERATE	Transportation impact associated with 1550 construction workers would be MODERATE. Impact during operation would be SMALL as the number of commuters would be reduced to 124.
4	Aesthetics	MODERATE	Moderate aesthetic impact due to visibility of plant units, exhaust stacks, cooling towers and plumes, and gas compressors. Intermittent noise from construction and continuous noise from cooling towers and mechanical equipment would result in MODERATE impact.	Moderate to LARGE	Impact would depend on the characteristics of the site, but would be similar to those for a natural-gas-fired plant at the VYNPS site with additional impact from the new transmission line and gas pipeline. The impact could range from MODERATE to LARGE.

Table 8-4. (contd)

Impact Category	VYNPS Site		Alternate Site		
	Impact	Comments	Impact	Comments	
1 2 3	Historic and archeological resources	SMALL to MODERATE	Impact would depend on the degree to which previously disturbed lands were utilized. A cultural resource inventory would be needed to identify, evaluate, and mitigate the potential impact of new plant construction.	SMALL to MODERATE	Impact would depend on the characteristics of the alternate site. A cultural resource inventory would be needed to identify, evaluate, and mitigate potential impacts of new plant construction.
4 5	Environmental justice	SMALL	Impacts on minority and low-income communities should be similar to those experienced by the population as a whole. Some impacts on housing may occur during construction; the loss of 554 operating jobs at VYNPS could reduce employment prospects for minority and low-income populations. Impact could be offset by projected economic growth and the ability of affected workers to commute to other jobs.	SMALL to MODERATE	Impact would depend on population distribution and makeup at site.

6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
disturbed land that could be used for the plant site, the use of existing transmission systems, and the proximity of an existing gas pipeline. Impacts on land use at an alternate site could be greater, depending on the site chosen and the land requirements for a new transmission line and new gas pipeline, and are characterized as MODERATE to LARGE.

• Ecology

At the VYNPS, there would be ecological impacts related to possible habitat loss and to cooling tower drift associated with siting of the gas-fired plant. There would also be ecological impacts associated with bringing a new underground gas pipeline to the VYNPS. Impacts due to habitat loss could be reduced through the use of previously impacted land. Ecological impacts at an alternate site would depend on the nature of the land converted for the plant and the possible need for a new gas pipeline and/or transmission line. Construction of the transmission line and construction and/or upgrading of the gas pipeline to serve the plant would be expected to have temporary ecological impacts. Ecological impacts on the plant site and utility easements could include impacts on threatened or endangered species, wildlife habitat loss and reduced productivity, habitat fragmentation,

Alternatives

1 and a local reduction in biological diversity. The cooling makeup water intake and discharge
2 could have aquatic resource impacts. Overall, the ecological impacts are considered
3 MODERATE to LARGE at either location.

• Water Use and Quality

7 Surface Water. Each of the natural-gas-fired units would include a heat-recovery boiler,
8 using a portion of the waste heat from the combustion turbines to generate additional
9 electricity. The net result would be an overall reduction in the amount of waste heat rejected
10 from the plant, with an associated reduction in the amount of cooling water required by the
11 plant. Thus, the cooling water requirements for the natural-gas-fired combined-cycle units
12 would be much less than those for conventional steam-electric generators, including the
13 existing nuclear unit. Plant discharge would consist mostly of cooling-tower blowdown, with
14 the discharge having a higher temperature and increased concentration of dissolved solids,
15 relative to the receiving body of water, and intermittent low concentrations of biocides (e.g.,
16 chlorine). In addition to the cooling-tower blowdown, treated process waste streams and
17 sanitary wastewater might also be discharged. All discharges would be regulated by the
18 Vermont Department of Environmental Conservation (VDEC). There would be consumptive
19 use of water due to evaporation from the cooling towers. Overall, the surface-water impacts
20 of operation under the natural-gas-fired plant alternative at the VYNPS site are considered
21 SMALL.

22 A natural-gas-fired plant at an alternate site is assumed to use surface water for cooling
23 makeup water and discharge. Intake and discharge would involve relatively small quantities
24 of water compared with the coal-fired plant alternative. The impact on surface water would
25 depend on the volume of water needed for makeup water, the discharge volume, and the
26 characteristics of the receiving body of water. Discharges would be the same as those
27 described above for a gas-fired plant at the VYNPS site. Intake from and discharge to any
28 surface body of water would be regulated by the VDEC. The impact would be SMALL to
29 MODERATE.

30 Water-quality impacts from sedimentation during construction were characterized in the
31 GEIS as SMALL (NRC 1996). The NRC staff also noted in the GEIS that operational water-
32 quality impacts would be similar to, or less than, those from other generating technologies.

33 Groundwater. Any groundwater withdrawal would require a permit from the local permitting
34 authority. VYNPS currently uses groundwater for potable water, and this practice would
35 likely continue under the gas-fired plant alternative. Impacts on groundwater use and quality
36 would be considered SMALL. Impacts on groundwater at an alternate site would depend on
37 the volume of water needed and characteristics of the groundwater source. The NRC staff
38 concludes that impacts at an alternate site would be SMALL to MODERATE, depending on
39 site-specific conditions.

1 • **Air Quality**

2
3 Natural gas is a relatively clean-burning fuel. The gas-fired plant alternative would release
4 similar types of emissions, but in lesser quantities than the coal-fired plant alternative.

5
6 A new gas-fired plant located in Vermont would likely need a PSD permit and an operating
7 permit under the CAA. A new combined-cycle natural gas power plant would also be
8 subject to the new-source performance standards for such units at 40 CFR Part 60,
9 Subparts D(a) and GG. These regulations establish emission limits for particulates, opacity,
10 SO₂, and NO_x.

11
12 The EPA has various regulatory requirements for visibility protection in 40 CFR Part 51,
13 Subpart P, including a specific requirement for review of any new major stationary source in
14 an area designated attainment or unclassified under the CAA. All of Vermont has been
15 classified as attainment or is unclassified for criteria pollutants (40 CFR 81.346).

16
17 Section 169A of the CAA establishes a national goal of preventing future and remedying
18 existing impairment of visibility in mandatory Class I Federal areas when impairment results
19 from man-made air pollution. The EPA issued a new regional haze rule in 1999
20 (64 FR 35714; July 1, 1999 (EPA 1999)). The rule specifies that for each mandatory Class I
21 Federal area located within a state, the state must establish goals that provide for
22 reasonable progress toward achieving natural visibility conditions. The reasonable progress
23 goals must provide for an improvement in visibility for the most impaired days over the
24 period of the implementation plan and ensure no degradation in visibility for the
25 least-impaired days over the same period (40 CFR 51.308(d)(1)). If a natural-gas-fired plant
26 were located close to a mandatory Class I area, additional air pollution control requirements
27 could be imposed. Lye Brook Wilderness Area, located about 35 mi northwest of VYNPS, is
28 a Class I area where visibility is an important value (40 CFR 81.431). Air quality in this area
29 could be affected by a gas-fired plant at the VYNPS site or at an alternate site if the site
30 chosen were located upwind of the wildlife refuge.

31
32 Entergy projects the following emissions for the natural-gas-fired plant alternative
33 (Entergy 2006):

- 34
35 • Sulfur oxides – 47.7 tons/yr
36
37 • Nitrogen oxides – 153.1 tons/yr
38
39 • Carbon monoxide – 32.2 tons/yr
40
41 • PM₁₀ particulates – 26.7 tons/yr

Alternatives

1 A natural-gas-fired plant would also have unregulated CO₂ emissions that could contribute
2 to global warming.

3
4 In December 2000, the EPA issued regulatory findings on emissions of hazardous air
5 pollutants from electric utility steam-generating units (EPA 2000a). The EPA found that
6 natural-gas-fired power plants emit arsenic, formaldehyde, and nickel. Unlike coal- and oil-
7 fired plants, the EPA did not determine that emissions of hazardous air pollutants from
8 natural-gas-fired power plants should be regulated under Section 112 of the CAA
9 (EPA 2000a).

10
11 Construction activities would result in temporary fugitive dust. Exhaust emissions would
12 also come from vehicles and motorized equipment used during the construction process.

13
14 Air emissions would likely be the same at VYNPS or at an alternate site. The overall air
15 quality impact for a new natural-gas-fired plant sited at VYNPS or at an alternate site is
16 considered MODERATE.

17 • **Waste**

18
19 There would be spent selective catalytic reduction (SCR) catalyst from NO_x emissions
20 control and small amounts of solid waste products (i.e., ash) from burning natural gas fuel.
21 In the GEIS, the NRC staff concluded that waste generation from gas-fired technology would
22 be minimal (NRC 1996). Natural gas combustion results in very few by-products because of
23 the clean nature of the fuel. Waste-generation impacts would be so minor that they would
24 not noticeably alter any important resource attribute. Construction-related debris would be
25 generated during construction activities.

26
27 Overall, the waste impacts associated with the natural-gas-fired plant alternative would be
28 SMALL for a plant sited at VYNPS or at an alternate site.

29 • **Human Health**

30
31 In Table 8-2 of the GEIS, the NRC staff identified cancer and emphysema as potential
32 health risks from gas-fired plants (NRC 1996). The risks may be attributable to NO_x
33 emissions that contribute to ozone formation, which in turn contributes to health risks.
34 Nitrogen oxide emissions from any gas-fired plant would be regulated. For a plant sited in
35 Vermont, NO_x emissions would be regulated by the VDEC. Overall, the impact on human
36 health of the natural-gas-fired plant alternative sited at VYNPS or at an alternate site is
37 considered SMALL.

1 • **Socioeconomics**

2
3 Construction of a natural-gas-fired plant would take approximately 3 years. Peak
4 employment would be less than approximately 1550 workers (Entergy 2006). The NRC staff
5 assumed that construction would take place while VYNPS continues operation and would be
6 completed by the time it permanently ceases operations. During construction, the
7 communities surrounding the VYNPS site would experience demands on housing and public
8 services that could have MODERATE impacts. These impacts would be tempered by
9 construction workers commuting to the site from other parts of Windham County or from
10 other nearby counties. After construction, the communities would be impacted by the loss of
11 jobs. The current VYNPS workforce (approximately 678 workers) would decline through a
12 decommissioning period to a minimal maintenance size. The gas-fired plant would
13 introduce a replacement tax base at VYNPS or at an alternate site and approximately
14 100 new permanent jobs. This would represent a net loss of 578 jobs at the VYNPS site.
15

16 In the GEIS (NRC 1996), the NRC staff concluded that socioeconomic impacts from
17 constructing a natural-gas-fired plant would not be very noticeable and that the small
18 operational workforce would have the lowest socioeconomic impacts of any nonrenewable
19 technology. Compared with the coal-fired and nuclear plant alternatives, the smaller size of
20 the construction workforce, the shorter construction time frame, and the smaller size of the
21 operations workforce would mitigate socioeconomic impacts. The loss of 578 permanent
22 jobs (up to 678 jobs if an alternate site is not located in Windham County) may be partially
23 tempered by the projected economic growth of the area. For these reasons, socioeconomic
24 impacts associated with construction and operation of a natural-gas-fired power plant would
25 be MODERATE and SMALL, respectively, for siting at VYNPS or at an alternate site.
26

27 • **Transportation**

28
29 Transportation impacts associated with construction and operating personnel commuting to
30 a natural-gas-fired plant would depend on the population density and transportation
31 infrastructure in the vicinity of the site. The impacts can be classified as MODERATE for
32 construction and SMALL for operation at VYNPS or at an alternate site.
33

34 • **Aesthetics**

35
36 For a natural-gas-fired plant, the turbine buildings (approximately 100 ft tall) and exhaust
37 stacks (approximately 125 ft tall), and cooling towers and plumes would be visible during
38 daylight hours from offsite. The gas pipeline compressors also would be visible. Noise and
39 light from the plant would be detectable offsite. Intermittent noise from construction and
40 continuous noise from cooling towers and mechanical equipment would result in
41 MODERATE impact. Overall, the aesthetic impacts associated with construction and
42 operation of a natural-gas-fired plant at the VYNPS site are categorized as MODERATE.
43

Alternatives

At an alternate site, the buildings, cooling towers, cooling-tower plumes, and the associated transmission line and gas pipeline compressors would be visible offsite. There would also be a visual impact from a new transmission line. Aesthetic impacts would be mitigated if the plant were located in an industrial area adjacent to other power plants. Noise impacts would be similar to those described for the VYNPS site. Overall, the aesthetic impacts associated with an alternate site are categorized as MODERATE to LARGE and would depend on the characteristics of the area to be developed. Depending on the site chosen, the greatest contributor to aesthetic impact would be the new transmission line.

• Historic and Archaeological Resources

Before construction or any ground disturbance at VYNPS or at an alternate site, studies would likely be needed to identify, evaluate, and address mitigation of the potential impacts of new plant construction on historic and archaeological resources. The studies would likely be needed for all areas of potential disturbance at the proposed plant site and along associated corridors where new construction would occur (e.g., roads, transmission and pipeline corridors, or other rights-of-way). Other lands, if any, that are acquired to support the plant would also likely need an inventory of cultural resources to identify and evaluate existing historic and archaeological resources and possible mitigation of adverse effects from subsequent ground-disturbing actions related to physical expansion of the plant site.

Historic and archaeological resources must be evaluated on a site-specific basis. The impacts can generally be effectively managed under current laws and regulations, and as such, the categorization of impacts ranges from SMALL to MODERATE, depending on what resources are present and whether mitigation is necessary.

• Environmental Justice

No environmental pathways or locations have been identified that would result in disproportionately high and adverse environmental impacts on minority and low-income populations if a new natural-gas-fired plant were built at the VYNPS site. Some impacts on housing availability and prices during construction might occur, and this could disproportionately affect minority and low-income populations. Closure of VYNPS would result in a decrease in employment of approximately 678 operating employees, partially offset by the 100 workers required for operation of the new plant, and possibly by general growth in the area. Following construction, it is possible that the ability of local government to maintain social services could be reduced at the same time as diminished economic conditions reduce employment prospects for minority or low-income populations. Overall, environmental justice impacts are expected to be SMALL. Projected economic growth in the area and the ability of minority and low-income populations to commute to other jobs outside the area could mitigate any adverse effects.

Environmental justice impacts at an alternate site would depend upon the site chosen and the nearby population distribution; therefore, impacts could range from SMALL to MODERATE.

8.2.2.2 Natural-Gas-Fired Plant with a Once-Through Cooling System

This section discusses the environmental impacts of constructing a natural gas-fired generation system at an alternate site using once-through cooling. The impacts (SMALL, MODERATE, or LARGE) of this option are the same as the impacts for a natural-gas-fired plant using the closed-cycle system. However, there are minor environmental differences between the closed-cycle and once-through cooling systems. Table 8.5 summarizes the incremental differences. The design and operation of the intake would need to comply with performance standards of the EPA's 316(b) regulations to minimize adverse impacts associated with water withdrawal, and heated discharges would need to comply with 316(a) regulations.

Table 8-5. Summary of Environmental Impacts of Natural Gas-Fired Generation at an Alternate Site with Once-Through Cooling

Impact Category	Change in Impacts from Closed-Cycle Cooling System
Land use	Impacts may be less (e.g., through elimination of cooling towers) or greater (e.g., if a reservoir is required).
Ecology	Impact would depend on the ecology at the site. Potential impacts associated with entrainment of fish and shellfish in early life stages, impingement of fish and shellfish, and heat shock. No impact on terrestrial ecology from cooling tower drift.
Water use and quality – surface water	Increased water withdrawal leading to possible water-use conflicts, thermal load higher on receiving body of water than with closed-cycle cooling; no discharge of cooling tower blowdown.
Water use and quality – groundwater	No change
Air quality	No change
Waste	No change
Human health	No change
Socioeconomics	No change
Transportation	No change
Aesthetics	Less aesthetic impact because cooling towers would not be used.
Historic and archaeological resources	No change
Environmental justice	No change

Alternatives

1 **8.2.3 Nuclear Power Plant Generation**

2
3 Since 1997, the NRC has certified four new standard designs for nuclear power plants under
4 10 CFR Part 52, Subpart B. These designs are the 1300-MW(e) U.S. Advanced Boiling Water
5 Reactor (10 CFR Part 52, Appendix A), the 1300-MW(e) System 80+ Design (10 CFR Part 52,
6 Appendix B), the 600-MW(e) AP600 Design (10 CFR Part 52, Appendix C), and the 1117- to
7 1154-MW(e) AP1000 design (10 CFR Part 52, Appendix D). All these plants are light-water
8 reactors. Although no applications for a construction permit or a combined license based on
9 these certified designs have been submitted to the NRC, the submission of the design
10 certification applications indicates continuing interest in the possibility of licensing new nuclear
11 power plants. In addition, recent escalation in prices of natural gas and electricity have made
12 new nuclear power plant construction more attractive from a cost standpoint. In addition,
13 System Energy Resources, Inc., Exelon Generation Company, LLC, Dominion Nuclear North
14 Anna, LLC, and Southern Nuclear Operating Company have recently submitted applications for
15 early site permits for new advanced nuclear power plants under the procedures in 10 CFR Part
16 52, Subpart A (SERI 2003; Exelon 2003; Dominion 2003; SNOC 2006). Consequently,
17 construction of a new nuclear power plant at the an alternate site is considered in this section.
18 The NRC staff assumed that the new nuclear plant would have a 40-year lifetime. An
19 evaluation of the impacts of a new nuclear generating plant to replace VYNPS was not included
20 in the Entergy ER (Entergy 2006).

21
22 The NRC has summarized environmental data associated with the uranium fuel cycle in
23 Table S-3 of 10 CFR 51.51. The impacts shown in Table S-3 are representative of the impacts
24 that would be associated with a replacement nuclear power plant built to one of the certified
25 designs, sited at an alternate site. In the GEIS, the NRC estimated that for a 1000-MW(e)
26 reactor, 500 to 1000 ac would be required for construction (NRC 1996). The impacts shown in
27 Table S-3 were adjusted to reflect the replacement of 650 MW(e) generated by VYNPS. The
28 environmental impacts associated with transporting fuel and waste to and from a light-water-
29 cooled nuclear power reactor are summarized in Table S-4 of 10 CFR 51.52.

30
31 The summary of the NRC's findings on NEPA issues for license renewal of nuclear power plants
32 in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B, is also relevant, although not directly
33 applicable, for consideration of environmental impacts associated with the operation of a new
34 nuclear power plant. Additional environmental impact information for a new nuclear power plant
35 using closed-cycle cooling is presented in Section 8.2.3.1, and using once-through cooling is
36 presented in Section 8.2.3.2.

37
38 **8.2.3.1 New Nuclear Plant with a Closed-Cycle Cooling System**

39
40 The overall impacts of a new nuclear plant are discussed in the following sections and are
41 summarized in Table 8-6. The extent of impacts at an alternate site would depend on the
42 location of the site that is selected.

1 **Table 8-6.** Summary of Environmental Impacts of a New Nuclear Power Plant Using
 2 Closed-Cycle Cooling at an Alternate Site
 3

	Impact Category	Impact	Comments
5	Land use	MODERATE to LARGE	Impact would depend on the characteristics of the alternate site. Impact would depend on the degree to which previously disturbed lands were utilized. Requires approximately 325 to 650 ac for the plant. Additional offsite land use impacts from uranium mining plus additional land for a transmission line.
6	Ecology	MODERATE to LARGE	Impact would depend on the characteristics of the land to be developed, surface-water body used for intake and discharge, and transmission line route. Impact on terrestrial ecology from cooling-tower drift. Some impingement and entrainment of aquatic organisms.
7	Water use and quality – surface water	SMALL to MODERATE	Impact would depend on the volume of water withdrawn and discharged and the characteristics of the surface-water body. Cooling-tower blowdown containing increased dissolved solids and intermittent low concentrations of biocides, as well as wastewater, would be released.
9	Water use and quality – groundwater	SMALL to MODERATE	Impact would depend on the volume of water withdrawn and discharged and the characteristics of the aquifer.
11	Air quality	SMALL	Impact from fugitive dust and emissions from vehicles and equipment during construction would be SMALL. Emissions from diesel generators and possibly other sources during operation would be similar to current VYNPS operation, and their impact on air quality would be SMALL.
12	Waste	SMALL	Waste would be generated and removed during construction. Waste impacts for an operating nuclear power plant are presented in 10 CFR Part 51, Appendix B, Table B-1.
13	Human health	SMALL	Human health impacts for an operating nuclear power plant are presented in 10 CFR Part 51, Appendix B, Table B-1.
14	Socioeconomics	MODERATE to LARGE	Construction impact would depend on location, but could be LARGE at a rural location. Windham County would experience a loss in its tax base and employment if the chosen site is located outside of the county, but possibly offset by economic growth in the area.
15	Transportation	MODERATE to LARGE	Impact would depend on the location of the site. Transportation impacts of up to 2500 construction workers could be MODERATE to LARGE. Transportation impacts of 678 commuting personnel could be SMALL to MODERATE.

Alternatives

Table 8-6. (contd)

Impact Category	Impact	Comments
Aesthetics	MODERATE to LARGE	Impact would depend on the characteristics of the site. Aesthetic impact due to the addition of cooling towers and other structures would be MODERATE.
		Intermittent noise from construction and commuter traffic and continuous noise from cooling towers and mechanical equipment could result in impacts ranging from SMALL to MODERATE. Additional visual impacts would occur from the new transmission line that would be needed.
Historic and archeological resources	SMALL to MODERATE	Impact would depend on the characteristics of the alternative site. A cultural resource inventory would be needed to identify, evaluate, and mitigate potential impacts of new construction.
Environmental justice	SMALL to LARGE	Impacts would vary, depending on population distribution and makeup at the site.

In addition to the impacts discussed below, impacts would occur offsite as a result of uranium mining. Impacts of mining would include an increase in fugitive dust emissions, surface-water runoff, erosion, sedimentation, changes in water quality, disturbance of vegetation and wildlife, disturbance of historic and archaeological resources, changes in land use, and impacts on employment.

The magnitude of these offsite impacts would be largely proportional to the amount of land affected by mining. However, there would be no net change in land needed for uranium mining because land needed for the new nuclear plant would offset land needed to supply uranium for fuel at VYNPS.

- **Land Use**

Land-use impacts at an alternate site would alter approximately 325 to 650 ac of land (NRC 1996) except for the land needed for a transmission line to connect to the grid. The amount of land needed for the transmission line would depend upon the location of the alternate site. In addition, it may be necessary to construct a rail spur to an alternate site to bring in equipment during construction. Depending particularly on transmission line routing, siting a new nuclear plant at an alternate site would result in MODERATE to LARGE land-use impacts.

1 • **Ecology**

2
3 At an alternate site, there would be construction impacts and new incremental operational
4 impacts. Even assuming siting at a previously disturbed area, the impacts would affect
5 ecological resources. Impacts could include impacts on threatened and endangered
6 species, wildlife habitat loss, reduced productivity, habitat fragmentation, and a local
7 reduction in biological diversity. Use of cooling makeup water from a nearby surface-water
8 body could have adverse aquatic resource impacts. Impacts on terrestrial ecology could
9 result from cooling-tower drift. Construction and maintenance of a transmission line, if
10 needed, would have ecological impacts. Overall, the ecological impacts at an alternate site
11 would be MODERATE to LARGE and would depend on the ecological conditions at the site
12 and the amount of land to be developed.

13
14 • **Water Use and Quality**

15
16 Surface Water. At an alternate site, the impact on the surface water would depend on the
17 volume of water needed for makeup water, the discharge volume, and the characteristics of
18 the receiving body of water. Intake from and discharge to any surface body of water would
19 be regulated by the VDEC. The impacts would be SMALL to MODERATE, and their
20 magnitude would depend on the characteristics of the surface-water body used as the
21 source of cooling water.

22
23 Groundwater. The NRC staff assumed that a new nuclear power plant located at an
24 alternate site would use groundwater for reactor makeup water and potable water
25 (see Section 2.2.2). Use of groundwater for a nuclear power plant sited at an alternate site
26 would require a permit from the local permitting authority.

27
28 Overall, impacts from a plant similar to VYNPS at an alternate site are considered to be
29 SMALL to MODERATE, depending on the volume of groundwater used and characteristics
30 of the aquifer.

31
32 • **Air Quality**

33
34 Construction of a new nuclear plant sited at an alternate site would result in fugitive dust
35 emissions during the 5-year construction period. Exhaust emissions would also be
36 produced by vehicles and motorized equipment used during the construction process. Air
37 quality impacts from construction could be MODERATE. An operating nuclear plant would
38 have minor air emissions associated with diesel generators and other minor intermittent
39 sources and would be similar to the current impacts associated with operation of VYNPS
40 (i.e., SMALL).

Alternatives

1 • **Waste**

2
3 The waste impacts associated with operation of a nuclear power plant are presented in
4 Table B-1 of 10 CFR Part 51, Subpart A, Appendix B. Construction-related waste would be
5 generated during construction activities and removed to an appropriate disposal site.
6 Overall, waste impacts are considered SMALL.

7 • **Human Health**

8
9 Human health impacts for an operating nuclear power plant are presented in
10 10 CFR Part 51, Subpart A, Appendix B, Table B-1. Overall, human health impacts are
11 considered SMALL.

12
13 Siting the replacement nuclear power plant at an alternate site would not alter human health
14 impacts. Therefore, the impacts would be SMALL.

15 • **Socioeconomics**

16
17 If a new nuclear power plant were constructed at an alternate site, the communities around
18 the new site would have to absorb the impacts of a large, temporary workforce (up to
19 2500 workers at the peak of construction) and a permanent workforce of approximately
20 678 workers. In the GEIS (NRC 1996), the NRC staff indicated that socioeconomic impacts
21 at a rural site would be larger than at an urban site because more of the peak construction
22 workforce would need to move to the area to work. Alternate sites would need to be
23 analyzed on a case-by-case basis, and impacts could range from MODERATE to LARGE,
24 depending on the socioeconomic characteristics of the area around the site.

25 • **Transportation**

26
27 Transportation-related impacts associated with commuting construction workers at an
28 alternate site are site dependent, but could be MODERATE to LARGE. Transportation
29 impacts related to commuting of plant operating personnel would also be site-dependent,
30 but can be characterized as SMALL to MODERATE, and would depend on the
31 characteristics of the transportation system and population in the vicinity of the site.

32 • **Aesthetics**

33
34 At an alternate site, there would be an aesthetic impact from the buildings, cooling towers,
35 and the plume associated with the cooling towers. There could also be a significant
36 aesthetic impact associated with construction of a new transmission line. The length of the
37 transmission line would depend upon the location of the plant. Noise and light from the
38 plant would be detectable offsite. The impact of noise and light would be less if the plant

were located in an industrial area adjacent to other power plants. Overall, the aesthetic impacts associated with locating a new nuclear plant at an alternate site can be categorized as MODERATE to LARGE. Depending on the location chosen, the greatest contributor to this categorization could be the aesthetic impact of the new transmission line.

• Historic and Archaeological Resources

Before construction or any ground disturbance at an alternate site, studies would likely be needed to identify, evaluate, and address mitigation of the potential impacts of new plant construction on historic and archaeological resources. The studies would likely be needed for all areas of potential disturbance at the proposed plant site and along associated corridors where new construction would occur (e.g., roads, transmission and pipeline corridors, or other rights-of-way). Other lands, if any, that are acquired to support the plant would also likely need an inventory of cultural resources to identify and evaluate existing historic and archaeological resources and possible mitigation of adverse effects from subsequent ground-disturbing actions related to physical expansion of the plant site.

Historic and archaeological resources must be evaluated on a site-specific basis. The impacts can generally be effectively managed under current laws and regulations, and as such, the categorization of impacts ranges from SMALL to MODERATE at an alternate site, depending on what resources are present and whether mitigation is necessary.

• Environmental Justice

The environmental justice impact at an alternate site would depend upon the site chosen and the nearby population distribution. Some impacts on housing availability and prices during construction might occur, and this could disproportionately affect the minority and low-income populations. After completion of construction, it is possible that the ability of the local government to maintain social services could be reduced at the same time as diminished economic conditions reduce employment prospects for the minority and low-income populations. Overall, impacts are expected to be SMALL.

8.2.3.2 New Nuclear Plant with a Once-Through Cooling System

This section discusses the environmental impacts of constructing and operating a new nuclear power plant using once-through cooling. The impacts (SMALL, MODERATE, or LARGE) of this option are similar to the impacts for a nuclear power plant using a closed-cycle system. However, there are minor differences between the closed-cycle and once-through cooling systems. Table 8-7 summarizes these differences. The design and operation of the intake would need to comply with performance standards of the EPA's 316(b) regulations to minimize adverse impacts associated with water withdrawal, and heated discharges would need to comply with 316(a) regulations.

Alternatives

Table 8-7. Summary of Environmental Impacts of a New Nuclear Power Plant Using Once-Through Cooling

Impact Category	Change in Impacts from Closed-Cycle Cooling System
Land use	Impact may be less (e.g., through elimination of cooling towers) or greater (e.g., if a reservoir is required).
Ecology	Impact would depend on the ecological conditions in areas to be developed. Possible impacts associated with entrainment of fish and shellfish in early life stages, impingement of fish and shellfish, and heat shock. No impact on terrestrial ecology from cooling-tower drift.
Water use and quality – surface water	Greater water withdrawal rates leading to possible water-use conflicts, thermal load higher on receiving body of water than with closed-cycle cooling; no discharge of cooling-tower blowdown.
Water use and quality – groundwater	No change
Air quality	No change
Waste	No change
Human health	No change
Socioeconomics	No change
Transportation	No change
Aesthetics	Less aesthetic impact because cooling towers are not used.
Historic and archaeological resources	No change
Environmental justice	No change

8.2.4 Purchased Electrical Power

If available, purchased power from other sources could potentially obviate the need to renew the VYNPS OL. A description of the current energy trading system in Vermont is provided in the Vermont Electric Plan (State of Vermont 2005a). It is unlikely, however, that sufficient baseload, firm power supply would be available to replace VYNPS capacity.

Imported power from Canada or Mexico is unlikely to be available for replacement of VYNPS capacity. In Canada, 60 percent of the country's electrical generation capacity is derived from renewable energy sources, principally hydropower (EIA 2004b). Canada plans to expand hydroelectric capacity, including large-scale projects (EIA 2004b). Canada's nuclear generation is projected to increase from 10,000 MW in 2001 to 15,200 MW in 2020 before reaching a

forecasted decline to 12,400 MW in 2025 (EIA 2004b). The EIA projected that total gross U.S. imports of electricity from Canada and Mexico will gradually increase from 38.4 billion kWh in 2001 to 47.2 billion kWh in 2010 and then gradually decrease to 15.2 billion kWh in 2025 (EIA 2004a). Consequently, it is unlikely that electricity imported from Canada or Mexico would be able to replace VYNPS capacity.

If power to replace VYNPS capacity were to be purchased from sources within the United States or a foreign country, the power-generation technology would likely be one of those described in this SEIS and in the GEIS (probably coal, natural gas, or nuclear). The description of the environmental impacts of other technologies in Chapter 8 of the GEIS is representative of the purchased electrical power alternative to renewal of the VYNPS OL. Thus, the environmental impacts of imported power would still occur but would be located elsewhere within the region, nation, or another country.

8.2.5 Other Alternatives

Other power-generation technologies considered by the NRC are discussed in the following paragraphs.

8.2.5.1 Oil-Fired Plant Generation

The EIA projects that oil-fired plants will account for very little of the new generation capacity in the United States between 2005 and 2025 because of higher fuel costs and lower efficiencies (EIA 2004a). Oil-fired generation is more expensive than nuclear or coal-fired generation. In addition, future increases in oil prices are expected to make oil-fired generation increasingly more expensive than coal-fired generation. The high cost of oil has prompted a steady decline in its use for electricity generation. For these reasons, oil-fired generation is not considered an economically feasible alternative to VYNPS license renewal.

Construction and operation of an oil-fired plant would have environmental impacts. For example, in Section 8.3.11 of the GEIS, the NRC staff estimated that construction of a 1000-MW(e) oil-fired plant would require about 120 ac of land for the facility and additional land for an oil pipeline (NRC 1996). In addition, operation of oil-fired plants would have environmental impacts (including impacts on the aquatic environment and air) that would be similar to those of a coal-fired plant.

8.2.5.2 Wind Power

Wind power, by itself, is not suitable for large baseload capacity. As discussed in Section 8.3.1 of the GEIS, wind is not constant, and average annual capacity factors for wind plants are relatively low (on the order of 30 percent) (NRC 1996). Wind power, only in conjunction with energy storage mechanisms or other sources of electrical generation, might serve as a means

Alternatives

1 of providing baseload power. However, current energy storage technologies are too expensive
2 for wind power to serve as a large baseload generator by itself.

3
4 Southeastern Vermont, including Windham County, has poor wind power potential. However,
5 crests along the Green Mountains located roughly 25 miles west of VYNPS have excellent wind
6 potential. The annual wind power estimates for Vermont range from a rating of Class 1 and
7 some Class 2, increasing to Classes 5 and 6 along the mountain crests (DOE 2006a). Areas
8 designated Class 3 or greater are suitable for most wind energy applications (DOE 2004). Most
9 of Vermont is below the Class 3 rating. Land-use conflicts, such as urban development,
10 farmland, and environmentally sensitive areas, also minimize the amount of land suitable for
11 wind energy applications (PNNL 1986).

12
13 DOE's National Renewable Energy Laboratory (NREL) estimates that the footprint of a 1.5-MW
14 wind turbine is between 0.25 and 0.5 ac. In addition, a spacing interval of 5 to 10 turbine rotor
15 diameters between wind turbines is typically maintained to prevent interferences between
16 turbines (NREL 2006). Five turbine rotor diameters would be suitable for optimal wind
17 conditions, increasing to 10 depending on the amount of wind turbulence and other potential
18 topographic disturbances. Land disturbance during construction to install the turbine is
19 estimated to be between 1 to 3 ac per turbine related to grading the site for installation, laydown
20 areas for equipment and materials, and staging areas for construction equipment used to hoist
21 the turbines and their towers into place. The area surrounding the turbine is then reclaimed
22 after construction is completed. These estimates do not include land used for substations,
23 control buildings, access roads, and other related facilities. Assuming the most common
24 commercially available land-based turbine is used (currently 1.5 MW^(a)), 453 turbines in a linear
25 array are estimated to be needed in land areas with a wind class of Class 3 or greater to
26 produce 680 MW(e), using the NREL's Wind Farm Area Calculator (NREL 2006). Assuming a
27 rotor diameter of roughly 200 ft for a 1.5-MW turbine, the total acreage for a wind farm with 453
28 turbines in a linear array in optimal wind conditions could require more than 2,075 ac; 226.5 ac
29 would be dedicated to the turbine footprint (assuming approximately 0.5 ac per turbine base),
30 and the remaining land between turbines could be available for other uses, such as grazing or
31 agricultural land. These numbers do not take into account the low annual capacity factor of
32 approximately 30 percent that is associated with wind energy.

33
34 Consequently, the current VYNPS site is too small to support a baseload level of wind
35 generation capacity. Although impacts would depend on the site chosen, common issues of
36 concern include visual impacts, noise, potential interferences with aircraft operations, and bird
37 and bat collisions.

(a) 1.8-MW and 2.3-MW turbines have recently been made available with approximately 300-ft rotor
diameters. The size of the construction footprint is not explicitly known at this time.

1 **8.2.5.3 Solar Power**

2
3 Solar technologies use the sun's energy and light to provide heat and cooling, light, hot water,
4 and electricity for homes, businesses, and industry. In the GEIS, the NRC staff noted that by its
5 nature, solar power is intermittent. Therefore, solar power by itself is not suitable for baseload
6 capacity and is not a feasible alternative to license renewal of VYNPS. The average capacity
7 factor of photovoltaic cells is about 25 percent, and the capacity factor for solar thermal systems
8 is about 25 to 40 percent. Solar power, in conjunction with energy storage mechanisms, might
9 serve as a means of providing baseload power. However, current energy storage technologies
10 are too expensive to permit solar power to serve as a large baseload generator.

11
12 Therefore, solar power technologies (photovoltaic and thermal) cannot currently compete with
13 conventional fossil-fueled technologies in grid-connected applications because of high costs per
14 kilowatt of capacity (NRC 1996).

15
16 Natural resources (e.g., wildlife habitat, land use, and aesthetics) can incur substantial impacts
17 from construction of solar-generating facilities. As stated in the GEIS, land requirements are
18 high – 35,000 ac per 1000 MW(e) for photovoltaic and approximately 14,000 ac per
19 1000 MW(e) for solar thermal systems. Neither type of solar electric system would fit at the
20 VYNPS site, and both would have LARGE environmental impacts at an alternate site.

21
22 Vermont receives between approximately 3.5 to 4.0 kWh of solar radiation per square meter per
23 day, compared with 6 to 8 kWh of solar radiation per square meter per day in areas of the
24 southwestern United States, such as Arizona and California, which are most promising for solar
25 technologies (DOE 2006b). Because of the natural resource impacts (land and ecological), the
26 area's relatively low rate of solar radiation, and high cost, solar power is not deemed a feasible
27 baseload alternative to renewal of the VYNPS OL. Some solar power may be substituted for
28 electric power in rooftop and building applications. Implementation of non-rooftop solar
29 generation on a scale large enough to replace VYNPS would likely result in LARGE
30 environmental impacts.

31 **8.2.5.4 Hydropower**

32
33 There are few remaining sites in the Vermont market region that would be environmentally
34 suitable for a hydroelectric facility to replace the generating capacity of VYNPS (INEEL 1996).
35 In Section 8.3.4 of the GEIS, the NRC staff points out that hydropower's percentage of
36 U.S. generating capacity is expected to decline because hydroelectric facilities have become
37 difficult to site as a result of public concern about flooding, destruction of natural habitat, and
38 alteration of natural river courses.

39
40
41 The NRC staff estimated in the GEIS that land requirements for hydroelectric power are
42 approximately 1 million ac per 1000 MW(e). Replacement of VYNPS generating capacity would
43 require flooding less than this amount of land. Because of the small supply of suitable sites in

Alternatives

1 Vermont and the large land-use and related environmental and ecological resource impacts
2 associated with siting hydroelectric facilities large enough to replace VYNPS, the NRC staff
3 concludes that hydropower is not a feasible alternative to VYNPS OL renewal on its own. Any
4 attempts to site hydroelectric facilities large enough to replace VYNPS would result in LARGE
5 environmental impacts.

6

7 **8.2.5.5 Geothermal Energy**

8

9 Geothermal energy has an average capacity factor of 90 percent and can be used for baseload
10 power where available. Geothermal technology is limited by the geographical availability of the
11 resource and immature status of the technology (NRC 1996). As illustrated in Figure 8.4 in the
12 GEIS, geothermal electric-generating plants are most likely to be sited in the western
13 continental United States, Alaska, and Hawaii, where hydrothermal reservoirs are prevalent.
14 There is no feasible location in Vermont for geothermal capacity to serve as an alternative to
15 VYNPS (DOE 2006b). The NRC staff concludes that geothermal energy is not a feasible
16 alternative to renewal of the VYNPS OL.

17

18 **8.2.5.6 Wood Waste**

19

20 The use of wood waste to generate electricity is largely limited to those states with significant
21 wood resources, such as California, Maine, Georgia, Minnesota, Oregon, Washington, and
22 Michigan. Electric power is generated in these states by the pulp, paper, and paperboard
23 industries that consume wood and wood waste for energy; these industries benefit from the use
24 of waste materials that could otherwise represent a disposal problem.

25

26 DOE estimates that Vermont has some resources for wood fuels consisting of urban, mill, and
27 forest residues; approximately 689,204 dry tons/yr are available in Vermont (Walsh et al. 2000).
28 The National Renewable Energy Laboratory (NREL) has estimated that 1100 kWh of electricity
29 can be produced by 1 dry ton of wood residue. Therefore, approximately 0.76 TWh of electricity
30 can be generated from wood residue in Vermont (NREL 2004).

31

32 A wood-burning facility can provide baseload power and operate with an average annual
33 capacity factor of around 70 to 80 percent and with 20 to 25 percent efficiency (NRC 1996).
34 The fuels required are variable and site-specific. A significant barrier to the use of wood waste
35 to generate electricity is the high delivered-fuel cost and high construction cost per MW of
36 generating capacity. The larger wood-waste power plants are only 40 to 50 MW(e) in size.
37 Estimates in the GEIS suggest that the overall level of construction impact per MW of installed
38 capacity should be approximately the same as that for a coal-fired plant, although facilities using
39 wood waste for fuel would be built at smaller scales. Like coal-fired plants, wood-waste plants
40 require large areas for fuel storage and processing and involve the same type of combustion
41 equipment.

1 While wood resources are available in Vermont, wood energy is not considered a reasonable
2 alternative to renewal of the VYNPS OL because of the disadvantages of low heat content,
3 handling difficulties, and high transportation costs.

4

5 **8.2.5.7 Municipal Solid Waste**

6

7 Municipal waste combustors incinerate the waste and use the resultant heat to generate
8 steam, hot water, or electricity. The combustion process can reduce the volume of waste by up
9 to 90 percent and the weight of the waste by up to 75 percent (EPA 2004). Municipal waste
10 combustors use three basic types of technologies: mass burn, modular, and refuse-derived fuel
11 (EIA 2001). Mass-burning technologies are most commonly used in the United States. This
12 group of technologies processes raw municipal solid waste "as is," with little or no sizing,
13 shredding, or separation before combustion.

14

15 Growth in the municipal waste combustion industry slowed dramatically during the 1990s
16 after rapid growth during the 1980s. The slower growth was due to three primary factors:
17 (1) the Tax Reform Act of 1986, which made capital-intensive projects such as municipal waste
18 combustion facilities more expensive relative to less capital-intensive waste disposal
19 alternatives such as landfills; (2) the 1994 Supreme Court decision (*C&A Carbone, Inc. v. Town*
20 *of Clarkstown*), which struck down local flow control ordinances that required waste to be
21 delivered to specific municipal waste combustion facilities rather than landfills that may have
22 had lower fees; and (3) increasingly stringent environmental regulations that increased the
23 capital cost necessary to construct and maintain municipal waste combustion facilities
24 (EIA 2001). The EIA projects an increase in electricity generation from municipal solid waste
25 and landfill gas by 7 billion kWh to 29 billion kWh in 2025; however, no new capacity is
26 expected (EIA 2005).

27

28 The decision to burn municipal waste to generate energy is usually driven by the need for an
29 alternative to landfills rather than by energy considerations. The use of landfills as a waste
30 disposal option is likely to increase in the near term; however, it is unlikely that many landfills
31 will begin converting waste to energy because of unfavorable economics, particularly with
32 electricity prices declining in real terms. U.S. electricity prices in 2002 dollars are expected to
33 decline by 8 percent between 2002 and 2008 and remain stable until 2011 (EIA 2004a). Prices
34 are expected to increase by 0.3 percent per year from 2011 until 2025, following the trend of the
35 generation component of electricity price (EIA 2004a).

36

37 Municipal solid waste combustion generates an ash residue that is buried in landfills. The ash
38 residue is composed of bottom ash and fly ash. Bottom ash refers to that portion of the
39 unburned waste that falls to the bottom of the grate or furnace. Fly ash represents the small
40 particles that rise from the furnace during the combustion process. Fly ash is generally
41 removed from flue-gases using fabric filters or scrubbers (EIA 2001).

Alternatives

1 Currently, there are approximately 89 waste-to-energy plants operating in the United States.
2 These plants generate approximately 2500 MW(e), or an average of approximately 28 MW(e)
3 per plant (Integrated Waste Services Association 2004), a much smaller capacity than that
4 needed to replace the 650 MW(e) of VYNPS.

5 The initial capital costs for municipal solid waste plants are greater than for comparable steam-
6 turbine technology at wood-waste facilities. This is because of the need for specialized waste-
7 separation and waste-handling equipment for municipal solid waste (NRC 1996). Furthermore,
8 estimates in the GEIS suggest that the overall level of construction impact from a waste-fired
9 plant should be approximately the same as that for a coal-fired plant. In addition, waste-fired
10 plants have the same or greater operational impacts (including impacts on the aquatic
11 environment, air, and waste disposal). Some of these impacts would be MODERATE, but still
12 larger than the environmental effects of license renewal of VYNPS; therefore, municipal solid
13 waste would not be a feasible alternative to renewal of the VYNPS OL, particularly at the
14 scale required.

16

17 **8.2.5.8 Other Biomass-Derived Fuels**

18

19 In addition to wood and municipal solid waste fuels, there are several other concepts for power
20 generation, including burning crops, converting crops to a liquid fuel such as ethanol, and
21 converting crops or wood waste to gaseous fuel. In the GEIS, the NRC staff points out that
22 none of these technologies has progressed to the point of being competitive on a large scale or
23 of being reliable enough to replace a baseload plant such as VYNPS. For these reasons, such
24 fuels do not offer a feasible alternative to renewal of the VYNPS OL.

25

26 **8.2.5.9 Fuel Cells**

27

28 Fuel cells work without combustion and its environmental impacts. Power is produced
29 electrochemically by passing a hydrogen-rich fuel over an anode and air over a cathode and
30 separating the two by an electrolyte. The only by-products are heat, water, and CO₂. Hydrogen
31 fuel can come from a variety of hydrocarbon resources by subjecting them to steam under
32 pressure. Natural gas is typically used as the source of hydrogen.

33 Phosphoric acid fuel cells are generally considered first-generation technology. These fuel cells
34 are commercially available at a cost of approximately \$4000 to \$4500/kW of installed capacity
35 (DOE 2006c). Higher-temperature second-generation fuel cells achieve higher fuel-to-electricity
36 and thermal efficiencies. The higher temperatures contribute to improved efficiencies and give
37 the second-generation fuel cells the capability to generate steam for cogeneration and
38 combined-cycle operations.

39
40 Due to cost issues, the DOE formed the Solid State Energy Conversion Alliance (SECA), with
41 the goal of producing new fuel cell technologies at a cost of \$400/kW or lower by 2010

(DOE 2006d). Fuel cells have the potential to become economically competitive if SECA can reach its goal. For comparison, the installed capacity cost for a natural-gas-fired, combined-cycle plant is about \$500 to \$600/kW (Northwest Power Planning Council 2000). At the present time, fuel cells are not economically or technologically competitive with other alternatives for baseload electricity generation. Consequently, fuel cells are not a feasible alternative to renewal of the VYNPS OL.

8.2.5.10 Delayed Retirement

Existing generating units slated for retirement would likely require major refurbishment to upgrade or replace plant components to meet current environmental regulations, such as those regarding air emissions. For this reason, delayed retirement of other Entergy generating units would not be a feasible alternative to renewal of the VYNPS OL. Entergy concluded in its ER (Entergy 2006) that closing the VYNPS would not remove the need for the 650 MW(e) produced by the plant. The environmental impacts of delayed retirement of non-nuclear generating sources would be similar to the impacts from the operation of coal-fired and natural-gas-fired plants. The NRC staff agrees that delayed retirement is not a feasible alternative to renewal of the VYNPS OL.

8.2.5.11 Utility-Sponsored Conservation

Market conditions that initially favored utility-sponsored conservation programs (i.e., demand-side management (DSM)), including educational programs, energy efficiency programs, and load management programs, have changed significantly. The viability of new or expanded DSM programs has decreased in recent years because of increased competition in the electric utility industry, mandated energy efficiency standards, and years of customer education programs that have made efficiency the normal practice. Vermont has enacted several electric energy efficiency programs (State of Vermont 2005b). These programs are administered by the Efficiency Vermont group that is paid for by an energy efficiency charge on state energy bills. Programs include promoting the use of energy-efficient appliances, providing information to homeowners and businesses on energy-efficient technologies, and information on energy-efficient building materials (Efficiency Vermont 2006). Although this program has resulted in peak demand reductions, and the environmental impacts of implementing a DSM program would be SMALL, implementation would not be able to realistically replace the 650 MW(e) of net generating capacity of VYNPS. Therefore, the conservation alternative by itself is not considered a reasonable alternative to renewing the VYNPS OL.

8.2.6 Combination of Alternatives

Even though individual alternatives to VYNPS might not be sufficient on their own to replace VYNPS capacity because of the small size of the resource or lack of cost-effective opportunities, it is conceivable that a combination of alternatives might be cost-effective. As

Alternatives

discussed previously, VYNPS has a combined net electrical capacity of 650 MW(e). For the coal- and natural-gas-fired plant alternatives, the use of standard-sized units as potential replacements for VYNPS were assumed for purposes of the analyses.

There are many possible combinations of alternatives. Table 8-8 presents the environmental impacts of one assumed combination of alternatives consisting of 530 MW(e) of combined-cycle natural-gas-fired plant generation using closed-cycle cooling, a DSM reduction in peak electric demand of 40 MW(e), and 80 MW in purchased power. The NRC staff considered a natural-gas-fired plant over a coal-fired plant because a comparison of the impacts indicates that a coal-fired plant would have greater impacts than a similar-sized gas-fired plant (see Tables 8-2 and 8-4). Also, the footprint of the natural-gas-fired plant is smaller and could be accommodated within previously disturbed portions of the VYNPS site. The impacts are based on the assumptions for constructing and operating a natural-gas-fired plant, as discussed in Section 8.2.2, adjusted for the reduced capacity. Energy reduction savings associated with DSM would result in no addition to the environmental impacts listed in Table 8-8 for a natural-gas-fired plant.

Operation of a new natural-gas-fired plant would result in increased emissions (compared with the proposed action) and other environmental impacts. Environmental impacts related to the number of acres of land disturbed and air emissions are scaled based on the reduced amount of electricity produced. However, the number of workers was not likewise scaled. Conservatively, the number of workers for a 608-MW(e) plant, as used in Table 8-4, is also used here for a 530-MW(e) natural-gas-fired-plant. The environmental impacts of power generation associated with power purchased from other generators would still occur, but would be located elsewhere in the region, nation, or another country (Canada) as discussed in Section 8.1.4. The environmental impacts associated with purchased power are not shown in Table 8-8.

The NRC staff also evaluated a combination of alternatives that employs only renewable energy alternatives. The combination evaluated includes 200 MW wind power, 200 MW solar power, 40 MW DSM reduction in peak electric demand, and 210 MW purchased renewable energy (assumed to be hydroelectric power purchased from Canada). The wind power capacity evaluated would require a minimum of 134 1.5-MW turbines on land (occupying an estimated 600 ac). The solar power capacity evaluated would require a minimum of 2800 ac for solar thermal energy or 7000 acres for photovoltaic energy. It should be noted that the acreage estimate for wind power is a conservative estimate, and significant additional acreage (up to approximately 1400 acres) could be required to provide 200 MW because the capacity factor of wind is estimated to be on the order of 30 percent; the 25 percent capacity factor of solar has been factored into the above estimate of area, which was determined based on information provided in the GEIS (NRC 1996). Thus, for the all-renewable-energy combination of alternatives, a minimum of 3400 ac would be needed for a land-based system. These estimates do not include installation of new transmission capacity, which would be needed.

Alternatives

1 **Table 8-8.** Summary of Environmental Impacts of Combination of Alternatives
 2 at the VYNPS Site and at an Alternate Site
 3

4	5	Impact Category	VYNPS Site		Alternate Site	
			Impact	Comments	Impact	Comments
6		Land use	SMALL to MODERATE	Impact would depend on the degree to which previously disturbed lands were utilized. Uses 32 ac for plant site. Additional impact of up to approximately 364 ac for construction of a 40-mi underground gas pipeline.	MODERATE to LARGE	Impact would depend on the characteristics of the alternate site. Uses 58 ac for power block, offices, cooling towers, roads, and parking areas. Additional land needed for a new transmission line (amount dependent on site chosen) and for construction and/or upgrade of a gas pipeline.
7		Ecology	SMALL to MODERATE	Impact would depend on the characteristics of land to be developed. Uses developed areas at current VYNPS site, thereby reducing impacts on ecology. Impacts could occur with construction of a gas pipeline. Impacts on terrestrial ecology from cooling-tower drift are expected. Impact on aquatic ecology would be reduced from current levels because surface-water intake and thermal discharge would be reduced.	MODERATE to LARGE	Impact would depend on the characteristics of the land to be developed, surface-water body used for intake and discharge, and transmission and pipeline routes.
8	9	Water use and quality – surface water	SMALL	Impact would be reduced from current level. Cooling-tower blowdown containing increased dissolved solids and intermittent low concentrations of biocides, as well as wastewater, would be released. Temporary erosion and sedimentation could occur in streams crossed during pipeline construction.	SMALL to MODERATE	Impact would depend on volume of water withdrawn and discharged and characteristics of surface-water body. Cooling-tower blowdown containing increased dissolved solids and intermittent low concentrations of biocides, as well as wastewater, would be released. Temporary erosion and sedimentation could occur in streams crossed during pipeline construction.

11

Alternatives

Table 8-8. (contd)

		VYNPS Site		Alternate Site	
	Impact Category	Impact	Comments	Impact	Comments
6	Water use and quality – groundwater	SMALL	Impact would be similar to current VYNPS operations if groundwater continues to be used for potable water.	SMALL to MODERATE	Impact would depend on the location of the site, volume of water withdrawn and discharged, and the characteristics of the aquifer.
9	Air quality	MODERATE	Impact from fugitive dust and emissions from vehicles and equipment during construction would be SMALL. Impact of operations on air quality would be MODERATE with the following emissions expected: Sulfur oxides <ul style="list-style-type: none">• 37 tons/yr Nitrogen oxides <ul style="list-style-type: none">• 119 tons/yr Carbon monoxide <ul style="list-style-type: none">• 172 tons/yr PM ₁₀ particulates <ul style="list-style-type: none">• 22 tons/yr Some hazardous air pollutants.	MODERATE	Same emissions as a natural-gas-fired plant at the VYNPS site, although pollution control standards may vary depending on location.
10	Waste	SMALL	Minimal waste product from fuel consumption. Waste would be generated and removed during construction.	SMALL	Same impact as a natural-gas-fired plant at the VYNPS site. Waste disposal constraints may vary.
11	Human health	SMALL	Human health risks associated with natural-gas-fired plants may be attributable to NO _x emissions, which are regulated. Impacts considered SMALL.	SMALL	Same impacts as a natural-gas-fired plant at the VYNPS site.

Table 8-8. (contd)

	Impact Category	VYNPS Site		Alternate Site	
		Impact	Comments	Impact	Comments
1	Socioeconomics	MODERATE	During construction, impact would be MODERATE. Up to 1550 additional workers during the peak of the 3-year construction period, followed by a reduction in the current VYNPS workforce from 678 to 124. Windham County would experience reduced demand for goods and services as well as a loss in its tax base and employment, but this would be potentially offset by projected economic growth in the area. Impact during operation would be SMALL.	MODERATE	Construction impact would depend on location, but could be MODERATE if the location is in a rural area. 1550 additional workers during the peak of the 3-year construction period. Windham County would experience a loss in its tax base and employment if a plant were constructed outside of the county, but this would be potentially offset by projected economic growth in the area.
2	Transportation	MODERATE	Transportation impact associated with construction workers would be MODERATE as 478 VYNPS workers and up to 1550 construction workers would be commuting to the site. Impact during operation would be SMALL as the number of commuters would be reduced to 124.	MODERATE	Transportation impact associated with 1550 construction workers and 124 plant workers would be MODERATE and SMALL, respectively.
3	Aesthetics	MODERATE	Moderate aesthetic impact due to visibility of plant units, exhaust stacks, cooling towers, plumes, and gas compressors. Intermittent noise from construction and continuous noise from cooling towers and mechanical equipment would result in MODERATE impacts.	Moderate to Large	Impact would depend on the characteristics of the site, but would be similar to those for a natural-gas-fired plant at the VYNPS site, with additional impact from the new transmission line and gas pipeline.

Alternatives

Table 8-8. (contd)

Impact Category	VYNPS Site		Alternate Site		
	Impact	Comments	Impact	Comments	
1 2 3	Historic and archeological resources	SMALL to MODERATE	Impact would depend on the degree to which previously disturbed lands were utilized. A cultural resource inventory would be needed to identify, evaluate, and mitigate potential impacts of new construction on cultural resources in undeveloped areas.	SMALL to MODERATE	Impact would depend on the characteristics of the alternate site. A cultural resource inventory would be needed to identify, evaluate, and mitigate potential impacts of new construction.
4 5	Environmental justice	SMALL	Impacts on minority and low-income communities should be similar to those experienced by the population as a whole. Some impacts on housing could occur during construction; loss of 554 operating jobs at VYNPS could reduce employment prospects for minority and low-income populations. Impact could be offset by projected economic growth and the ability of affected workers to commute to other jobs.	SMALL to MODERATE	Impact would depend on population distribution and makeup at the site. Some impact on housing could occur during construction.

The impacts of this combination of alternatives would approach a rating of LARGE during construction (wind turbine installation and construction of a solar power plant). Less land disturbance would result if rooftops are used throughout the local communities for solar applications. Depending on site locations, installation of wind turbines, solar panels, and associated facilities including transmission systems would have potentially LARGE impacts associated with land disturbance. Land disturbance would result in impacts to land use, terrestrial ecology, aquatic ecology, and archaeological sites. Construction impacts on air quality, water quality, and noise could be MODERATE depending on location and construction practices. Wind and solar technologies would require systems to store electricity for periods of peak demand to compensate for periods of intermittency. Local impacts during operation likely would be SMALL for wind, solar, DSM, and purchased power in most environmental areas. Impacts would depend on the site chosen, but common concerns regarding wind power that could cause MODERATE impacts include visual impacts, potential interferences with radar and aircraft, and bird and bat collisions.

1 The NRC staff concludes that it is very unlikely that the environmental impacts of any
2 reasonable combination of generating and conservation options could be reduced to the level of
3 impacts associated with the proposed action.

5 **8.3 Summary of Alternatives Considered**

7 The environmental impacts of the proposed action, renewal of the VYNPS OL, would be SMALL
8 for all impact categories, except for collective offsite radiological impacts from the fuel cycle and
9 from HLW and spent fuel disposal. Collective offsite radiological impacts from the fuel cycle
10 and from HLW and spent fuel disposal were not assigned a single significance level but were
11 determined by the Commission to be Category 1 issues nonetheless. Alternatives to the
12 proposed action that were evaluated include license renewal with implementation of the
13 no-action alternative (discussed in Section 8.1), new-generation alternatives (from coal, natural
14 gas, and nuclear discussed in Sections 8.2.1 through 8.2.3, respectively), purchased electrical
15 power (discussed in Section 8.2.4), alternative technologies (discussed in Section 8.2.5), and a
16 combination of alternatives (discussed in Section 8.2.6).

17 The no-action alternative would require the replacement of electrical-generating capacity by
18 (1) DSM and energy conservation, (2) power purchased from other electricity providers,
19 (3) power-generation alternatives other than VYNPS, or (4) some combination of these options.
20 For each of the new-generation alternatives (coal, natural gas, and nuclear), the environmental
21 impacts would be greater than the impacts of license renewal. For example, the
22 land-disturbance impacts resulting from construction of any new facility would be greater than
23 the impacts of continued operation of VYNPS. The impacts of purchased electrical power
24 (imported power) would still occur, but would occur elsewhere. Alternative technologies are not
25 considered feasible at this time, and it is very unlikely that the environmental impacts of any
26 reasonable combination of generation and conservation options could be reduced to the level of
27 impacts associated with renewal of the VYNPS OL.

28 The NRC staff concludes that the alternative actions, including the no-action alternative, may
29 have environmental effects in at least some impact categories that reach MODERATE or
30 LARGE significance.

34 **8.4 References**

35
36 10 CFR Part 50. *Code of Federal Regulations*, Title 10, Energy, Part 50, "Domestic Licensing of
37 Production and Utilization Facilities."

38
39 10 CFR Part 51. *Code of Federal Regulations*, Title 10, Energy, Part 51, "Environmental
40 Protection Regulations for Domestic Licensing and Related Functions."

Alternatives

1 10 CFR Part 52. *Code of Federal Regulations*, Title 10, *Energy*, Part 52, "Early Site Permits;
2 Standard Design Certifications; and Combined Licenses for Nuclear Power Plants."

3
4 40 CFR Part 50. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 50,
5 "National Primary and Secondary Ambient Air Quality Standards."

6
7 40 CFR Part 51. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 51,
8 "Requirements for Preparation, Adoption, and Submittal of Implementation Plans."

9
10 40 CFR Part 60. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 60,
11 "Standards of Performance for New Stationary Sources."

12
13 40 CFR Part 81. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 81,
14 "Designation of Areas for Air Quality Planning Purposes."

15
16 *C & A Carbone, Inc. v. Town of Clarkstown, New York*, 511 U.S. 383 (U.S. Supreme Court
17 1994).

18
19 Clean Air Act (CAA). 42 USC. 7401, et seq.

20
21 Dominion Nuclear North Anna, LLC (Dominion). 2003. Letter from D.A. Christian, Dominion, to
22 J.E. Dyer, U.S. Nuclear Regulatory Commission. Subject: "North Anna Early Site Permit
23 Application." (September 25, 2003).

24
25 Efficiency Vermont. 2006. "Efficiency Vermont Program." Available URL:
26 <http://www.efficiencyvermont.com/pages> (Accessed May 19, 2006).

27
28 Energy Information Administration (EIA). 2001. *Renewable Energy 2000: Issues and Trends*.
29 DOE/EIA-0628 (2000). Washington, D.C.

30
31 Energy Information Administration (EIA). 2004a. *Annual Energy Outlook 2004 with Projections
32 to 2025*. DOE/EIA-0383 (2004). Washington, D.C.

33
34 Energy Information Administration (EIA). 2004b. *International Energy Outlook 2004*. DOE/EIA-
35 0484 (2004). Washington, D.C.

36
37 Energy Information Administration (EIA). 2005. *Annual Energy Outlook 2005 with Projections
38 to 2025*. DOE/EIA-0383 (2005). Washington, D.C.

39
40 Energy Information Administration (EIA). 2006. *Annual Energy Outlook 2006 with Projections
41 to 2030*. DOE/EIA-0383 (2006). Washington, D.C.

42
43 Energy Policy Act of 2005. 42 USC 20.

Alternatives

1 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006.
2 *Applicant's Environmental Report – Operating License Renewal Stage, Vermont, Yankee Power*
3 *Station.* Docket No. 50-271. Brattleboro, Vermont. (January 25, 2006).

4
5 Exelon Generation Company, LLC (Exelon). 2003. Letter from M.C. Kray, Exelon, to
6 U.S. Nuclear Regulatory Commission. Subject: "Early Site Permit Application."
7 (September 25, 2003).

8
9 Federal Aviation Administration (FAA). 2000. "Obstruction Marking and Lighting." Advisory
10 Circular AC 70/7460-1K. Available URL: <http://www.faa.gov/ats/ata/ai/circV.pdf>
11 (Accessed November 10, 2005).

12
13 Gabbard, A. 1993. "Coal Combustion: Nuclear Resource or Danger." Oak Ridge National
14 Laboratory Review. Oak Ridge, Tennessee. Summer/Fall 1993. Available URL:
15 <http://www.ornl.gov/ORNLReview/rev26-34/text/colmain.html> (Accessed April 6, 2006).

16
17 Idaho National Engineering and Environmental Laboratory (INEEL). 1996. *U.S. Hydropower*
18 *Resource Assessment for Vermont.* DOE/ID-10430(VT). Idaho Falls, Idaho. (February 1996).

19
20 Integrated Waste Services Association. 2004. *Waste-to-Energy: Clean, Reliable, Renewable*
21 *Power.* Fact Sheet. Washington, D.C. (June 2004).

22
23 National Environmental Policy Act of 1969 (NEPA). 42 USC 4321, et seq.

24
25 National Renewable Energy Laboratory (NREL). 2004. "Biomass and Biofuels."
26 Available URL: http://www.nrel.gov/gis/il_biomass.html (Accessed June 16, 2004).

27
28 National Renewable Energy Laboratory (NREL). 2006. "Wind Farm Area Calculator."
29 Available URL: www.nrel.gov/analysis/power_databook_3ed/calc_wind.php
30 (Accessed April 14, 2006).

31
32 Northwest Power Planning Council. 2000. *Northwest Power Supply Adequacy/Reliability Study*
33 *Phase I Report.* Paper No. 2000-4. (March 6, 2000).

34
35 Pacific Northwest Laboratory (PNL). 1986. *Wind Energy Resource Atlas of the United States,*
36 *The Great Lakes Region.* DOE/CH 10093-4. Solar Energy Research Institute, Golden,
37 Colorado. (October 1986).

38
39 Resource Conservation and Recovery Act of 1976 (RCRA). 42 USC 6901, et seq.

40
41 Southern Nuclear Operating Company (SNOC). 2006. Vogtle Early Site Permit.
42 (August 2006).

Alternatives

1 State of Vermont. 2005a. *Vermont Department of Public Service 2005 Vermont Electric Plan*.
2 Department of Public Service.

3
4 State of Vermont. 2005b. *Vermont State Agency Energy Plan for State Government*. Agency
5 of Administration. (July 2005).

6
7 Systems Energy Resources, Inc. (SERI). 2003. Letter from W.A. Eaton, SERI, to U.S. Nuclear
8 Regulatory Commission. Subject: "Early Site Permit Application." (October 16, 2003).

9
10 U.S. Department of Energy (DOE). 2004. "U.S. Wind Energy Resource Map." Available URL:
11 http://www.eere.energy.gov/windandhydro/wind_potential.html?print (Accessed May 13, 2004).

12
13 U.S. Department of Energy (DOE). 2006a. "Vermont Wind Activities." Available URL:
14 http://www.eere.energy.gov/windandhydro/windpoweringamerica/astate_template.asp?stateab=VT (Accessed May 19, 2006).

15
16
17 U.S. Department of Energy (DOE). 2006b. "Alternative Energy Resources in Vermont."
18 Available URL: http://www.eere.energy.gov/states/alternatives/resources_vt.cfm
19 (Accessed May 19, 2006).

20
21 U.S. Department of Energy (DOE). 2006c. "Phosphoric Acid Fuel Cells." Available URL:
22 http://www.eere.energy.gov/hydrogenandfuelcells/fuelcells/fc_types.html#phosphoric
23 (Accessed October 19, 2006).

24
25 U.S. Department of Energy (DOE). 2006d. "Fuel Cells Powering America." Brochure. Solid
26 State Energy Conversion Alliance. August 2006. Available URL: http://www.netl.doe.gov/technologies/coalpower/distgen/pdf/SECA%20Brochure%208_29_06.pdf (Accessed
27 October 19, 2006).

28
29
30 U.S. Environmental Protection Agency (EPA). 1998. "Revision of Standards of Performance for
31 Nitrogen Oxide Emissions from New Fossil-Fuel Fired Steam Generating Units; Revisions to
32 Reporting Requirements for Standards of Performance for New Fossil-Fuel Fired Steam
33 Generating Units, Final Rule." *Federal Register*, Vol. 63, No. 179, pp. 49442–49455.
34 Washington, D.C. (September 16, 1998).

35
36 U.S. Environmental Protection Agency (EPA). 1999. "Regional Haze Regulations, Final Rule."
37 *Federal Register*, Vol. 64, No. 126, pp. 35714–35717. Washington, D.C. (July 1, 1999).

38
39 U.S. Environmental Protection Agency (EPA). 2000a. "Regulatory Finding on the Emissions of
40 Hazardous Air Pollutants from Electric Utility Steam Generating Units." *Federal Register*,
41 Vol. 65, No. 245, pp. 79825–79831. Washington, D.C. (December 20, 2000).

Alternatives

- 1 U.S. Environmental Protection Agency (EPA). 2000b. "Notice of Regulatory Determination on
2 Wastes from the Combustion of Fossil Fuels." *Federal Register*, Vol. 65, pp. 32214–32237.
3 Washington, D.C. (May 22, 2000).
- 4
- 5 U.S. Environmental Protection Agency (EPA). 2004. "Municipal Solid Waste." Available URL:
6 <http://www.epa.gov/epaoswer/non-hw/muncpl/facts.htm> (Accessed April 6, 2006).
- 7
- 8 U.S. Environmental Protection Agency (EPA). 2005. "Mercury – Controlling Power Plant
9 Emissions: Overview." Available URL: http://www.epa.gov/mercury/control_emissions/
10 index.htm (Accessed December 15, 2005).
- 11
- 12 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement*
13 *for License Renewal of Nuclear Plants*. NUREG-1437, Vols. 1 and 2, Washington, D.C.
- 14
- 15 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement*
16 *for License Renewal of Nuclear Plants: Main Report*, "Section 6.3 – Transportation, Table 9.1
17 Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants, Final
18 Report." NUREG-1437, Vol. 1, Addendum 1, Washington, D.C.
- 19
- 20 U.S. Nuclear Regulatory Commission (NRC). 2001. "NRC Organizes Future Licensing Project
21 Organization." Press Release No. 01-035, March 30, 2001. Available URL: <http://www.nrc.gov/reading-rm/doc-collections/news/2001/01-035.html> (Accessed April 6, 2006).
- 22
- 23 U.S. Nuclear Regulatory Commission (NRC). 2002. *Final Generic Environmental Impact*
24 *Statement on Decommissioning Nuclear Facilities, Supplement 1, Regarding the*
25 *Decommissioning of Nuclear Power Reactors*. NUREG-0586, Vols. 1 and 2. Washington, D.C.
- 26
- 27 U.S. Nuclear Regulatory Commission (NRC). 2006. "Proposed Reorganization of the Office of
28 Nuclear Reactor Regulation." SECY-06-0144. (July 21, 2006).
- 29
- 30
- 31 Walsh, M.E., et al. 2000. "Biomass Feedstock Availability in the United States: 1999 State
32 Level Analysis." Available URL: <http://bioenergy.ornl.gov/resourcedata/index.html>
33 (Accessed December 16, 2005).

1 9.0 Summary and Conclusions

2

3

4 By letter dated January 25, 2006, Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear
5 Operations, Inc. (Entergy) submitted an application to the U.S. Nuclear Regulatory Commission
6 (NRC) to renew the operating license (OL) for Vermont Yankee Nuclear Power Station (VYNPS)
7 for an additional 20-year period (Entergy 2006a). If the OL is renewed, State regulatory
8 agencies and Entergy will ultimately decide whether the plant will continue to operate based on
9 factors such as the need for power, or other matters within the State's jurisdiction or the purview
10 of the owners. If the OL is not renewed, then the plant must be shut down at or before the
11 expiration of the current OL, which expires on March 21, 2012.

12 Section 102 of the National Environmental Policy Act (NEPA) directs that an Environmental
13 Impact Statement (EIS) is required for major Federal actions that significantly affect the quality
14 of the human environment. The NRC has implemented Section 102 of NEPA in Title 10,
15 Part 51, of the *Code of Federal Regulations* (10 CFR Part 51). Part 51 identifies licensing and
16 regulatory actions that require an EIS. In 10 CFR 51.20(b)(2), the Commission requires
17 preparation of an EIS or a supplement to an EIS for renewal of a reactor OL; 10 CFR 51.95(c)
18 states that the EIS prepared at the OL renewal stage will be a supplement to the *Generic*
19 *Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437,
20 Volumes 1 and 2 (NRC 1996, 1999).^(a)

21 Upon acceptance of the Entergy application, the NRC began the environmental review process
22 described in 10 CFR Part 51 by publishing a Notice of Intent to prepare an EIS and conduct
23 scoping (*Federal Register*, Volume 71, page 20733 (71 FR 20733) (NRC 2006a)) on April 21,
24 2006. The NRC staff visited the VYNPS site in May 2006, conducted an open house on June 6,
25 2006, at which comments were accepted, and held public scoping meetings on June 7, 2006, in
26 Battleboro, Vermont (NRC 2006b). The NRC staff reviewed the Entergy Environmental Report
27 (ER) (Entergy 2006b) and compared it with the GEIS, consulted with other agencies, and
28 conducted an independent review of the issues following the guidance set forth in NUREG-
29 1555, Supplement 1, the *Standard Review Plans for Environmental Reviews for Nuclear Power*
30 *Plants, Supplement 1: Operating License Renewal* (NRC 2000). The NRC staff also
31 considered the public comments received during the scoping process for preparation of this
32 draft Supplemental Environmental Impact Statement (SEIS) for VYNPS. The public comments
33 received during the scoping process that were considered to be within the scope of the
34 environmental review are provided in Appendix A, Part 1, of this draft SEIS.

35 The NRC staff will hold two public meetings in Battleboro, Vermont, in January 2007, to
36 describe the preliminary results of the NRC environmental review and to answer questions to

(a) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the "GEIS" include the GEIS and its Addendum 1.

Summary and Conclusions

1 provide members of the public with information to assist them in formulating their comments on
2 this draft SEIS. When the comment period ends, the NRC staff will consider and address all of
3 the comments received. These comments will be addressed in Appendix A, Part 2, of the final
4 SEIS.

5 This draft SEIS includes the NRC staff's preliminary analysis that considers and weighs the
6 environmental effects of the proposed action, including cumulative impacts, the environmental
7 impacts of alternatives to the proposed action, and mitigation measures available for reducing
8 or avoiding adverse effects. This draft SEIS also includes the staff's preliminary
9 recommendation regarding the proposed action.

10 The NRC has adopted the following statement of purpose and need for license renewal from the
11 GEIS:

12 The purpose and need for the proposed action (renewal of an operating license) is to
13 provide an option that allows for power generation capability beyond the term of a
14 current nuclear power plant operating license to meet future system generating needs,
15 as such needs may be determined by State, utility, and, where authorized, Federal
16 (other than NRC) decisionmakers.

17 The evaluation criterion for the NRC staff's environmental review, as defined in
18 10 CFR 51.95(c)(4) and the GEIS, is to determine

19 ... whether or not the adverse environmental impacts of license renewal are so great that
20 preserving the option of license renewal for energy-planning decisionmakers would be
21 unreasonable.

22 Both the statement of purpose and need and the evaluation criterion implicitly acknowledge that
23 there are factors, in addition to license renewal, that will ultimately determine whether an
24 existing nuclear power plant continues to operate beyond the period of the current OL.

25 NRC regulations (10 CFR 51.95(c)(2)) contain the following statement regarding the content of
26 SEISs prepared at the license renewal stage:

27 The supplemental environmental impact statement for license renewal is not required to
28 include discussion of need for power or the economic costs and economic benefits of
29 the proposed action or of alternatives to the proposed action except insofar as such
30 benefits and costs are either essential for a determination regarding the inclusion of an
31 alternative in the range of alternatives considered or relevant to mitigation. In addition,
32 the supplemental environmental impact statement prepared at the license renewal stage

Summary and Conclusions

need not discuss other issues not related to the environmental effects of the proposed action and the alternatives, or any aspect of the storage of spent fuel for the facility within the scope of the generic determination in § 51.23(a) and in accordance with § 51.23(b).^(a)

The GEIS contains the results of a systematic evaluation of the consequences of renewing an OL and operating a nuclear power plant for an additional 20 years. It evaluates 92 environmental issues using the NRC's three-level standard of significance – SMALL, MODERATE, or LARGE – developed using the Council on Environmental Quality guidelines. The following definitions of the three significance levels are set forth in the footnotes to Table B-1 of 10 CFR Part 51, Subpart A, Appendix B:

SMALL – Environmental effects are not detectable or are so minor that they will neither destabilize nor noticeably alter any important attribute of the resource.

MODERATE – Environmental effects are sufficient to alter noticeably, but not to destabilize, important attributes of the resource.

LARGE – Environmental effects are clearly noticeable and are sufficient to destabilize important attributes of the resource.

For 69 of the 92 issues considered in the GEIS, the NRC staff analysis in the GEIS shows the following:

- (1) The environmental impacts associated with the issue have been determined to apply either to all plants or, for some issues, to plants having a specific type of cooling system or other specified plant or site characteristics.
- (2) A single significance level (i.e., SMALL, MODERATE, or LARGE) has been assigned to the impacts (except for collective off-site radiological impacts from the fuel cycle and from high-level waste (HLW) and spent fuel disposal).
- (3) Mitigation of adverse impacts associated with the issue has been considered in the analysis, and it has been determined that additional plant-specific mitigation measures are likely not to be sufficiently beneficial to warrant implementation.

(a) The title of 10 CFR 51.23 is "Temporary storage of spent fuel after cessation of reactor operations – generic determination of no significant environmental impact."

Summary and Conclusions

These 69 issues were identified in the GEIS as Category 1 issues. In the absence of new and significant information, the NRC staff relied on conclusions as amplified by supporting information in the GEIS for issues designated Category 1 in Table B-1 of 10 CFR Part 51, Subpart A, Appendix B. The NRC staff also determined that information provided during the public comment period did not identify any new issue that requires site-specific assessment.

Of the 23 issues that do not meet the criteria set forth above, 21 are classified as Category 2 issues requiring analysis in a plant-specific supplement to the GEIS. The remaining two issues, environmental justice and chronic effects of electromagnetic fields, were not categorized. Environmental justice was not evaluated on a generic basis and must also be addressed in a plant-specific supplement to the GEIS. Information on the chronic effects of electromagnetic fields was not conclusive at the time the GEIS was prepared.

This draft SEIS documents the NRC staff's consideration of all 92 environmental issues identified in the GEIS. The NRC staff considered the environmental impacts associated with alternatives to license renewal and compared the environmental impacts of license renewal and the alternatives. The alternatives to license renewal that were considered include the no-action alternative (not renewing the OL for VYNPS) and alternative methods of power generation. These alternatives were evaluated assuming that the replacement power generation plant is located at either the VYNPS site or at some other unspecified location.

9.1 Environmental Impacts of the Proposed Action – License Renewal

Entergy and the NRC staff have established independent processes for identifying and evaluating the significance of any new information on the environmental impacts of license renewal. Neither Entergy nor the NRC staff has identified information that is both new and significant related to Category 1 issues that would call into question the conclusions in the GEIS. Similarly, neither the scoping process, Entergy, nor the NRC staff has identified any new issue applicable to VYNPS that has a significant environmental impact. Therefore, the NRC staff relies upon the conclusions of the GEIS for all Category 1 issues that are applicable to VYNPS.

Entergy's license renewal application presents an analysis of the Category 2 issues that are applicable to VYNPS. The NRC staff has reviewed the Entergy analysis for each issue and has conducted an independent review of each issue plus environmental justice and chronic effects from electromagnetic fields. Three Category 2 issues are not applicable because they are related to plant design features or site characteristics not found at VYNPS. Four Category 2 issues are not discussed in this draft SEIS because they are specifically related to refurbishment. Entergy (Entergy 2006b) has stated that its evaluation of structures and components, as required by 10 CFR 54.21, did not identify any major plant refurbishment

Summary and Conclusions

activities or modifications as necessary to support the continued operation of VYNPS for the license renewal period. In addition, any replacement of components or additional inspection activities are within the bounds of normal plant component replacement and, therefore, are not expected to affect the environment outside of the bounds of the plant operations evaluated in the Final Environmental Statement Related to Operation of VYNPS (AEC 1972).

Fourteen Category 2 issues related to operational impacts and postulated accidents during the renewal term, as well as environmental justice and chronic effects of electromagnetic fields, are discussed in detail in this draft SEIS. Five of the Category 2 issues and environmental justice apply to both refurbishment and to operation during the renewal term and are only discussed in this draft SEIS in relation to operation during the renewal term. For all 14 Category 2 issues and environmental justice, the NRC staff concludes that the potential environmental impacts would be of SMALL significance in the context of the standards set forth in the GEIS. In addition, the NRC staff determined that appropriate Federal health agencies have not reached a consensus on the existence of chronic adverse effects from electromagnetic fields. Therefore, no further evaluation of this issue is required. For severe accident mitigation alternatives (SAMAs), the NRC staff concludes that a reasonable, comprehensive effort was made to identify and evaluate SAMAs. Based on its review of the SAMAs for VYNPS and the plant improvements already made, the NRC staff concludes several candidate SAMAs are potentially cost-beneficial. However, none of these SAMAs relate to adequately managing the effects of aging during the period of extended operation. Therefore, they need not be implemented as part of license renewal pursuant to 10 CFR Part 54.

Mitigation measures were considered for each Category 2 issue. Current measures to mitigate the environmental impacts of plant operation were found to be adequate, and no additional mitigation is warranted. However, under the provisions of the Clean Water Act 316(b) Phase II regulations, the Vermont Department of Environmental Conservation may impose further restrictions or require modifications to the cooling system to reduce the impacts on aquatic resources from entrainment and impingement. Cumulative impacts of past, present, and reasonably foreseeable future actions were considered, regardless of what agency (Federal or non-Federal) or person undertakes such other actions. For purposes of this analysis, where VYNPS license renewal impacts are deemed to be SMALL, the NRC staff concluded that these impacts would not result in significant cumulative impacts on potentially affected resources.

The following sections discuss unavoidable adverse impacts, irreversible or irretrievable commitments of resources, and the relationship between local short-term use of the environment and long-term productivity.

9.1.1 Unavoidable Adverse Impacts

An environmental review conducted at the license renewal stage differs from the review conducted in support of a construction permit because the plant is in existence at the license

Summary and Conclusions

1 renewal stage and has operated for a number of years. As a result, adverse impacts associated
2 with the initial construction have been avoided, have been mitigated, or have already occurred.
3 The environmental impacts to be evaluated for license renewal are those associated with
4 refurbishment and continued operation during the renewal term.

5
6 The adverse impacts of continued operation identified are considered to be of SMALL
7 significance, and none warrants implementation of additional mitigation measures. However,
8 under the provisions of the Clean Water Act 316(b) Phase II regulations, the Vermont
9 Department of Environmental Conservation may impose further restrictions or require
10 modifications to the cooling system to reduce the impacts on aquatic resources from
11 entrainment and impingement. The adverse impacts of likely alternatives if VYNPS ceases
12 operation at or before the expiration of the current OL would not be smaller than those
13 associated with continued operation of this unit, and they may be greater for some impact
14 categories in some locations.

15 **9.1.2 Irreversible or Irretrievable Resource Commitments**

16
17 The commitment of resources related to construction and operation of VYNPS during the
18 current license period was made when the plant was built. The resource commitments
19 considered in this draft SEIS are associated with continued operation of the plant for an
20 additional 20 years. These resources include materials and equipment required for plant
21 maintenance and operation, the nuclear fuel used by the reactors, and ultimately, permanent
22 offsite storage space for the spent fuel assemblies.

23
24 The most significant resource commitments related to operation during the renewal term are the
25 fuel and the permanent storage space. VYNPS replaces a portion of the fuel assemblies in its
26 unit during every refueling outage, which occurs on an 18-month cycle.

27
28 The likely power-generation alternatives if VYNPS ceases operation on or before the expiration
29 of the current OL will require a commitment of resources for construction of the replacement
30 plants as well as for fuel to run the plants.

31 **9.1.3 Short-Term Use Versus Long-Term Productivity**

32
33 An initial balance between short-term use and long-term productivity of the environment at the
34 VYNPS site was set when the plant was approved and construction began. That balance is
35 now well-established. Renewal of the OL for VYNPS and continued operation of the plant
36 would not alter the existing balance, but may postpone the availability of the site for other uses.
37 Denial of the application to renew the OL would lead to shutdown of the plant and would alter

1 the balance in a manner that depends on subsequent uses of the site. For example, the
2 environmental consequences of turning the VYNPS site into a park or an industrial facility are
3 quite different.

4

5 **9.2 Relative Significance of the Environmental Impacts of 6 License Renewal and Alternatives**

7

8 The proposed action is renewal of the OL for VYNPS. Chapter 2 describes the site, power
9 plant, and interactions of the plant with the environment. As noted in Chapter 3, no
10 refurbishment and no refurbishment impacts are expected at VYNPS. Chapters 4 through 7
11 discuss environmental issues associated with renewal of the OL. Environmental issues
12 associated with the no-action alternative and alternatives involving power generation and use
13 reduction are discussed in Chapter 8.

14

15 The significance of the environmental impacts from the proposed action (approval of the
16 application for renewal of the OL), the no-action alternative (denial of the application),
17 alternatives involving nuclear, coal-, or gas-fired power generation at the VYNPS site and at an
18 unspecified alternate site, and a combination of alternatives are compared in Table 9-1.
19 Closed-cycle cooling systems are assumed for all power-generation alternatives.

20

21 Substitution of once-through cooling for the closed-cycle cooling system in the evaluation of the
22 nuclear and gas- and coal-fired generation alternatives would result in somewhat greater
23 environmental impacts in some impact categories.

24

25 Table 9-1 shows the significance of the environmental effects of the proposed action are
26 SMALL for all impact categories (except for collective offsite radiological impacts from the fuel
27 cycle and from HLW and spent fuel disposal, for which a single significance level was not
28 assigned (see Chapter 6)). The alternative actions, including the no-action alternative, may
29 have environmental effects in at least some impact categories that reach MODERATE or
30 LARGE significance.

31

32 **9.3 NRC Staff Conclusions and Recommendations**

33

34 Based on (1) the analysis and findings in the GEIS (NRC 1996, 1999), (2) the Entergy ER
35 (Entergy 2006b), (3) consultation with Federal, State, and local agencies, (4) the NRC staff's
36 own independent review, and (5) the NRC staff's consideration of public comments received,
37 the preliminary recommendation of the NRC staff is that the Commission determine that the
38 adverse environmental impacts of license renewal for VYNPS are not so great that preserving
39 the option of license renewal for energy-planning decisionmakers would be unreasonable.

Table 9-1. Summary of Environmental Significance of License Renewal, the No Action Alternative, and Alternative Power Generation Using Closed-Cycle Cooling

Impact Category	Proposed Action	Coal-Fired Generation		Natural-Gas-Fired Generation		New Nuclear Generation		Combination of Alternatives	
		No-Action Alternative (Denial of Renewal)	Alternate Site	VYNPS Site	Alternate Site	Alternate Site	VYNPS Site	Alternate Site	Alternate Site
Land use	SMALL	SMALL	MODERATE to LARGE	SMALL to MODERATE	MODERATE to LARGE	MODERATE to LARGE	MODERATE to LARGE	MODERATE to LARGE	MODERATE to LARGE
Ecology	SMALL	SMALL	MODERATE to LARGE	SMALL to MODERATE	MODERATE to LARGE	MODERATE to LARGE	MODERATE to LARGE	MODERATE to LARGE	MODERATE to LARGE
Water use and quality – surface water	SMALL	SMALL	SMALL to MODERATE	SMALL	SMALL to MODERATE	SMALL to MODERATE	SMALL	SMALL	SMALL to MODERATE
Water use and quality – groundwater	SMALL	SMALL	SMALL to MODERATE	SMALL	SMALL to MODERATE	SMALL to MODERATE	SMALL	SMALL	SMALL to MODERATE
Air quality	SMALL	SMALL	MODERATE	MODERATE	MODERATE	MODERATE	MODERATE	MODERATE	MODERATE
Waste	SMALL	SMALL	MODERATE	SMALL	SMALL	SMALL	SMALL	SMALL	SMALL
Human health	SMALL ^(a)	SMALL	SMALL	SMALL	SMALL	SMALL ^(a)	SMALL	SMALL	SMALL
Socioeconomics	SMALL	SMALL to LARGE	SMALL to LARGE	Moderate	Moderate	Moderate to LARGE	Moderate to LARGE	Moderate	Moderate
Transportation	SMALL	SMALL	Moderate to LARGE	Moderate	Moderate	Moderate to LARGE	Moderate to LARGE	Moderate	Moderate
Aesthetics	SMALL	SMALL	Moderate to LARGE	SMALL to MODERATE	Moderate	Moderate to LARGE	Moderate to LARGE	Moderate	Moderate
Historic and archaeological resources	SMALL	SMALL	SMALL to MODERATE	SMALL to MODERATE	SMALL to MODERATE	SMALL to MODERATE	SMALL to MODERATE	SMALL to MODERATE	SMALL to MODERATE
Environmental justice	SMALL	SMALL	SMALL to MODERATE	SMALL	SMALL to MODERATE	SMALL to LARGE	SMALL to LARGE	SMALL	SMALL to MODERATE

a) Except for collective offsite radiological impacts from the fuel cycle and from HLW and spent fuel disposal, for which a significance level was not assigned. See Chapter 6 for details.

a) Except for collective offsite radiological impacts from the fuel cycle and from HLW and spent fuel disposal, for which a significance level was not assigned. See Chapter 6 for details.

9.4 References

10 CFR Part 51. *Code of Federal Regulations, Title 10, Energy*, Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions."

10 CFR Part 54. *Code of Federal Regulations, Title 10, Energy*, Part 54, "Requirements for Renewal of Operating Licenses for Nuclear Power Plants."

Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006a. *License Renewal Application, Vermont Yankee Nuclear Power Station, Facility Operating License No. DPR-28*. Docket No. 50-271. Brattleboro, Vermont.

Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006b. *Applicant's Environmental Report – Operating License Renewal Stage, Vermont Yankee Nuclear Power Station*. Docket No. 50-271. Brattleboro, Vermont. (January 25, 2006).

Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006c. *Entergy Nuclear Waste Minimization Plan*. (July 2006).

National Environmental Policy Act of 1969 (NEPA), as amended. 42 USC 4321, et seq.

U.S. Atomic Energy Commission (AEC). 1972. *Final Environmental Statement Related to Operation of the Vermont Yankee Nuclear Power Station, Vermont Yankee Nuclear Power Corporation*. Docket No. 50-271. Washington, D.C. (July 1972).

U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*. NUREG-1437, Volumes 1 and 2, Washington, D.C.

U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants: Main Report*, "Section 6.3 – Transportation, Table 9.1, Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants, Final Report." NUREG-1437, Volume 1, Addendum 1, Washington, D.C.

U.S. Nuclear Regulatory Commission (NRC). 2000. *Standard Review Plans for Environmental Reviews for Nuclear Power Plants, Supplement 1: Operating License Renewal*. NUREG-1555, Supplement 1, Washington, D.C.

Summary and Conclusions

- 1 U.S. Nuclear Regulatory Commission (NRC). 2006a. "Entergy Nuclear Operations, Inc.,
2 Vermont Yankee Nuclear Power Station; Notice of Intent to Prepare an Environmental Impact
3 Statement and Conduct Scoping Process." *Federal Register*, Vol. 71, No. 77,
4 pp. 20733–20735. Washington, D.C. (April 21, 2006).
- 5
- 6 U.S. Nuclear Regulatory Commission (NRC). 2006b. *Environmental Impact Statement Scoping*
7 *Process: Summary Report – Vermont Yankee Nuclear Power Station, Windham County,*
8 *Vermont.* Washington, D.C.
- 9

Appendix A

Comments Received on the Environmental Review

Appendix A

Comments Received on the Environmental Review

Part I – Comments Received During Scoping

On April 21, 2006, the U.S. Nuclear Regulatory Commission (NRC) published a Notice of Intent in the *Federal Register* (Volume 71, page 20733) to notify the public of the NRC staff's intent to prepare a plant-specific supplement to the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS), NUREG-1437, Volumes 1 and 2, to support the renewal application for the Vermont Yankee Nuclear Power Station (VYNPS) operating license and to conduct scoping. The plant-specific supplement to the GEIS has been prepared in accordance with the National Environmental Policy Act (NEPA) of 1969, Council on Environmental Quality (CEQ) guidance, and Title 10, Part 51, of the *Code of Federal Regulations* (10 CFR Part 51). As outlined by NEPA, the NRC initiated the scoping process with the issuance of the *Federal Register* Notice. The NRC invited the applicant; Federal, State, and local government agencies; Native American Tribal organizations; local organizations; and individuals to participate in the scoping process by providing oral comments at the scheduled public meetings and/or by submitting written suggestions and comments no later than June 23, 2006.

The scoping process included two public scoping meetings that were held at the Latchis Theatre in Brattleboro, Vermont, on June 7, 2006. Additionally, the NRC held an informal open house at the Quality Inn & Suites, Brattleboro, Vermont, on Tuesday, June 6th. Approximately 200 members of the public attended the meetings. During the open house on June 6th, oral comments from 3 attendees were recorded and transcribed by a certified court reporter. The scoping meeting sessions began with NRC staff members providing a brief overview of the license renewal process and the NEPA process. After the NRC's prepared statements, the meetings were open for public comments. Forty-seven attendees provided oral statements that were recorded and transcribed by a certified court reporter. In addition to the comments received during the public meetings, eighteen comment letters were received by the NRC in response to the Notice of Intent.

At the conclusion of the scoping period, the NRC staff and its contractors reviewed the transcripts and all letters to identify specific comments and issues. Each set of comments from a given commenter was given a unique identifier (Commenter ID), so that each set of comments from a commenter could be traced back to the transcript or letter by which the comments were submitted. Specific comments were numbered sequentially within each comment set. Several commenters submitted comments through multiple sources (e.g., afternoon and evening scoping meetings). All of the comments received and the NRC staff responses are included in the VYNPS Scoping Summary Report dated October 30, 2006.

Appendix A

1 Table A.1 identifies the individuals who provided comments applicable to the environmental
2 review and the Commenter ID associated with each person's set(s) of comments. The
3 individuals are listed in the order in which they spoke at the public meeting, and in alphabetical
4 order for the comments received by letter or e-mail. To maintain consistency with the Scoping
5 Summary Report, the unique identifier used in that report for each set of comments is retained
6 in this appendix.

7 Specific comments were categorized and consolidated by topic. Comments with similar specific
8 objectives were combined to capture the common essential issues raised by the commenters.
9 The comments fall into one of the following general groups:

- 12 • Specific comments that address environmental issues within the purview of the NRC
13 environmental regulations related to license renewal. These comments address
14 Category 1 or Category 2 issues or issues that were not addressed in the GEIS. They
15 also address alternatives and related Federal actions.
- 17 • General comments (1) in support of or opposed to nuclear power or license renewal or
18 (2) on the renewal process, the NRC's regulations, and the regulatory process. These
19 comments may or may not be specifically related to the VYNPS license renewal
20 application.
- 22 • Questions that do not provide new information.
- 24 • Specific comments that address issues that do not fall within or are specifically excluded
25 from the purview of NRC environmental regulations related to license renewal. These
26 comments typically address issues such as the need for power, emergency
27 preparedness, security, current operational safety issues, and safety issues related to
28 operation during the renewal period.

30 Comments applicable to this environmental review and the NRC staff's responses are
31 summarized in this appendix. The parenthetical alphanumeric identifier after each comment
32 refers to the comment set (Commenter ID) and the comment number. This information, which
33 was extracted from the VYNPS Scoping Summary Report, is provided for the convenience of
34 those interested in the scoping comments applicable to this environmental review. The
35 comments that are general or outside the scope of the environmental review for VYNPS are not
36 included here. More detail regarding the disposition of general or inapplicable comments can
37 be found in the Scoping Summary Report. The Agencywide Document Access and
38 Management System (ADAMS) accession number for the Scoping Summary Report is
39 ML063030576.

41 This accession number is provided to facilitate access to the document through the Public
42 Electronic Reading Room (<http://www.nrc.gov/reading-rm.html>).

Appendix A

Table A-1. Individuals Providing Comments During Scoping Comment Period

Commenter ID	Commenter	Affiliation (If Stated)	Comment Source ^(a)
VS-A	Michael Mulligan		Open House
VS-B	Nancy Crompton		Open House
VS-C	Ellen Kaye		Open House
VS-D	Raymond Shadis	New England Coalition (NEC)	Afternoon Scoping Meeting
VS-E	Evan Mulholland		Afternoon Scoping Meeting
VS-F	Chris Williams	Nuclear Information and Resources Service (NIRS)	Afternoon Scoping Meeting
VS-G	Shawn Banfield	Vermont Energy Partnership	Afternoon Scoping Meeting
VS-H	Dan MacArthur	Marlboro County Emergency Management Director	Afternoon Scoping Meeting
VS-I	Bill Burton		Afternoon Scoping Meeting
VS-J	Robert English		Afternoon Scoping Meeting
VS-K	Carol Boyer		Afternoon Scoping Meeting
VS-L	Nancy Nelkin		Afternoon Scoping Meeting
VS-M	Sally Shaw	NEC	Afternoon Scoping Meeting
VS-N	Sarah Kotkov	NEC	Afternoon Scoping Meeting
VS-O	Gary Sachs		Afternoon Scoping Meeting
VS-P	Ann Elizabeth Howes		Afternoon Scoping Meeting
VS-Q	David McElwee	Entergy Nuclear Vermont Yankee (Entergy)	Afternoon Scoping Meeting
VS-R	Deborah Reger	Leftovers Affinity	Afternoon Scoping Meeting
VS-S	Cora Brooks		Afternoon Scoping Meeting
VS-T	Beth Adams	CAN	Afternoon Scoping Meeting
VS-U	Jane Newton		Afternoon Scoping Meeting
VS-V	Governor Thomas B. Salmon		Evening Scoping Meeting
VS-W	Deb Katz	CAN	Evening Scoping Meeting
VS-X	Sunny Miller	Traprock Peace Center	Evening Scoping Meeting
VS-Y	Beth McElwee		Evening Scoping Meeting
VS-Z	Ellen Cota	Entergy	Evening Scoping Meeting
VS-AA	Michael Flory	Entergy	Evening Scoping Meeting
VS-BB	Shawn Banfield	Vermont Energy Partnership	Evening Scoping Meeting
VS-CC	Claire Change	CAN	Evening Scoping Meeting
VS-DD	Raymond Shadis	NEC	Evening Scoping Meeting
VS-EE	Bernard Buteau	Entergy	Evening Scoping Meeting
VS-FF	Marian Kelner		Evening Scoping Meeting
VS-GG	Ted Sullivan		Evening Scoping Meeting
VS-HH	John Dreyfuss		Evening Scoping Meeting
VS-II	Mike Hamer		Evening Scoping Meeting

Appendix A

Table A-1. (contd)

Commenter ID	Commenter	Affiliation (If Stated)	Comment Source ^(a)
VS-JJ	Chris Nord	CAN	Evening Scoping Meeting
VS-KK	Dart Everett	Brattleboro Development Center	Evening Scoping Meeting
VS-LL	Bill Pearson	VT Earth Institute	Evening Scoping Meeting
VS-MM	Emily Tinkham	Entergy	Evening Scoping Meeting
VS-NN	Clay Turnbill	Nuclear Free Vermont/CAN/NEC	Evening Scoping Meeting
VS-OO	Dennis Girroir	Entergy	Evening Scoping Meeting
VS-PP	Emma Stamas		Evening Scoping Meeting
VS-QQ	George Iselin		Evening Scoping Meeting
VS-RR	Sherry Zabriskie		Evening Scoping Meeting
VS-SS	Gary Sachs		Evening Scoping Meeting
VS-TT	Larry Lukens		Evening Scoping Meeting
VS-UU	Joan Horman		Evening Scoping Meeting
VS-VV	Beth Adams		Evening Scoping Meeting
VS-WW	Jon Block	Attorney	E-mail (ML061770066)
VS-XX	Cora Brooks		Letter (ML061840614)
VS-YY	Tina Emery-Howe		E-mail (ML061730420)
VS-ZZ	Dart Everett	Brattleboro Development Center	Evening Scoping Meeting
VS-AAA	Catherine Gjessing	Vermont Agency of Natural Resources	E-mail (ML061770066)
VS-BBB	Mike Hebert		E-mail (ML061730415)
VS-CCC	Jacob Iselin		Letter (ML061840615)
VS-DDD	Becca King		E-mail (ML061730399)
VS-EEE	Thomas Matsuda		E-mail (ML061740035)
VS-FFF	Sunny Miller	Traprock Peace Center	E-mail (ML061770071)
VS-GGG	Massachusetts Attorney General Thomas F. Reilly		Letter (ML061780088)
VS-HHH	Sally Shaw	NEC	E-mail (ML061770056)
VS-III	William Sherman	Vermont Department of Public Service (same comments in the letter and e-mail)	E-mail (ML061770052) Letter (ML061840612)
VS-JJJ	E. Stamas		Letter (ML061920474)
VS-KKK	Edward and Emma Stamas		Letter (ML061840613)
VS-LLL	Jonathon Von Ranson		E-mail (ML061730427)
VS-MMM	Pam Walker	CAN	E-mail (ML061730431)
VS-NNN	Dory Zelman		E-mail (ML061770078)

(a) The open house, afternoon and evening transcripts can be found in ADAMS under accession numbers: ML061840036, ML061840033, and ML061840029, respectively.

Comments in this section are grouped in the following categories:

- A.1.1 License Renewal and Its Processes
- A.1.2 NRC Hearing Process
- A.1.3 Support of License Renewal at Vermont Yankee Nuclear Power Station
- A.1.4 Opposition to License Renewal at Vermont Yankee Nuclear Power Station
- A.1.5 Support of Nuclear Power
- A.1.6 Opposition to Nuclear Power
- A.1.7 Ecology
- A.1.8 Threatened and Endangered Species
- A.1.9 Surface-Water Quality, Hydrology, and Use
- A.1.10 Human Health
- A.1.11 Socioeconomics
- A.1.12 Postulated Accidents
- A.1.13 Uranium Fuel Cycle and Waste Management
- A.1.14 Alternative Energy Sources

A.1 Comments and Responses

A.1.1 Comments Concerning License Renewal and Its Processes

Comment: I was interested, the person before me was going through the benefits of nuclear energy, but, as we all know, there are many, many hidden costs included in producing energy from nuclear power. One of them being that there is a sizeable payroll at the Federal level, paid for by our taxes, which is specifically for the purpose of seeing that nuclear energy continues to operate fairly cheaply. So just think of that. The people who are here today getting paid by us, the citizenry, we're paying for that in our taxes, but it's really a cost that should be associated with the electric costs of nuclear power. (VS-H-4)

Comment: I think part of the problem is, as taxpayers, we're paying the NRC as our employees, to be the knowledgeable representatives of public interest. The NRC is responsible for overseeing the nuclear industry. And when they do a poor job, they risk our health and well being, when you do not rigorously and objectively evaluate the impacts of nuclear power on us. (VS-L-1)

Comment: The Executive Summary of the 600 some odd page Environmental Impact Statement, is full of little items like that. Here's another. The staff concludes that the generic analysis of a severe accident, applies to all reactors.

Appendix A

1 The probability weighted consequences of atmospheric releases fall out onto open bodies of
2 water, groundwater releases and the societal and economic impacts are of small significance,
3 for all reactors.

4
5 That, with the stroke of a pen, wipes out all our concerns. They also conclude that the
6 environmental impacts of design-basis accidents, are of small significance for all plants.
7

8 And, because additional measures to reduce such impacts would be costly, don't worry, they
9 won't burden the Licensee with extra mitigations. (VS-M-3)
10

11 **Comment:** And one of my concerns, when I hear the NRC at this meeting, in regard to the data
12 that they use for their studies, is that they take much of their data, not from their own sources,
13 but from the Licensee. And, in my opinion, that's poor practice. (VS-O-2)
14

15 **Comment:** One of the problems that citizens have and citizen-intervenors have is that when
16 issues like this are found within a plant, typically a condition report will be written. That is not
17 public. That does not go into the NRC public document room. And then the item may or may
18 not be entered into the company's Corrective Action Program. That's a place where NRC buries
19 a lot of issues too. They sort of hand it back to the company and say you guys fix it and make
20 sure you keep records. But those records are not public and there's really no way to access
21 them unless you get involved in a legal proceeding and then maybe you can touch them. (VS-
22 DD-8)
23

24 **Comment:** I'd like to recite a couple of excerpts right from your own website, that I think help
25 support the position to allow Vermont Yankee to consider operation. It's the NRC primary
26 mission to protect the public health and safety and the environment. That's what we're talking
27 about tonight is the environmental effects. In the environment, the effects of radiation from
28 nuclear reactors, materials and waste facilities and you also regulate these nuclear materials
29 and facilities to promote the common defense and security. There's also a section there that
30 talks about reactor license renewal overview. And it states that the Atomic Energy Act and the
31 NRC regulations limit commercial power reactor licenses to an initial 40-year -- 40 years, as you
32 said, but also permits such licenses to be renewed. That original 40-year term for reactor
33 licenses was based on economic and anti-trust considerations and not on limitations of nuclear
34 technology. Due to this selective period, however, some structures and components may have
35 been engineered on the basis of a 40-year service life. The NRC has established a timely
36 license renewal process which we've heard something about tonight and clear requirements
37 codified in 10 CFR parts 51 and 54 that are needed to assure safe plant operation for extended
38 plant life.
39

40 The timely renewal of licenses for an additional 20 years, where appropriate to renew them,
41 may be important to ensuring an adequate energy supply for the United States during the first
42 half of the 21st century. (VS-EE-1)

1 **Comment:** Another point is that we are regulated in this industry and when you're regulated,
2 there's rules that you have to follow and those -- and we are governed by the NRC and we have
3 to follow all those rules. As we apply for this application, the look that is given to the site and to
4 all the processes that it has is exhaustive. It's a mess. And all of those rules have to be met.
5 So let's let the facts decide what it is. If the NRC after their investigation into what's going on at
6 the plant and whether or not we're following the rules, if they conclude that we will have an
7 effect on the environment that are of such a nature that it doesn't meet the regulations, then
8 they need to not approve this license application. But if it does meet the rules and regulations,
9 then it needs to be approved. (VS-GG-3)

10
11 **Comment:** They have a very, very large team of inspectors looking at every possible aspect
12 you can look at for aging management, for how we're going to handle aging management. It's
13 the future replacement of certain parts that wear out, things like that, based on operating
14 experience, etcetera and everything. It's a very involved process. It's not taken lightly by the
15 NRC or Vermont Yankee. (VS-II-6)

16
17 **Comment:** I'll go back to my original question, who do you actually work for? Are these
18 meetings, these public meetings, merely an appeasement so you have the general public come
19 up to the microphone, make a few statements, and then they go away and you get to go on your
20 merry business and decide in collusion with this industry how it's going to go. Or are you
21 actually taking into account the real concerns that are obvious, if you just sit and think about
22 them, we're talking about 35 million curies of Cesium-137 sitting in that spent-fuel pool.
23 (VS-JJ-7)

24
25 **Comment:** I think that in every meeting that the NRC is a part of, they had better rethink who
26 they're working for and start thinking about the children and grandchildren who are going to
27 have to get out of this technology of nuclear energy and nuclear waste proliferation, and get into
28 something safer and more sustainable. (VS-PP-3)

29
30 **Comment:** I've spoken many times against nuclear power and I'm at the point where I feel like
31 nobody's listening as far as Vermont Yankee or Entergy. The government, the NRC for sure.
32 (VS-RR-1)

33
34 **Comment:** Dozens of Entergy (Vermont Yankee) employees and their family members were
35 allowed to speak and citizens who had come on their own had to wait until late in the evening
36 and cut their comments short and questions short (earlier in the evening when questions were
37 taken). (VS-KKK-1)

38
39 **Response:** *The comments are in regard to license renewal and its processes in general. The
40 Commission has established a process, by rule, for the environmental and safety reviews to be
41 conducted to review a license renewal application. The development of the Commission's*

Appendix A

1 *regulations governing the license renewal process was already subject to public review and
2 comment. The comments provide no new information; therefore, they will not be evaluated
3 further.*

4 **A.1.2 Comments Concerning NRC Hearing Process**

5 **Comment:** I think that many of us are quite disgusted by the fact that the Atomic Safety and
6 Licensing Board has recently refused to hear, or refused to accept the contentions, the new
7 contentions of New England Coalition, based solely on their lack of timeliness in filing. And yet,
8 in a few weeks, we'll have another one of these public meetings. We think that these decisions,
9 the decisions on uprate and on re-licensing, are based, and should be based on science and
10 engineering, and to have a show of soliciting the views of the citizens, many of us believe is a
11 sham and a travesty and I think that is why people have not shown up today, not because it's a
12 little bit rainy. (VS-N-1)

13
14
15 **Response:** *The Atomic Safety and Licensing Board rules on petitions and motions in
16 accordance with NRC regulations. The comment provides no new and significant information;
17 therefore, the comment will not be evaluated further.*

18 **A.1.3 Comments in Support of License Renewal at Vermont Yankee Nuclear Power 19 Station**

20 **Comment:** In closing, the Vermont Yankee has an important and crucial role to play in the
21 future of your state. It is both environmentally and economically appropriate to grant the plant a
22 license extension. We know that there is a wide array of support for the continued operation of
23 this plant, for the reasons I have articulated here today. Its essential economic benefits. Its
24 environmentally sound operations, and its important role as a component of the Vermont energy
25 portfolio. (VS-G-4)

26
27
28 **Comment:** I'm probably one of the few people here from Windham County that endorses the
29 re-licensing of Vermont Yankee, and its, and hopefully looks upon with the environmental
30 issues, favorably. (VS-I-1)

31
32 **Comment:** Vermont Yankee is a safe, well run plant and is a great asset to the area. It
33 provides good paying jobs, provides an infrastructure to attract new businesses to the area. To
34 help, and help eliminate tons of pollutants that would otherwise be put into the air that we
35 breathe. And I look forward to another 20 years of operation at Vermont Yankee, and hope that
36 the NRC will approve the license renewal application. (VS-Q-2)

37
38
39 **Comment:** Since 1972, when the Vernon plant came online, the State of Vermont has avoided
40 some 100 million metric tons of fossil fuel pollution and that's not an inconsequential
41 environmental effect of life, particularly given the realities of potential replacement power later in

1 this century with the candidates principally being natural gas and coal, both of which cause
2 gaseous greenhouse emissions into the environment.

3
4 Point two is the fact that we're in the midst of a global warming debate in this country. And in
5 my view, decisions ultimately made by regulatory bodies such as the NRC must factor in the
6 realities of global warming and the clear and present danger suggested by unnecessary and
7 unwanted ingestions of improper pollution into the Vermont and the environment of the country.
8

9 Now I have an old-fashioned view, having watched this plant grow, having been in the
10 legislature of Vermont when it was authorized many years ago and that view is not likely
11 accepted by all, maybe viewed as heresy in some quarters, but it speaks to the notion that this
12 plant has been both safe and environmentally friendly over these many years and in that context
13 in terms of its contribution or I should say noncontribution to pollution in this state, has helped
14 make Vermont a cleaner place in which to live. Now we're engaged in our state in a
15 conversation about energy as we speak and this meeting tonight is an exceedingly important
16 meeting on that subject. Now there are some interesting participants in this discussion and I'm
17 aware of one. The Sharon Academy up in Sharon, Vermont, senior class, this past winter, put
18 together an energy plan and they went up to Montpelier and introduced the plan before the
19 House Natural Resources Committee. We had opportunity in the Vermont Energy Partnership,
20 myself and Amanda Eiby, got to visit with the students and offer a critique of their remarkable
21 work, but what we learned is this. These students in their analysis of Vermont's energy future
22 included that nuclear energy is "clean, reliable, affordable and long lasting." And in opting for
23 renewal of the license issue before us tonight and beyond, to describe the "cultural negativity
24 about nuclear power as unjustified." That was the students' view in their words.
25

26 The point is this. People of all ages and perspectives are entitled to participate in this debate
27 and maybe, just maybe, our kids might teach us a lesson or two on this important subject.
28

29 Now this Commission will travel many miles before it sleeps on these issues. You begin the
30 process here in Brattleboro tonight and I for one wish you well in your profoundly important
31 work. (VS-V-1)
32

33 **Comment:** Vermont Yankee provides the needed infrastructure to attract other businesses to
34 this area, so that young adults like me will be able to stay in Vermont and enjoy the area we've
35 grown to appreciate. We need to make sure that there are jobs available here to support those
36 who wish to make this area our home. Vermont Yankee goes a long way in helping to secure
37 this future for Vermonters. Vermont Yankee should stand tall in this community. In addition to
38 providing the most reliable, clean and safe source of energy throughout New England, their
39 commitment to community involvement, youth development, and vast employment opportunities
40 makes them a crucial and highly beneficial component of this community. A renewal of their
41 operating license is integral to the continuation of the flourishing New England rural
42 communities that we've all come to love. (VS-Y-1)

Appendix A

1 **Comment:** It make sense to approve the license renewal. Entergy is committed to being
2 environmentally and socially responsible and has given a lot to this community. The financial
3 impact of not extending the license would affect Vermont negatively for many years. But more
4 importantly, the environmental impact of closing Vermont Yankee would pose even greater
5 threat. People have been told not to eat the fish out of the Connecticut River because of the
6 mercury levels. Well, Vermont Yankee and other nuclear power plants do not emit the poisons
7 or greenhouse gases which are slowly devastating our environment.

8
9 In addition, Vermont Yankee has a proven record of safe operations. Safety is and has been its
10 number one priority. Entergy is a business. Corporate Entergy is a business. And I can assure
11 you that Corporate Entergy would not put money into this license renewal process if they did not
12 believe that Vermont Yankee was a well run, well maintained, safe facility. Vermont Yankee is
13 committed to safe operation and if I did not believe this, I would not work there.

14
15 The environmental benefits of generating electricity without emitting greenhouse gases is a
16 wonderful legacy for our children and our grandchildren. I believe that we should approve the
17 license renewal process. (VS-Z-1)

18
19 **Comment:** Vermont Yankee's value to my home state can only become more valuable as time
20 goes on. As global warming becomes more and more destructive, we can remain an
21 environmentally friendly source of power with zero greenhouse gas emissions. As the world
22 energy market has become more competitive, we can continue to be a source of reliable,
23 economic, baseload power and that is why we encourage the NRC to renew Vermont Yankee's
24 license. (VS-AA-3)

25
26 **Comment:** Vermont Yankee has an important and crucial to play in the future of our state. It is
27 both economically and environmentally appropriate to grant the plant's license extension. We
28 know there's a wide array of support for the continued operation of this plant for the reasons I
29 have articulated here tonight: its essential economic benefits, its environmentally sound
30 operations and its important role as a component in the Vermont energy portfolio. (VS-BB-5)

31
32 **Comment:** Considering what I've presented, the worldwide recognition of the need for
33 additional nuclear power to help save our environment from the effluence of fossil fuels and to
34 help establish energy security and I would go on to say world peace, and considering the
35 existing guidance for granting license extensions, I would submit that it would be arbitrary and
36 in defiance of the rules and guidelines already in place to not grant Vermont Yankee an
37 operating license extension if all requirements established in 10 CFR Parts 51 and 54 are met.
38 (VS-EE-3)

39
40 **Comment:** You know, we're very proud of the impeccable environmental record that this plant
41 currently enjoys. We've had a sustained, safe, operational record with excellent environmental
42 stewardship. We pledge to continue that going forward. I'm also very proud of the people and

1 the processes we have in place that helps sustain that environmental performance. The scope
2 of the environmental audit conducted by the NRC was very broad. It touched on many subjects.
3 There were many people here, both NRC staff and the contractors. They were very
4 challenging. They were very rigorous. They were very thorough. And we've resolved the
5 issues and we're answering questions, many questions that came up. Again, I am satisfied that
6 the process will hold true and the questions will be answered. And if we can provide
7 satisfactory record and good answers to the questions that came up, the license should be
8 renewed. (VS-HH-1)

9
10 **Comment:** I truly believe that the only way to keep this amazing area that we live in
11 environmentally friendly, while producing 34 percent of Vermont's electricity is to continue the
12 safe and reliable operation of Vermont Yankee. (VS-MM-1)

13
14 **Comment:** I look at the overall impact of Vermont Yankee, environmentally, economically, and
15 very personally, and I've got some pretty significant observations over the last 30-35 years, and
16 I'm still waiting to identify one that is truly negative, truly negatively impacting all of us.
17 (VS-OO-1)

18
19 **Comment:** I haven't heard anything tonight that says there's anything new and significant.
20 Actually, I haven't heard anything new, and I haven't heard anything that sounds significant. We
21 have met all the requirements. We have exceeded many of them. We continue to meet the
22 environmental requirements. We continue to be, as John Dreyfus said, good stewards of our
23 environment. This plant emits no carbon dioxide. In fact it emits nothing that would be
24 considered a hazard. We don't emit radioactivity. And the people who have spoken tonight
25 have, as far as I can tell, not raised a substantive issue that identifies a new or significant
26 environmental impact that would be an obstacle to the renewal of this plant's license.
27 (VS-TT-1)

28
29 **Comment:** This letter is in support of renewing the operating license of the Vermont Yankee
30 nuclear facility. I believe the environmental benefits that Vermont Yankee provides are a crucial
31 part of ensuring that Vermont's landscape remains clean and pristine. It has not gone
32 unnoticed that Vermont has one of the lowest emissions ratings in the country, largely because
33 of our nuclear plant in Vernon.

34
35 Nuclear energy avoids the emissions of harmful toxins or other pollutants into the atmosphere
36 that other large power facilities, like coal or natural gas are guilty of. More and more
37 environmental scientists have concluded that nuclear energy is the only power source that can
38 help combat global warming.

39
40 Vermont and the entire New England region is in need of this plant, and as long as it maintains
41 its high level of safe operations, there is no reason why this plant should not remain online.

Appendix A

1 Vermont Yankee is a necessary component to this state's current and future energy portfolio,
2 and I hope that the NRC rules in favor of a license extension. (VS-YY-1)

3
4 **Comment:** It is estimated that by mid-century, the world will require a doubling of the current
5 worldwide energy demand of 14 terawatts of power. To achieve this demand will require the
6 equivalent of one 1,000 megawatt power plant going on line every day for nearly 38 years
7 (article from Discover, February 2005, pp 16-17 attached).

8
9 Although I assume the initial mandate to the NRC regarding environmental issues 30 to 40
10 years ago concerned the rather micro impact, that is of a limited area surrounding a nuclear
11 plant, certainly now the issue is equally the global concern of greenhouse gasses, foremost
12 carbon dioxide.

13
14 I am not an expert. I am a concerned citizen, concerned about the future of energy for the State
15 of Vermont, the future energy requirement for the world and the environmental impact the
16 sources of that energy will have.

17
18 Dr. Arthur Westing, a resident of Putney, VT, 10 miles up the road, is an expert. He has served
19 on the faculty of, or been a research fellow at several education institutions, including Harvard
20 University and the Stockholm International Peace Research Institute, served as the director of
21 the United Nations Environmental Programme project on "Peace, Security, & the
22 Environment," and is the author of many articles and books on the environment. At the
23 moment, Dr. Westing is in Sweden. He told me he wished he could be here to testify on the
24 importance of Vermont Yankee to the energy future of Vermont, and give his wholehearted
25 support to the relicensing. I am submitting an email from Dr. Westing to me giving me the
26 authority to give you two letters he has written on energy and environmental issues, as well as
27 his resume. His latest letter cites a British report on *The Role of Nuclear Power in a Low*
28 *Carbon Economy* which he uses to calculate the impacts shown on the following page.

29
30 Thank you for beginning this lengthy process for the relicensing of the Entergy Nuclear Vermont
31 Yankee Nuclear Plant. I hope the evidence shows a positive decision. (VS-ZZ-1)

32
33 **Comment:** The Vermont Yankee nuclear power plant plays an integral role in Vermont's
34 current energy portfolio, and must be part of our future. Vermont Yankee is a clean, emissions
35 free generating facility that provides stable, low-cost power to our state. These are all crucial
36 factors that businesses take into consideration when determining whether to remain here, or
37 relocate to Vermont. If Vermont Yankee goes off-line in 2012 where will we find replacement
38 power that is as clean and reliable? Vermont Yankee is critical to Windham County and
39 Southeast Vermont in particular. Currently, the plant and its contractors employ full time
40 approximately 600 men and women, and provides \$80 million to local Vermont businesses
41 through the purchase of goods and services.

1 Its clean power, sound operations, well paying jobs, and community participation and support
2 helps make the region a great place to live and work. For all of these reasons, I encourage the
3 Nuclear Regulatory Commission to extend the license of Vermont Yankee for another 20 years.
4 (VS-BBB-1)

5
6 **Response:** *The comments support license renewal at VYNPS. The comments are general in*
7 *nature and provide no new information; therefore, they will not be evaluated further.*

8
9 **A.1.4 Comments in Opposition to License Renewal at Vermont Yankee Nuclear Power**
10 **Station**

11
12 **Comment:** Because we have to live with the effects on the Connecticut River. We have to live
13 with the effects on our health, increased cancers. These are things that need to be looked
14 seriously, by the NRC, in this process. Not to mention the nuclear waste that's stored in our
15 backyard. It's bad enough that it's already there, it's at risk by an accident. It's at risk by
16 criminal act. (VS-L-3)

17
18 **Comment:** I do not believe that Vermont Yankee should be open one more day. We need to
19 close Vermont Yankee, not just think about extending licensing for 20 years. (VS-T-1)

20
21 **Comment:** I want to end with this notion of a vision. We envision a future of safety, prosperity
22 and health for all. People generate their own electricity in their own homes. Local energy
23 production is easy and accessible for all. We live in a world where safety, prosperity and human
24 health are what we value above all and it is something that we have to hold sacred for all of us,
25 not relicensing Vermont Yankee. (VS-W-4)

26
27 **Comment:** Until and unless we can ensure the health and safety of human beings, and of all
28 the environment, and all forms of life, we shouldn't even be using nuclear power. Let me
29 register my vote as not being in favor of a 20 year extension of Vermont Yankee. (VS-LL-7)

30
31 **Comment:** I think that the main issue is whether we are gonna let this outfit produce more
32 waste, contributing hot water to the rivers, and things that actually do contribute to the global
33 warming, and we need to decide whether it's suicidal, actually murderous, to allow these wastes
34 to be put on to future generations. (VS-QQ-3)

35
36 **Comment:** At what point do we take responsibilities for the damage we are doing with nuclear
37 energy and radiation? At what point do we say to ourselves, that we have gone too far, and that
38 this is not about profit or power or comfort but about safety for us, our world, and its future? Do
39 we want to risk another Chernobyl, or another Three Mile Island? Safety is defined as a state of
40 being safe, freedom from injury or damage, the quality of ensuring against hurt, injury, danger or
41 risk, or the state of being protected from harm. Do we want to risk our safety with toxic nuclear

Appendix A

1 byproducts that jeopardize our future generations and ourselves? Please. I hope you can take
2 a moment and hear me from my heart to your heart, and then act from that place.

3
4 Do our personal comforts, and your profits, justify the risk of proceeding with nuclear power,
5 particularly at this staging facility? (VS-UU-1)

6
7 **Comment:** I think this plant should be closed as soon as possible, and that planned into the
8 closing of it should be planning for jobs for the people that have worked so well at Vermont
9 Yankee. (VS-VV-3)

10
11 **Comment:** Maybe you could allow the reactor at Vernon, VT be shut down and ask Entergy to
12 decommission as was promised. The radioactive waste is a serious, unresolved problem.
13 Hazardous. No reason to increase our risk to cancer and catastrophe. No reason to approve
14 Entergy's plant. (VS-XX-1)

15
16 **Comment:** I deeply oppose the 20 year lease renewal and the uprate in power. Please
17 do not approve either of these. Please listen to the citizens you are supposed to represent and
18 protect. (VS-EEE-1)

19
20 **Comment:** Please respond to reason and our concern for the safety of our population, our
21 tourist industry, organic farms, our colleges, and our homes. All these things would be severely
22 and adversely affected by even a small release of nuclear radiation due to human error, aging
23 machinery or pipes, or terrorism. Please help us by closing and decommissioning this facility in
24 5 or 6 years as originally planned. Please help us reduce the risks to our health and safety
25 instead of increasing them. (VS-JJJ-5)

26
27 **Comment:** Please let our region become an example to the rest of the nation. Many regions
28 are growing in population and energy usage. Our region is stable and able to reduce our usage
29 through conservation. Please let us try. Please give us the incentive to try by closing this
30 nuclear plant by 2012. Please stop saying that we need nuclear power and there is not a
31 cleaner, safer solution. This is untrue in a region like ours where the population is stable, highly
32 educated, and extremely concerned about the risks of aging nuclear power plants and poorly
33 stored, highly radioactive "spent" fuel rods. Please listen to our concerns and respond by
34 closing down this plant as planned. (VS-JJJ-7)

35
36 **Comment:** I am writing to express my grave concern about the re-authorization of the Vermont
37 Yankee Nuclear Power Plant. I want the plant closed. Cheap, renewable and alternative
38 sources of power need to be supported by the government. Nuclear power is not the answer. I
39 do not want to be irradiated. Nor my rivers, farmlands, children. I am a fisherman, an organic
40 gardener living a wholesome rural lifestyle. You may not know what this lifestyle is like. It is
41 about connecting with the land, with the seasons, with the ways of the earth. I am honored to
42 work with children with special needs. Don't you realize that all these environmental insults

1 cause diseases in our children? Why do you think so many have diseases like autism, mental
2 retardation, cancer? It is no coincidence, our modern practices of poisoning earth, air and water
3 have made us sick, literally.

4
5 We must learn to live with greater integrity. Please stop this nuclear madness. There is no safe
6 way to store the spent fuel rods. There is no safe way to mine the uranium. There is no safe
7 level of radiation sent down our rivers and streams. There is many other ways to address
8 energy needs. Please help us protect our beautiful valley from further harm. Close the plant.
9 Now. (VS-NNN-1)

10
11 **Response:** *The comments oppose license renewal at VYNPS. The comments are general in
12 nature and provide no new and significant information; therefore, they will not be evaluated
13 further.*

14
15 **A.1.5 Comments in Support of Nuclear Power**

16
17 **Comment:** We've had no national energy policy. We're talking about 20 years down the road.
18 That's short-term, 40 years down the road is short-term. I started out dealing with energy in
19 1962, and one of my students made a hydrogen fuel cell, that's how I got enlightened in this
20 thing. 1962, that's a lot of years ago. And I've been involved in learning about energy for all
21 these years. All right, now, what's going to happen? I really feel we not only need to re-license
22 Vermont Yankee, but we need more nuclear power plants throughout the country. (VS-I-3)

23
24 **Comment:** In surfing the web recently, I found an interesting article. It was an excerpt from
25 Physics Today. It was dated June 4th. It states, "Some two dozen power plants are scheduled
26 to be built or refurbished during the next five years in Canada, China, several European Union
27 countries, India, Iran, Pakistan, Russia, South Africa. In the U.S. and U.K., government
28 preparations are underway that may lead to 15 new reactor orders by 2007. The new interest in
29 civilian nuclear energy results from attempts to reduce carbon dioxide emissions and increasing
30 concerns about energy security." (VS-EE-2)

31
32 **Response:** *The comments support nuclear power. The comments are general in nature and
33 provide no new and significant information; therefore, they will not be evaluated further.*

34
35 **A.1.6 Comments in Opposition to Nuclear Power**

36
37 **Comment:** We need to be forward thinking. And my sense is that nuclear power is kind of
38 passe. We've all looked at this. We see what the risks are, and there are huge chunks in
39 Russia that have been, in their terms, withdrawn from public use, for the foreseeable future
40 because of an accident. And, as far as I know, nobody has repealed Murphy's Law. So I'd like
41 to suggest that we be responsible and that we get this message today that we are asking all of
42 you to look beyond what has become an old mantra, and make use of the truly up-to-date

Appendix A

1 technology, that could allow all of us to feel good about living our lives without adding to the
2 environmental burdens. (VS-K-2)

3
4 **Comment:** Nobody knows what's going to happen in the future. There are people who believe
5 that this plant is safe. There are other people who believe that it's not safe. There's no way to
6 determine this, I guess. Time will tell, but the criteria that I'd like to present is what happens for
7 each side if that side is wrong? If the people who believe the nuclear power plant is safe and
8 they're wrong, the land becomes polluted, thousands of people die. This will be an effect that
9 will be in effect for hundreds of thousands of years. If the people who believe that the nuclear
10 power plant is unsafe and they're wrong, what will be the effect? The effect will be that there
11 will be other sources of power, conservation and nobody gets hurt. So since nobody on the
12 planet knows which side is correct, I think that using this criteria might guide us in the right
13 direction. (VS-FF-1)

14
15 **Response:** *The comments oppose nuclear power. The comments are general in nature and
16 provide no new and significant information; therefore, they will not be evaluated further.*

A.1.7 Comments Concerning Ecology

16
17
18 **Comment:** Issues 18, 20, 23, 24, and 28 through 30 (Thermal plume barrier to migrating fish,
19 Premature emergence of aquatic insects, Losses among organisms exposed to sublethal
20 stresses, Stimulation of nuisance organisms, Entrainment, Impingement, and Heat shock) As
21 we understand it, these issues are associated with intake structures and thermal discharge
22 issues which require a NPDES permit. The requirements of the Clean Water Act and the
23 NPDES permit will provide assurance that the impacts of permitted intake structures and
24 discharges meet the applicable federal and state requirements. It would be helpful, however, to
25 have some limited site specific review of these issues. For example, have recent scientific
26 studies regarding intake structure and thermal impacts on migrating fish species and aquatic
27 organisms, in similar habitats or within this region, led to new knowledge applicable to these
28 issues? Are there any organisms present in the Vernon area which are particularly susceptible
29 to sublethal stresses or heat shock? Are there any specific study protocols recommended for
30 determining the impacts of intake and discharges on species present in the affected regions of
31 the Connecticut River? (VS-AAA-1)

32
33
34
35 **Comment:** Specifically, I've got concerns about the effect on the Connecticut River and on the
36 fish and other wildlife that live in and on the river. According to the environmental report drafted
37 for this license renewal process, Entergy states that it withdraws water to cool the reactor, from
38 the river, at a rate of up to 360,000 gallons per minute when using once through cooling. The
39 majority of this water is discharged back into the river at temperatures that can reach 100
40 degrees Fahrenheit, at the point of discharge. The recently issued NPDES Permit Amendment,
41 which New England Coalition is appealing, allows for Vermont Yankee to increase the
42 temperature of the river by an additional one degree Fahrenheit over what it was previously

1 allowed. The environmental impact of this extra thermal waste discharged into the river, is
2 potentially significant. Temperature is critical for American Shad and other fish species,
3 particularly during migration and spawning.

4
5 Even this one degree increase in water temperature may adversely effect the Shad and other
6 species, reducing their population in the river system. In its report, however, Entergy does not
7 assess these impacts. Entergy's conclusion that the impact on the environment is small, is
8 based on the fact that the discharge complies with state and Federal pollution limits. There's no
9 further discussion of what effect another 20 years of increased thermal discharge will have on
10 the eco-system. Whether or not the discharge from Vermont Yankee is in compliance with its
11 State and Federal permits, Entergy should be required to take a hard look at, and assess a
12 direct, indirect and cumulative impacts on the river eco-system of 20 more years of increased
13 thermal discharge. (VS-E-1)

14
15 **Comment:** I am concerned that the continued release of heated water into the Connecticut
16 River from Vermont Yankee is adversely affecting aquatic life in the river. Several school and
17 citizen awareness groups have measured temperatures as high as 10 degrees Fahrenheit
18 warmer below the plant than above, and it is my understanding that only 1-2 degrees Fahrenheit
19 is allowed. Since this has continued for many years, I fear that plant officials do not plan to
20 stop this. I ask that you please address this ongoing problem in your considerations of whether
21 or not to extend the license of the Vermont Yankee Nuclear Power Plant. (VS-CCC-1)

22
23 **Comment:** The increase in the river temperature needs to be fully analyzed for the affects over
24 the new 20 year lease period. This raise could seriously affect the environment. (VS-EEE-3)

25
26 **Comment:** Please save the Connecticut River from overheating. Many of us are also
27 concerned about the hot water that is being released into the Connecticut River. Studies have
28 shown that the current levels of hot water are harmful and with the 20% "uprate" the
29 temperatures are rising to much higher levels. Why do you want to destroy the ecology of this
30 beautiful river? (VS-JJJ-6)

31
32 **Response:** *The comments relate to aquatic ecology issues. Some of the comments specifically
33 relate to the potential impact on aquatic biota of the heated water that will be released from
34 VYNPS when once through cooling is used. This issue will be evaluated and addressed in
35 Section 4.7 of the SEIS. In addition, heat shock, entrainment, and impingement will be
36 evaluated and discussed in Chapters 2 and 4 of the SEIS.*

37
38 **Comment:** As an ecologist, I'm compelled to point out that environmental impacts are multi-
39 variate impacts. They are not generic. Life is not generic. And although biological systems are
40 resilient and they recover from damage, radiation exposure causes genetic impacts that will
41 change life forever. Genetic damage can be passed on to our offspring and theirs. It can

Appendix A

1 change biological communities forever. I submit that the very idea of a GEIS is sheis. In NRC's
2 Executive Summary of their Generic Environmental Impact Statement, which I consider an
3 oxymoron. (VS-M-1)

4
5 **Comment:** I ask NRC to revisit the permitting of this defacto LLRW dumping ground, and
6 consider the impact of nuclides in river sediments which are the spawning beds for American
7 Shad and Salmon. I learned from VT Dept. of Health employee Larry Crist that Cobalt 60 and
8 Cesium 137 levels have been found in river sediments. Embryonic exposure to these isotopes
9 by fish or other aquatic biota have not been sampled or quantified. Laboratory experimentation
10 might reveal the potential for ecological impact. (VS-HHH-2)

11
12 As an organic farmer with livestock and vegetable crops, I consider the radiation emissions from
13 the plant's operation to be one more degrading influence in the environment, added to a number
14 of others, that affects both crop plants and livestock raised in this area. It is difficult to quantify
15 but I am confident from reading about the experiences of farmers in the area of this plant and
16 others that the radiation stressor exists. For these reasons, I strongly oppose the relicensing of
17 the Vernon nuclear plant beyond 2012. I am willing to use less electricity if the license
18 extension is denied, and to pay more for it. (VS-LLL-2)

19
20 **Response:** *The comments relate to the effects of radiation from plant effluents on biota other
21 than man. The effects of radiation from VYNPS effluents on biota is not one of the 92 issues
22 evaluated by the NRC for license renewal. The levels of plant effluents are limited by radiation
23 standards for human exposure, and those limitations are generally considered to be sufficiently
24 protective of biota other than man. The NRC staff will review the reports of the environmental
25 radiological monitoring programs conducted by Entergy and the Vermont Department of Health
26 for the last several years to ensure that the levels of radioactive concentrations in the
27 environment are within expected levels. Entergy's environmental radiological monitoring
28 program will be discussed in Section 2.2.7 of the SEIS.*

29
30 **Comment:** Issues 43 and 46 (Bird collisions). The Agency is interested in bird mortality rates.
31 In particular, the Agency is interested in whether the numbers and species of birds which have
32 experienced mortalities with the cooling towers and the power lines are an issue of concern.
33 This concern is also applicable to the met towers on site. (VS-AAA-2)

34
35 **Response:** *The comment relates to Category 1 terrestrial ecology issues. Bird collisions with
36 power lines will be discussed in Section 4.2 of the SEIS.*

37 38 **A.1.8 Comments Concerning Threatened and Endangered Species**

39
40 **Comment:** Issue 45 (Power line right of way management). The Agency is interested in this
41 issue as it relates to rare, threatened and endangered species which may be present in

1 proximity to the power lines. In addition, the Agency is interested in preserving undisturbed
2 riparian buffers in areas of surface water or stream crossings. (VS-AAA-3)

3
4 **Response:** *The comment relates to threatened and endangered species and terrestrial*
5 *resources, particularly riparian buffers. The NRC conducts an independent analysis of the*
6 *impacts of license renewal on aquatic and terrestrial resources including threatened and*
7 *endangered species, flood plains, and wetlands. The occurrence of Federally- and State-listed*
8 *species on the VYNPS site and associated transmission line rights-of-way will be discussed in*
9 *Sections 2.2.5 and 2.2.6 of the SEIS. An analysis of impacts to these listed species is*
10 *presented in Section 4.6 of the SEIS. The environmental impacts of power line rights-of-way*
11 *management on flood plains and wetlands will be discussed in Section 4.2 of the SEIS.*

12
13 **A.1.9 Comment Concerning Surface-Water Quality, Hydrology, and Use**

14
15 **Comment:** I am an ecologist and mother living in the 10-mile EPZ, downstream of the VT
16 Yankee Nuclear Reactor. I would like the NRC to expand the scope of the EIS to examine the
17 consequences of the surface spreading of radioactive septic waste and stockpiling of tons of
18 contaminated soil on fields adjacent to the Connecticut River. I think it is important to consider
19 the possibility that some radionuclides wash into the river in heavy rains and spring melt. A
20 1991 study of the suitability of the VY site for low level radioactive waste commissioned by the
21 VT Low-Level Radioactive Waste Authority, and conducted by Batelle Company, concluded that
22 it was not a promising LLRW site due to short groundwater travel time, a shallow groundwater
23 depth, seeps discharging to the riverbank and springs discharging south of the site, poor
24 drainage in parts of the site, jurisdictional wetlands on the site, with one apparently significant
25 wetland under VT wetland law, potential liquification of some soils on the site during an
26 earthquake, and the need to remove and replace existing soils to meet the regulatory
27 requirement to enhance the retardation of the movement of radionuclides. (Battelle. 1991. Site
28 Characterization Data Report for the Vernon/VT Yankee Site Volume I - The Report. Wagner
29 Heindel and Noyes, Inc.) (VS-HHH-1)

30
31 **Response:** *The comment is related to Category 1 surface-water quality, hydrology,*
32 *groundwater, and water use issues evaluated in the GEIS. These issues will be addressed in*
33 *Chapter 2 of the SEIS. The comment regarding soil liquification is addressed as a design basis*
34 *issue in Section 15 of the Appendix.*

35
36 **A.1.10 Comments Concerning Human Health Issues**

37
38 **Comment:** I'm raising a child here. I hear that cancer rates near the plant are higher than in
39 other places. There's some studies. I hear that Strontium-90 turns up in baby teeth. So this is
40 an experimental thing and we're being experimented on. I don't think it should continue. (VS-C-
41 2)

Appendix A

1 **Response:** *The comment concerns Strontium-90 in baby teeth. In 2000, a report entitled,*
2 *"Strontium-90 in Deciduous Teeth as a Factor in Early Childhood Cancer," was published by the*
3 *Radiation and Public Health Project. The report alleges there has been an increase in cancer*
4 *incidence due to strontium-90 released from nuclear power facilities. Elevated levels of*
5 *strontium-90 in deciduous (baby) teeth was claimed in the report as the evidence for the*
6 *increase in childhood cancer. This study has been largely discredited by the scientific*
7 *community for a number of reasons including the lack of controls, small sample sizes, and the*
8 *lack of environmental sampling and analysis (see [http://www.nrc.gov/reading-rm/doc-](http://www.nrc.gov/reading-rm/doc-collections/fact-sheets/tooth-fairy.html)*
9 *collections/fact-sheets/tooth-fairy.html).* The assessment of human health impacts in the SEIS
10 will determine if the facility is currently limiting and will continue to limit radiological releases to
11 within Federal limits, which are considered protective of the public. The comment provides no
12 new and significant information; therefore, it will not be evaluated further.

13
14 **Comment:** I would like to submit the BEIR 7 Report of the National Academy of Sciences. The
15 biological effects of ionizing radiation. The National Academy of Sciences told us that, in fact,
16 there is not a threshold dose phenomenon. The GEIS presupposes a threshold dose
17 phenomenon. Therefore, it claims that it does make sense to normalize early fatalities. That's
18 based on the BEIR 5 Report, not BEIR 7. I would like to suggest that you recalculate using the
19 conclusions of BEIR 7. What does BEIR 7 say about radiation risks to workers under exposure
20 of one REM per year. That was another little nugget in the Appendices of the GEIS. I'm just
21 curious. I would love to see that calculated. I think your Appendix E.4.1.2 is faulty, also based
22 on BEIR 7, because it's based on the notion of a threshold of effects. That does not seem to be
23 the case. Your Appendices E.8.2, these Appendices show the tables and the calculations
24 behind a lot of their conclusions in the GEIS.

25
26 Quantities and units, assumes non-stochastic effects will not occur if the dose equivalent from
27 internal and external sources combined, is less than 50 rems or fewer in a year. This, too,
28 contradicts the conclusions of the BEIR 7 Study. Your cost estimates also use BEIR 5, not 7,
29 and the costs are based on 1980 costs, or maybe they were updated to 1994, 12 years ago.
30 (VS-M-6)

31
32 **Comment:** In Appendix E, I think it was Page E-43, we talk about ALARA limits. That stands
33 for As Low As Reasonably Achievable. These are radiation exposure limits for workers. And
34 they were derived using analytic techniques to identify the approximate point at which the cost
35 of providing additional protection, would exceed the risk averted. But what dollar value do you
36 place on a workers life? I'm just curious. I guess I'll conclude with saying that it seems to me
37 that your Generic Environmental Impact Statement is fatally flawed, in many ways.
38 Recalculations of early fatalities and latent fatalities, are biased. They are based on old
39 information, BEIR 5, not BEIR 7, and I humbly request that you recalculate them based on the
40 most currently available knowledge on the effects of radiation. Particularly, low level radiation.
41 (VS-M-9)

1 **Comment:** I have a question that comes up, that I didn't ask in the beginning of the meeting,
2 which is, on what do you base radiation exposure? Is it the ICRP? International Committee on
3 Radiological Protection? Or is it on the European, on the European Committee on Radiation
4 Risk? (VS-O-9)

5
6 **Comment:** In July of 2005, and this has already been brought up tonight, the U.S. National
7 Academy of Sciences released its latest biological effects of ionizing radiation report, otherwise
8 known as BEIR VII. Basically what it pointed out was that no amount of radiation can be
9 considered safe. How ethical and moral is it then to site an elementary school directly across
10 the street from Vermont Yankee? Children are far more vulnerable to radiological damage than
11 adults. (VS-LL-4)

12
13 **Comment:** Regarding the Generic Environmental Impact Statement (the GEIS), I would like to
14 request that you consider the National Academy of Sciences Biological Effects of Ionizing
15 Radiation VII report new and significant information and recalculate early fatalities, latent
16 fatalities and any injury projections based on this information.

17
18 Herewith and in these comments I formally petition the NRC for a 2.802 rulemaking to reconcile
19 with current science, in particular, but not exclusively, The National Academy of Sciences BEIR
20 VII Report, the Part 100 tables in 10 CFR for radiation exposure. BEIR VII was published in
21 2005. Throughout the Generic Environmental Impact Statement you cite BEIR V, which came
22 out in 1990. This is not acceptable. If you insist on using a Generic EIS, an oxymoron at best,
23 you must at least reference the latest and best available science in your calculations of risk and
24 consequences.

25
26 "In 1990, the NAS estimated that the risks of dying from cancer due to exposure to radiation
27 were about five percent higher for women than for men," said Dr. Arjun Makhijani, president of
28 the Institute for Energy and Environmental Research. "In BEIR VII, the cancer mortality risks for
29 females are 37.5 percent higher. The risks for all solid tumors, like lung, breast, and kidney,
30 liver, and other solid tumors added together are almost 50 percent greater for women than men,
31 though there are a few specific cancers, including leukemia, for which the risk estimates for men
32 are higher." (Summary estimates are in Table ES-1 on page 28 of the BEIR VII report
33 prepublication copy, on the Web at <http://books.nap.edu/books/030909156X/html/28.html.>)

34
35 Unlike the 1990 NAS report, BEIR VII estimates risks for cancer incidence rates as well as
36 mortality and also provides detailed risk figures according to age of exposure for males and
37 females, by cancer type. This is a great advance over the previous report. The BEIR VII report
38 has thoroughly reviewed available human and animal cancer data and scientific understanding
39 arrived at using cellular level studies. Cancer risk incidence figures for solid tumors for women
40 are also about double those for men.

Appendix A

1 The BEIR VII report estimates that the differential risk for children is even greater. For instance,
2 the same radiation in the first year of life for boys produces three to four times the cancer risk as
3 exposure between the ages of 20 and 50. Female infants have almost double the risk as male
4 infants. (Table 12 D-1 and D2, on pages 550-551 of the prepublication copy of the report, on
5 the Web starting at <http://books.nap.edu/books/030909156X/html/550.html>).--IEER July 2005.
6 (VS-HHH-3)

7
8 **Comment:** In the GEIS you mention: "Because of a threshold dose phenomenon, it does not
9 make sense to normalize early fatalities." I believe you reference BEIR V and other sources. It
10 is my understanding that the BEIR reports never proved the existence of a threshold dose
11 phenomenon, and the current BEIR VII report explicitly concludes that there is no evidence that
12 such a phenomenon exists. Therefore the NRC's attitude that public or worker exposure to
13 radiation from nuclear power plants can be "below regulatory concern" MUST be re-examined,
14 and revised. I call upon you to suspend the license renewal process for VT Yankee until such a
15 time as this re-examination and recalculation of all tables in the GEIS related to radiation
16 exposure and projected consequences is completed. (VS-HHH-5)

17
18 **Comment:** Third, the actual human health impacts of an accident with radiation release should
19 be recalculated using assumptions from BEIR VII, not an arbitrary and false threshold dose
20 model. The GEIS reports radiation risks to nuclear workers of 1 REM/year based on BEIR V.
21 These should be recalculated using BEIR VII and the latest science in medical journals which
22 include exposure to internal radiation sources--alpha and beta emitters, via inhalation or
23 ingestion. Recent work on people exposed to depleted uranium might be enlightening. In the
24 Appendices of the GEIS, Appendix E.4.1.2. is faulty in that it is based on the notion of a
25 threshold dose. This should be entirely re-done in the light of BEIR VII which definitively states
26 there is no evidence of such a threshold dose. The calculations on page E-39 in the
27 appendices assumes non-stochastic effects will not occur if the dose equivalent from internal
28 and external sources combined is less than 50 REM in a year. This too must be recalculated in
29 the light of BEIR VII.

30
31 RE page E-43: ALARA limits were derived using analytic techniques to identify the approximate
32 point at which the cost of providing additional protection would exceed the cost consequences
33 of the risk averted. If BEIR VII is correct, any exposure to extra radiation from nuclear reactors
34 is costly in terms of human health, and the consequences are cumulative. What dollar value
35 does the NRC place on worker's lives? (VS-HHH-7)

36
37 **Response:** *The comments relate to the NRC's radiation protection standards. NRC and the
38 Environmental Protection Agency (EPA) consider available information and recommendations
39 from a number of sources in the development and periodic reassessment of radiation standards
40 in the United States. Those sources include the National Commission on Radiation Protection
41 and Measurements (NCRP), International Committee on Radiation Protection (ICRP), National
42 Academy of Sciences, and others.*

1 In spring 2006, the National Research Council of the National Academies published, "Health
2 Risks from Exposure to Low Levels of Ionizing Radiation, Biological Effects of Ionizing Radiation
3 (BEIR) VII Phase 2." A pre-publication version of the report was made public in June 2005.
4 The major conclusion of the report is that current scientific evidence is consistent with the
5 hypothesis that there is a linear, no-threshold dose response relationship between exposure to
6 ionizing radiation and the development of cancer in humans. This conclusion is consistent with
7 the system of radiological protection the NRC uses to develop its regulations. Therefore, the
8 NRC's regulations continue to be adequately protective of public health and safety and the
9 environment. None of the findings in the BEIR VII report warrant changes to the NRC
10 regulations. The BEIR VII report does not say there is no safe level of exposure to radiation; it
11 does not address "safe versus not safe." It does continue to support the conclusion that there is
12 some amount of cancer risk associated with any amount of radiation exposure and that the risk
13 increases with exposure and exposure rate. It concludes that the risk of cancer induction at the
14 dose levels in NRC's and EPA's radiation standards is very small. Similar conclusions have
15 been made in all of the associated BEIR reports since 1972 (BEIR I, III, and V). The BEIR VII
16 report does not constitute new and significant information; therefore, the comments will not be
17 evaluated further.

18
19 The petition for rulemaking made by Sally Shaw, in comment VS-HHH-3, has been forwarded to
20 the Office of the Secretary for the Commission for appropriate action.

21
22 **Comment:** I believe we have to take responsibility right now for the effect that we are having
23 because we are already seeing its effects upon our children and grandchildren. We know that
24 mercury in the ponds in the fish that we happily go out and catch on a Sunday already in
25 Vermont, we can't allow the children to eat more than four ounces a month and we have seen
26 the effects of children who have more than that. The illnesses and cancers and neurological
27 damage already caused by different kinds of pollutants in Vermont is staggering. We certainly
28 don't need any more. (VS-B-5)

29
30 **Comment:** But what I want the NRC to weigh heavily, it's the waste issue, environmentally, and
31 the cancer issue. Are there cancer clusters around nuclear power plants? Are there elevated
32 rates of breast cancer around nuclear power plants? I read reports that say that there are and it
33 is unfair to experiment with a population when these are questions hanging in the air. It's
34 unconscionable. (VS-C-4)

35
36 **Comment:** As you know, the state of Vermont posts radiation measuring devices, TLDs,
37 around the plant perimeter. And the state reports that three times in the last decade or so, that
38 the state limit of 20 millirem per year has been exceeded at the fence line. And we took a quick
39 look at those reports for those three years, and then also at a study, I believe, done by Duke
40 Engineering for Vermont Yankee, and found that the TLDs in the same sector were the ones

Appendix A

1 that read high in each of those instances. And, you know, this is not an anomaly for a bad
2 detection instrument, because they are changed out quarterly, and the excess is the average
3 over a year.

4
5 The other thing that we noticed is that the only other abnormally high reading, that occurred in
6 each of those three instances, was at the interior of the Vernon Elementary School. The other
7 thing that we noticed was that the turbine hall and the offending TLD, and the elementary
8 school, line up axially. There's a straight line to be drawn from the turbine hall, to the one
9 monitor that read high, to the elementary school reading high.

10
11 The state folks thought this might be an artifact of excess of radon in the school. But, of course,
12 we don't generally use TLDs to go chasing radon. The other thing that we noticed, was that
13 there was no correlation between the measured amount of radon in the school, for those
14 instances, and the high TLD readings. From an amateur science point of view, we believe
15 there's enough here to warrant real investigation. I should point out to you that we have not
16 looked for correlation on weather or meteorological conditions, but it might well be a
17 consideration that these high readings are a result of temperature inversion and downdraft from
18 the release stack. (VS-D-2)

19
20 **Comment:** Here at Vernon, as in the rest of the country, it's part of the operating license that
21 the Nuclear Regulatory Commission gives the companies that operate these power plants, as
22 part of that process and part of that license, they're allowed to routinely emit radioactive
23 releases, in both the air and water. I'm sure everybody in this room knows that. Long-term,
24 that's a problem. We'd like to know how much has been released by the operation of Vermont
25 Yankee, year-to-date, or operational lifetime to date. And how much is projected under routine
26 operational conditions? How much is going to be released over the proposed license
27 extension? (VS-F-3)

28
29 **Comment:** They state that among the 150 million people who live within 50 miles of a U.S.
30 Nuclear Power Plant, I prefer to call it a reactor, not a plant. About 30 million who will die of
31 spontaneous cancers. That's one in five people, by their calculations. And they say that since
32 we can't prove a one of them was caused by radiation, therefore the NRC doesn't have to worry
33 about them, note bene. They admit that five calculated fatalities associated with nuclear
34 powered induced cancers will occur. So I ask which one of us, or our children, living within 50
35 miles, will die of radiation induced cancer, over the lifetime of this plant. That's the cost of
36 progress. Tough luck, sucker. Most of the people who die of radiation induced cancers, will live
37 within ten miles. Thus, there's a very good possibility that we will know, we in this room, will
38 know some of them. At last count, my husband and I counted, between us, 28 people we know
39 who have died or are living with cancer, in our extended community. Can I prove that their
40 cancers are radiation related? No. Therefore, the effects, the impact of these deaths, on our
41 life, is considered by the NRC to be of small significance. (VS-M-2)

1 **Comment:** Richard Monson of the Harvard School of Public Health stated, quote, the scientific
2 research base shows that there is no threshold below which low levels of ionizing radiation can
3 be demonstrated to be harmless or beneficial. I'm going to repeat that. There is no threshold
4 below which low levels of ionizing radiation can be demonstrated to be harmless or beneficial.
5 The health risks, particularly the development of solid cancers in organs, rise proportionately
6 with exposure. At low doses of radiation, the risk of inducing solid cancers is very small. As the
7 overall lifetime exposure increases, so does the risk. Every nuclear reactor emits small
8 amounts of radiation. Even, supposedly, zero-emission reactors. (VS-O-4) (VS-SS-2)
9

10 **Comment:** There's an article about Vermont Yankee from 1980, about the town of Vernon, and
11 how much anxiety--1980, we're talking about. How much anxiety exists in the communities
12 around this plant. And not only does this plant--let's say it--causes cancer, causes cancer of
13 unborn, yet unborn children. Not only does it cause cancer, it causes heart attacks for the
14 anxiety that people live with. (VS-S-1)

15 **Comment:** Secondly, radiation monitoring is now inadequate and will be inadequate. In
16 Western Massachusetts, the Department of Health is doing no radiological monitoring.
17 (VS-X-1)

18 **Comment:** Thirdly, health monitoring is inadequate. And it will be inadequate. (VS-X-2)

19 **Comment:** Vermont Yankee routinely emits radioactive material into the air, soil and water.
20 Presumably these emissions are permissible. But who knows? Permissible emissions are not
21 the same thing as safe emissions. (VS-LL-3)

22 **Comment:** Let me give you a quick review of some results from accidents at other nuclear
23 facilities.

24 A 400 percent increase in leukemia incidents in the population living downwind of the Pilgrim
25 nuclear power reactor in Massachusetts in the first five years after fuel was known to have
26 leaked excess radioactivity.

27 Three to 400 percent increase in lung cancer in the general population within the plume of the
28 Three Mile Island accident.

29 Six to 700 percent increase in leukemia in the general population within the plume of Three Mile
30 Island.

31 Eight thousand percent increase in thyroid cancer in Belarus children living near Chernobyl,
32 reported six years after the meltdown.

Appendix A

1 Further effects found in victims of the Chernobyl accident, less than 10 years after the meltdown
2 include the following. A 500 percent increase in thyroid cancer in children in Ukraine. A 75
3 percent increase, incidence of heart disease.

4
5 A 200 percent increase in respiratory and digestive disease. A 200 percent increase in birth
6 defects.

7
8 Among atomic workers, a 250 percent increase in all cancers. And finally, a 1200 percent
9 increase in all cancers exist around the Sheffield [sic] reprocessing facility in England.
10 (VS-LL-5)

11
12 **Comment:** 1. Subjects to include in a supplement to the GEIS for Vermont Yankee and
13 analyze in depth:

14 1.5 Extent of groundwater contamination on (and beneath) site, including, but not limited to
15 tritium contamination.

16 1.6 Extent of any off-site groundwater contamination, including, but not limited to tritium
17 contamination of drinking water wells and other off site ground water locations. (VS-WW-2)

18
19 **Comment:** there is ample evidence in the publicly available records for Vermont Yankee that
20 numerous spills occurred during operations under the original license and the facility engaged in
21 shoddy record keeping to document the extent and location of such events.¹ Thus, including a
22 complete inventory and analysis of all the items in the list within the scope of the EIS for
23 Vermont Yankee license renewal makes good practical sense based on the historical record for
24 this licensee. Further, as the NRC is aware, tritium contamination--which is a part of the
25 historical record for this facility--has become a major issue at reactor sites across the country.
26 Thus, on and off site tritium contamination due to past (and continued) operation of the Vermont
27 Yankee Nuclear Power Station should be thoroughly investigated, including all sources and
28 pathways on and off site, to assure if the NRC renews VY's license it will not permit continued
29 radioactive contamination of groundwater. (VS-WW-5)

30
31 **Comment:** In July of 1975, did faulty valves discharge radioactive water into the Connecticut
32 River and Atlantic fisheries? In 1995 did faulty fuel assemblies interfere with valve closing? An
33 adequate scope of environmental assessment will require an extensive period for assessing
34 contamination levels in air, water, soil, plant, animal tissues. Adequate scope will establish
35 radiation monitoring in a 100-mile radius of the Vernon reactor in Massachusetts, New
36 Hampshire and Vermont, on an ongoing basis for the remainder of the license period.
37 (VS-FFF-3)

38
39 **Response:** *The comments relate to potential health effects from radiation exposure. The GEIS*
40 *concluded that public radiation exposure is a Category 1 issued based on the assumption that*
41 *the plant continues to meet NRC and EPA dose regulations. As part of its search for new and*
42 *significant information, the NRC staff will review recent results from the licensee's effluent and*

1 *environmental radiological monitoring programs. In addition, the NRC staff will review recent*
2 *reports from the environmental radiological monitoring program conducted by the Vermont*
3 *Department of Health (VDH) around Vermont Yankee. The staff regards information from the*
4 *effluent and environmental reports over the last several years as the best source of information*
5 *to use to assess the expected levels of radiological impact during the license renewal period.*
6 *The radiological effluent and environmental monitoring programs and the impacts from*
7 *VYNPS's radiological effluents will be discussed in Chapters 2 and 4 of the SEIS.*

8
9 *In 1990, the U.S. Congress requested that the National Cancer Institute study cancer rates in*
10 *the areas surrounding nuclear facilities, such as nuclear power plants, to determine if there are*
11 *detrimental effects on the population. VYNPS was included in the study. This extensive report*
12 *found no evidence that nuclear facilities may be linked causally with excess deaths from*
13 *leukemia or from other cancers in populations living nearby. The comments concerning cancer*
14 *provide no new and significant information; therefore, they will not be evaluated further.*

15
16 **Comment:** The company uses an oxidizer called glutaraldehyde in small parts, two-tenths of a
17 part per million. It triggers asthma. Two-tenths of a part per million exceeds California's
18 occupational exposure standards. In all the regulation, we don't find any place that the
19 regulation anticipates spray. It anticipates fumes. It anticipates skin contact, but I don't think
20 any regulator ever figured you would spray people with this stuff. The glutaraldehyde plus,
21 surfactant, anti-rust compounds, other pesticides, other biocides, and fluorine and bromine
22 compounds are used by the company. The water gets circulated in the cooling towers. It flows
23 out in spray. It goes up to a mile downwind. And I just want to point out that in terms of
24 concentrations as those droplets travel, they dry and we don't know what the concentrations are
25 when they land on the skin, but unless it's quantified, we have to assume that it's toxic. Unless
26 it's quantified, we have to assume that there are health effects and those things need to be
27 measured in the Village of Vernon and across the river in Hinsdale. (VS-DD-10)

28
29 **Response:** The comment relates to potential releases of chemicals in the cooling tower drift
30 from Vermont Yankee. Specifically, the comment relates to a chemical called glutaraldehyde
31 that Entergy added to the cooling water as part of a commercially available biocide mixture.
32 Entergy discontinued use of the glutaraldehyde in the fall of 2005. The use of chemicals in the
33 cooling water at Vermont Yankee is regulated by air and water permits, such as the National
34 Pollutant Discharge Elimination System permit, issued by the Vermont Agency for Natural
35 Resources. The NRC staff will review those permits and discuss the environmental impacts of
36 chemical releases in the cooling tower drift in Chapters 2 and 4 of the SEIS.

37
38 **Comment:** Issue 89 (Water Quality) The Agency believes that groundwater and surface water
39 quality are issues of great importance to Vermonters and should be subject to a site specific
40 analysis. With respect to groundwater, it would be very useful to determine the natural
41 background levels of radionuclides at the Entergy Vermont Yankee facility and in the vicinity of
42 regional monitoring devices. What is the potential contribution to groundwater of constituents

Appendix A

1 from land spreading of low-level constituents on site? How will both the natural and
2 anthropogenic background levels be used when determining whether future releases from the
3 facility exceed health standards? (VS-AAA-6)

4
5 **Response:** *The comment concerns potential radiological contamination in ground and surface*
6 *water. Groundwater is monitored by Entergy both within the boundaries of the VYNPS site and*
7 *outside. Entergy has installed test wells for monitoring the ground water around the periphery*
8 *of the on-site land-spreading plot where the sludge from the on-site septic tanks is periodically*
9 *disposed. The State of Vermont also monitors the ground water at several locations in the*
10 *vicinity of the site. The results of Entergy's and the State's monitoring programs are published*
11 *annually. These monitoring programs will be described in Section 2.2.7 of the SEIS.*
12 *Cumulative radiological impacts will be discussed in Section 4.8.3 of the SEIS.*

A.1.11 Comments Concerning Socioeconomics

16 **Comment:** From an economic standpoint, I would just quickly say that a stable, relatively low-
17 cost power provider will help to maintain and expand businesses here in Vermont, while at the
18 same time providing for an opportunity to bring and attract new businesses to the state. In a
19 time where Vermont faces an increasing, aging population, the plant provides employment to
20 600 highly skilled men and women. These individuals and the company provide more than 200
21 million in economic benefits to the Windham County Region and the state as a whole.
22 According to the Vermont Public Board, I'm sorry, the Public Service Department, the company,
23 through the State's Power Purchase Agreement, will provide customers in Vermont,
24 approximately 250 million dollars in savings over the life of the contract. (VS-G-2)

25
26 **Comment:** We have seen and been instrumental in the plant's continued enhancements and
27 upgrades, most recently during the power uprate process. The cost of Vermont Yankee's power
28 to Vermont consumers like myself is also far below regional market prices. As a baseload
29 generator, we are able to provide lower cost power which is so critical for this state. (VS-AA-2)

30
31 **Comment:** From an economic standpoint, a stable, relatively low-cost power provider helps to
32 maintain and expand businesses in Vermont, while at the same time providing an opportunity to
33 attract new business. In a time when Vermont faces an increasing, aging population the plant
34 provides employment to 600 highly skilled men and women. Those individuals in the company
35 provide more than \$200 million in economic benefits to the Wyndham County region and the
36 State of Vermont as a whole. (VS-BB-2)

37
38 **Comment:** According to the Vermont Public Service Department, the company through the
39 power purchase agreement, will provide Vermont customers approximately \$250 million in
40 savings over the life of the contract. This estimate, it should be noted, was made when energy
41 prices were far lower than they are today. And in fact, at 3.95 cents per kilowatt hour, Vermont

1 Yankee power today costs Vermonters 40 percent less than other sources of electricity. This
2 matters most to Vermont's elderly and the poor. (VS-BB-3)

3
4 **Comment:** The economic impact of shutting down or not granting a license extension for
5 Vermont Yankee is very, very severe. To take one third of the electricity out of the state, one
6 third of what it needs to run, that electricity has to be generated somewhere and come from
7 some other means. (VS-GG-1)

8
9 **Comment:** Living within about 14 miles of a nuclear plant weighs on the minds of people, and
10 my friends and neighbors virtually unanimously feel a strain whenever they think about Vermont
11 Yankee. I am in both the construction trades and farming, self-employed in both fields, and as a
12 contractor, dealing with others in that line of work, I have seen how strongly many people in
13 construction feel an aversion to the Vernon, Vt., area because of uneasiness about the nuclear
14 plant. I have heard builders voice scruples against building spec housing in that area. They
15 wouldn't want to live there themselves and don't feel right about selling a family a house so
16 close to the potential danger of meltdown, or the actual, ongoing radiation health hazard from
17 the plant's operation. The town of Vernon remains quite sparsely populated despite taxes being
18 low, and I believe appropriate concern about the nuclear power plant explains why. The effects
19 of worry don't cease at the town boundary, either—by harming the peace of mind, they
20 negatively influence the choices of home buyers, adders-on and renovators, and of businesses
21 looking to relocate in a radius of easily a dozen or perhaps 20 miles. (VS-LLL-1)

22
23 **Response:** *The comments relate to socioeconomic issues. Socioeconomic issues will be*
24 *discussed in Chapters 2 and 4 of the SEIS.*

25
26 **A.1.12 Comments Concerning Postulated Accidents**

27
28 **Comment:** I'm very concerned about dry-cask storage, alongside the Connecticut River which
29 flows through Massachusetts and Connecticut to the Long Island Sound and just the idea that
30 nuclear radioactivity could be carried by that water all the way to Long Island Sound should give
31 us great pause. I believe we have to take responsibility right now for the effect that we are
32 having because we are already seeing its effects upon our children and grandchildren.
33 (VS-B-4)

34
35 **Comment:** We, there's many of us in the local citizenry know that our environment, our homes,
36 our farms, our entire livelihood are at risk here. If there's ever a sizeable release of
37 radioactivity, then our property values will plummet. Our ability to sell, possibly even eat our
38 own produce, will be diminished. And I can't imagine a greater environmental impact than that.
39 I mean we're talking about all or nothing, here. And I don't know whether you want to try to do a
40 mathematical analysis of all or nothing, or not.

Appendix A

1 But from my perspective, it doesn't make any sense. If there's any possibility, that there's going
2 to be any kind of impact like that, then I think that the NRC can only include that in the
3 environmental scoping. (VS-H-2)

4
5 **Comment:** At a recent ACRS hearing in Rockville, Maryland, NRC staff, I think maybe it was
6 NRR staff, testified that in a design-basis accident or loss of cooling accident, under upgraded
7 conditions, which they're not looking at, of course, with this re-licensing thing. The entire
8 quantity of the core would be released in about 30 seconds. And accident impacts after uprate,
9 are greater than the 20 percent uprate, they may approach 40 percent, maybe more. And this
10 might result in a 500 roentgen exposure at the limiting location, which happens to be very near a
11 residence, which happens to be on the plant perimeter. I submit that such an accident would
12 have a significant impact on the person or family living there. So I would ask the NRC to
13 recalculate. That goes on and on, I'm going to skip. (VS-M-4)

14
15 **Comment:** The other thing, quarrel I have with your cost estimates, is that you skip Indian
16 Point, hypothetical accident costs for Indian Point. I don't blame the NRC for skipping Indian
17 Point. Lots of folks live down there. The cost of an accident would be astronomical, but it's not
18 good science to leave out a big outlier like that, in this case. (VS-M-7)

19 **Comment:** This afternoon is the first time, maybe the second time I've heard that the reactor is
20 70 feet in the air, which is a decision as to whether or not any kind of explosion would suck
21 water and dirt into the air and emit, you know, to the hills, but it would probably be buffeted.
22 Like there is a higher rate of survivor-hood, on the other side of the mountains from Hiroshima.
23 That it's at, you're buffeted by the earth. (VS-P-1)

24
25 **Comment:** I urgently request that you refuse to re-license the VT Yankee Nuclear Power Plant
26 I am extremely worried about the dangers of this aging plant and all the harm it can do to us, as
27 residents of the Pioneer Valley. I live immediately downwind, to the S. of Vernon, and I am an
28 educator. We all know we will not be protected from the radiation of a nuclear accident. Yes,
29 we need cheap electrical power. I am unwilling however, to risk our lives for this. I will insure
30 my car, my home, etc, but there is no insurance to protect us from radiation damage to our
31 health, or from a terrorist attack. Already there are radiation and chemical leaks. What are you
32 trying to do to us? (VS-DDD-1) (VS-MMM-1)

33
34 **Comment:** Another quarrel I have with the GEIS is that early fatality calculations are based on
35 a 50-mile radius from reactors, however graphs in the report only show numbers for a 150-mile
36 radius. Where are the numbers for a 50-mile radius?

37
38 The GEIS cost estimates on an accident at a reactor, based on outdated cost information from
39 1980 updated only to 1994, 12 years ago, is flawed for a number of reasons. First, the outdated
40 cost information, aforementioned, should be updated to reflect current reality. Second, you did
41 not include Indian Point. This is disingenuous. Although it may be an "outlier" due to the large
42 population living within 50 miles of its reactors, nevertheless an accident there would have an

1 enormous impact on the economy of New England, and the entire country. It should not be left
2 out of your accident consequence cost calculations. (VS-HHH-6)

3
4 **Response:** *The comments relate to Category 1 design-basis and severe accidents issues.*
5 *Environmental impacts of postulated design basis and severe accidents will be discussed in*
6 *Chapter 5 of the GEIS.*

7
8 **A.1.13 Comments Concerning Uranium Fuel Cycle and Waste Management**

9
10 **Comment:** Vermont Yankee had gotten permission to store contaminated soil on site, starting
11 back, I think in 1998, maybe a little earlier. And, at the time, the amount was some excavated
12 soil from a construction project, about 135 cubic yards. And then roughly at 35 or 40 cubic
13 yards per year, they anticipated generating through contaminated sanding salts from the roads
14 from silt in the cooling towers, and also from waste sludge. And, in 2004, Entergy received
15 permission to increase that amount. They had accumulated, they thought, about 500 cubic
16 meters of contaminated soil on site, and they wished to dispose of, on-site, an additional 150
17 cubic meters per year. That's about ten big dump truck loads. And this disposal site or, excuse
18 me, this storage site is on the south end of the site, just south of the cooling towers. It is
19 constantly sprayed down with what is called drift, sideways spray from the cooling towers. It is
20 on the riverbank. We believe that the phenomenon of bio uptake, of sedimentary separation, of
21 chemical combination, can leach and separate and concentrate the radioactive material in that
22 disposed of or stored soil, complicating decommissioning, polluting the river, winding up in the
23 biota. And so we believe that should also be investigated as part of the environmental
24 assessment. (VS-D-3)

25
26 **Comment:** So we have to run the other way to nuclear. You have to really think hard about all
27 of the nuclear waste that's going to be with us forever. And will Entergy be with us forever. As
28 long as it takes for the radiation to dissipate. (VS-L-5)

29
30 **Comment:** Especially if Entergy gets its way and does not even have to provide berms around
31 the casks. And, of course, there's also a flooding danger. In 1991, there was a study regarding
32 the construction of a low-level waste repository down on the plant grounds, and it was deemed
33 not wise. (VS-N-3)

34
35 **Comment:** Nuclear is not cheap electricity. Protect the waste for 100,000 years, tell us how
36 much that's going to cost. Spend some of that money to protect that waste, and then tell us it's
37 cheap, affordable or inexpensive electricity. I challenge you on that. To anyone who claims that
38 there was a benefit to nuclear power, please show me this cost benefit analysis, including the
39 price of dealing with this waste. Because the rate we're given as for the power purchase
40 agreement, from 2002, does not tell us the true cost of the economics behind this. (VS-O-1)

Appendix A

1 **Comment:** But we know that this is not clean, there's no answer for the waste. You know
2 Vermonters don't want this. (VS-RR-2)

3
4 **Comment:** We were asking the same questions then that we're asking the NRC now, and that
5 is, why produce power when you don't know what to do with the waste? When you don't know
6 what to do with the waste. When you don't know what to do with the waste. When the waste,
7 now, has become subject to the possibility of a terrorist attack. (VS-VV-2)

8
9 **Comment:** CAN contends that the following are proper subjects of environmental concern that
10 should be fully investigated prior to renewal of the Vermont Yankee license to operate:

11 1. Subjects to include in a supplement to the GEIS for Vermont Yankee and analyze in depth:

12 1.1 Accumulation of low-level radioactive waste on site.

13 1.2 Accumulation of chemical wastes on site.

14 1.3 Extent of on and off site contamination due to radioactive materials, chemicals and
15 other VY waste in on and off site locations, including, but not limited to disposal in the
16 Brattleboro and other area landfills that are now part of the Windham Solid Waste Management
17 District and/or out of state landfills utilized by the WSWMD.

18 1.4 Extent of site contamination due to chemical and other hazardous wastes, including,
19 but not limited to PCB contamination in paint, accumulated TCE, PERC and other organic
20 solvents, lead, and asbestos. (VS-WW-1)

21
22 **Comment:** 1. Subjects to include in a supplement to the GEIS for Vermont Yankee and
23 analyze in depth:

24
25 1.7 Extent of radionuclide inventory and location of radioactive waste accumulated in
26 on-site disposal locations for contaminated silt, sand, soil, sewage and other materials. (VS-
27 WW-3)

28
29 **Comment:** In the event that Vermont Yankee is given an additional twenty years (or less) of
30 operation under license renewal, now is the time to access the above listed environmental
31 issues in order to inventory and fully analyze the extent of these problems at the originally
32 contemplated end-of-life for this reactor. This inventory and analysis is appropriate, as the use
33 and improper disposal of many of the environmental hazards listed above, along with on-site
34 disposal of construction waste during construction of the facility, were commonly accepted and
35 customary business and industrial practices during a major portion of the original license period.
36 (VS-WW-4)

37
38 **Comment:** Issue 87 (Waste Management) The Agency is suggesting that low level radioactive
39 waste issue should be evaluated on a site specific basis. Title 10 Vermont Statute Annotated
40 contains §7066 (c) states:

1 No generator of low-level radioactive waste in the state existing on the date of enactment of this
2 action may increase its generation of waste in a year by more than 20 percent of the total
3 annual volume of waste from all generators estimated for disposal by the secretary of natural
4 resources, under subdivision 7065(a)(3) of this title, unless that generator receives a favorable
5 determination from the secretary of natural resources that disposal capacity will be available as
6 provided by section 3.04(11) of the compact agreement.

7
8 The Agency would like to know whether Entergy Vermont Yankee will increase production of
9 low-level radioactive waste as a consequence of the renewal and, if so, will any increase remain
10 in compliance with the state statutory requirements regarding low level radioactive waste
11 generation, minimization, and reporting. (VS-AAA-5)

12
13 **Comment:** Assessors will compare cultural willingness to isolate materials no longer in use,
14 when those materials pose a health risk, whether is no longer interest in those materials, or
15 whether substantial bribes are available to sell nuclear remains illegally, in both prosperous and
16 desperate times. An adequate assessment team will include sociologists who can assess the
17 human factors relevant for environmental protection for the length of time needed for isolating
18 wastes produced in a twenty year period, not the environmental protection needed in a twenty
19 year period. (VS-FFF-5)

20
21 **Comment:** I think the uranium that's mined to operate this nuclear power plant, is coming from
22 native land, from very, people that have lived for over 30, what, 40 years, with the tailings of the
23 uranium mining. And why doesn't the environmental scoping include the people that live, you
24 know, with these tailings, with the still births and the water, from the water, from the polluted
25 water, from the polluted air. (VS-R-1)

26
27 **Comment:** For the people who are trying to tell us that nuclear energy is clean and it doesn't
28 contribute to greenhouse gases, are not taking into consideration the amount of nonrenewable
29 energy used to dig up and process the uranium, to make it into a fissionable form. (VS-U-1)

30
31 **Comment:** In the uprate proceeding before the Vermont Public Service Board, Entergy
32 presented quite a remarkable witness, Dr. Ernest Moniz, M-O-N-I-Z, from MIT and he is a
33 former Assistant Secretary of Energy and I had the privilege of cross examining the good doctor
34 and he made some startling admissions. Number one is that all of the fuel, commercial nuclear
35 fuel produced in the United States to his best recollection was produced at the Portsmouth
36 enrichment plant and the Paducah enrichment plant and both of those plants, which absorb
37 enormous quantities of electricity in the process, are supplied by coal-fired stations.

38
39 My question for Dr. Moniz was well, then the pollution gets here ahead of the fuel, doesn't it?
40 And in fact, the mercury that some speaker referred to earlier, those heavy, heavy coal-fired
41 plants in Ohio and the ones that provide electricity to enrich nuclear fuel, among the dirtiest, do
42 send their mercury to our waters and our fish. (VS-DD-1)

Appendix A

1 **Comment:** The facts show us that huge amounts of pollution are released during the mining
2 and processing of uranium for fuel rods. (VS-JJJ-2)

3
4 **Response:** *The comments relate to Category 1 uranium fuel cycle and waste management*
5 *issues. The environmental impacts of the uranium fuel cycle including waste disposal will be*
6 *addressed in Chapter 6 of the SEIS.*

7 8 **A.1.14 Comments Concerning Alternative Energy Sources**

9
10 **Comment:** We also do not have to demand so much electricity. We don't really require it. Our
11 inflated desires for the expansion of electrical power have been -- are a 20th century notion of
12 progress at any cost. The cost is now coming due and we are going to have to begin paying for
13 the expansion....And I very much want to hear the NRC, the Regulatory Commission and other
14 leaders in our country talking about conservation. This is indeed a war. It's as if we are at war
15 against our unchecked desire to progress at the expense of other nations and at the expense of
16 the environment. And we can indeed change our ways and show a willingness to conserve.
17 (VS-B-2)

18
19 **Comment:** I don't think it should continue. It should be closed down. We should be looking for
20 safer forms of energy production and we should be conserving. (VS-C-3)

21
22 **Comment:** The Partnership fully supports the re-licensing of the Vermont Yankee Nuclear
23 Power Plant in Vernon and I will explain to you why. It is no secret that Vermont's demand for
24 energy is continuing to grow. It may be a less known fact, however, that Vermont faces
25 uncertainty over its future energy supply. Currently, one-third of Vermont's electric supply
26 comes from Hydro Quebec. These long-term contracts with the state will begin to expire in
27 2014, and there is no guarantee that these contracts will either be renewed or renegotiated
28 given the company's, Hydro Quebec's more local business opportunities in the province.
29 Another approximate one-third of our supply here in Vermont, is made up of a wide array of both
30 in-state and out-of-state sources, renewable and non-renewable. The Partnership supports the
31 in-state development of renewable sources, and we encourage the increased used of energy
32 efficiency in the expansion on conservation measures. However, the fact remains a reliable
33 energy portfolio, here in Vermont, must be made up elsewhere, of base load sources of power.
34 Vermont Yankee accounts for the last one-third of our Vermont portfolio.

35
36 About 34 percent of Vermont's total electricity supply needs are met by the Vermont Yankee
37 Plant. So let me put this debate into proper context. Vermont has not brought on a single,
38 significant power generating facility in over 20 years. And there are no plans to do so in the
39 near term. To make matters worse, proposals to develop small scale generation in Vermont,
40 have been met with sharp criticism and serious opposition.

1 In a time when energy costs are at their highest, Vermont Yankee will not only play an essential
2 role in our state's energy portfolio, it is critically important to the Vermont economy and
3 environment. (VS-G-1)

4
5 **Comment:** In 2005, alone, according to the Nuclear Energy Institute, Vermont Yankee avoided
6 emissions of 7,700 tons of sulphur dioxide, 2,000 tons of nitrogen oxides, and 2.5 million tons of
7 carbon dioxide. Emissions of sulphur dioxide, lead to the formation of acid rain. Nitrogen oxide
8 is the precursor to both ground-level ozone and smog. And greenhouse gases, like carbon
9 dioxide, contribute to global warming.

10
11 We live in a country where half the electricity generated comes from coal-burning sources. Yet,
12 in Vermont, we can be very proud to say that that's not the case. Vermont Yankee does not
13 release harmful greenhouse gases or other toxins into the atmosphere which are the primary
14 cause for global warming. The issue of global warming, a climate change, has rapidly reached
15 alarming levels.

16
17 And power-generated facilities have been at the heart of that crisis. In the United States, coal is
18 the leading power provider with over 600 plants operating. Of these plants, of the 600 plants,
19 36 percent of all U.S. emissions are accounted by those plants' generation. It has become
20 abundantly clear that the nuclear energy is the only emission-free source that can meet
21 consumer demand, reliably and at a reasonable cost. Leading environmentalists, from around
22 the world, like Dr. Patrick Moore, Co-Founder of Green Peace, have come to the conclusion that
23 nuclear power is the only source that can help remedy and save the planet from catastrophic
24 climate change.

25
26 Just last month, Dr. Moore said in the Washington Post, nuclear energy is the only large scale,
27 cost effective energy source that can reduce these emissions, while continuing to satisfy the
28 growing demand for power. And these days, in these days it can do so safely. He went on to
29 say that it's extremists who fail to consider the enormous and obvious benefits of nuclear power,
30 also fail to understand that nuclear energy is practical, safe and environmentally friendly.

31
32 Without Vermont Yankee, Vermont utilities would be forced to buy additional power on the spot
33 market that would be less reliable and certainly considerably more expensive. So the
34 Partnership asks, do Vermonters really want to pay more and to depend on power from fossil
35 fuel sources, such as natural gas and coal, which contribute to the global warming and the
36 earth's degradation? The Vermont Partnership thinks not. (VS-G-3)

37
38 **Comment:** I feel that in any electrical generation, no matter what type of process you are
39 using, there are benefits and risks. And I firmly believe that the benefits of nuclear power,
40 greatly exceed the risks. I know a lot of you are in disagreement. The main reason that I feel
41 this way is other than hydro-electric power, all of the other forms of electrical generation involve
42 carbon fuels. Either coal, oil, natural gas, biomass, you name it. All of these are going to

Appendix A

1 produce gases that are going to be harmful to the environment. They are going to produce
2 greenhouse gases. And I know some people don't believe in global warming, certainly the
3 President of the United States doesn't agree about global warming, but it does exist. (VS-I-2)

4
5 **Comment:** Because fossil fuels are going to diminish. China wants them, everybody else
6 wants them. They're polluting the atmosphere. They're going to kill the earth in just a very, very
7 few decades. Now with nuclear power we have the ability to get the fuel right here in North
8 America. We can use nuclear power to generate electricity. We can use nuclear power to
9 electrolyze water and get hydrogen. And hydrogen is going to be the fuel of the future.
10 (VS-I-4)

11
12 **Comment:** About 30 years ago the Union of Concerned Scientists developed a program that
13 provided the way that the United States could be 70 percent solar-powered by the year 2000.
14 Well, here it's 2006, and we're talking about energy problems and energy shortages.

15
16 Well, for the last 25 years, I've lived in a solar home that I built, and I've lived off the grid with
17 solar electricity from portable tag panels. If you came into my house, you wouldn't notice much
18 difference from your house. I have computers, I have monitors, I have televisions, I have a
19 microwave. I have a washing machine. I cook on electric hot plates in the summer and I cook
20 on a wood cook stove in the winter. I don't use any oil to heat my house. So when people tell
21 you that we need to risk the very ground that we stand on, that we need to risk making it
22 uninhabitable for 15 generations, in order to heat our homes and have electricity, it simply isn't
23 true. Technologically we can solve energy problems, we can do it without destroying the
24 environment. The problem is political and social. We need to say we want renewable energy,
25 we are not willing to pay the price of the destruction of the earth, to heat our homes. (VS-J-1)

26
27 **Comment:** And I would like to suggest that we follow up and that each of us become
28 responsible for learning that, for example, our own Department of Energy has very firm studies
29 that clearly tell us that if we exerted the political and social will, we would have no need for any
30 of the risky enterprises that we use now to meet our needs for energy and heat. (VS-K-1)

31
32 **Comment:** I want to add that I question this assumption that we need more and more energy
33 and that the only choices are centralized forms of energy that use fossil fuels, coal that uses,
34 uranium. This is not an automatic assumption. One aspect of this renewal, as I understand it,
35 is to consider alternatives. And I want to ask my neighbors, who live in this area, to really look
36 seriously at alternatives. There are so many renewable options. There's solar, there's wind,
37 and people have a way of making it sound like, oh, well you know you really can't do that, that's
38 not practical. That's not true. It's very practical, it's very doable. This is an article that's very
39 low researched. It's being done in other countries. It's being done in Western Europe. People
40 are putting solar panels on their homes and getting paid by the utility for producing that

1 electricity. So we need to open our minds and not get into an either/or situation where people
2 saying well coal plants are so bad for the environment and it's making, causing global warming.
3 (VS-L-4)

4
5 **Comment:** No other power generation source comes close to having to expend so much
6 money and so much energy, just to convince us that it won't kill thousands of us. If Entergy,
7 Exelon and others just invested in wind and solar, none of this would be necessary. I do hope
8 that you will consider that possibility in your NEPA required look at alternatives to re-licensing
9 ENVY. (VS-M-8)

10
11 **Comment:** In order for nuclear to cover the carbon-based emissions, better used in coal and in
12 natural gas plants, etcetera, we would have to have a new nuclear power plant built every two
13 weeks, between now and 2050. I don't think that's going to happen, sir. (VS-O-3)

14
15 **Comment:** But if we were to stop the creation of nuclear waste, and stop our mental
16 dependence on extremely bright street lights. Over, hugely over air-conditioned environments
17 and brought our electrical usage, personally at home, down to seriously conservative levels, that
18 we would feel some relaxation of social economic status stress, that is the equation of the
19 success of industrial America. And it's, you know, you're at that big decision point in your life,
20 where you straighten up and start respecting incredible simplicity, and really learn solar panel.
21 Really contemplate wind farms and harness the hydro-electric potential in the rivers and
22 streams and waterfalls. And gauge down to accepting that as the amount of electricity that you
23 can look at and use. (VS-P-2)

24
25 **Comment:** Greenhouse gas emissions are a real problem and we need to do something about
26 it. We need to stop relying on fossil fuels for the generation of electricity and turn more towards
27 nuclear energy. Nuclear energy is safe, clean and readily available for use in this country, and
28 it does not contribute to the greenhouse gas emissions and helps keep our green mountains
29 green. To not allow Vermont Yankee to operate an additional 20 years, would be a significant
30 impact on our environment. (VS-Q-1)

31
32 **Comment:** I want to speak to alternatives. In my home town of Corinth, we publish Northern
33 Woodlands magazine. Last month--I want to give these, I don't have enough for all 25
34 employees, but I want to give you all a copy to read tonight in your hotel. "Energy From Wood:
35 Turning Woodchips Into Power, Heat and Ethanol." We have the answers. We have the
36 alternatives. We've listened to Amory Levans* [phonetic], Rocky Mountain Institute, and other
37 experts. We can use energy efficiency. (VS-R-3)

38
39 **Comment:** And, you know you do have a choice. Every worker has a choice. I don't think it's
40 our job to provide alternative jobs, but we can convert that plant, we can still have a good
41 economy, we can convert that plant, run it on gas, like I said we can use alternatives and
42 provide the same amount of energy. (VS-R-4)

Appendix A

1 **Comment:** We can develop the technology at a reasonable price, relatively much more
2 reasonable price than creating nuclear, keeping this plant alive, create wind power, geothermal,
3 which hasn't been mentioned. Geothermal energy and hydro energy to create sustainable
4 energy resources. I came from Maine. We closed Maine Yankee [sic]. They have a viable
5 renewal energy plan in Maine. They have a dam that actually has little elevators that lift the fish
6 uphill and people can buy into energy produced by that type of energy. Geothermal. There's a
7 lot of hope in what that can do. We have a heated core from the center of the Earth, that we're
8 not utilizing, we're not resourcing ourselves with that yet, except in areas of--when I say "we" I'm
9 thinking of this area. But other areas of the world and other parts of the country rely on
10 geothermal energy for electricity and fuel already. So there are things that we can do and that's
11 what I think we should be focusing on, and it should be a regional discussion since it affects
12 regional issues. (VS-T-4)
13

14 **Comment:** In New York State, Congresswoman Nita Lowey commissioned a study by the
15 National Academy of Sciences about whether Indian Point could be replaced, the Indian Point
16 reactors. And it, in fact, found that Indian Point reactors could be replaced in the State of New
17 York. It wouldn't be easy, but it was possible. But why don't we have a National Academy of
18 Science study here? Why haven't our legislators called for that so that we can have an
19 independent look at what it would take to replace Vermont Yankee, not done by the NRC as
20 part of their environmental impact study which is set up to permit Vermont Yankee to go ahead,
21 not done just by the Public Service Commission which has mixed loyalties in terms of this, but a
22 real independent study. It is the will that we have to exert on our legislators to do what's right.
23 We need a clear vision at this point of a safe energy future, a future that we know is safe for our
24 children. (VS-W-3)

25
26 **Comment:** Our work at the plant helps to make Vermont a cleaner, more prosperous place to
27 live. Without Vermont Yankee, the 620 megawatts that we currently supply to the New England
28 grid would have to come from a fossil fuel power plant. Wind power, the Connecticut River
29 hydro project and energy conservation, while all nice ideas, simply cannot replace the steady,
30 reliable, baseline power that we produce. Since opening in 1972, Vermont Yankee has
31 prevented more than 100 million tons of fossil fuel emissions from entering the atmosphere.
32 This has been prevented not only by rendering an in-state coal plant unnecessary, but also from
33 reducing the amount of out-of-state electricity that we have to purchase, most of which would
34 come from coal plants, as coal still accounts for half of the power produced in America today. In
35 2005, Vermont Yankee avoided the emissions of 7,700 tons of sulphur dioxide; 2,000 tons of
36 nitrogen oxide and 2.5 million metric tons of carbon dioxide. Emissions of sulphur dioxide lead
37 to the formation of acid rain. Nitrogen oxides are a key precursor of both ground level ozone
38 and smog and greenhouse gases like carbon dioxide contribute to global warming. The 2,000
39 tons of nitrogen oxide prevented by Vermont Yankee last year is the equivalent of what would
40 have been generated by 105,000 vehicles. For comparison, in Vermont, we have 280,000
41 registered cars. (VS-AA-1)
42

1 **Comment:** The partnership [Vermont Energy Partnership] fully supports the relicensing of the
2 Vermont Yankee nuclear power plant in Vernon and I will explain why. It is no secret that
3 Vermont's demand for energy is continuing to grow. But it may be a less known fact that
4 Vermont faces uncertainty over its future energy supply. Currently, one third of Vermont's
5 electric supply comes from the Hydro Quebec -- from Hydro Quebec. And these long-term
6 contracts will begin to expire starting in 2014. There is no guarantee that the contracts will
7 either be renewed or renegotiated, given the other more local business opportunities Hydro
8 Quebec has in the province. Another approximate one third of Vermont's electric supply is
9 made up of a wide array of both in-state and out-of-state renewable sources and nonrenewable
10 sources. The Partnership supports the in-state development of renewable energy supplies,
11 encourages the increased use of energy efficiency and the expansion of conservation
12 measures. However, the fact remains a reliable energy portfolio must be made up of a
13 baseload source of power. Vermont Yankee accounts for the last one third of the Vermont
14 portfolio, energy portfolio. About 34 percent of Vermont's total electricity supply needs are met
15 by Vermont Yankee today. So let me put this debate in further context. Vermont has not
16 brought online a significant power generating facility in over 20 years and there are no plans to
17 date to do so in the near future. To make matters worse, proposals to develop small-scale
18 generation in Vermont have been met with sharp criticism and severe opposition.

19
20 In a time when energy costs are at their highest, the Vermont Yankee plant will not only play an
21 essential role in our state's energy portfolio, it is critically important to Vermont's economy and
22 environment. (VS-BB-1)

23
24 **Comment:** Today, we live in a country where half of the electricity generated comes from coal-
25 burning sources, yet Vermonters can be proud to say that that is not true here. Vermont
26 Yankee is a clean, emissions-free facility. Unlike fossil fuel-generating facilities, nuclear power
27 does not release harmful greenhouse gases and other toxins into the atmosphere that are the
28 primary cause for global warming.

29
30 It is becoming abundantly clearly that nuclear energy is the only emissions-free source that can
31 meet consumers' demand for reliability and at a reasonable cost. Leading environmentalists
32 around the world, like Dr. Patrick Moore, co-founder of Greenpeace, have come to the
33 conclusion that nuclear power is the only source that can help remedy and save the planet from
34 catastrophic climate change. Just last month, Dr. Moore said in the Washington Post "nuclear
35 energy is the only large-scale, cost-effective energy source that can reduce these greenhouse
36 emissions while continuing to satisfy a growing demand for power. In these days, it can do so
37 safely." He went on to say, "the extremists who fail to consider the enormous and obvious
38 benefits of nuclear power also fail to understand that nuclear energy is practical, safe and
39 environmentally friendly." In closing, without Vermont Yankee, Vermont utilities will be forced to
40 buy additional power on the spot market that would be less reliable and considerably more
41 expensive.

Appendix A

1 Do Vermonters really want to pay more and be dependent on power from fossil fuel sources
2 such as natural gas and coal which now contribute to global warming and the earth's
3 degradation? The Vermont Energy Partnership thinks not. (VS-BB-4)

4
5 **Comment:** Entergy, because it's also a public -- not a public, but a privately-owned utility
6 company, also sells its electricity out on the market and trades. Traders buy it and compete for
7 whatever can be generated. So for Vermont Yankee, all of its electrical generating capacity
8 has been planned out for 2006. That's the rest of this year and for part of 2007. All that
9 electricity has already been sold and paid for, speculatively, by traders, by the national grid, by
10 whoever Entergy can sell the power to.

11
12 So there isn't any way that they can now change the cost of that electricity that they've sold it for
13 and I don't know the numbers. I just know that it was sold. So it's committed to this generation
14 of a set price of baseload power and baseload power means that it's running 24/7 at a very
15 even amount and I think Vermont Yankee is now at 650 kilowatt hours or something -- huh?
16 Megawatt hours, right, sorry. So they've already sold all this to the grid and the grid has already
17 agreed to a price, but the national grid or the regional grid actually for New England currently
18 has a surplus. There's extra electricity out there. We don't actually have to have part of the
19 electricity that's coming from VY right now. And I don't know the technical aspects of how the
20 grid works, what happens to this extra electricity.

21
22 But what we need to do is to investigate other ways of producing this electricity and to make it
23 economically unfeasible for Entergy to continue running Vermont Yankee at its rate right now,
24 which does not mean firing all the workers. (VS-CC-1)

25
26 **Comment:** Energy efficiency and conservation are the easiest and lowest cost ways of
27 reducing that energy demand. It's already been estimated that even in Vermont, if we replace
28 five lightbulbs with compact fluorescents and a refrigerator or other major appliance like an air
29 conditioner or home heating, other large electrical demand with energy-efficient or EnergyStar-
30 rated appliances, we could reduce the demand in Vermont by 25 percent. Now this does
31 require the participation of every household or double participation by half the households. But I
32 don't think that that's an unreasonable goal to have, especially since it would mean that we
33 would no longer have to depend on Vermont Yankee's electrical generation. (VS-CC-2)

34
35 **Comment:** So in order to think about what other choices we have and what we need to do, as
36 individuals, it's really hard to think about wind power and solar power and what can we do as
37 individuals. The best thing that I can think of that we need to do is to read. Read books, read
38 magazines, read articles, go to the web and Harvey Wasserman has a wonderful book out
39 called Solar Topia which is a fantasy, but it gives you something to hold on to and something to
40 dream about and something to think about of how you can apply it to your every day life. In it he
41 says that basically wind power right now, as it is technologically developed is capable of

1 replacing a majority of the electrical generation in the United States from fossil fuels and nuclear
2 power. We're not just talking about only nuclear. (VS-CC-3)

3
4 **Comment:** Now some of the complaints about wind power are that it kills birds. Well, the first
5 wind towers that went up and I can't remember where the path in California where they went up,
6 those wind towers were placed -- yes -- those wind towers were designed without thinking about
7 the birds. They were like the erector set towers that have lots of braces, four legs and cross
8 bracing and then finally the wind turbine at the top. Well, what was happening was that the
9 birds were resting on these bracings and then when they'd see a squirrel or a chipmunk or
10 whatever they wanted to get, these birds of prey would then fly down and get knocked out by
11 the blades as they were coming around. Well, now the towers are not built like that. They're
12 single pole structures, so there's nothing the birds can rest on. The other thing is that the
13 turbines turn so slowly now that you'd really have to have a suicidally-depressed bird to fly into
14 one of these and get knocked out. So the arguments about birds is really unfounded [sic].
(VS-CC-4)

16
17 **Comment:** the other thing about nuclear power, not nuclear power, wind power is that it's not
18 something that's just a dream. In 2002, the Conference on American Wind Power Generating
19 Association, was attended by maybe 1500 people. Last year, it was attended by more than
20 5,000 people. It had grown so much that it is not something that's just a pipe dream. You can
21 go and visit wind towers that are installed in Vermont, in New Hampshire and in Massachusetts
22 right now and see how they operate. You can listen that they're not noisy and you can talk to
23 the residents there who live next to them who really like their wind power. (VS-CC-5)

24
25 **Comment:** And if it is a fossil means, whether it's oil, coal or gas, it's going to increase the
26 pollutants that are going in the air. It will affect the environment, much, much, more worse than
27 what the effect is of nuclear power. The 100 million tons that the government talked about, that
28 is a very, very significant amount of pollutants in the air and there's empirical data that supports
29 that that has caused global warming and that is now causing the oceans to heat up and that is
30 having a dramatic effect on things like hurricanes. The number of hurricanes that we're having
31 now is a direct result of this global warming. (VS-GG-2)

32
33 **Comment:** Another thing I wanted to touch on here, just very briefly, is that there was a report
34 by the National Academy of Sciences that talked about Indian Point. One of the key
35 conclusions of that report are that the economic and environmental impact of closing those
36 plants, shutting those plants down, was very significant. And that was the key conclusion of it.
37 So I urge you to educate yourself, read about it, and understand, you know, the impact of
38 closing down a plant like Vermont Yankee. (VS-HH-2)

39
40 **Comment:** When we first started making power in this country, a lot of heavy polluters. We're
41 all ruining the environment. We're damming up rivers for hydro, a lot of coal-fired power plants,
42 the most abundant source of electricity in this country is coal. Fifty-eight percent of our power in

Appendix A

1 the United States is made from coal. We're the largest coal burning country in the world, as a
2 matter of fact. We're starting to see a lot of the results of that over the years. (VS-II-1)

3
4 **Comment:** We're looking at 20 more years of operation from this facility right here. I believe
5 that there will be a better technology one day and than our current technology for making power.
6 I honestly believe that. We're on the verge of a lot of those things right now to this. Hydrogen
7 cell power, but scientists are predicting right now that maybe ten years, possibly twenty years to
8 be able to make megawatts of hydrogen cells. Ironically, nuclear power plants produce
9 hydrogen. But then we use some more energy to take that hydrogen and re-combine it back
10 with the oxygen and make water out of it and put it back to the power plant. So imagine if you
11 have a hydrogen cell sitting outside a nuclear power plant to make power from that hydrogen.
12 Stepping stones of technology. I think that we can't get from one point to another point to being
13 completely nuclear free without going through that process. We started out with plants years
14 ago, but we've improved on those technologies. We've made them more efficient. We've
15 learned from our lessons of the past and made better plants to continue on in the future with.
16 (VS-II-2)

17
18 **Comment:** One day, we'll reach that point where we can probably start shutting down these
19 plants. But that day isn't today. Six hundred twenty megawatts of power electric. What scares
20 me is how are going to, if we shut this plant down in 2012, where are going to produce that
21 power from right now? That's baseload electricity. That's not wind power with a 20 percent
22 efficiency factor. Those numbers you can look them up on NEPAX. It's a website that tells how
23 much power the capacity, how much those places actually stay online. (VS-II-3)

24
25 **Comment:** I'll support any power made from any source that's safe like that. I believe Vermont
26 Yankee is a very safe plant having worked there for as long as I have. But I don't believe that
27 we're going to be ready in the next 10 or 15 years to get away from nuclear power. It's not
28 feasible. We're not going to be able to produce 620 megawatts without going to coal, without
29 going to gas power, which gas has been touted as being the clean source of energy, it's not. It
30 produces half of the amount of waste that our coal plants produce. (VS-II-4)

31
32 **Comment:** Oil is out of the question. Oil is like less than 10 percent, less than 5 percent of the
33 entire production of power in this country, just because of the unavailability of it and that we
34 need it for automobiles and other things like that, other smaller, small-type things. But consider
35 that. Consider where we're going to get our power from if we shut this plant down. We have to
36 get it from somewhere. It's not in my back yard. It's here. It's safe. We have a proven track
37 record of being safe. Why not continue for 20 more years. (VS-II-5)

38
39 **Comment:** I wanted to address first an issue that has come up over and over again that
40 Governor Salmon, I think was the first to speak to the issue of global warming and how nuclear
41 is purported to be a solution, a near-term solution for global warming, just to say that it has been
42 shown in numerous studies, chief among them, out of Rocky Mountain Institute which is run by

1 world renown Emory Lovins and his wife, Hunter, a couple of researchers back in the late 1990s
2 looked at global carbon mitigation strategies, using nuclear and using renewables as two
3 alternative paths. And they discovered a finding that they put two different ways which I think
4 are provocative. One, that for every \$100 spent on nuclear that could otherwise have been
5 spent on what we call renewables, an extra ton of carbon is released to the atmosphere that
6 would have otherwise been prevented. And that's because, as Ray Shadis pointed out earlier,
7 it's going to take many, many years of many, many hundreds of nuclear plants to begin to cut
8 back on the acceleration of global carbon using nuclear. And the energy efficiency and
9 renewable strategy is a much simpler, more direct, cost-effective way to go about it. (VS-JJ-1)

10
11 **Comment:** According to Rich Smalley, who is a Nobel Peace Prize winner for chemistry in
12 1996 for his work on nanotechnology by mid-century the world will require a doubling of its
13 current world-wide energy demand of 14 terawatts of power. To achieve this demand will
14 require the equivalent of one 1,000 megawatt power plant going online every day for nearly 38
15 years. And this is from Discover of February 2005 and I have it in the testimony here. Although
16 I assume the initial mandate of the NRC regarding environmental issues 30 to 40 years ago
17 concerned the rather micro impact that is of the areas immediately surrounding a nuclear plant,
18 certainly now the issue is equally a global concern of greenhouse gases, foremost carbon
19 dioxide. (VS-KK-1)

20
21 **Comment:** Dr. Arthur Westing, a resident of Putney, Vermont, 10 miles up the road, is an
22 expert. He has served on the faculty or been a research fellow at several education institutions,
23 including Harvard University, the Stockholm International Peace Research Institute. He has
24 served as the director of the United Nations Environmental Program Project, Peace, Security
25 and the Environment, and is the author of many articles and several books on the environment.
26 At the moment, unfortunately, he is in Sweden. He told me he wished he could be here to
27 testify on the importance of Vermont Yankee to the energy future of Vermont and give his
28 wholehearted support to the relicensing. I am submitting an email from him to me giving me
29 the authority to give you two letters he has written on energy and the environmental issues, as
30 well as his résumé. His latest letter cites a British report on the role of nuclear power and low
31 carbon economy which he uses to calculate the impact shown on the following page.

32
33 Thank you for beginning this lengthy process for the relicensing of Entergy and Nuclear
34 Vermont Yankee Power Plant. I hope the evidence supports a positive decision.

35
36 I think this is very important. It shows that for CO₂ production from various sources of power,
37 that kilograms of CO₂ per kilowatt of electricity for cradle to grave or a full production cycle.
38 Coal, it's 891. Natural gas is 356. Photovoltaics, interestingly enough is 50, while wind and
39 nuclear are 16. Nuclear power is very important to the future energy of this world and this state
40 and please, I hope you consider relicensing it. (VS-KK-2)

Appendix A

1 **Comment:** They were also in error to dismiss as, quote, inadequate, alternative energy
2 sources. We need to understand that solar wind, biomass, geothermal and others are safe,
3 clean, dependable, and most important, sustainable. Conservation and efficiency should also
4 be added to the list. If given the billions in Federal subsidies that nuclear has enjoyed over the
5 years, these alternative energies could easily meet our energy needs without harming the
6 environment. (VS-LL-6)

7 **Comment:** Vermont Yankee produces enough electricity to power about 620,000 homes and it
8 does not burn fossil fuel. Over the years, this has avoided millions of tons of fossil air pollution.
9

10 If Vermont Yankee were to close, it would be replaced with large amounts of fossil fuel
11 generation and greenhouse gas emissions that lead to global warming. (VS-MM-2)

12 **Comment:** Global warming. Are you concerned about global warming? Twenty years ago,
13 folks were, scientists were making quite a bit of noise about it, and the administrator at the time
14 said, nah. Do you believe it? And if you do believe global warming is an issue, and you think
15 it's upon us, do you want your power coming from coal-burning facilities that generate
16 greenhouse gases and smog? We know that our use of electricity contributes to global
17 warming. If you believe we can fulfill our electric needs in Vermont without Vermont Yankee's
18 baseload electricity, if you want economical power, then please listen closely. If you are
19 concerned about greenhouse gases, we can't afford this distraction of dangerous, dirty,
20 expensive source of electricity. Low cost, safe, clean power, zero greenhouse gases
21 emissions. That must be wind and solar. (VS-NN-1)
22

23 **Comment:** But I do believe that in the long run, we really need to embrace safe, clean energy--
24 wind, solar, and other sustainable long-term renewables....A reliable source of power must
25 include baseload power, so let's buy windpower from New York, if Governor Douglas won't get
26 out of the way and let the public get their wind generation in Vermont, when the wind's not
27 blowing we'll use hydro, and as a last resort, we'll use the power that we get off the open
28 market, not spot market, though. Vermonters overwhelmingly embrace renewable energy. 75
29 percent want wind. There's probably even more that want solar. Small-scale renewables.
30 When the first incentive program came out in Vermont two years ago, they thought it would last
31 for two years. In seven months, it was all used up. People wanted solar. People wanted wind.
32 Our elderly, who must choose between electricity, or food, or medicine, they need solar hot
33 water systems. They need energy audits. They need efficiency upgrades of their homes and
34 their apartments. And there's jobs in doing that. Lots of jobs. Vermont needs jobs. We need
35 plumbers, carpenters, engineers, concrete workers, electricians, energy planners, and that's
36 exactly why we need to implement a clean, renewable energy program today, putting nice
37 tradespeople to work. (VS-NN-2)
38

39 **Comment:** We're making that bet, and I think that that's a foolish bet because I think we're not
40 so dumb, that we're willing to take that risk, and I also think we're not so dumb that we can't
41 create better technologies, safer technologies, other than continuing to rely on fossil fuels and
42

1 nuclear power and all the old standbys that we've continued to try to pretend are our only
2 choices. We have lots of choices to make, lots of decisions to make, and they can create jobs,
3 they can create energy, they can create a better life for the future inhabitants of this region. If
4 we're so smart to create this technology, so well, that we can be positive it's gonna be safe over
5 the next 20 years, why aren't we smart enough to make it better, to create safer nuclear power
6 plants with safer designs, and to close those that are no longer capable of operating safely?
7 And why aren't we capable of beginning to create more wind and solar and conservation
8 technologies that could create immediate jobs for many more people who wouldn't have to be
9 as highly educated as the people who build nuclear power plants or decommission them? (VS-
10 PP-2)

11
12 **Comment:** I think the solution, even better than soft-path technology of windmills and solar
13 and photovoltaics, which we need, is conservation. (VS-QQ-2)

14
15 **Comment:** We know there's other answers. I, for one, live off the grid. I don't rely on this
16 power, we don't need it, and like Clay said, 75 percent of Vermonters know this, and we can
17 move on. (VS-RR-3)

18
19 **Comment:** So let's take Commissioner David O'Brien who's the head of the state department
20 of Public Service. He put a \$60 million figure on the cost that would come to Vermont
21 ratepayers if VY closed in 2008. Vermont Yankee provides roughly 250 megawatts to Vermont.
22 That represents one-third of our Vermont total energy demand, which is about 750 megawatts.

23
24 A recent PSB study determined that energy efficiency measures could reduce Vermont's total
25 electricity use by 20 percent, or 150 megawatts. Let's apply that savings to what VY provides.
26 Then we'd reduce the amount of power needed to replace VY to 100 megawatts. That's 250
27 minus 150. If it would cost Vermont 60 million bucks to replace the 250 megawatts over four
28 years, it would cost us 40 percent of that or \$24 million to replace the 100 megawatts that would
29 remain, if we implemented all the efficiency measures we could. Now we're down to \$24
30 million. Spread that over four years. That's \$6 million a year, divided by 250,000 households in
31 Vermont, and the increase in each household's electricity bill for the entire year would be
32 roughly \$24.00. That's not even considering the contribution from industrial and commercial
33 users. That doesn't sound like a lot of money to invest in freeing Vermont from this role in the
34 production of hundreds of tons and millions, hundreds of tons of radioactive waste, millions of
35 curies of deadly nuclear substances created by the Vermont Yankee nuclear reactor, stored on
36 the banks of the Connecticut River. It doesn't sound like a lotta money to spend to get rid of
37 Vermont Yankee. (VS-SS-1)

38
39 **Comment:** in 18 years in Princeton, all those years we have a windmill, thanks to the citizens
40 of that town, and they've now decided to improve on the windmill that has been there, and it has
41 provided well for, without any pollution at all, for 30 percent of the energy needed for that
42 community. And I believe they're adding another windmill. I'm not sure of the statistics. But I

Appendix A

1 then went to Maine. Maine got rid of its nuclear power plant, Maine Yankee, I'm not sure what
2 year, and the governor of Maine has led the people that work for the government to create a
3 plan, a 50-point plan of creating renewable energies in the state of Maine. They're encouraging
4 cities and towns to develop renewable energies that they will market elsewhere, that universities
5 can use, that can provide jobs for people, that can be safe and viable for the next generations.
6 Why don't we go that direction? I attended a recent conference at Smith College at which there
7 was all different kinds of renewables presented, and for the first time, I found out about
8 geothermal energy and that people in Massachusetts, at least there, I'm not sure about Vermont
9 or anywhere else, are utilizing geothermal energy for commercial buildings as well as residential
10 properties, either by going straight down to the center of the Earth, not the center, but down
11 where it's hotter than it is on the surface--I'm not sure how many feet down you have to go--but
12 going straight down or else spreading out along a piece of land next to your building and
13 creating energy right from the Earth itself, with of course no pollutants in that process at all.
14 (VS-VV-1)

15
16 **Comment:** The assessment team will compare the environmental impact of wind, solar, hydro
17 and geo-thermal alternatives as if they enjoyed the full insurance and financial benefits enjoyed
18 by nuclear energy utilities, and report those comparisons year by year for operations for 10,000
19 generations-- or for the length of time future generations will need to manage our waste without
20 benefit. (VS-FFF-4)

21
22 **Comment:** The facts show that our region could produce power more cheaply and without any
23 pollution or risk of pollution by starting to install wind towers offshore or in the hills of our region
24 over the next 5 years. The facts show that this region could reduce its power needs significantly
25 by educating people about compact fluorescent bulbs, insulation, heat pumps, more efficient
26 appliances, solar hot water heaters, and hundreds of ways of conserving energy. The mere
27 price of electricity is currently a huge incentive for conservation, but other tax incentives could
28 also help us to reduce our power needs to a level that would allow the Vernon facility to close in
29 5 years. (VS-JJJ-4)

30
31 **Response:** *The comments relate to alternative energy development and conservation. The
32 environmental impacts of alternatives to license renewal will be addressed in Chapter 8
33 (alternatives) of the SEIS; they include conservation (demand-side management) and
34 renewable energy sources such as wind and solar energy.*

Appendix B

Contributors to the Supplement

1

Appendix B

2

Contributors to the Supplement

3

4

5

6 The overall responsibility for the preparation of this supplement was assigned to the Office of
7 Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission (NRC). The supplement
8 was prepared by members of the Office of Nuclear Reactor Regulation with assistance from
9 other NRC organizations and Argonne National Laboratory and Information Systems
10 Laboratories, Inc..

Name	Affiliation	Function or Expertise
NUCLEAR REGULATORY COMMISSION		
Rani Franovich	Nuclear Reactor Regulation	Branch Chief
Richard Emch	Nuclear Reactor Regulation	Project Manager
Robert Schaaf	Nuclear Reactor Regulation	Socioeconomics
Andrew Luu	Nuclear Reactor Regulation	Radiation Protection
Jason Flemming	Nuclear Reactor Regulation	Hydrology
Scott Werts	Nuclear Reactor Regulation	Hydrology
Sam Hernadez	Nuclear Reactor Regulation	Cultural Resources; Alternatives
Michael Masnik	Nuclear Reactor Regulation	Ecology
Nathan Goodman	Nuclear Reactor Regulation	Ecology
Jessie Muir	Nuclear Reactor Regulation	Principal Project Support
Robert Palla	Nuclear Reactor Regulation	Severe Accident Mitigation Alternatives
ARGONNE NATIONAL LABORATORY^(a)		
David Miller		Team Leader
Halil Avci		Deputy Team Leader; Health Physics
Timothy Allison		Socioeconomics
Ronald Kolpa		Meteorology; Air Quality
Kirk LaGory		Terrestrial Ecology
William Metz		Land Use
Vic Comello		Technical Editor
Ellen Moret		Administrative Support
Daniel O'Rourke		Cultural Resources; Alternatives
Terri Patton		Hydrology
William Vinikour		Aquatic Ecology
Konstance Wescott		Cultural Resources; Alternatives
(a) Argonne National Laboratory is operated for the U.S. Department of Energy by UChicago Argonne, LLC.		
INFORMATION SYSTEMS LABORATORIES, INC.		
Lauren Fleishman		Severe Accident Mitigation Alternatives
Robert Schmidt		Severe Accident Mitigation Alternatives

Appendix C

**Chronology of NRC Staff Environmental Review Correspondence
Related to the Entergy Nuclear Vermont Yankee, LLC
and Entergy Nuclear Operations, Inc.
Application for License Renewal of
Vermont Yankee Nuclear Power Station**

1

Appendix C

2

3

Chronology of NRC Staff Environmental Review Correspondence 4 Related to the Entergy Nuclear Vermont Yankee, LLC 5 and Entergy Nuclear Operations, Inc. 6 Application for License Renewal of 7 Vermont Yankee Nuclear Power Station

8

9

10 This appendix contains a chronological listing of correspondence between the U.S. Nuclear
11 Regulatory Commission (NRC) and Entergy Nuclear Vermont Yankee, LLC and Entergy
12 Nuclear Operations, Inc. (Entergy), and other correspondence related to the NRC staff's
13 environmental review, under Title 10, Part 51, of the *Code of Federal Regulations* (10 CFR Part
14 51), of Entergy's application for renewal of the Vermont Yankee Nuclear Power Station
15 (VYNPS) operating license. All documents, with the exception of those containing proprietary
16 information, have been placed in the Commission's Public Document Room, at One White Flint
17 North, 11555 Rockville Pike (first floor), Rockville, Maryland, and are available electronically
18 from the Public Electronic Reading Room found on the Internet at the following web address:
19 <http://www.nrc.gov/reading-rm.html>. From this site, the public can gain access to the NRC's
20 Agencywide Document Access and Management Systems (ADAMS), which provides text and
21 image files of NRC's public documents in the Publicly Available Records (PARS) component of
22 ADAMS. The ADAMS accession numbers for each document are included below.

23

- 24 January 25, 2006 Letter from Entergy to NRC, forwarding the application for renewal of
25 the operating license for VYNPS, requesting an extension of the
26 operating license for an additional 20 years
27 (Accession No. ML060300082).
- 28
- 29 January 31, 2006 Letter from NRC to Entergy, "Receipt and Availability of the License
30 Renewal Application for the Vermont Yankee Nuclear Power Station"
31 (Accession No. ML060310684).
- 32
- 33 March 21, 2006 Letter from NRC to Entergy, transmitting "Determination of
34 Acceptability and Sufficiency for Docketing, Proposed Review
35 Schedule, and Opportunity for a Hearing Regarding the Application
36 from Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear
37 Operations, Inc. for Renewal of the Operating License for the Vermont
38 Yankee Nuclear Power Station" (Accession No. ML060800664).
- 39
- 40

Appendix C

- 1 April 12, 2006 Letter from NRC to Entergy, forwarding the *Federal Register* "Notice
2 of Intent to Prepare an Environmental Impact Statement and Conduct
3 Scoping Process for License Renewal for the Vermont Yankee
4 Nuclear Power Station" (Accession No. ML061040142).
5
- 6 May 5, 2006 Letter from NRC to Ms. Patricia A. Kurkul, National Oceanic and
7 Atmospheric Administration (NOAA), National Marine Fisheries
8 Service, Northeast Regional Office, "Request for List of Protected
9 Species and Essential Fish Habitat Within the Area Under Evaluation
10 for the Vermont Yankee Nuclear Power Station License Renewal
11 Application Review" (Accession No. ML061280184).
12
- 13 May 5, 2006 Letter from NRC to Mr. Marvin Moriarty, U.S. Fish and Wildlife Service
14 (FWS), Northeast Regional Office, "Request for List of Protected
15 Species Within the Area Under Evaluation for the Vermont Yankee
16 Nuclear Power Station License Renewal Application Review"
17 (Accession No. ML061280128).
18
- 19 May 8, 2006 Letter from NRC to Mr. Don L. Klima, Director, Advisory Council on
20 Historic Preservation, "Vermont Yankee Nuclear Power Station
21 License Renewal Application Review" (Accession No. ML061290255).
22
- 23 May 8, 2006 Letter from NRC to Ms. Jane Lendway, Vermont Historic Preservation
24 Officer, "Vermont Yankee Nuclear Power Station License Renewal
25 Application Review" (Accession No. ML061300034).
26
- 27 May 10, 2006 Letter to The Honorable April St. Francis-Rushlow, Chief, Abenaki
28 Nation of Missisquoi, St. Francis/Sokoki Band, inviting participation in
29 the scoping process related to NRC's environmental review of the
30 license renewal application for Vermont Yankee Nuclear Power
31 Station (Accession No. ML061300680).
32
- 33 May 10, 2006 Letter to The Honorable Nelson Bolding, Chief, Boldwing Clan, inviting
34 participation in the scoping process related to NRC's environmental
35 review of the license renewal application for Vermont Yankee Nuclear
36 Power Station (Accession No. ML061310133).
37
38
39
40

- 1 May 10, 2006 Letter to The Honorable Tom Eagle Rising Libby, Chief, Greater
2 Lowell Indian Cultural Association, inviting participation in the scoping
3 process related to NRC's environmental review of the license renewal
4 application for Vermont Yankee Nuclear Power Station
5 (Accession No. ML061300677).
6
- 7 May 10, 2006 Letter to The Honorable Paul Pouliot, Council Chief, Cowasuck
8 Band-Pennacook Abenaki People, inviting participation in the scoping
9 process related to NRC's environmental review of the license renewal
10 application for Vermont Yankee Nuclear Power Station
11 (Accession No. ML061310144).
12
- 13 May 10, 2006 Letter to The Honorable Peter Newell, Council Chief, NH Intertribal
14 Native American Council, inviting participation in the scoping process
15 related to NRC's environmental review of the license renewal
16 application for Vermont Yankee Nuclear Power Station
17 (Accession No. ML061310108).
18
- 19 May 10, 2006 Letter to The Honorable Charles True, Chief, Abenaki Nation of New
20 Hampshire, inviting participation in the scoping process related to
21 NRC's environmental review of the license renewal application for
22 Vermont Yankee Nuclear Power Station
23 (Accession No. ML061300684).
24
- 25 May 10, 2006 Letter to Ms. Nancy Lyons, Ambassador, First Nation of New
26 Hampshire, inviting participation in the scoping process related to
27 NRC's environmental review of the license renewal application for
28 Vermont Yankee Nuclear Power Station
29 (Accession No. ML061300480).
30
- 31 May 10, 2006 Letter to Mr. Steven Montembeault, President, Laconia Indian
32 Historical Association, inviting participation in the scoping process
33 related to NRC's environmental review of the license renewal
34 application for Vermont Yankee Nuclear Power Station
35 (Accession No. ML061300282).
36
- 37 June 1, 2006 Letter to Entergy from NRC, "Request for Additional Information (RAI)
38 Regarding Severe Accident Mitigation Alternatives (SAMAs) for
39 Vermont Yankee Nuclear Power Station"
40 (Accession No. ML061520506).
41
- 42 July 11, 2006 "Summary of Public Scoping Meetings Conducted Related to the
43 Review of Vermont Yankee Nuclear Power Station License Renewal
44 Application" (Accession No. ML061920495).
45

Appendix C

- 1 July 21, 2006 Letter from NRC to Mr. Marvin Moriarty, U.S. Fish and Wildlife Service
2 (FWS), Northeast Regional Office, "Amended Request for List of
3 Protected Species Within the Area Under Evaluation for the Vermont
4 Yankee Nuclear Power Station License Renewal Application Review,"
5 (Accession No. ML062020755).
- 6 August 1, 2006 Letter from Entergy to NRC, "Vermont Yankee Nuclear Power Station
7 License No. DPR-28 (Docket No. 50-271) License Renewal
8 Application, Amendment 7," (Accession No. ML062160079)
- 9 August 10, 2006 Letter from U.S. Fish and Wildlife Service to Rani Franovich, NRC,
10 regarding threatened and endangered species, (Accession No.
11 ML062370102)
- 12 August 25, 2006 Email from Lynn DeWald, Entergy, to Richard Emch, NRC, "Appendix
13 3 to 316a Demonstration," (Accession No. ML062920340)
- 14 September 15, 2006 Letter from U.S. National Marine Fisheries Service to Rani Franovich,
15 NRC, "Vermont Yankee Nuclear Power Station Renewal Application
16 Review," (Accession No. ML063260338)
- 17 September 18, 2006 Email from Bob West, FTN Associates, to Richard Emch, NRC,
18 "VYNPS ER - Supplemental Information Chestnut Hill 115-kV
19 Transmission Line," (Accession No. ML062850144)
- 20 September 18, 2006 Email from Lynn DeWald, Entergy, to Richard Emch, NRC, "Air
21 Emissions Inventory Report foer 2005 and MSDS for Nalco H-550,"
22 (Accession No. ML062850148)
- 23 September 19, 2006 Letter from Entergy to NRC, "Vermont Yankee Nuclear Power Station
24 License No. DPR-28 (Docket No. 50-271) License Renewal
25 Application, Amendment 13," (Accession No. ML062680034)
- 26 September 27, 2006 Email from Richard L. Emch, Jr., NRC to Michael Hamer, Entergy,
27 "Request for Clarification Regarding Responses to RAIs for Severe
28 Accident Mitigation Alternatives for the Vermont Yankee Nuclear
29 Power Station (TAC No. MC9670)," (Accession No. ML062920434)
- 30 September 30, 2006 Email from Lynn DeWald, Entergy, to Richard Emch, NRC, "VY 2005
31 DMR's," (Accession No. ML062910400)

1	September 30, 2006	Email from Lynn DeWald, Entergy, to Richard Emch, NRC, "VY 2006 DMR's to date," (Accession No. ML062920270)
2	October 3, 2006	Email from Lynn DeWald, Entergy, to Richard Emch, NRC, "Waste Minimization Plan," (Accession No. ML062920265)
3	October 3, 2006	Email from Jill Brochu, Entergy, to Richard Emch, NRC, "Figures 3-2 and 3-3 ER," (Accession No. ML062920352)
4	October 3, 2006	Email from Lynn DeWald, Entergy, to Richard Emch, NRC, "Current Air Certification and Fishway Temperature Table form 2003 Annual Report," (Accession No. ML062920385417)
5	October 3, 2006	Email from Lynn DeWald, Entergy, to Richard Emch, NRC, "Cooling Tower Report for VY," (Accession No. ML062920423)
6	October 3, 2006	Email from Rick Buckley, Entergy, to Richard Emch, NRC, "Thermophilic Microorganisms," (Accession No. ML062920358)
7	October 5, 2006	Email from Lynn DeWald, Entergy, to Richard Emch, NRC, "VY Cooling Tower Operation," (Accession No. ML062920372)
8	October 5, 2006	Email from Lynn DeWald, Entergy, to Richard Emch, NRC, "VY Drift," (Accession No. ML062920377)
9	October 5, 2006	Email from Lynn DeWald, Entergy, to Richard Emch, NRC, "Current IDP Permit," (Accession No. ML062920385)
10	October 12, 2006	Email from Lynn DeWald, Entergy, to Richard Emch, NRC, "Ecological Studies of the Connecticut River Vernon/Vermont Report X," (Accession No. ML062920069)
11	October 12, 2006	Email from Lynn DeWald, Entergy, to Richard Emch, NRC, "VY Annual Ecological reorts from 1980's," (Accession No. ML062980249)
12	October 12, 2006	Email from Lynn DeWald, Entergy, to Richard Emch, NRC, "Ecological Studies of the Connecticut River Vernon,Vermont Report 31," (Accession No. ML062920329)
13	October 17, 2006	Email from Lynn DeWald, Entergy, to Richard Emch, NRC, "Ecological Studies of the Connecticut River Vernon/Vermont Report XIV," (Accession No. ML062920075)

Appendix C

- 1 October 20, 2006 Letter from Entergy to NRC, "Vermont Yankee Nuclear Power Station
2 License No. DPR-28 (Docket No. 50-271) License Renewal
3 Application, Amendment 18," (Accession No. ML062990155)
4
5 October 30, 2006 Letter from NRC to Entergy, "Issuance of Environmental Scoping
6 Summary Report Associated with the Staff's Review of the Application
7 by Entergy Nuclear Operations, Inc. For Renewal of the Operating
8 License for Vermont Yankee Nuclear Power Station (TAC NO.
9 MC9670)," (Accession No. ML063030576).
10
11 October 30, 2006 Letter from NRC to Mr. John Fisk, Vermont Electric Power Company,
12 "Vermont Yankee Nuclear Power Station License Renewal Application
13 Review," (Accession No. ML062970318).
14
15 November 6, 2006 Letter from Entergy to NRC, "Vermont Yankee Nuclear Power Station
16 License No. DPR-28 (Docket No. 50-271) License Renewal
17 Application, Amendment 21," (Accession No. ML063170080)
18

Appendix D

Organizations Contacted

Appendix D

Organizations Contacted

During the course of the U.S. Nuclear Regulatory Commission staff's independent review of environmental impacts from operations during the renewal term, the following Federal, State, regional, local, and Native American Tribal agencies were contacted:

Abenaki Nation of Missisquoi, St. Francis/Sokoki Band, Swanton, Vermont

Abenaki Nation of New Hampshire, Whitefield, New Hampshire

Advisory Council on Historic Preservation

Boldwing Clan, Goffstown, New Hampshire

Cheshire County, Keene, New Hampshire

Cowasuck Band-Pennacook Abenaki People, Forestdale, Massachusetts

First Nation of New Hampshire, Franconia, New Hampshire

Franklin Council of Governments Greenfield Massachusetts

Greater Lowell Indian Cultural Association, Lowell, Massachusetts

Laconia Indian Historical Association, Laconia, New Hampshire

National Marine Fisheries Service, Gloucester, Massachusetts

New Hampshire Fish and Game Department, Concord, New Hampshire

New Hampshire Intertribal Native American Council, Inc., New Hampshire

Editorial Team: Prof. Dr. M. A. Riaz, Prof. Dr. M. I. Khan, Prof. Dr. M. S. Qadri

Appendix D

- 1 Vermont Agency of Natural Resources, Waterbury Vermont
- 2
- 3 Vermont Department of Environmental Conservation, Waterbury, Vermont
- 4
- 5 Vermont Department of Health, Division of Radiological Health, Burlington, Vermont
- 6
- 7 Vermont Division of Historic Preservation, Montpelier, Vermont
- 8
- 9 Vermont Fish and Wildlife Program, Waterbury, Vermont
- 10
- 11 Vermont Nongame and Natural Heritage Program, Waterbury, Vermont
- 12
- 13 Vernon Schools, Brattleboro, Vermont
- 14
- 15 Windham Regional Commission, Brattleboro, Vermont

Appendix E

Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. Compliance Status and Consultation Correspondence

Appendix E

Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. Compliance Status and Consultation Correspondence

Correspondence received during the process of evaluation of the application for renewal of the license for Vermont Yankee Nuclear Power Station (VYNPS) is identified in Table E-1. Copies of the correspondence are included at the end of this appendix.

The licenses, permits, consultations, and other approvals obtained from Federal, State, regional, and local authorities for VYNPS are listed in Table E-2.

Table E-1. Consultation Correspondence

Source	Recipient	Date of Letter
U.S. Nuclear Regulatory Commission (R.L. Franovich)	U.S. National Marine Fisheries Service (P. Kurkul)	May 5, 2006
U.S. Nuclear Regulatory Commission (R.L. Franovich)	U.S. Fish and Wildlife Service (M. Moriarty)	May 5, 2006
U.S. Nuclear Regulatory Commission (R.L. Franovich)	Director, Advisory Council on Historic Preservation (D. Klima)	May 8, 2006
U.S. Nuclear Regulatory Commission (R.L. Franovich)	Vermont State Historic Preservation Officer (J. Lendway)	May 8, 2006
U.S. Nuclear Regulatory Commission (R.L. Franovich)	Boldwing Clan (N. Bolding)	May 10, 2006 ^(a)
U.S. Nuclear Regulatory Commission (R.L. Franovich)	U.S. Fish and Wildlife Service (M. Moriarty)	July 21, 2006
U.S. Fish and Wildlife Service (M.J. Amaral)	U.S. Nuclear Regulatory Commission (R.L. Franovich)	August 10, 2006
U.S. National Marine Fisheries Service (L.A. Chiarella)	U.S. Nuclear Regulatory Commission (R.L. Franovich)	September 15, 2006

(a) Similar letters were sent to seven other Native American Tribes listed in Appendix C.

Appendix E

1 In the letter to the U.S. National Marine Fisheries Service dated May 5, 2006, the NRC
2 requested that the NMFS determine if any species needed to be evaluated under the essential
3 fish habitat provisions of the Magnuson-Stevens Fishery Conservation and Management Act for
4 the Vermont Yankee license renewal review. In the letter to the NRC dated September 15,
5 2006, the NMFS indicated that the Connecticut River and tributaries are designated essential
6 fish habitat for Atlantic salmon; therefore, the NMFS instructed the NRC to evaluate the impact
7 of the operation of VYNPS on the essential fish habitat of the Atlantic salmon. The NRC staff's
8 assessment of the essential fish habitat for the Atlantic salmon, "ESSENTIAL FISH HABITAT
9 ASSESSMENT FOR RENEWAL OF THE VERMONT YANKEE NUCLEAR POWER STATION
10 OPERATING LICENSE," is included in this appendix for review by the NMFS.

11

1
2
3
Appendix E

4
5
6
7
8
9
10
11
12
13
Table E-2. Federal, State, Local, and Regional Licenses, Permits, Consultations, and Other
Approvals for Vermont Yankee Nuclear Power Station

4 Agency	5 Authority	6 Description	7 Number	8 Issue Date	9 Expiration Date	10 Remarks
NRC	10 CFR Part 50	Operating license, Vermont Yankee Nuclear Power Station	DPR-28	04/09/72	03/21/12	Authorizes operation of the VYNPS.
FWS	Section 7 of the Endangered Species Act (16 USC 1536)	Consultation	NA	NA	NA	Requires a Federal agency to consult with the FWS regarding whether a proposed action will affect endangered or threatened species.
NOAA	Section 7 of the Endangered Species Act and Essential Fish Habitat	Consultation	NA	NA	NA	Requires a Federal agency to consult with the NOAA fisheries regarding whether a proposed action will affect endangered or threatened species and essential fish habitat.
Vermont Division of Historic Preservation	Section 106 of the National Historic Preservation Act	Consultation	NA	NA	NA	The National Historic Preservation Act requires Federal agencies to take into account the effect of any undertaking on any district, site, building, structure, or object that is included in or eligible for inclusion in the <i>National Register of Historic Places</i> .
VDEC	Section 112 of the Clean Air Act	Air Contaminant Source Registration Certificate	WM2335	07/01/06	06/30/07	Operation of air emission sources (diesel generators, boilers, and oil burners).
VDEC	Section 402 of the Federal Water Pollution Control Act	NPDES Permit	VT0000264 (VDEC #3-1199)	07/11/01	03/31/06 ^{a)}	Plant wastewater discharges to Connecticut River.

Table E-2. (contd)

1	2	3	4	Agency	Authority	Description	Number	Issue Date	Expiration Date	Remarks
December 2006		VDEC	Subtitle C of the Resource Conservation and Recovery Act	Hazardous Waste Generator	VTR00504167	NA	NA			Hazardous waste generation.
		VDEC	Title 10 V.S.A., §1259 and §1263	Indirect Discharge Permit	ID-9-0036-2	12/14/05	09/30/10			Indirectly discharge treated domestic sewage and other wastes to the groundwater and indirectly into the Connecticut River.
	E-4	VDEC	Title 10 V.S.A., §1671 and §1675(b)	Public Water System Permit to Operate (Construction Office Building Water System)	20559	05/21/02	05/21/08			Withdrawal of groundwater for drinking and plant purposes.
		VDEC	Title 10 V.S.A., §1671 and §1675(b)	Public Water System Permit to Operate (Main Plant Water System)	8332	05/21/02	05/21/08			Withdrawal of groundwater for drinking and plant purposes.
		VDEC	Title 10 V.S.A., §1671 and §1263	Public Water System Permit to Operate (New Engineering Office Building Water System)	20738	05/21/02	05/21/08			Withdrawal of groundwater for drinking and plant purposes.
		USACE	Section 404 of the Clean Water Act	Dredging Permit	200302129	10/15/02	10/15/07			Fill in of the Connecticut River in conjunction with the maintenance of security wires at the intake structure.
		VDEC	RCRA-Subtitle 1	Underground Storage Permit	806	10/01/04	10/01/09			Underground diesel and gasoline storage.
		VDEC	Section 405 (d) and 40 CFR 503 of the Clean Water Act	Solid Waste Management Facility Certification	F9906-A1	12/03/04	09/30/09			Land application of septicage.
		DOT	49 CFR 107, Subpart G	Hazardous Materials Certificate of Registration	063003 006 013LN	03/21/72	03/21/12			Radioactive and hazardous materials shipments.

Appendix E

Table E-2. (contd)

1	2	3	4	Agency	Authority	Description	Number	Issue Date	Expiration Date	Remarks
CVDEM	Title 44, Code of Virginia, Chapter 3.3, Section 44-146.30	Application for Registration to Transport Hazardous Radioactive Materials	VY-S-123107	12/27/05	12/21/07	Transportation of radioactive waste into the Commonwealth of Virginia.				
SCDHEC	Act No. 429 of 1980, South Carolina Radioactive Waste Transportation and Disposal Act	South Carolina Radioactive Waste Transport Permit	0002-44-04-X	01/01/06	12/31/06	Transportation of radioactive waste into the State of South Carolina.				
TDEC	Tennessee Department of Environment and Conservation Regulations	Tennessee Radioactive Waste-License-for-Delivery	T-VT001-L06	01/01/06	12/31/06	Shipment of radioactive material into Tennessee to a disposal/processing facility.				
(a)	Application pending.									
7	CFR	= <i>Code of Federal Regulations</i>								
8	CVDEM	= Code of Virginia, Department of Emergency Management								
9	DOT	= U.S. Department of Transportation								
10	FWS	= U.S. Fish and Wildlife Service								
11	NA	= not applicable								
12	NOAA	= National Oceanic and Atmospheric Administration								
13	NPDES	= National Pollutant Discharge Elimination System								
14	NRC	= U.S. Nuclear Regulatory Commission								
15	RCRA	= Resource Conservation and Recovery Act								
16	SCDHEC	= South Carolina Department of Health and Environmental Control								
17	TDEC	= Tennessee Department of Environment and Conservation								
18	USACE	= U.S. Army Corps of Engineers								
19	USC	= <i>United States Code</i>								
20	VDEC	= Vermont Department of Environmental Conservation								
21	VNNHP	= Vermont Nongame and Natural Heritage Program								
22	VYNPS	= Vermont Yankee Nuclear Power Station								

Appendix E

May 5, 2006

Ms. Patricia A. Kurkul, Regional Administrator
NOAA's National Marine Fisheries Service
Northeast Regional Office
One Blackburn Drive
Gloucester, MA 09130-2298

SUBJECT: REQUEST FOR LIST OF PROTECTED SPECIES AND ESSENTIAL FISH
HABITAT WITHIN THE AREA UNDER EVALUATION FOR THE VERMONT
YANKEE NUCLEAR POWER STATION LICENSE RENEWAL APPLICATION
REVIEW

Dear Ms. Kurkul:

The U.S. Nuclear Regulatory Commission (NRC) is reviewing an application submitted by Entergy Nuclear Operations, Inc. (Entergy) for the renewal of the operating license for the Vermont Yankee Nuclear Power Station (VYNPS). VYNPS is located in the town of Vernon, Vermont, in Windham County on the west shore of the Connecticut River. As part of the review of the license renewal application (LRA), the NRC is preparing a Supplemental Environmental Impact Statement (SEIS) under the provisions of Title 10 of the *Code of Federal Regulations* Part 51 (10 CFR Part 51), the NRC regulation that implements the National Environmental Policy Act (NEPA) of 1969. The SEIS includes an analysis of pertinent environmental issues, including endangered or threatened species and impacts to marine resources and habitat. This letter is being submitted under the provisions of the Endangered Species Act of 1973, as amended, and the Fish and Wildlife Coordination Act of 1934, as amended, and the Magnuson-Stevens Fishery Conservation and Management Act.

The proposed action would include the use and continued maintenance of existing plant facilities and transmission lines. VYNPS stated that no major refurbishment activities have been identified as necessary to support the continued operation of VYNPS beyond the end of the existing operating license term. VYNPS is situated on approximately 125 acres of land on the west shore of the Connecticut River 0.75 miles upstream of the Vernon Hydroelectric Station. This section of the river is known as Vernon Pool. The areas adjacent to the station are primarily farm and pasture lands. The area within a five mile radius is predominantly rural with the exception of a portion of the town of Brattleboro, Vermont, and the town of Hinsdale, New Hampshire. Between 75 percent and 80 percent of the area within five miles of the station is wooded. The remainder is occupied by farms and small industries. Enclosure 1 shows the layout of the general area near the VYNPS site and Enclosure 2 presents an overview of the site location.

Appendix E

P. Kurkul

- 2 -

The VYNPS utilizes a once-through cooling system and mechanical draft cooling towers to remove waste heat from the condensers. The three circulating water pumps are located in the enclosed intake structure at the river bank. Water from the main condensers is returned to the discharge structure where it is either discharged through an aerating structure to the river or is diverted to the cooling towers. Water circulated through the towers may be either discharged through the aerating structure to the river or recirculated in a closed loop path to the intake structure, or a combination of both, known as hybrid cycle mode. The discharge path is manually selected by the operator and is contingent upon seasonal variation in environmental parameters.

The only transmission lines considered to be in scope for the review are located inside the 125 acre plant site. These transmission lines were constructed to connect VYNPS to the New England transmission grid. The transmission lines exiting the switchyards are part of the New England transmission grid that was constructed to supply purchased power to the State of Vermont. The New England transmission grid is not considered to be in scope of the license renewal review.

To support the SEIS preparation process and to ensure compliance with Section 7 of the Endangered Species Act, the NRC requests information on Federally listed, proposed and candidate species, and critical habitat under the jurisdiction of the National Marine Fisheries Service that may be in the vicinity of the VYNPS site.

In addition, please provide any information you consider appropriate under the provisions of the Fish and Wildlife Coordination Act. Also in support of the SEIS preparation and to ensure compliance with Section 305 of the Magnuson-Stevens Fishery Conservation and Management Act, the NRC requests a list of essential fish habitat that has been designated in the vicinity of the VYNPS site.

From May 23-25, 2006, the NRC staff plans to conduct a site audit at the VYNPS. On June 7, 2006, the NRC staff plans to hold two public NEPA scoping meetings at the Latchis Theatre, 50 Main Street, Brattleboro, Vermont 05301. The first session will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second session will convene at 7:00 p.m., with a repeat of the overview portions of the meeting, and will continue until 10:00 p.m., as necessary. In addition to the environmental scoping meeting described above, the NRC will hold an informal open house at the Quality Inn & Suites, 1380 Putney Road, Brattleboro, Vermont 05301, on Tuesday, June 6, 2006, from 2:00-8:00 p.m., as necessary. You and your staff are invited to attend both the site audit and the public meetings. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is December 2006.

Appendix E

P. Kurkul

- 3 -

If you have any questions concerning the NRC staff review of this LRA, please contact Mr. Richard L. Emch Jr., Senior Environmental Project Manager at 301-415-1590 or RLE@nrc.gov.

Sincerely,

/RA/

Rani Franovich, Branch Chief
Environmental Branch B
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-271

Enclosures:

1. Layout of General Area near VYNPS Site
2. Overview of the Site Location

cc w/encls.: See next page

Appendix E

May 5, 2006

Mr. Marvin Moriarty, Regional Director
Northeast Regional Office
U.S. Fish and Wildlife Service
300 Westgate Center Drive
Hadley, MA 01035-9589

SUBJECT: REQUEST FOR LIST OF PROTECTED SPECIES WITHIN THE AREA UNDER
EVALUATION FOR THE VERMONT YANKEE NUCLEAR POWER STATION
LICENSE RENEWAL APPLICATION REVIEW

Dear Mr. Moriarty:

The U.S. Nuclear Regulatory Commission (NRC) is reviewing an application submitted by Entergy Nuclear Operations, Inc. (Entergy) for the renewal of the operating license for the Vermont Yankee Nuclear Power Station (VYNPS). VYNPS is located in the town of Vernon, Vermont, in Windham County on the west shore of the Connecticut River immediately upstream of the Vernon Hydroelectric Station. As part of the review of the license renewal application (LRA), the NRC is preparing a Supplemental Environmental Impact Statement (SEIS) under the provisions of Title 10 of the *Code of Federal Regulations* Part 51 (10 CFR Part 51), the NRC regulation that implements the National Environmental Policy Act (NEPA) of 1969. The SEIS includes an analysis of pertinent environmental issues, including endangered or threatened species and impacts to fish and wildlife. This letter is being submitted under the provisions of the Endangered Species Act of 1973, as amended, and the Fish and Wildlife Coordination Act of 1934, as amended.

The proposed action would include the use and continued maintenance of existing plant facilities and transmission lines. VYNPS stated that no major refurbishment activities have been identified as necessary to support the continued operation of VYNPS beyond the end of the existing operating license term. VYNPS is situated on approximately 125 acres of land on the west shore of the Connecticut River 0.75 miles upstream of the Vernon Hydroelectric Station. This section of the river is known as Vernon Pool. The areas adjacent to the station are primarily farm and pasture lands. The area within a five mile radius is predominantly rural with the exception of a portion of the town of Brattleboro, Vermont, and the town of Hinsdale, New Hampshire. Between 75 percent and 80 percent of the area within five miles of the station is wooded. The remainder is occupied by farms and small industries. Enclosure 1 shows the layout of the general area near the VYNPS site and Enclosure 2 presents an overview of the site location.

Appendix E

M. Moriarty

-2-

The VYNPS utilizes a once-through cooling system and mechanical draft cooling towers to remove waste heat from the condensers. The three circulating water pumps are located in the enclosed intake structure at the river bank. Water from the main condensers is returned to the discharge structure where it is either discharged through an aerating structure to the river or is diverted to the cooling towers. Water circulated through the towers may be either discharged through the aerating structure to the river or recirculated in a closed loop path to the intake structure, or a combination of both, known as hybrid cycle mode. The discharge path is manually selected by the operator and is contingent upon seasonal variation in environmental parameters.

The only transmission lines considered to be in scope for the review are located inside the 125 acre plant site. These transmission lines were constructed to connect VYNPS to the New England transmission grid. The transmission lines exiting the switchyards are part of the New England transmission grid that was constructed to supply purchased power to the State of Vermont. The New England transmission grid is not considered to be in scope of the license renewal review.

To support the SEIS preparation process and to ensure compliance with Section 7 of the Endangered Species Act, the NRC requests information on Federally listed, proposed, and candidate species and critical habitat that may be in the vicinity of the VYNPS site. In addition, please provide any information you consider appropriate under the provisions of the Fish and Wildlife Coordination Act.

From May 23-25, 2006, the NRC staff plans to conduct a site audit at the VYNPS. On June 7, 2006, the NRC staff plans to hold two public NEPA scoping meetings at the Latchis Theatre, 50 Main Street, Brattleboro, Vermont 05301. The first session will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second session will convene at 7:00 p.m., with a repeat of the overview portions of the meeting, and will continue until 10:00 p.m., as necessary. In addition to the environmental scoping meeting described above, the NRC will hold an informal open house at the Quality Inn & Suites, 1380 Putney Road, Brattleboro, Vermont 05301, on Tuesday, June 6, 2006, from 2:00 p.m.-8:00 p.m., as necessary. You and your staff are invited to attend both the site audit and the public meetings. Your office will receive a copy of the draft SEIS along with a request for comments. The anticipated publication date for the draft SEIS is December 2006.

Appendix E

M. Moriarty

-3-

If you have any questions concerning the NRC staff review of this LRA, please contact Mr. Richard L. Emch Jr., Senior Environmental Project Manager at 301-415-1590 or RLE@nrc.gov.

Sincerely,

/RA Michael Masnik For/
Rani Franovich, Branch Chief
Environmental Branch B
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-271

Enclosures:

1. Layout of General Area near VYNPS Site
2. Overview of the Site Location

cc w/encls.: See next page

Appendix E

May 8, 2006

Mr. Don L. Klima, Director
Advisory Council on Historic Preservation
Office of Federal Agency Programs
1100 Pennsylvania Ave, NW, Suite 803
Washington, DC 20004

SUBJECT: VERMONT YANKEE NUCLEAR POWER STATION LICENSE RENEWAL
APPLICATION REVIEW

Dear Mr. Klima:

The U.S. Nuclear Regulatory Commission (NRC) staff is reviewing an application to renew the operating license for the Vermont Yankee Nuclear Power Station (VYNPS). VYNPS is located in the town of Vernon, Vermont, in Windham County on the west shore of the Connecticut River. VYNPS is operated by Entergy Nuclear Operations, Inc. (Entergy). The application for renewal was submitted by Entergy in a letter dated on January 25, 2006, as supplemented by letter dated March 15, 2006, pursuant to Title 10 of the *Code of Federal Regulations* Part 54 (10 CFR Part 54).

The NRC has established that, as part of the staff's review of any nuclear power plant license renewal action, a site-specific Supplemental Environmental Impact Statement (SEIS) to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (GEIS), NUREG-1437, will be prepared under the provisions of 10 CFR Part 51, the NRC regulation that implements the National Environmental Policy Act of 1969 (NEPA). In accordance with 36 CFR 800.8, the SEIS will include analyses of potential impacts to historic and cultural resources.

On June 7, 2006, the NRC will conduct two public NEPA scoping meetings at the Latchis Theatre, 50 Main Street, Brattleboro, Vermont 05301. In addition to the environmental scoping meeting described above, the NRC will hold an informal open house at the Quality Inn & Suites, 1380 Putney Road, Brattleboro, Vermont 05301, on Tuesday, June 6, 2006, from 2:00 p.m. to 8:00 p.m., as necessary. You and your staff are invited to attend. Your office will receive a copy of the draft SEIS along with a request for comments. The staff expects to publish the draft SEIS in December 2006.

Appendix E

D. Klima

2

If you have any questions or require additional information, please contact the Senior Environmental Project Manager, Mr. Richard L. Emch, Jr., by telephone at 301-415-1590 or by e-mail RLE@nrc.gov.

Sincerely,

/RA/

Rani L. Franovich, Branch Chief
Environmental Branch B
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-271

cc: See next page

Appendix E

May 8, 2006

Ms. Jane Lendway
State Historic Preservation Officer
Vermont Division for Historic Preservation
National Life Building, Drawer 20
Montpelier, VT 05620-0501

SUBJECT: VERNONT YANKEE NUCLEAR POWER STATION LICENSE RENEWAL
APPLICATION REVIEW (SHPO NO. DHP NO. WD03-001)

Dear Ms. Lendway:

The U.S. Nuclear Regulatory Commission (NRC) staff is reviewing an application to renew the operating license for the Vermont Yankee Nuclear Power Station (VYNPS). VYNPS is located in the town of Vernon, Vermont, in Windham County on the west shore of the Connecticut River. VYNPS is operated by Entergy Nuclear Operations, Inc. (Entergy). The application for renewal was submitted by Entergy in a letter dated on January 25, 2006, as supplemented by letter dated March 15, 2006, pursuant to Title 10 of the *Code of Federal Regulations* Part 54 (10 CFR Part 54).

The NRC has established that, as part of the staff's review of any nuclear power plant license renewal action, a site-specific Supplemental Environmental Impact Statement (SEIS) to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (GEIS), NUREG-1437, will be prepared under the provisions of 10 CFR Part 51, the NRC regulation that implements the National Environmental Policy Act of 1969 (NEPA). In accordance with 36 CFR 800.8, the SEIS will include analyses of potential impacts to historic and cultural resources.

In the context of the National Historic Preservation Act of 1966, as amended, the NRC staff has determined that the area of potential effect (APE) for a license renewal action is the area at the power plant site and its immediate environs that may be impacted by post-license renewal land-disturbing operations or projected refurbishment activities associated with the proposed action. The APE may extend beyond the immediate environs in those instances where post-license renewal land-disturbing operations or projected refurbishment activities specifically related to license renewal may potentially have an effect on known or proposed historic sites. This determination is made irrespective of ownership or control of the lands of interest.

On June 7, 2006, the NRC will conduct two public NEPA scoping meetings at the Latchis Theatre, 50 Main Street, Brattleboro, Vermont 05301. In addition to the environmental scoping meeting described above, the NRC will hold an informal open house at the Quality Inn & Suites, 1380 Putney Road, Brattleboro, Vermont 05301, on Tuesday, June 6, 2006, from 2:00 p.m.- 8:00 p.m., as necessary. You and your staff are invited to attend. Your office will receive a copy of the draft

Appendix E

Ms. Lendway

-2-

SEIS along with a request for comments. The staff expects to publish the draft SEIS in December 2006.

If you have any questions or require additional information, please contact Mr. Richard L. Emch, Jr., Senior Environmental Project Manager, by telephone at 301-415-1590 or by e-mail at RLE@nrc.gov.

Sincerely,
/RA/

Rani L. Franovich, Branch Chief
Environmental Branch B
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-271

cc: See next page

Appendix E

May 10, 2006

The Honorable Nelson Bolding, Chief
Boldwing Clan
357 Tirrell Hill Road
Goffstown, NH 03045

SUBJECT: REQUEST FOR COMMENTS CONCERNING THE VERMONT YANKEE
NUCLEAR POWER STATION LICENSE RENEWAL APPLICATION REVIEW

Dear Chief Bolding:

The U.S. Nuclear Regulatory Commission (NRC) is seeking input for its environmental review of an application from Entergy Nuclear Operations, Inc. (Entergy) for the renewal of the operating license for the Vermont Yankee Nuclear Power Station (VYNPS), located in the town of Vernon, Vermont, in Windham County on the west shore of the Connecticut River. VYNPS is in close proximity to lands that may be of interest to the Boldwing Clan. As described below, the NRC's process includes an opportunity for public and inter-governmental participation in the environmental review. We want to ensure that you are aware of our efforts and, pursuant to Title 10 of the *Code of Federal Regulations* Part 51.28(b) (10 CFR 51.28(b)), the NRC invites the Boldwing Clan to provide input to the scoping process relating to the NRC's environmental review of the application. In addition, as outlined in 36 CFR 800.8, the NRC plans to coordinate compliance with Section 106 of the National Historic Preservation Act of 1966, through the requirements of the National Environmental Policy Act of 1969.

Under NRC regulations, the original operating license for a nuclear power plant is issued for up to 40 years. The license may be renewed for up to an additional 20 years, if NRC requirements are met. The current operating license for VYNPS will expire in March 21, 2012. Entergy submitted its application for renewal of the VYNPS operating license in a letter dated January 25, 2006, as supplemented by letter dated March 15, 2006.

The NRC is gathering information for a VYNPS site-specific supplement to its "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (GEIS), NUREG-1437. The supplement will contain the results of the review of the environmental impacts on the area surrounding the VYNPS site that are related to terrestrial ecology, aquatic ecology, hydrology, cultural resources, and socioeconomic issues (among others) and will contain a recommendation regarding the environmental acceptability of the license renewal action. Provided for your information is the layout of the general area near the VYNPS site (Enclosure 1) and an overview of the site location (Enclosure 2).

Appendix E

Chief Bolding

-2-

The NRC will hold two public scoping meetings for the VYNPS license renewal supplement to the GEIS on June 7, 2006, at the Latchis Theatre, 50 Main Street, Brattleboro, Vermont 05301. There will be two sessions to accommodate interested parties. The first session will convene at 1:30 p.m. and will continue until 4:30 p.m., as necessary. The second session will convene at 7:00 p.m., with a repeat of the overview portions of the meeting, and will continue until 10:00 p.m., as necessary. Additionally, the NRC staff will host informal discussions one hour before the start of each session. To be considered, comments must be provided either at the transcribed public meetings or in writing. No formal comments on the proposed scope of the supplement to the GEIS will be accepted during informal discussions.

In addition to the environmental scoping meeting described above, the NRC will hold an informal open house at the Quality Inn & Suites, 1380 Putney Road, Brattleboro, Vermont 05301, on Tuesday, June 6, 2006, from 2:00 p.m. to 8:00 p.m., as necessary. At the open house, NRC staff will be available to provide information about the environmental review process for license renewal of nuclear plants. During the open house, members of the public will have the opportunity to provide formal comments on the proposed scope of the supplement to the GEIS either verbally or in writing to a transcriptionist. Comments provided to the transcriptionist will be considered in the same manner as comments provided during the scoping meetings described above. No formal comments on the proposed scope of the supplement to the GEIS will be accepted at the open house during informal discussions with the staff.

The license renewal application (LRA) is publicly available at the NRC Public Document Room (PDR), located at One White Flint North, 11555 Rockville Pike, Rockville, Maryland, 20852, or from the NRC's Agencywide Documents Access and Management System (ADAMS). The ADAMS Public Electronic Reading Room is accessible at <http://adamswebsearch.nrc.gov/dologin.html>. The Accession Number for the LRA is ML060300086. Persons who do not have access to ADAMS, or who encounter problems in accessing the documents located in ADAMS, should contact the NRC's PDR Reference staff by telephone at 1-800-397-4209, or 301-415-4737, or by e-mail at pdr@nrc.gov.

The VYNPS license renewal application is also available on the Internet at www.nrc.gov/reactors/operating/licensing/renewal/applications/vermont-yankee.html. In addition, the LRA is available for public inspection near the VYNPS site at the following four public libraries: Vernon Free Library, 567 Governor Hunt Road, Vernon, VT 05354; Brooks Memorial Library, 224 Main Street, Brattleboro, VT 05301; Hinsdale Public Library, 122 Brattleboro Road, Hinsdale, NH, 03451; and Dickinson Memorial Library, 115 Main Street, Northfield, MA 01360.

The GEIS, which assesses the scope and impact of environmental effects that would be associated with license renewal at any nuclear power plant site, also can be found on the NRC's website or at the NRC's PDR.

Please submit any comments that the Boldwing Clan may have to offer on the scope of the environmental review by June 23, 2006. Written comments should be submitted by mail to the Chief, Rules and Directives Branch, Division of Administrative Services, Mail Stop T-6D59, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001. Electronic comments may be submitted to the NRC by e-mail at VermontYankeeEIS@nrc.gov. At the conclusion of the scoping process, the NRC staff will prepare a summary of the significant issues identified and the conclusions reached, and mail a copy to you.

Appendix E

Chief Bolding

-3-

The staff expects to publish the draft supplement to the GEIS in December 2006. The NRC will hold another set of public meetings in the site vicinity to solicit comments on the draft. A copy of the draft supplemental environmental impact statement (SEIS) will be sent to you for your review and comment. After consideration of public comments received on the draft, the NRC will prepare a final SEIS. The issuance of a final SEIS for VYNPS is planned for August 2007. If you need additional information regarding the environmental review process, please contact Mr. Richard L. Emch, Jr., Senior Environmental Project Manager, at 301-415-1590 or by e-mail at RLE@nrc.gov.

Sincerely,
/RA/

Rani L. Franovich, Branch Chief
Environmental Branch B
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-271

Enclosures:

1. Layout of General Area near VYNPS Site
2. Overview of the Site Location

cc w/encls: See next page

Appendix E

July 21, 2006

Mr. Marvin Moriarty, Regional Director
Northeast Regional Office
U.S. Fish and Wildlife Service
300 Westgate Center Drive
Hadley, MA 01035-9589

SUBJECT: AMENDED REQUEST FOR LIST OF PROTECTED SPECIES WITHIN THE AREA UNDER EVALUATION FOR THE VERMONT YANKEE NUCLEAR POWER STATION LICENSE RENEWAL APPLICATION REVIEW

Dear Mr. Moriarty:

In a letter dated May 5, 2006, the U.S. Nuclear Regulatory Commission (NRC) staff requested information on Federally listed, proposed, and candidate species and critical habitat that might be in the vicinity of the Vermont Yankee Nuclear Power Station (VYNPS) site. In that letter the staff indicated that the only area considered to be in scope for the license renewal environmental review was the 125 acre plant site. The letter further stated that no transmission lines were considered to be in scope for the review.

After obtaining additional information related to the construction of the transmission lines, the staff has reconsidered its initial position and come to the conclusion that two transmission lines exiting the VYNPS will be considered within the scope of the environmental review.

The reconsidered transmission lines are the 115 Kv transmission lines from VYNPS to the Coolidge Substation in Vermont (51 miles) and from VYNPS to the Chestnut Hill Substation in New Hampshire (2 miles).

To support the Supplemental Environmental Impact Statement (SEIS) preparation process and to ensure compliance with Section 7 of the Endangered Species Act of 1973, the NRC requests information on Federally listed, proposed, and candidate species and critical habitat that might be in the vicinity of the VYNPS site and the previously mentioned transmission lines. In addition, please provide any information you consider appropriate under the provisions of the Fish and Wildlife Coordination Act.

Appendix E

M. Moriarty

- 2 -

VYNPS is situated on approximately 125 acres of land on the west shore of the Connecticut River 0.75 miles upstream of the Vernon Hydroelectric Station. This section of the river is known as Vernon Pool. Enclosure 1 shows the transmission line from VYNPS to the Coolidge Substation in Vermont. Enclosure 2 shows the transmission line from VYNPS to the Chestnut Hill Substation in New Hampshire.

Sincerely,

/RA/

Rani Franovich, Branch Chief
Environmental Branch B
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-271

Enclosures:
As stated

cc w/encls: See next page



UNITED STATES DEPARTMENT OF COMMERCE
National Oceanic and Atmospheric Administration
NATIONAL MARINE FISHERIES SERVICE
NORTHEAST REGION
One Blackburn Drive
Gloucester, MA 01930-2298

SEP 15 2006

Rani Franovich, Branch Chief
Environmental Branch B
Division of License Renewal
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

RE: Vermont Yankee Nuclear Power Station Renewal Application Review

Dear Mr. Franovich:

The National Marine Fisheries Service (NMFS) has reviewed the letter dated May 5, 2006 pertaining to the Vermont Yankee Nuclear Power Station (VYNPS) license renewal application. VYNPS is located on the Connecticut River in Vernon, Vt. The Nuclear Regulatory Commission (NRC) is preparing a Supplemental Environmental Impact Statement (SEIS) as part of the license renewal application. As part of the development of the SEIS, the NRC is seeking comments from NMFS pertaining to the Endangered Species Act (ESA), Fish and Wildlife Coordination Act, and Essential Fish Habitat (EFH) under the Magnuson-Stevens Fishery Conservation and Management Act (MSA). Therefore, NMFS has the following comments.

Endangered Species

While a population of the federally endangered shortnose sturgeon (*Acipenser brevirostrum*) occurs in the Connecticut River, this species does not occur upstream of the dam at Turners Falls. As such, no federally listed or proposed threatened or endangered species and/or designated critical habitat for listed species under the jurisdiction of NMFS are known to exist in the project area. Therefore, no further consultation pursuant to section 7 of the ESA is required. If project plans change or new information becomes available that changes the basis for this determination, then consultation should be reinitiated.

Fish and Wildlife Coordination Act

The Fish and Wildlife Coordination Act (FWCA) requires federal agencies to consult with federal and state natural resource agencies regarding activities or licensing that impact fish and wildlife resources. The Connecticut River supports a diverse array of aquatic species that help maintain a healthy ecosystem. American shad and sea lamprey, for instance, pass above the Vernon dam. Impacts on anadromous fish resources from facility operations should be fully evaluated in the SEIS.

Essential Fish Habitat

The EFH provisions of the MSA require federal agencies to consult with NMFS on projects such




Appendix E

as this which may adversely affect EFH. The consultation process is guided by the requirements of our EFH regulation at 50 CFR 600.905, which mandates the preparation of EFH assessments and generally outlines each agency's obligations in this consultation procedure. The Connecticut River and tributaries are designated EFH for Atlantic salmon. Impacts on Atlantic salmon and their habitat occurring from facility operations should be fully evaluated in the SEIS.

Should you have any questions about this matter, please contact Sean McDermott at 978-281-9113.

Sincerely,



Louis A. Chiarella
New England Field Office Supervisor
for Habitat Conservation

Appendix E



United States Department of the Interior

FISH AND WILDLIFE SERVICE

New England Field Office
70 Commercial Street, Suite 300
Concord, New Hampshire 03301-5087



August 10, 2006

Rani Franovich
Division of License Renewal
Nuclear Regulatory Commission
Washington, D.C. 20555-0001

Dear Mr. Franovich:

This responds to your recent correspondence requesting information on the presence of federally-listed and/or proposed endangered or threatened species in relation to the Vermont Yankee Nuclear Power Station.

Bald eagles (*Haliaeetus leucocephalus*) are known to nest less than 1 mile downstream of the plant. No other federally-listed or proposed, threatened or endangered species or critical habitat under the jurisdiction of the U.S. Fish and Wildlife Service are known to occur in the project area. Preparation of a Biological Assessment or further consultation with us under Section 7 of the Endangered Species Act is not required.

Based upon our knowledge, no impacts to the eagles are known to occur at this site that could be attributed to the power station or its transmission lines. This concludes our review of listed species and critical habitat in the project location and environs referenced above. No further Endangered Species Act coordination of this type is necessary for a period of one year from the date of this letter, unless additional information on listed or proposed species becomes available.

We will be providing comments with regard to the Fish and Wildlife Coordination Act under separate cover.

Thank you for your coordination. Please contact us at 603-223-2541 if we can be of further assistance. **In the future, in order to expedite your reply, please direct any inquiries of this nature to this office at the above address.**

Sincerely yours,

A handwritten signature in black ink that reads "Michael J. Amaral".

Michael J. Amaral
Endangered Species Specialist
New England Field Office

Appendix E

This page intentionally left blank.

**ESSENTIAL FISH HABITAT ASSESSMENT
FOR PROPOSED RENEWAL OF THE
VERMONT YANKEE NUCLEAR POWER
STATION OPERATING LICENSE**

Appendix E

This page intentionally left blank.

1.0 INTRODUCTION

The Magnuson-Stevens Fishery Conservation and Management Act (MSFCMA), which was reauthorized and amended by the Sustainable Fisheries Act of 1996, sets forth the essential fish habitat (EFH) provisions designed to protect important habitats of Federally managed marine and anadromous species. The Act requires the eight regional fishery management councils to describe and identify EFH, and to minimize the adverse effects of fishing on EFH. Pursuant to the Act, Congress has defined EFH as “those waters and substrate necessary to fish for spawning, breeding, feeding, or growth to maturity.” Federal agencies that fund, permit, or undertake activities that may adversely affect EFH are required to consult with the National Marine Fisheries Service (NMFS) regarding the potential effects of their actions on EFH, and respond in writing to NMFS’s conservation recommendations. For the purpose of consultation, an adverse effect includes any impact that reduces the quality and/or quantity of EFH. The consultation document must include the following information:

- A description of the proposed action;
- An analysis of the potential adverse effects of the action on EFH and the managed species;
- The Federal agency’s conclusions regarding the effects of the action on EFH; and
- Proposed mitigation, if applicable.

On January 25, 2006, Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy), submitted an application for renewal of the operating license (OL) of the Vermont Yankee Nuclear Power Station (VYNPS) to the U.S. Nuclear Regulatory Commission (NRC) (Energy 2006a). The current OL expires at midnight on March 21, 2012. As part of the application, Entergy submitted an Environmental Report (ER) (Entergy 2006b) prepared in accordance with the requirements of Title 10, Part 51, of the *Code of Federal Regulations* (10 CFR Part 51).

On April 21, 2006, the NRC staff published a Notice of Intent (NRC 2006a) to prepare a plant-specific supplement to the *Generic Environmental Impact Statement for License Renewal of Nuclear Plants* (GEIS) (NRC 1996,1999).^(a) During the development of the Supplemental Environmental Impact Statement (SEIS), the NRC staff visited the site, visited the Conte Anadromous Fish Lab, met with members of Federal and State regulatory agencies, spoke to local citizens, interviewed individuals who had conducted environmental research in the

(a) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the “GEIS” include the GEIS and its Addendum 1.

1 Appendix E

2 Connecticut River, and reviewed a variety of technical reports, journal articles, and other
3 relevant information to determine whether renewal would result in adverse environmental
4 impacts. This information and other sources relevant to EFH issues were consulted during the
5 development of this document. This EFH assessment has been developed to fulfill the NRC
6 requirement under the MSFCMA for the VYNPS license renewal review.

7 **2.0 PROPOSED FEDERAL ACTION**

8 The proposed Federal action is renewal of the OL for VYNPS, a nuclear power plant that is
9 located in southeastern Vermont in the town of Vernon, Windham County, on the western shore
10 of the Connecticut River at River Mile (RM) 142. VYNPS is a single-unit plant with a boiling
11 water reactor manufactured by General Electric. The unit was originally licensed for a reactor
12 core power of 1593 megawatts-thermal (MW[t]), with a net electrical capacity of 540 megawatts-
13 electric (MW[e]). VYNPS submitted, and the NRC approved, a power uprate to increase the
14 maximum core power level to 1912 MW(t) on March 2, 2006. The gross electrical output at this
15 core power level would be approximately 650 MW(e). The Connecticut River is the source for
16 cooling water for the main condensers at the VYNPS. Cooling river water can be circulated
17 through the system in one of three modes of operation: closed-cycle, open-cycle (also referred
18 to as once-through cooling), or hybrid-cycle. Cooling towers are used when the plant operates
19 in closed- or hybrid-cycle modes. The current OL for VYNPS expires on March 21, 2012. On
20 January 25, 2006, Entergy submitted an application (Entergy 2006a) to the NRC to renew the
21 OL for an additional 20 years of operation (i.e., until March 21, 2032).

22 **3.0 ENVIRONMENTAL SETTING**

23 VYNPS is located in southeastern Vermont, approximately 5 mi southeast of Brattleboro,
24 Vermont and 28 mi north of Amherst, Massachusetts (Figure 1). The plant site is located on the
25 western shore of the Connecticut River (Figure 2). VYNPS is located 0.75 mi upstream of the
26 Vernon Dam, which is located at RM 142 (Figure 3). Two other dams, Turners Falls (RM 123)
27 and Holyoke (RM 86) are also downstream of VYNPS on the main stem of the Connecticut
28 River. The area upstream of Vernon Dam is known as Vernon Pool. Vernon Pool covers 2250
29 acres (at full-pond elevation of 220.13 ft behind the Vernon Dam) and extends upstream to
30 Bellows Falls Dam at RM 174. Maximum water depth at Vernon Dam is 40 ft (Entergy 2006b).
31 The Connecticut River near Vernon Dam is about 0.5 mi wide (AEC 1972). The minimum
32 sustained flow from the Vernon Dam is 1250 cfs, or the inflow, if river flow is less than this.
33 Average daily flow is about 10,500 cfs with an average annual flow of $3.3 \times 10^{11} \text{ ft}^3$ (Entergy
34 2006b). During 2004, the lowest daily river discharge at Vernon Dam was 1757 cfs and the
35 highest was 50,618 cfs. Monthly flow rate averages from 6347 cfs in August to 23,570 cfs in
36 April (Normandeau 2005).

Appendix E




Figure 1. Location of Vermont Yankee Nuclear Power Station, 50-mi Region
 (Source: Entergy 2006b)

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38

Appendix E




Figure 2. Location of Vermont Yankee Nuclear Power Station,
6-mi Region (Source: Entergy 2006b)

1




Figure 3. Location of Vernon Dam and River Monitoring Stations 3 and 7 Relevant to VYNPS (Source: Entergy 2006b)

Appendix E

1 Yearly ambient water temperatures in the vicinity of VYNPS vary from 32 to 84°F with daily
2 variations rarely exceeding 2°F (Entergy 2006b). During 2004, the monthly average daily river
3 temperature upstream of VYNPS ranged from a low of 32.5°F in February to 72.7°F in July.
4 The lowest daily river temperature was 32.4°F on February 22, 2004 while the highest daily
5 river temperature was 76.4°F on August 5, 2004 (Normandeau 2005).

6
7 A number of physical and chemical stresses have caused major changes and modifications to
8 the aquatic resources within the Connecticut River. The major industrial use of the river is the
9 12 hydroelectric dams (9 are upstream of VYNPS) and 4 storage dams (3 are upstream of
10 VYNPS) located on the mainstream of the river. Vernon Dam creates a lentic (lake-like)
11 condition above the dam and a lotic (flowing) condition below the dam. A fishway was
12 constructed at Vernon Dam in 1981. Prior to that time, the dam was a barrier to fish movement.
13 The fishway is a concrete structure that consists of a vertical slot ladder from the tailrace to a
14 fish trap and viewing gallery. An Ice Harbor-style ladder provides passage from there to Vernon
15 Pool. The fishway is supplied with a flow of 65 cfs while it operates. An attraction flow of 40 cfs
16 is also discharged near the foot of the ladder (Normandeau 2004a). A downstream fish conduit
17 was first operated in 1991 (Normandeau 2004a). The primary downstream conduit, located in
18 the center of the powerhouse, has a 350-cfs bypass flow through a 9-ft by 6-ft gate and tube
19 that narrows to a 4-ft by 5-ft opening at its discharge end. An alternative or supplemental pipe
20 that supplies the 40 cfs attraction flow at the foot of the fishway was converted to a "fish pipe" in
21 1994 for additional downstream passage of fish (Normandeau 2004a). Both warmwater and
22 coolwater fish exist upstream and downstream of Vernon Dam. Fish are routinely sampled
23 upstream and downstream of Vernon Dam as part of the National Pollutant Discharge
24 Elimination System (NPDES) permit monitoring requirements (VANR 2006).

25 26 4.0 PLANT COOLING WATER SYSTEM DESCRIPTION

27
28 The Connecticut River is the source for cooling water for the main condensers at the VYNPS.
29 Cooling river water can be circulated through the system in one of three modes of operation:
30 closed-cycle, open-cycle (also referred to as once-through cooling), or hybrid-cycle. Cooling
31 towers are used when the plant operates in closed- or hybrid-cycle modes. Unless otherwise
32 noted, the discussion of the circulating-water system was obtained from the Final Environmental
33 Statement for VYNPS operations (AEC 1972) and the applicant's ER (Entergy 2006b,c).

34
35 In all three modes, the circulating water exits the condenser and flows into the discharge
36 structure. In the open-cycle mode, after entering the discharge structure the water returns to
37 the river through an aerating structure. The cooling towers are not used in the open-cycle mode
38 of operation. In both the closed-cycle and hybrid cycle, after entering the discharge structure,
39 the circulating water is pumped up to the cooling towers. After being cooled, the water returns
40 to a weir collection chamber in the discharge structure. A gate inside this chamber allows all or
41 a portion of the water to return to the intake structure. In the closed-cycle mode all of the tower
42 cooled water is returned to the intake structure for re-use in the condenser. In the hybrid cycle

mode of operation a portion of the water returns to the intake structure while the remainder is returned to the river through the aerating structure. The exact amount of water returned to both the intake structure and the river in hybrid mode depends on seasonal variation in environmental parameters, particularly the temperature in the Connecticut River. Blowdown from the circulating water system is discharged to the river through piping near the discharge structure. Make-up water lost from blowdown and evaporation from the cooling towers is withdrawn from the river. VYNPS has two mechanical draft cooling towers, one of which has a deep basin holding 1.4 million gal of water for emergency cooling (VDEC 2003, VDEC 2006a, Entergy 2004).

The concrete intake structure has three pump bays for three circulating pumps and two service water bays for four service water pumps and two fire water pumps. All bays are provided with trash racks and traveling water screens to remove debris in the intake water. Water treatment equipment at the intake structure delivers biocides to both the circulating water and service water pump bays to minimize biofouling of the system. Corrosive control agents and chemicals to adjust pH are also added (Entergy 2004).

Cooling water for the main condensers is drawn from the Connecticut River using three vertical circulating water pumps, which provide a total maximum flow capacity of 360,000 gpm (802 cfs) (during once-through operation) and a minimum of 10,000 gpm (22 cfs) (during closed-cycle operation). Approach velocities at the intake trash racks are about 1.2 ft/s at a low water level of 215 ft mean sea level (MSL) and 1.0 ft/s for the normal water level of 220 ft MSL, while intake velocities at the traveling screens are 1.96 ft/s for an extreme low water level of 212 ft MSL, 1.73 ft/s for a low water level of 215 ft MSL, and 1.57 ft/s for a normal water level of 220 ft MSL.

Water is also drawn from the river for the plant's service water system, which provides water for turbine and reactor auxiliary equipment cooling, reactor shutdown cooling, and miscellaneous services. Four vertical, two-stage, turbine-like pumps, located at the north end of the intake structure, supply water to the service water system, providing a total flow capacity of 13,400 gpm. Additionally, two pumps with a total flow capacity of 5000 gpm, which are operated infrequently, are located at the north end of the intake structure to withdraw water from the river for fire protection (Entergy 2006b).

Cooling water discharge to the Connecticut River flows through an aerating discharge structure located near the riverbank. The structure is about 199 ft long by 108 ft wide by 46 ft deep. An aerating spillway, consisting of three rows of dissipating concrete blocks with approximately nine blocks per row, is adjacent to and downstream of the discharge structure. It provides air entrainment, energy dissipation, and warm water dispersion of the discharged cooling water. Sheet piling is used to prevent scouring of the aerating apron (Entergy 2004). NPDES-permit established limitations for circulating water discharges are 543 million gpd for open- and hybrid-cycle modes and 12.1 million gpd for the closed-cycle mode (NRC 2006c).

Appendix E

5.0 POTENTIAL IMPACTS OF PLANT OPERATION ON BIOTA AND HABITAT

The cooling water system associated with VYNPS utilizes water from the Connecticut River and may potentially affect EFH in the following ways:

- Impingement of juvenile and adults life stages and/or their larger prey items;
 - Entrainment of eggs and larvae and/or planktonic prey items;
 - Withdrawal of water from the water column; and
 - Discharge of heated cooling water.

These impacts are discussed in this section.

5.1 IMPINGEMENT

As part of its NPDES permit requirements, Entergy is required to monitor fish impingement at VYNPS. Routine impingement sampling is conducted from April 1 through June 15 and from August 1 through October 31. Limits are established for the number of Atlantic salmon (*Salmo salar*) and American shad (*Alosa sapidissima*) that can be impinged. The impingement limit for Atlantic salmon is set at 0.1 percent of the estimated smolt-equivalents (estimated number of smolts from a population that successfully emigrate from a specified area) migrating past VYNPS. If the limit is exceeded, the plant must run in a closed-cycle mode until June 15. American shad impingement limit is set at one impinged shad for each adult shad that passes the Vernon Dam fishway and/or is transported by State or Federal fisheries personnel upstream of Vernon Dam (Aquatec 1990). Impingement numbers below those established for the two anadromous fish species are considered by the Environmental Advisory Committee^(a) (comprised of representatives from the Vermont Department of Environmental Conservation, Vermont Department of Fish and Wildlife, New Hampshire Department of Environmental Services, New Hampshire Department of Fish and Game, Massachusetts Department of Environmental Protection, Massachusetts Division of Fish and Wildlife, and the U.S. Fish and Wildlife Service (FWS) Coordinator of the Connecticut River Anadromous Fish Program) to be impingement losses that are not adverse to the populations of these species (Entergy 2006a). To date, the NPDES permit limits established for these species have not been exceeded.

(a) The Environmental Advisory Committee has an advisory function that reviews and evaluates the aquatic environmental monitoring and studies program at VYNPS. It also defines specific objective investigations for Entergy to complete.

1 During the initial FWPCA Section 316 Demonstration (Aquatec 1978), an average of 23 fish per
2 day was impinged during 685 days of once-through operation. The Turners Falls and Vernon
3 Dam fishways were not in place until the early 1980s therefore, no Atlantic salmon or American
4 shad were impinged prior to this period (Aquatec 1990). During the impingement sampling
5 periods of the 1980s, an average of 26 fish were impinged per day (Aquatec 1990). Over 80
6 percent were small sunfish, rock bass (*Ambloplites rupestris*), minnows, and yellow perch
7 (*Perca flavescens*). During the 1980s, 59 juvenile Atlantic salmon and one American shad
8 were impinged (Aquatec 1990).

9
10 Table 1 presents some results of impingement collections that have been made at VYNPS since
11 1988. Impingement collections at VYNPS are generally made from April 1 through June 15 and
12 August 1 through October 31 each year, as dictated by NPDES permit stipulations. In general,
13 the common warmwater residents within Vernon Pool were predominant in impingement
14 collections. These included sunfish, rock bass, and yellow perch. The numbers of American
15 shad and Atlantic salmon impinged at VYNPS were lower than the yearly NPDES permit limits
16 set for these species. For example, the permit limits were set at 1666 American shad and 231
17 Atlantic salmon, but only 25 American shad and 9 Atlantic salmon were impinged in 2001
18 (VYNPS and Normandeau 2002). In 2003, 13 American shad and 28 Atlantic salmon were
19 impinged, while the permit limits for that year were set at 1140 and 364, respectively (Entergy
20 and Normandeau 2004). In 2004, 73 American shad and no Atlantic salmon were impinged; the
21 NPDES permit impingement limits for 2004 were set at 1005 American shad and 252 Atlantic
22 salmon (Normandeau 2005).

23
24 Based on riverine and impingement collections of resident and anadromous fish that have been
25 ongoing since VYNPS began withdrawing water from Vernon Pool, no observable adverse
26 impacts to any fish species or to the overall fish community due to the operation of VYNPS has
27 been demonstrated (Aquatec 1978, 1990; Normandeau 2004a, 2005; Entergy 2006b).

28
29 **5.2 ENTRAINMENT**

30
31 Entrained fish eggs and larvae experience thermal stress and mechanical and hydraulic forces
32 during transport through a plant's cooling system. In a study of the Haddam Neck Plant, a
33 nuclear plant with once-through cooling that formerly operated on the lower Connecticut River,
34 Marcy (2004c (1976c) and references cited therein) found mechanical damage to be the main
35 cause of entrainment mortality, while thermal shock was responsible for only about 20 percent
36 of the mortality. While some entrainment survival occurs, 100 percent mortality is normally
37 assumed as a conservative estimate of entrainment losses for all operational modes. When
38 ichthyoplankton are at their peak in the Connecticut River (e.g., late spring through early
39 summer), VYNPS is generally operating in an open-cycle or hybrid mode. The NPDES permit
40 requires larval fish sampling to be done weekly during this period (Normandeau 2005).

Appendix E

Table 1. Percentages (and Numbers) of Fish Species Impinged at VYNPS^(a)

Species	Collection Period			
	1988 and 1990-1997	2001	2003	2004
Sea lamprey (<i>Petromyzon marinus</i>)	0.9 (130) ^(b)	34.4 (241)	0.2 (2)	0.0 (0)
American shad (<i>Alosa sapidissima</i>)	2.6 (387)	3.6 (25)	1.1 (13)	30.8 (73)
Atlantic salmon (<i>Salmo salar</i>)	1.4 (202)	1.3 (9)	2.5 (28)	0.0 (0)
Chain pickerel (<i>Esox niger</i>)	0.2 (31)	0.4 (3)	1.0 (11)	0.8 (2)
Golden shiner (<i>Notemigonus crysoleucas</i>)	1.1 (161)	2.1 (15)	0.6 (7)	0.4 (1)
Spottail shiner (<i>Notropis hudsonius</i>)	7.7 (1139)	0.3 (2)	0.8 (9)	2.1 (5)
Yellow bullhead (<i>Ameiurus natalis</i>)	1.5 (227)	0.0 (0)	3.4 (39)	0.4 (1)
Rock bass (<i>Ambloplites rupestris</i>)	10.8 (1599)	4.7 (33)	9.5 (108)	9.7 (23)
Pumpkinseed (<i>Lepomis gibbosus</i>)	5.8 (853)	1.7 (12)	14.2 (162)	2.5 (6)
Bluegill (<i>Lepomis macrochirus</i>)	19.9 (2937)	28.7 (201)	32.6 (372)	28.3 (67)
Unidentified sunfish (<i>Lepomis</i> spp.)	20.1 (2967)	0.0 (0)	0.0 (0)	0.0 (0)
Smallmouth bass (<i>Micropterus dolomieu</i>)	1.9 (279)	1.0 (7)	2.4 (27)	3.8 (9)
Largemouth bass (<i>Micropterus salmoides</i>)	0.9 (134)	0.6 (4)	5.1 (58)	1.3 (3)
Black crappie (<i>Pomoxis nigromaculatus</i>)	0.01 (1)	1.7 (12)	11.0 (126)	4.2 (10)
Yellow perch (<i>Perca flavescens</i>)	15.2 (2247)	18.3 (128)	15.0 (171)	8.4 (20)
Other species (including unidentifiable fishes)	28.3 (4184)	1.1 (8)	0.8 (9)	7.2 (17)
Totals	100 (14,778)	100 (700)	100 (1142)	100 (237)

(a) Data presented represent a portion of the impingement data collected at this facility.

(a) Data presented represent a portion of the impingement data collected at this facility.
(b) The percent of the total number of fish followed by the total number of fish impinged in parentheses for each species during the collection period.

Sources: Normandeau 1999; VYNPS and Normandeau 2002; Entergy and Normandeau 2004; Normandeau 2005.

The portion of Vernon Pool near VYNPS was found not to be a good fish spawning area due to daily water level fluctuations, a steep shoreline, and a silty sand substrate. Therefore, the amount of ichthyoplankton entrained in the area would be expected to be limited. Overall, densities of ichthyoplankton near the VYNPS intake were <1 fish/m³, which were much lower than densities in littoral areas estimated by Aquatec (1990). For example, minnow densities near the VYNPS intake were <0.6 larvae/m³, whereas densities in shallow, slow-moving nearshore areas were as high as 3000/m³ (Aquatec 1990). Monitoring results indicate that larval fish densities are low in the VYNPS area and the impact of entrainment has been minimal (Entergy 2006a).

Table 2 presents some of the results of entrainment collections that have been made in the Connecticut River in the vicinity of the VYNPS intake since 1988. Entrainment collections at VYNPS are generally made from early May through early to mid July each year, as dictated by the NPDES permit. In general, the common warmwater species that are resident within Vernon Pool were predominant in entrainment collections. These included the spottail shiner (*Notropis hudsonius*), white perch (*Morone americana*), and centrarchids. No Atlantic salmon has been collected in entrainment samples, and one American shad has been collected in entrainment samples.

5.3 THERMAL RELEASES

The discharge of heated water from VYNPS creates elevated temperatures in the Connecticut River and produces a thermal plume that varies in extent and magnitude based on operational characteristics of the plant, ambient air and water temperatures, and hydrodynamic characteristics of the river. The maximum discharge flow temperature for VYNPS is 100°F, although this seldom occurs (Normadeau 2004a). Thermal discharges have the potential to affect food web dynamics, alter fish behavior, or produce acute or chronic impacts on temperature-sensitive species.

5.3.1 Temperature Requirements under the Current NPDES Permit

The current NPDES permit (VDEC 2003) defines two seasonal periods (winter, from October 15 through May 15; and summer, from May 16 through October 14) and sets limits for the increase in temperatures at River Monitoring Station 3, less than a mile downstream of Vernon Dam (Figure 3). These are presented in detail in Table 3.

NPDES permits are issued for five years at a time. On July 11, 2001, VDEC issued a renewed permit for VYNPS with an expiration date of March 31, 2006, and the permit was amended on June 9, 2003 (VDEC 2003). On February 20, 2003, Entergy applied to the VDEC to amend the permit for VYNPS to increase the temperature of the Connecticut River by 1°F as determined at River Monitoring Station 3 (downstream monitoring station) during the NPDES summer period

1
2
3 Appendix E

1
2 **Table 2.** Percentages (and Numbers) of Fish Eggs and Larvae by Species
3 Entrained at VYNPS

4	5	6	Collection Period				
			7 Species	8 1988 and 9 1990-1997	10 2001	11 2003	12 2004
13	14	Common carp <i>(Cyprinus carpio)</i>		0.3 ^(a) (18)	0.2 (3)	2.2 (27)	0.5 (5)
15	16	Spottail shiner <i>(Notropis hudsonius)</i>		0.03 (2)	57.9 (978)	71.6 (875)	25.4 (269)
17	18	<i>Notropis</i> spp.		49.6 ^(b) (2850)	0.0 (0)	0.0 (0)	0.0 (0)
19	20	Cyprinidae		13.7 ^(b) (788)	0.0 (0)	0.0 (0)	0.0 (0)
21	22	White sucker <i>(Catostomus commersoni)</i>		0.02 (1)	37.9 (640)	0.2 (2)	1.0 (11)
23	24	White perch <i>(Morone americana)</i>		20.7 (1191)	1.8 (31)	14.6 (178)	3.4 (36)
25	26	Sunfish <i>(Lepomis</i> spp.)		10.9 (628)	1.8 ^(c) (31)	8.2 ^(c) (100)	68.7 (726)
27	28	Largemouth bass <i>(Micropterus salmoides)</i>		0.07 (4)	0.0 ^(d) (0)	0.0 ^(d) (0)	0.0 (0)
29	30	Yellow perch <i>(Perca flavescens)</i>		4.2 (244)	0.1 (2)	3.2 (39)	0.5 (5)
31	32	Walleye <i>(Sander vitreus)</i>		0.14 (8)	0.1 (2)	0.1 (1)	0.2 (2)
33	34	Other species (including unidentifiable fishes)			0.1 ^(e) (2)	0.0 (0)	0.3 ^(e) (3)
35	36	Total		100 (5747)	100 (1690)	100 (1222)	100 (1057)

- (a) The percent of the total number collected followed by the total number of entrained in parentheses for each species during the collection period.
(b) Based on entrainment sample identifications done in the subsequent years and fish species known from lower Vernon Pool, most individuals identified as only *Notropis* spp. or Cyprinidae were probably spottail shiners.
(c) Listed as Centrarchidae and therefore may also include some largemouth bass.
(d) See footnote (c) - likely that some largemouth bass eggs and larvae were entrained.
(e) The Other species category is almost entirely the tessellated darter (*Etheostoma olmstedi*).

Sources: Normandeau 1999; VYNPS and Normandeau 2002; Entergy and Normandeau 2004; Normandeau 2005

Plant and the Environment

Table 3. Discharge Temperature Requirements under the Current and Amended NPDES Permits for VYNPS

	Currently Enforced NPDES Permit (June 9, 2003)	March 30, 2006 Amendment Request to NPDES Permit
3	Winter (October 15 through May 15) at downstream Station 3 ^(a) :	Winter (October 15 through May 15) at downstream Station 3 ^(a) :
4	• Temperature shall not exceed 65°F;	• Temperature shall not exceed 65°F;
5	• The rate of change of temperature (i.e., the mean difference between consecutive hourly average temperatures) shall not exceed 5°F per hour;	• The rate of change of temperature (i.e., the mean difference between consecutive hourly average temperatures) shall not exceed 5°F per hour;
6	• The plant-induced increase in temperature above ambient water temperature as measured at Station 7 shall not exceed 13.4°F.	• The plant-induced increase in temperature above ambient water temperature as measured at Station 7 shall not exceed 13.4°F.
7		
8		
9		
10		
11		
12	Summer (May 16 through October 14):	Early Summer (May 16 through June 15):
13	• The increase in river water temperature at Station 3 above ambient water temperature as measured at Station 7 shall not exceed the following:	• The increase in river water temperature at Station 3 above ambient water temperature as measured at Station 7 shall not exceed the following:
14		
15		
16		
17		
18		
19		
20		
21	Above 63°F ≥59°F, ≤63°F ≥55°F, ≤59°F Below 55°F	Above 63°F ≥59°F, ≤63°F ≥55°F, ≤59°F Below 55°F
22		
23		
24		
25		
26		
27		
28		
29		
30		
31		
32		
33		
34		
35		
36		
37		
38		
39		
40		
41		
42		
43		

- When the average hourly temperature at Station 3 equals or exceeds 85°F, the thermal output of the discharge must be reduced to the extent that the average hourly temperature at Station 3 does not exceed 85°F.

Appendix E

(May 16 through October 14). On March 30, 2006, VDEC issued an amendment to the permit for VYNPS; however, the amended permit only authorized the requested temperature increase for the period from June 16 through October 14 (VDEC 2006a). VDEC concluded that additional information was needed to evaluate the impacts of the temperature increase on migrating salmon smolt during the May 16 through June 15 portion of the NPDES summer period, since it marks the end of the smolt outmigration period. The permit would have expired on March 31, 2006; however, Entergy submitted an application for a renewed permit on September 29, 2005 (Entergy 2005e). By letter dated September 30, 2005, VDEC informed Entergy that the renewal application was timely and that the permit would remain valid under an administrative extension until VDEC completes the review of the permit renewal application (VDEC 2005a).

In May 2006, the New England Coalition (NEC) appealed the NPDES permit amendment that was issued on March 30, 2006. The amendment was stayed by the State of Vermont Environmental Court on August 28, 2006. At the time this SEIS was published, VYNPS was operating under the NPDES permit as issued on June 9, 2003 (VDEC 2003). The future status of the permit depends on the outcome of the NEC appeal. If the appeal is upheld, an increase in thermal discharge will not be granted and the discharge requirements in the current permit (issued June 9, 2003) will continue until a new permit is issued. If the appeal is denied, the NPDES permit as amended March 30, 2006, will be reinstated and remain in effect until a new permit is issued by VDEC (NRC 2006d). The temperature requirements of the current and amended NPDES permits are presented in Table 3.

The NRC staff's evaluation of the environmental impact in the SEIS and this assessment of essential fish habitat considered the 1°F increase for the time period May 16 through October 14. This evaluation would be bounding if the VDEC grants Entergy the 1°F increase in the May 16 through June 14 time period or the NEC appeal is denied or the NEC appeal is upheld.

5.3.2 Methods of Demonstrating Compliance

The NPDES permit requirements, as of the date of this SEIS, are described below. The permit requires that during the winter period (October 15 through May 15), the plant-induced temperature at downstream River Monitoring Station 3 shall not exceed 65°F (Table 3). The plant-induced temperature increase is calculated using the equation published in the executive summary of the 1978 demonstration report (Aquatec 1978). The equation is based on the principle of energy conservation and takes into account the heat content of the plant's circulating water system and cooling towers, the heat content of the plant's cooling water discharge to the river, and the average discharge (flow) of the Connecticut River as measured

1 at Vernon Dam.^(a) Measurement and cooling system data are linked to a process computer that
2 allows plant personnel to adjust operations on the basis of continual real-time data to meet the
3 thermal requirements of the permit (Normandeau 2005).

4
5 The Vernon Dam regulates the river discharge to maintain a minimum sustained flow of
6 1250 cfs. At 1250 cfs, the permitted theoretical maximum increase in temperature at River
7 Monitoring Station 3 due to the plant's thermal discharge is 12.9°F. In effect, the plant can
8 operate in an open-cycle cooling mode (without cooling tower operation) when ambient river
9 temperatures as measured at the upstream River Monitoring Station 7 are less than 52.1°F (i.e.,
10 65°F minus 12.9°F) during the winter period. At ambient temperatures equal to or greater than
11 52.1°F, the plant's heat discharge can be reduced by using the cooling towers to dissipate heat
12 to the atmosphere (especially during periods of low river flow) (Normandeau 2005). The
13 NPDES permit requires that the plant-induced increase in temperature never exceeds 13.4°F
14 and that the rate of increase never exceeds 5°F per hour.

15
16 Table 4 summarizes the maximum simulated river temperature increases at River Monitoring
17 Station 3 and the flows at which they occurred during the winter period (October 15 through
18 May 15) for the years 2000 through August 2006.

19
20 Table 5 summarizes the maximum simulated river temperature increases at the station and the
21 flows at which they occurred during the summer period for the years 2000 through 2006.

22
23 Exceedences occurred in each of the years between 2000 and 2004, but in each case were
24 less than 1 hr in duration:

- 25
26 • On July 16 and 21, 2000, two 59-minute exceedences occurred (2.74°F and 0.03°F,
27 respectively) when Vernon Dam went to minimum flow as a result of a loss of offsite
28 power caused by a lightning strike (Normandeau 2001).
29
30 • On July 5, 2001, a 59-minute exceedence of 0.12°F occurred because plant
31 operators did not shift to closed-cycle mode quickly enough to respond to changing
32 river conditions.
33
34 • On October 5, 2002, a 60-minute exceedence of 0.05°F occurred because of
35 unreliable automated input associated with new equipment (Normandeau 2003).

(a) The heat content of the circulating water system and cooling towers is calculated on the basis of the change in condenser inlet temperatures over a specified time interval. The heat content of the cooling water discharge is calculated on the basis of the number and pumping capacity of circulating water intake pumps, the difference between condenser inlet and outlet temperatures, the number of circulating intake and cooling tower booster pumps, and the cooling tower outlet temperatures all over a specified time interval (Normandeau 2005).

1
2
3
4
5
6 Appendix E

1 **Table 4.** Maximum Simulated River Temperature Increase at River
2 Monitoring Station 3 during the NPDES Winter Period (October 15
3 through May 15)

5	6	Year	Day	Maximum Temperature Increase	Permit Limit	River Flow (cfs)	Exceeded 5°F/hour?
7	8	2006 ^(a)	March 12	6.03°F	13.4°F	2958	No
9	10	2005	February 10	12.91°F	13.4°F	1285	No
11	12	2004	February 2	12.90°F	13.4°F	1331	No
13	14	2003	January 25	13.16°F	13.4°F	1308	No
15	16	2002	January 23	12.70°F	13.4°F	1367	No
17	18	2001	December 21	12.67°F	13.4°F	1250	No
19	20	2000	November 26	12.60°F	13.4°F	1275	No

21 (a) Data through August 2006.

22 Source: Normandeau 2001, 2002, 2003, 2004b, 2005; DeWald 2005a, 2006b

18 **Table 5.** Maximum Simulated River Temperature Increase at River
19 Monitoring Station 3 during the NPDES Summer Period (May 16
20 through October 14)

22	23	24	25	26	27	28	29	Maximum Temperature Increase (Permit Limit)	Permit limit	River Flow (cfs)	Exceeded 5°F/hour?
23	24	25	26	27	28	29	30	2.94°F	3.0°F	3168	No
31	32	33	34	35	36	37	38	1.97°F	2.0°F	6760	No
39	40	41	42	43	44	45	46	2.06°F	2.0°F	3483	No
47	48	49	50	51	52	53	54	2.16°F	2.0°F	2802	No
55	56	57	58	59	60	61	62	2.05°F	2.0°F	1697	No
63	64	65	66	67	68	69	70	2.12°F	2.0°F	3923	No
71	72	73	74	75	76	77	78	2.74°F	2.0°F	6571	No

30 (a) Data through August 2006.

31 (b) There was an exceedence on July 21, 2000, but it was not the maximum for the year 2000.

32 Source: Normandeau 2001, 2002, 2003, 2004b, 2005; DeWald 2005b, 2006c

- 1 • On September 19, 2003, an 11-minute exceedence of 0.16°F occurred because
2 plant operators shifted operating parameters in anticipation of an increase in river
3 flow (reported by the Wilder Hydroelectric Dam). The increase in river flow
4 occurred, but not to the degree anticipated (Normandeau 2004b).
- 5 • On July 6, 2004, a 45-minute exceedence of 0.06°F occurred when the plant
6 was brought back on-line after an outage caused by a transformer fire
7 (Normandeau 2005).
- 8

9 There were no exceedences in 2005 or 2006 through August.

12 **5.3.3 Temperatures in the Connecticut River**

14 The monthly variation in river temperatures as measured at River Monitoring Stations 3
15 (downstream) and 7 (upstream) over a 5-year period (2000 to 2004) are shown in Figures 4 and
16 5, respectively. Over this period, monthly averages ranged from 34.5°F in January to 75.5°F in
17 July at River Monitoring Station 3 and from 33.4°F in February to 73.3°F in August at River
18 Monitoring Station 7.

20 Figure 6 is a plot of the difference in average monthly temperatures between River Monitoring
21 Stations 3 and 7 (i.e., Station 3 temperature minus Station 7 temperature) in 2000 through 2004.
22 There is an increasing trend throughout the spring, peaking in May, with Station 3 having an
23 average temperature that was 5.9°F higher than that at Station 7, with a decreasing trend
24 throughout the summer. In most months during this summer period, the average monthly
25 temperatures at the downstream station were greater than those at the upstream station.
26 However, in September and December, the average monthly temperatures at River Monitoring
27 Station 7 were higher than River Monitoring Station 3 (1.4°F and 0.4°F, respectively). The
28 average temperature difference between the stations was less than 1°F in January and March
29 (Normandeau 2001, 2002, 2003, 2004b, 2005).

31 In June, July, and August of 2002, temperature measurements were taken from thermistor
32 stations along three bank-to-bank transects across Vernon Pool perpendicular to the river flow,
33 as part of a study to characterize the circulation and distribution of heated water in the area
34 between the VYNPS discharge structure and Vernon Dam (Figure 7; ASA 2004). Temperatures
35 were measured at three depths at each of the three stations along each transect (Figure 7;
36 Table 6). The June-July sampling period was chosen to represent expected conditions; August
37 was chosen to represent low-flow, high-temperature conditions, usually considered the worst-
38 case for potential impacts to aquatic biota.

39 The June-July measurements showed that temperature ranges were fairly similar along each
40 transect between the VYNPS discharge structure and Vernon Dam: 67.1°F to 81.5°F at C

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41

Appendix E




Figure 4. Seasonal Variation in Temperature at River Monitoring Station 3,
Located about 0.65 miles Downstream of Vernon Dam (2000-2004)
(Source: Normandeau 2001, 2002, 2003, 2004b, 2005)




Figure 5. Seasonal Variation in Temperature at River Monitoring Station 7,
Located 4 Miles Upstream of VYNPS (2000-2004) (Source:
Normandeau 2001, 2002, 2003, 2004b, 2005)




Figure 6. Difference in Average Monthly Temperatures
between River Monitoring Stations 3 (downstream) and 7 (upstream)
(Source: Normandeau 2001, 2002, 2003, 2004b, 2005)

Table 6. Total Water Depth and Temperature Sampling Depths
in Vernon Pool

Station Total	Water Depth (ft)	Surface Depth (ft)	Middle Depth (ft)	Bottom Depth (ft)
C1/C2	17	1	8.5	16
C3/C4	17	1	8.5	16
C5/C6	14	1	7	13
D1/D2	20	1	10	19
D3/D4	14.1	1	7	13
D5/D6	23	1	11.5	22
E1/E2	39	1	19.5	38
E3/E4	13	1	6.5	12
E5/E6	5	1	2.5	4
F1/F2	13	1	6.5	12
F3/F4	21	1	10.5	20

Source: ASA 2004

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42

Appendix E




Figure 7. Locations of Thermistor Stations at Vernon Pool (Source: ASA 2004)

Appendix E

1 stations, 67.3°F to 82.9°F at D stations, and 66.7°F to 81.9°F at E stations (Figure 7).
2 Temperatures were generally lower at the F stations (67.1°F to 77.0°F), located upgradient of
3 the VYNPS intake structure, during the same sampling period (Figure 7).

4 In the June-July sampling period, thermal stratification of the water column was greatest (up to a
5 6.3°F difference across the thermocline) near the VYNPS intake structure and had a decreasing
6 trend toward the dam. Measurements at the E stations near Vernon Dam showed little
7 stratification of the water column; however, the diurnal variation in surface temperature, due to
8 fluctuations in river flow and the effects of solar heating, was as high as 1.8°F.
9

10 Significant spatial gradients in the surface water temperature of Vernon Pool were also detected
11 in the June-July sampling period. Temperatures across the transects varied as much as 5.4°F
12 to 7.2°F, with the higher temperatures recorded near the west bank. Temperature variations
13 were least pronounced during periods of high river flow. The average temperature difference
14 between the upstream River Monitoring Station 7 and the downstream River Monitoring Station
15 3 during the June-July sampling period was 4.3°F.
16

17 The August temperature measurements also showed similarities along each transect between
18 the VYNPS discharge structure and Vernon Dam: 75.2°F to 85.1°F at C stations, 75.2°F to
19 84.7°F at D stations, and 75.9°F to 86.6°F at E stations. Temperatures were generally lower at
20 the F station (74.8°F to 83.8°F), located upgradient of the VYNPS intake structure, during the
21 same sampling period.
22

23 The August diurnal variation in temperature due to fluctuations in river flow and the effects of
24 solar heating was most pronounced at the surface (upper 1 ft) in Vernon Pool, with the highest
25 variation (3.6°F) occurring near the VYNPS discharge structure (Station C1/C2); diurnal
26 variation was less pronounced at the upstream location (Transect F), with a variation of about
27 1.5°F at the surface.
28

29 There was little spatial variation in temperature across the bank-to-bank transects in Vernon
30 Pool during the August sampling period. Although temperatures were slightly higher near the
31 VYNPS discharge structure, thermistor temperatures were within about 1.8°F of each other
32 across a single transect at any given time. The average temperature difference between the
33 upstream River Monitoring Station 7 and the downstream River Monitoring Station 3 during the
34 August sampling period was 2.9°F (ASA 2004).
35

36 No fish mortalities or delays in fish migration have been observed due to the VYNPS thermal
37 discharge. VYNPS operations have not been observed to have caused fish mortality or been a
38 barrier to fish migration due to thermal releases or delays in the movement of migratory fish
39 species due to the thermal plume (Aquatec 1990; Normandeau 2004b).
40

41

42

1
2
3
4 Appendix E

5
6
7
8 **6.0 POTENTIAL EFFECTS OF THE PROPOSED ACTION**
9 **ON DESIGNATED ESSENTIAL FISH HABITAT**

10
11 **6.1 EVALUATION OF SPECIES REQUIRING EFH CONSULTATION**

12
13 During the development of this EFH assessment, NMFS websites (NMFS 2006a,b) were
14 consulted to develop an initial list of candidate fish species that would be considered for EFH
15 consultation. On May 5, 2006, the NRC contacted the NMFS and requested information on
16 EFH under the MSFCMA (NRC 2006d). In NMFS's response on September 15, 2006, NMFS
17 stated that the Connecticut River and tributaries are designated EFH for Atlantic salmon and
18 that the potential impacts from VYNPS operation on Atlantic salmon and their habitat should be
19 fully evaluated in the SEIS (NMFS 2006c). This EFH Assessment is in support of the NRC's
20 initiation of an EFH consultation with NMFS regarding the potential license renewal of VYNPS.

21
22 **6.2 ATLANTIC SALMON**

23
24 **6.2.1 Life History of Atlantic Salmon**

25
26 Atlantic salmon are anadromous and have a complex life history that includes spawning in
27 freshwater rivers and feeding migrations in the Atlantic Ocean. Most Atlantic salmon of United
28 States origin spend two years (ranging from one to three or more years) in the ocean before
29 returning to their natal rivers to spawn. Spawning of Atlantic salmon in New England typically
30 occurs in late October and November. Eggs are deposited by the females in nests constructed
31 out of river rocks; the nests are referred to as redds. A typical female lays about 7000 eggs,
32 which are then fertilized by the males. Although some adults survive to spawn in subsequent
33 years, most die following spawning. Those that do return to sea, do so either immediately after
34 spawning or during the following spring (FWS 2002). Few Atlantic salmon live to be more than
35 eight or nine years old (Bigelow and Schroeder 2002). The eggs overwinter in the gravel and
36 hatch the following spring, usually in March and April. Newly hatched sac fry (alevins, the
37 beginning of larval stage) remain in the gravel and use the energy reserves in their yolk sacs to
38 continue development. Once the yolk sacs become depleted the fry emerge from the gravel
39 and begin feeding on plankton and small invertebrates. Fry emergence generally occurs from
40 March through June (FWS 2002). They inhabit shallow riffles with moderate currents
41 (McCormick et al. 1998)

42
43 About early December, the fry disperse into riffles with faster currents and coarse substrates
44 (McCormick et al. 1998). The fry develop markings along their sides; at this point, the young
45 Atlantic salmon are called parr (beginning of juvenile stage). Parr inhabit cool, swift-flowing
46 streams with riffles and gravel-cobble substrates. As they mature, they will also inhabit slower-
47 moving waters with pools and vegetation (Kart et al. 2004; NHFGD 2005). They may also move
48 into small tributaries during their first summer as parr and remain there until they leave as
49 smolts (McCormick et al. 1998). Parr are opportunistic feeders, feeding mostly on aquatic

1 insects; they in turn fall prey to fish and bird species (FWS 2002). The parr stage lasts for one
2 to three years. During this period, they reach a length of about 4 in. (10 cm). After reaching this
3 size, most parr undergo a developmental change during the spring (smoltification) to become
4 smolts; however, some parr will become sexually mature before smoltification and are capable
5 of fertilizing the eggs of returning females (Henry and Cragg-Hine 2003). Some of these mature
6 parr can undergo smoltification in the following spring (McCormick et al. 1998). As smolts, the
7 juvenile Atlantic salmon begin migrating toward the ocean. During their migration, they begin
8 schooling and develop a tolerance to salt water necessary before they enter the ocean.
9

10 Once in the ocean, they eventually migrate toward their major feeding grounds in the North
11 Atlantic near Greenland and Iceland. While in the ocean, Atlantic salmon prey upon various fish
12 species and large zooplankton and are preyed upon by seals, sharks, tuna, striped bass
13 (*Morone saxatilis*), bluefish (*Pomatomus saltatrix*), and other predators (FWS 2002). After
14 spending one to three or more years at sea, adult salmon migrate back to their natal streams to
15 spawn. In New England, the migration generally occurs from May through October with May
16 through July being the primary time period. Spawning normally occurs from late October
17 through November in New England (FWS 2002). Once they enter freshwater, adult Atlantic
18 salmon cease feeding and will not feed again until they re-enter the ocean some six months to a
19 year later (FWS 2002). Adults that do not die after spawning will overwinter in the river before
20 migrating back to sea.

21 **6.2.2 EFH for Atlantic Salmon**

22 EFH for Atlantic salmon is described as all waters currently or historically accessible to Atlantic
23 salmon within Maine, New Hampshire, Vermont, Massachusetts, Rhode Island, and Connecticut
24 (NMFS 1998). The Connecticut River and its tributaries are considered EFH for all life stages of
25 the Atlantic salmon (eggs, larvae, juveniles, adults [those that are in-migrating to spawning
26 sites, overwintering, or out-migrating to the sea], and spawning adults). The following EFH
27 requirements are applicable for the specific life stages of the Atlantic salmon (NMFS 1998):
28

- 30 • *Eggs*. Substrates within a gravel or cobble riffle above or below a pool in rivers and
31 streams. Generally, the water temperature in the excavations that Atlantic salmon
32 construct for egg-laying (i.e., redds) is below 50°F and consists of clean, well-
33 oxygenated freshwater. Atlantic salmon eggs are most frequently present in redds
34 between October and April.
- 35 • *Larvae*. Substrates within a gravel or cobble riffle above or below a pool in rivers and
36 streams. Generally, Atlantic salmon larvae (i.e., alevins and fry) occur in locations with
37 clean, well-oxygenated freshwater and water temperatures below 50°F. Atlantic salmon
38 alevins and fry occur most frequently observed between March and June.
39

Appendix E

- 1 • *Juveniles.* Shallow gravel or cobble riffles interspersed with deeper riffles and pools of
2 rivers and estuaries. Generally, Atlantic salmon juveniles (e.g., parr) are found in areas
3 with clean, well-oxygenated freshwater; water temperatures below 77°F, water depths of
4 4 to 24 in.; and water flows of 12 to 36 in./s. As they grow, parr transform into smolts.
5 Atlantic salmon smolts require downstream access to make their way to the ocean.
6 Upon entering the sea, “post-smolts” become pelagic and range from Long Island Sound
7 north to the Labrador Sea.
- 8 • *Adults.* For adult Atlantic salmon returning to spawn, EFH includes habitats with resting
9 and holding pools in rivers and estuaries. Returning Atlantic salmon require access to
10 their natal streams and access to the spawning grounds. Generally, conditions where
11 returning Atlantic salmon adults are found migrating to the spawning grounds include
12 water temperatures below 73°F and dissolved oxygen levels above 5 parts per million
13 (ppm). Oceanic adult Atlantic salmon are primarily pelagic and range from the waters of
14 the continental shelf off southern New England north throughout the Gulf of Maine.
- 15 • *Spawning adults.* EFH for spawning adults includes gravel or cobble substrates of riffles
16 above or below a pool of specific rivers and streams that currently support or historically
17 supported Atlantic salmon spawning. Generally, conditions where spawning Atlantic
18 salmon are found include water temperatures below 50°F; water depths of 12 to 24 in.;
19 water flows around 24 in./s; and clean, well-oxygenated freshwater. Spawning Atlantic
20 salmon adults are most frequently observed during October and November.

24 EFH regulations also direct the fishery management councils to consider a second, more limited
25 habitat designation for each species in addition to EFH. Habitat areas of particular concern
26 (HAPCs) are described in the regulations as subsets of EFH that are rare, particularly
27 susceptible to human-induced degradation, especially ecologically important, or located in an
28 environmentally stressed area. Designated HAPCs are not afforded any additional regulatory
29 protection under the MSFCMA. However, Federal projects with potential adverse impacts on
30 HAPCs are more carefully scrutinized. In addition to identifying general EFH for Atlantic
31 salmon, the New England Fishery Management Council also identified HAPC for adult Atlantic
32 salmon in 11 coastal watersheds in Maine that support unique and important populations of
33 Atlantic salmon. Thus, those HAPCs would not be affected by VYNPS operations.

35 **6.2.3 Atlantic Salmon in the Connecticut River**

37 Prior to damming of the Connecticut River watershed, Atlantic salmon spawning runs occurred
38 as far upstream as Beecher Falls (near the Vermont-Canadian border, about RM 370) (NHFGD
39 2005). Spawning runs mostly occurred in the spring, but a small number of Atlantic salmon also
40 migrate upriver in the early fall. Those that return in the spring spend the summer in deep, cold
41 pools of their natural streams before spawning in fall (Connecticut River Atlantic Salmon
42 Commission 1998). The optimal temperature range for migratory adults is 57.2 to 68°F

Appendix E

(Krisweb.com undated). Since the installation of fishways on the Connecticut River, Atlantic salmon have reached as far upstream as the Ammonoosuc River, downstream of the Ryegate Dam (RM 273) (FWS undated). Historically, little of the mainstem of the Connecticut River downstream of the present-day site of the Ryegate Dam supported Atlantic salmon rearing habitat (Gephard and McMenemy 2004). Spawning habitat primarily occurs in the Connecticut River tributaries (Gephard and McMenemy 2004). Artificial barriers (e.g., dams and faulty culverts) and natural barriers (e.g., waterfalls > 10 ft high) pose problems for adults migrating to their spawning areas (Kart et al. 2004). Most returning Atlantic salmon are captured for broodstock, although about 10 percent are released upstream of Holyoke Dam to spawn naturally (Connecticut River Atlantic Salmon Commission 1998). In 2004, nearly 7.8 million fry, parr, and smolts were stocked in the Connecticut River watershed (U.S. Atlantic Salmon Assessment Committee 2005).

In 2004, it was estimated that 183,000 smolts were produced above Holyoke Dam (RM 87) (U.S. Atlantic Salmon Assessment Committee 2005). Smolt passage efficiency at Bellows Falls, Vernon, Turners Falls, and Holyoke Dams has been estimated at 80 percent at each dam (Boubee and Haro 2003).

Optimal spawning temperature is 41 to 46.4°F (Krisweb.com undated). Spawning habitat consists of coarse, clean gravel stretches that are at least 3 to 10 ft long and 3 ft wide with water depths 1 to 2 ft. Self-sustaining populations of Atlantic salmon do not currently occur within the Connecticut River watershed are therefore, dependent on a multi-state stocking effort (Kart et al. 2004). Juvenile Atlantic salmon have been stocked in streams as far north as the Nulhegan River, Vermont, about 350 mi upstream on the Connecticut River (FWS undated).

Annual spawning runs in the Connecticut River have numbered in the hundreds but more recently have declined to less than one hundred. For example, in 2004 there were only 69 documented Atlantic salmon returns to the river, and only 1635 to all rivers in the United States (U.S. Atlantic Salmon Assessment Committee 2005). Spawning run declines have been occurring throughout the range during the last 30 years (Gephard and McMenemy 2004). There is a no-take policy for Atlantic salmon in the Connecticut River (NHFGD 2005). The Connecticut River Atlantic Salmon Commission establishes annual schedules for the passage of migratory fish species for a number of dams on the Connecticut River (FWS 2006). The 2006 schedule for upstream passage operations at Vernon Dam was May 15 through July 15 and September 15 through November 15 for Atlantic salmon; the 2006 schedule for downstream Atlantic salmon passage was April 1 through June 15 for smolts and October 15 through December 31 for adults (FWS 2006). The number of Atlantic salmon that have annually passed upstream of Vernon Dam from 1981 to 2006 has ranged from 0 to 13. Four passed the dam in 2006 (FWS 2006).

A variety of factors, including stream hydrology, water temperatures, pH, dissolved oxygen, streambed characteristics, availability of food, competition, predation, pollution, and recreational and commercial fishing, interact to affect the survival of the various life stages of Atlantic salmon

Appendix E

1 in rivers and streams (Maine Atlantic Salmon Task Force 1997). In addition to turbine mortality
2 and other passage issues at dams, dams and their impoundments can delay migration of
3 Atlantic salmon smolts and increase water temperature, which can lead to a loss of smolt
4 characteristics. This can have a negative impact on the capacity of smolts to survive in
5 seawater and return as adults (McCormick et al. 1999). Extended residency in impoundments
6 can also increase predatory pressure to smolts. Low pH due to acid deposition appears to be
7 detrimental to outmigrating smolts. Water temperature fluctuations in the Atlantic Ocean over
8 the past ten years may be contributing to reduced adult salmon returns throughout much of their
9 range (Kart et al. 2004). Atlantic salmon recovery is also hindered by degraded water quality
10 parameters, siltation in tributary streams, and predation of early life history stages by a variety of
11 species including the striped bass.

12
13 The results of studies conducted at VYNPS suggest that no eggs and larvae or any life stage of
14 Atlantic salmon are entrained. There are no records of adults being impinged. Each year low
15 numbers of smolts are impinged at VYNPS. These losses are inconsequential when compared
16 to the total number of smolts in the river. The number of smolts impinged has been a small
17 portion of the applicant's NPDES permit limit for Atlantic salmon (Aquatec 1978, 1990; Entergy
18 2006a; Entergy and Normandeau 2004; Normandeau 1999, 2004a, 2005; VYNPS and
19 Normandeau 2002).

20
21 The only life stages of the Atlantic salmon exposed to the VYNPS thermal plume are smolts
22 (during spring) and migrating adults (during spring and fall). The schedule for upstream fish
23 passage operations at Vernon Dam is from mid May to mid July and from mid September to mid
24 November for adult salmon. The downstream fish passage operations are from about April 1
25 through mid June for smolts and mid October to the end of December for adults (FWS 2006).

26
27 Few adults pass by VYNPS as adult spawning runs in the Connecticut River are small and 90
28 percent of the adults that reach Holyoke Dam are captured for broodstock. Adult Atlantic
29 salmon passage at Vernon Dam occurs during mid June (VFWD 2006).

30
31 The optimum temperature range for adult Atlantic salmon migration is 57.2 to 68°F with the
32 highest temperature for normal upstream migration being about 80.6°F, depending upon
33 acclimation and duration of exposure (Fay et al. 2006). The optimum temperature range for
34 smolt migration is 44.6 to 57.7°F with the highest temperature being about 66.2°F (Fay et al.
35 2006).

36
37 In 2004, river temperatures of VYNPS averaged about 42.9°F in April, 57.3°F in May, and
38 65.7°F in June, while at the downstream monitoring Station 3 they averaged about 43.3°F in
39 April, 59.5°F in May, and 67.5°F in June. Average daily temperatures at the Vernon Dam
40 fishway from mid May through the end of June ranged from 55.5°F(May 27) to 70.6°F (June 15)
41 (Normandeau 2005). Thus, river temperatures near the VYNPS are within the tolerance limits
42 of migrating adult Atlantic salmon and, most often, for migrating smolts. June appears to be the
43 only month during which water temperatures exceed tolerance limits for outmigrating smolts;

1 therefore smolt migration could potentially be affected during June. No blockages of adult
2 Atlantic salmon past Vernon Dam due to VYNPS operations were observed during Project
3 SAVE (Save Available Vermont Energy) (Aquatec 1990). Seventy-five percent of the adult
4 Atlantic salmon that passed Turners Falls Dam passed the Vernon Dam fishway, while
5 radiotelemetry studies of smolts revealed that downstream movement into and through the
6 VYNPS thermal plume occurred without any observed delays (Aquatec 1990). Most Atlantic
7 salmon smolt migrate past VYNPS before the upper limit for survival of 82°F is exceeded
8 (Normandeau 2004a). Atlantic salmon smolts migrating past VYNPS would not be subjected to
9 elevated temperatures for more than 12 hr, and could avoid the warmest waters by swimming
10 around or under the plume (Normandeau 2004a). Therefore, there may be a slight habitat
11 squeeze in the migration corridor in the vicinity of VYNPS, but studies indicate that most smolts
12 successfully complete their downstream migration.

13
14 Although prey items for Atlantic salmon are entrained or impinged in the VYNPS cooling
15 system, there is no indication that prey populations have been measurably affected and that
16 prey populations near VYNPS are not limited by station operation. The NRC staff concludes
17 VYNPS operations would likely have a minimal adverse effect on Atlantic salmon EFH (See
18 Table 7 for a summary of potential adverse effects).

20 **7.0 MITIGATION MEASURES**

21

22 Four categories of impacts related to VYNPS operations that could influence EFH for the
23 Atlantic salmon are: (1) entrainment of Atlantic salmon early life stages; (2) impingement of
24 juvenile or adult Atlantic salmon; (3) discharge of heated cooling water; and (4) mortality of
25 Atlantic salmon prey species due to impingement, entrainment, or thermal effects. The
26 applicant's NPDES permit contains operational and temperature limits to protect water quality
27 and minimize impacts to aquatic biota. The State of Vermont has established limits on the
28 increase in water temperature above ambient in the Connecticut River due to station operations.
29 These limits were established, in part, to minimize impacts to Atlantic salmon during the
30 spawning migration and outmigration of smolts. Additionally, the VYNPS intake is located in an
31 area devoid of unique spawning habitat for Atlantic salmon so entrainment of eggs and larvae
32 are not a concern. Should impingement of smolts prove to be a problem in the future,
33 particularly if the Connecticut River salmon population increases substantially, the licensee
34 could install a fish return system or operate the station in the closed-cycle cooling mode during
35 the period of time the smolts are outmigrating.

37 **8.0 CONCLUSION**

38

39 For each life stage, VYNPS operations were evaluated to determine whether they resulted in
40 (1) no adverse impact, (2) minimal adverse impacts, or (3) substantial adverse impact on
41 Atlantic salmon EFH. These impact categories follow the standards used by the Northeast
42 Regional Office of the NMFS. The expected impacts of VYNPS operations on EFH for the

Appendix E

1 Atlantic salmon are summarized in Table 7. Because VYNPS operates for a portion of the year
2 in a once-through mode, it has the potential to have an adverse impact on EFH for the Atlantic
3 salmon due to withdrawal from the Connecticut River. However, the low level of interactions
4 between the Atlantic salmon and the facility, as well as current mitigation measures in place at
5 VYNPS, reduce the potential adverse effect on the various life stages of the Atlantic salmon and
6 their respective EFHs. The 316(a) and (b) Demonstration that has been conducted at VYNPS,
7 coupled with results of annual impingement, entrainment, and riverine sampling of fish required
8 by NPDES permit stipulations, have demonstrated that VYNPS operations do not have an
9 adverse effect on the aquatic biota in the Connecticut River, including the movement of
10 migrating Atlantic salmon smolts and adults (Aquatec 1978, 1990; Entergy 2006a; Entergy and
11 Normandeau 2004; Normandeau 1999, 2004a, 2005; VYNPS and Normandeau 2002). The
12 affected area from VYNPS operations would not affect any habitats in or near bays, estuaries,
13 or offshore areas. Accordingly, there would be no adverse effects on EFH or Federally
14 managed species in such areas. The NRC staff concludes that license renewal of VYNPS for
15 an additional 20 years of operation would result in a minimal adverse effect on EFH of the
16 Atlantic salmon.

Table 7. Impacts of VYNPS Operations on EFH of the Atlantic Salmon

Life Stage	EFH Description	Expected Effect of VYNPS Operations on EFH
Eggs	Bottom habitats with gravel or cobble riffles above or below a pool in rivers; clean, well-oxygenated water with water temperatures <50°F and water depths of 30 to 61 cm (1 to 2 ft); occur most frequently between October and April.	No Adverse Effect. No spawning habitat near plant. Additionally, eggs incubate in gravel and are, therefore, not subject to entrainment. Spawning areas not affected by thermal discharges.
Larvae	Bottom habitats with gravel or cobble riffles above or below a pool in rivers; clean, well-oxygenated water with water temperatures <50°F; occur most frequently between March and June for alevins/fry.	No Adverse Effect. No spawning habitat near the plant so no thermal effects. Additionally, alevins remain buried in gravel and once fry emerge from the redd they tend to remain in their natal stream. Therefore, larvae are not subject to entrainment.
Juveniles	Shallow gravel/cobble habitats interspersed with deeper riffles and pools in rivers and estuaries; clean, well-oxygenated water with water temperatures 77°F; prefers water depths of 10 to 61 cm (0.3 to 2 ft) and water velocities of 30 to 92 cm/s (1 to 3 ft/s).	Minimal Adverse Effect. Parr habitat no present in immediate area of VYNPS therefore no thermal effects. Smolts not commonly impinged; impingement numbers well below yearly NPDES permit limits. Prey items are entrained or impinged at VYNPS, but prey population size not affected. Smolts move into and through the VYNPS thermal plume without observed delays.
Adults	Areas with resting and holding pools in rivers and estuaries for adults returning to spawn; water temperatures <73°F and with dissolved oxygen levels >5 ppm; oceanic adults are mainly pelagic and range from the continental shelf off southern New England north throughout the Gulf of Maine.	Minimal Adverse Effect. Very few returning Atlantic salmon allowed to continue upstream spawning migrations past Holyoke Dam. Generally, those that pass Turners Falls Dam also pass Vernon Dam, and most of those subsequently pass Bellows Falls Dam. Few post-spawning adults expected to pass the VYNPS area. Generally, impingement of adults would be unlikely. Adults do not feed while in freshwater; thus, other fish species impinged at VYNPS do not comprise a loss of prey items for adult Atlantic salmon. Thermal effects on adults not observed and unlikely.
Spawning Adults	Bottom habitats with gravel or cobble riffles above or below a pool in rivers; clean, well-oxygenated water with temperatures <50°F, depths of 30 to 61 cm (1 to 2 ft), and velocities about 61 cm/s (2 ft/s); spawning most frequently occurs in October and November.	No Adverse Effect. No spawning habitat near the plant so no adverse effect due to thermal discharges or impingement.

Sources: Maine Atlantic Salmon Task Force 1997; NMFS 1998, 2006a; Scott and Crossman 1973

1 Appendix E

2 **9.0 REFERENCES**

- 3 10 CFR Part 51. *Code of Federal Regulations*, Title 10, Energy, Part 51, "Environmental
4 Protection Regulations for Domestic Licensing and Related Regulatory Functions."
- 5 Applied Science Associates, Inc. (ASA). 2004. *Hydrothermal Modeling of the Cooling water
6 Discharge from the Vermont Yankee Power Plant to the Connecticut River*. ASA Report
7 02-088. (April 2004).
- 8 Aquatec Inc. (Aquatec). 1978. *Executive Summary 316 Demonstration Vermont Yankee
9 Nuclear Power Station - Biological, Hydrological & Engineering Information*. Aquatec Inc.,
10 South Burlington, Vermont. (March 1978).
- 11 Aquatec Inc. (Aquatec). 1990. *316 Demonstration Vermont Yankee Nuclear Power Station
12 Connecticut River, Vernon, Vermont - Biological, Hydrological & Engineering Information*.
13 Aquatec Inc., South Burlington, Vermont. (June 1990).
- 14 Bigelow, H.B., and W.C. Schroeder. 2002. *Fishes of the Gulf of Maine*. Fishery Bulletin 74,
15 Revision 1.1. Fishery Bulletin of the Fish and Wildlife Service. Available URL:
16 <http://www.gma.org/fogm/Default.htm> (Accessed September 22, 2006).
- 17 Boubee, J., and A. Haro. 2003. "Downstream Migration and Passage Technologies for
18 Diadromous Fishes in the United States and New Zealand: Tales from Two Hemispheres."
19 Downstream Movement of Fish in the Murray-Darling Basin - Canberra Workshop. June.
20 Available URL: http://www.mdbc.gov.au/data/pages/509/Jacques_Boubee_&_Alex_Haro.pdf
21 (Accessed July 26, 2006).
- 22 Connecticut River Atlantic Salmon Commission. 1998. "Strategic Plan for the Restoration of
23 Atlantic Salmon to the Connecticut River." Connecticut River Atlantic Salmon Commission,
24 Sunderland, Massachusetts. July 1998. Available URL:
25 <http://www.fws.gov/r5crc/documents.strplan.pdf> (Accessed April 6, 2006).
- 26 Dewald, L. 2005a. Letter from L. DeWald, Entergy, to Theresa Tanner, VDEC. Subject:
27 "Monthly NPDES Discharge Monitoring Report for February 2005." (March 7, 2005).
- 28 Dewald, L. 2005b. Letter from L. DeWald, Entergy, to Theresa Tanner, VDEC. Subject:
29 "Monthly NPDES Discharge Monitoring Report for July 2005." (August 12, 2005).
- 30 Dewald, L. 2006a. Letter from L. DeWald, Entergy, to Theresa Tanner, VDEC. Subject:
31 "Monthly NPDES Discharge Monitoring Report for March 2006." (April 11, 2006).

Appendix E

- 1 Dewald, L. 2006b. Letter from L. DeWald, Entergy, to Theresa Tanner, VDEC. Subject:
2 "Monthly NPDES Discharge Monitoring Report for August 2006." (September 11, 2006).
- 3
- 4 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2004.
5 *Vermont Yankee Nuclear Power Station, Updated Final Safety Analysis Report, Revision 19.*
6 Docket No. 50-271. Brattleboro, Vermont. (November 1, 2004).
- 7
- 8 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006a.
9 *License Renewal Application, Vermont Yankee Nuclear Power Station, Operating License No.*
10 *DPR-28.* Docket No. 50-271. Brattleboro, Vermont. (January 25, 2006).
- 11
- 12 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc.(Entergy). 2006b.
13 *Applicant's Environmental Report - Operating License Renewal Stage, Vermont Yankee*
14 *Nuclear Power Station.* Docket No. 50-271. Brattleboro, Vermont. (January 25, 2006).
- 15
- 16 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006c.
17 *Vermont Yankee Nuclear Power Station License No. DPR-28 (Docket No. 50-271) License*
18 *Renewal Application, Amendment 6.* Brattleboro, Vermont. (July 2006).
- 19
- 20 Entergy Nuclear Vermont Yankee, LLC, and Normandeau Associates, Inc. (Entergy and
21 Normandeau). 2004. *Ecological Studies of the Connecticut River, Vernon, Vermont.* Report
22 33. Prepared for Entergy Nuclear Vermont Yankee, LLC, Vernon, Vermont by Entergy Nuclear
23 Vermont Yankee, LLC and Normandeau Associates, Inc., Bedford, New Hampshire. (May
24 2004).
- 25
- 26 Fay, C. et al. 2006. *Status Review of Anadromous Atlantic Salmon (*Salmo salar*) in the United*
27 *States, Report to the National Marine Fisheries Service and U.S. Fish and Wildlife Service.*
28 Available at <http://www.nmfs.noaa.gov/pr/species/statusreview.htm>. (Accessed November 13,
29 2006).
- 30
- 31 Gephard. S. and J. McMenemy. 2004. "An Overview of the Program to Restore Atlantic
32 Salmon and Other Diadromous Fishes to the Connecticut River with Notes on the Current
33 Status of These Species in the River." Pages 287-317 in Jacobson, P.M., D.A. Dixon, W.C.
34 Leggett, B.C. Marcy, Jr., and R.R. Massengill (eds.). *The Connecticut River Ecological Study*
35 *(1965-1973) Revisited: Ecology of the Lower Connecticut River 1973-2003.* American Fisheries
36 Society, Monograph 9. Bethesda, Maryland.
- 37
- 38 Henry, K. and D. Cragg-Hine. 2003. "Ecology of the Atlantic Salmon." *Conserving Natura*
39 *2000 Rivers Ecology Series No. 7.* English Nature, Peterborough. Available URL:
40 <http://www.english-nature.org.uk/LIFEinUKRivers/publications/Salmon.pdf> (Accessed August
41 23, 2006).
- 42

Appendix E

1 Kart, J., R. Regan, S.R. Darling, C. Alexander, K. Cox, M. Ferguson, S. Parren, K. Royar, and
2 B. Popp (eds.). 2004. "Vermont's Wildlife Action Plan." Vermont Fish & Wildlife Department,
3 Waterbury, Vermont. Available URL: http://www.vtfishandwildlife.com/swg_cwcs_report.cfm
4 (Accessed August 22, 2006).

5
6 Krisweb.com. Undated. "Water Temperature and Gulf of Maine Atlantic Salmon." Klamath
7 Resource Information System. Available URL:
8 http://www.krisweb.com/krissheepscot/krisdb/html/krisweb/stream/temperature_sheepscot.htm
9 (Accessed July 31, 2006).

10
11 Maine Atlantic Salmon Task Force. 1997. "Atlantic Salmon Conservation Plan for Seven Maine
12 Rivers." Maine Atlantic Salmon Task Force, Augusta, Maine. Available URL: <http://mainegov->
13 images.informe.org/asc/archive/Atlantic%20Salmon%20Conservation%20Plan1.pdf (Accessed
14 June 2, 2005).

15
16 McCormick, S.D., L.P. Hansen, T.P. Quinn, and R.L. Saunders. 1998. "Movement, Migration,
17 and Smolting of Atlantic Salmon (*Salmo salar*)." *Canadian Journal of Fisheries and Aquatic
18 Sciences*, Vol. 55 (Suppl. 1): 77-92.

19
20 McCormick, S.D., R.A. Cunjak, B. Dempson, M.F. O'Dea, and J.B. Carey. 1999. "Temperature-
21 Related Loss of Smolt Characteristics in Atlantic Salmon (*Salmo salar*) in the Wild." *Canadian
22 Journal of Fisheries and Aquatic Sciences*, Vol. 56, pp. 1649-1658.

23
24 National Marine Fisheries Service (NMFS). 1998. "Essential Fish Habitat Description Atlantic
25 Salmon (*Salmo salar*)." *Available URL: <http://www.nero.noaa.gov/hcd/salmon.pdf>* (Accessed
26 September 19, 2006).

27
28 National Marine Fisheries Service (NMFS). 2006a. "Summary of Essential Fish Habitat (EFH)
29 and General Habitat Parameters for Federally Managed Species." *Available URL:
30 <http://www.nero.noaa.gov/hcd/efhtables.pdf>* (Accessed September 21, 2006).

31
32 National Marine Fisheries Service (NMFS). 2006b. "Guide to EFH Consultations." *Available
33 URL: <http://www.nero.noaa.gov/hcd/appguide1.html>* (Accessed September 21, 2006).

34
35 National Marine Fisheries Service (NMFS). 2006c. Letter from L.A. Chiarella, National Marine
36 Fisheries Service, Gloucester, Massachusetts, to R. Franovich, U.S. Nuclear Regulatory
37 Commission, Washington, D.C. (September 15, 2006).

38
39 New Hampshire Fish and Game Department (NHFGD). 2005. "New Hampshire Wildlife Action
40 Plan," New Hampshire Fish and Game Department, Concord, New Hampshire. Available URL:
41 http://www.wildlife.state.nh.us/Wildlife/wildlife_plan.htm (Accessed August 22, 2006).

Appendix E

- 1 Normandeau Associates, Inc. (Normandeau). 1999. *Summary Report on the 1986-1997*
2 *Ecological Studies of the Connecticut River, Vernon, Vermont.* Prepared for Vermont Yankee
3 Nuclear Power Corporation, Vernon, Vermont by Normandeau Associates, Inc., Drumore,
4 Pennsylvania. (April 22, 1999).
- 5
- 6 Normandeau Associates, Inc. (Normandeau). 2001. "Ecological Studies of the Connecticut
7 River, Vernon, Vermont." Report 30 (January-December 2000). (April 2001).
- 8
- 9 Normandeau Associates, Inc. (Normandeau). 2002. "Ecological Studies of the Connecticut
10 River, Vernon, Vermont." Report 31 (January-December 2001). (April 2002).
- 11
- 12 Normandeau Associates, Inc. (Normandeau). 2003. "Ecological Studies of the Connecticut
13 River, Vernon, Vermont." Report 32 (January-December 2002). (May 2003).
- 14
- 15 Normandeau Associates, Inc. (Normandeau). 2004a. *§316(a) Demonstration in Support of a*
16 *Request for Increased Discharge Temperature Limits at Vermont Yankee Nuclear Power*
17 *Station during May through October.* Prepared for Entergy Nuclear Vermont Yankee, Vernon,
18 Vermont, by Normandeau Associates, Inc., Bedford, New Hampshire. (April 2004).
- 19
- 20 Normandeau Associates, Inc. (Normandeau). 2004b. "Ecological Studies of the Connecticut
21 River, Vernon, Vermont." Report 33 (January-December 2003). (May 2004).
- 22
- 23 Normandeau Associates, Inc. (Normandeau). 2005. "Ecological Studies of the Connecticut
24 River, Vernon, Vermont." Report 34 (January-December 2004). (May 2005).
- 25
- 26 Scott, W.B. and E.J. Crossman. 1973. "Freshwater Fishes of Canada." Bulletin 184. Fisheries
27 Research Board of Canada. Ottawa, Canada.
- 28
- 29 U.S. Atlantic Salmon Assessment Committee. 2005. "Annual report of the U.S. Atlantic Salmon
30 Assessment Committee." Report No. 17 - 2004 Activities. Annual Report 2005/17. U.S.
31 Atlantic Salmon Assessment Committee, Woods Hole, Massachusetts. Available URL:
32 <http://www.nefsc.noaa.gov/USASAC/2005%20USASAC%20Report/USASAC%2017%20report%20final.pdf> (Accessed April 12, 2006).
- 33
- 34
- 35 U.S. Atomic Energy Commission (AEC). 1972. *Final Environmental Statement Related to the*
36 *Operation of the Vermont Yankee Nuclear Power Station, Vermont Yankee Nuclear Power*
37 *Corporation.* Docket No. 50-271. Directorate of Licensing. Washington, D.C. (July 1972).
- 38
- 39 U.S. Fish and Wildlife Service (FWS). 2002. "The Natural History of Atlantic Salmon (*Salmo*
40 *salar*)." U.S. Fish and Wildlife Service, Central New England Fishery Resources Office,
41 Nashua, New Hampshire. Available URL: <http://www.fws.gov/r5cneafp/salmon.htm> (Accessed
42 April 7, 2006).
- 43

Appendix E

1 U.S. Fish and Wildlife Service (FWS). 2006. "Fish Passage Schedule." U.S. Fish and Wildlife
2 Service, Connecticut River Coordinator's Office, Sunderland, Massachusetts. Available URL:
3 http://www.fws.gov/r5crc/Habitat/fish_passage_schedule.htm (Accessed April 6, 2006).

4
5 U.S. Fish and Wildlife Service (FWS). Undated. "Fish Facts." U.S. Fish and Wildlife Service,
6 Connecticut River Coordinator's Office, Sunderland, Massachusetts. Available URL:
7 <http://www.fws.gov/r5crc/Fish/facts.html> (Accessed April 6, 2006).

8
9 U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement*
10 *for License Renewal of Nuclear Plants*. NUREG-1437, Vols. 1 and 2, Washington, D.C.

11
12 U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement*
13 *for License Renewal of Nuclear Plants Main Report*, "Section 6.3 - Transportation, Table 9.1.
14 Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants, Final
15 Report." NUREG-1437, Vol. 1, Addendum. Washington, D.C.

16
17 U.S. Nuclear Regulatory Commission (NRC). 2006a. *Vermont Yankee Nuclear Power Station -*
18 *License Renewal Application*. Available URL: <http://www.nrc.gov/reactors/operating/licensing/renewal/applications/vermont-yankee.html> (Accessed September 22, 2006).

19
20 U.S. Nuclear Regulatory Commission (NRC). 2006b. "Entergy Nuclear Operations, Inc.,
21 Vermont Yankee Nuclear Power Station; Notice of Intent to Prepare an Environmental Impact
22 Statement and Conduct Scoping Process." *Federal Register*, Vol. 71, No. 77, pp. 20733-20735.
23 Washington, D.C. (April 21, 2006).

24
25 U.S. Nuclear Regulatory Commission (NRC). 2006c. *Vermont Yankee Nuclear Power Station -*
26 *Final Environmental Assessment and Finding of No Significant Impact Related to the Proposed*
27 *License Amendment to Increase the Maximum Power Level*. Docket No. 50-271. Washington,
28 D.C. (January 20, 2006).

29
30 U.S. Nuclear Regulatory Commission (NRC). 2006d. Letter from R. Franovich, U.S. Nuclear
31 Regulatory Commission, Washington, D.C., to P. Kurkul, National Marine Fisheries Service,
32 Gloucester, Massachusetts. (May 5, 2006).

33
34 Vermont Agency of Natural Resources (VANR). 2006. *Final Amended Discharge Permit #3-*
35 *1199*. Vermont Agency of Natural Resources, Department of Environmental Conservation,
36 Wastewater Management Division, Waterbury, Vermont. (March 2006).

37
38 Vermont Department of Environmental Conservation (VDEC). 2003. *National Pollutant*
39 *Discharge Elimination System Permit Number VT0000264* (VDEC Permit No. 3-1199).
40 Wastewater Management Division. (June 9, 2003).

Appendix E

1 Vermont Department of Environmental Conservation (VDEC). 2005. *Renewal of Permit No.*
2 *3-1199*. Permit renewal with letter from C. Fowler, VDEC, to L. DeWald, Entergy. (September
3 30, 2005).

4
5 Vermont Department of Environmental Conservation (VDEC). 2006a. *Final Amended*
6 *Discharge Permit No. 3-1199*. Amended permit with letter from B.D. Kooiker, VDEC, to L.
7 DeWald, Entergy. (March 30, 2006).

8
9 Vermont Yankee Nuclear Power Station and Normandeau Associates, Inc. (VYNPS and
10 Normandeau). 2002. *Ecological Studies of the Connecticut River, Vernon, Vermont*. Report
11 31, January-December 2001. Prepared for Vermont Yankee Nuclear Power Corporation,
12 Brattleboro, Vermont, by Vermont Yankee Nuclear Power Station, Brattleboro, Vermont, and
13 Normandeau Associates, Inc., Bedford, New Hampshire. (April 2002).

Appendix F

Generic Environmental Impact Statement Environmental Issues Not Applicable to Vermont Yankee Nuclear Power Station

1

Appendix F

2

Generic Environmental Impact Statement 3 Environmental Issues Not Applicable to 4 Vermont Yankee Nuclear Power Station

5

6

7

8 Table F-1 lists those environmental issues listed in the *Generic Environmental Impact*
9 *Statement for License Renewal of Nuclear Plants* (GEIS) (NRC 1996, 1999)^(a) and Title 10,
10 Part 51, of the *Code of Federal Regulations* (10 CFR Part 51), Subpart A, Appendix B,
11 Table B-1, that are not applicable to Vermont Yankee Nuclear Power Station (VYNPS) because
12 of plant or site characteristics.

13

14 **Table F-1.** GEIS Environmental Issues Not Applicable to VYNPS

15

16 ISSUE–10 CFR Part 51, Subpart A, 17 Appendix B, Table B-1	18 Category	19 GEIS Sections	20 Comment
SURFACE-WATER QUALITY, HYDROLOGY, AND USE (FOR ALL PLANTS)			
21 Altered salinity gradients	1	4.2.1.2.2; 4.4.2.2	VYNPS does not discharge to an estuary.
22 Altered thermal stratification of lakes	1	4.2.1.2.2; 4.4.2.2	VYNPS does not use surface water from lakes.
GROUNDWATER USE AND QUALITY			
23 Groundwater-use conflicts (potable and 24 service water, and dewatering; plants that 25 use >100 gpm)	2	4.8.1.1; 4.8.2.1	VYNPS does not use >100 gpm of groundwater.
26 Groundwater-use conflicts (Ranney wells)	2	4.8.1.4	VYNPS does not use Ranney wells.
27 Groundwater-quality degradation (Ranney 28 wells)	1	4.8.2.2	VYNPS does not use Ranney wells.
29 Groundwater-quality degradation 30 (saltwater intrusion)	1	4.8.2.1	VYNPS uses <100 gpm of groundwater and is not located near a saltwater body.
31 Groundwater-quality degradation (cooling 32 ponds in salt marshes)	1	4.8.3	VYNPS does not use a cooling pond.

(a) The GEIS was originally issued in 1996. Addendum 1 to the GEIS was issued in 1999. Hereafter, all references to the “GEIS” include the GEIS and its Addendum 1.

1
2
3
4 Appendix F

5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
Table F-1. (contd)

ISSUE–10 CFR Part 51, Subpart A, Appendix B, Table B-1	Category	GEIS Sections	Comment
Groundwater-quality degradation (cooling ponds at inland sites)	2	4.8.3	VYNPS does not use a cooling pond.
TERRESTRIAL RESOURCES			
Bird collisions with cooling towers	1	4.3.5.2	VYNPS does not use natural draft towers.
Cooling pond impacts on terrestrial resources	1	4.4.4	VYNPS does not use a cooling pond.

F.1 References

- 10 CFR Part 51. *Code of Federal Regulations*, Title 10, Energy, Part 51, “Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions.”
- U.S. Nuclear Regulatory Commission (NRC). 1996. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*. NUREG-1437, Vols. 1 and 2, Washington, D.C.
- U.S. Nuclear Regulatory Commission (NRC). 1999. *Generic Environmental Impact Statement for License Renewal of Nuclear Plants: Main Report*, “Section 6.3 – Transportation, Table 9.1, Summary of Findings on NEPA Issues for License Renewal of Nuclear Power Plants, Final Report.” NUREG-1437, Vol. 1, Addendum 1, Washington, D.C.

Appendix G

**NRC Staff Evaluation of Severe Accident Mitigation Alternatives
(SAMAs) for Vermont Yankee Nuclear Power Station, in Support of the
License Renewal Application Review**

Appendix G

NRC Staff Evaluation of Severe Accident Mitigation Alternatives (SAMAs) for Vermont Yankee Nuclear Power Station, in Support of the License Renewal Application Review

G.1 Introduction

Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy) submitted an assessment of severe accident mitigation alternatives (SAMAs) for Vermont Yankee Nuclear Power Station (VYNPS) as part of the environmental report (ER) (Entergy 2006a). This assessment was based on the most recent VYNPS probabilistic safety assessment (PSA) available at that time (Model VY04R1), a plant-specific offsite consequence analysis performed using the MELCOR Accident Consequence Code System 2 (MACCS2) computer code, and insights from the VYNPS individual plant examination (IPE) (VYNPC 1993) and individual plant examination of external events (IPEEE) (VYNPC 1998). In identifying and evaluating potential SAMAs, Entergy considered SAMAs that addressed the major contributors to core damage frequency (CDF) and population dose at VYNPS, as well as SAMA candidates for other operating plants which have submitted license renewal applications. Entergy identified 302 potential SAMA candidates. This list was reduced to 66 unique SAMA candidates by eliminating SAMAs that: are not applicable to VYNPS due to design differences, have already been implemented at VYNPS, or are similar in nature and could be combined with another SAMA candidate. Entergy assessed the costs and benefits associated with each of the potential SAMAs and concluded in the ER that several of the candidate SAMAs evaluated are potentially cost-beneficial.

Based on a review of the SAMA assessment, the U.S. Nuclear Regulatory Commission (NRC) issued a request for additional information (RAI) to Entergy by letter dated June 1, 2006 (NRC 2006a). Key questions concerned: findings of the Boiling Water Reactor Owners Group (BWROG) and the independent assessment team reviews of the VYNPS PSA; the approach used to assign source terms for each release category as a part of the Level 2 analysis; justification for the multiplier used for external events; further information on several specific candidate SAMAs and low cost alternatives; and details for several of the cost estimates provided. Entergy submitted additional information by letters dated August 1, 2006, September 19, 2006, October 20, 2006 and November 6, 2006 (Entergy 2006b, Entergy 2006c, Entergy 2006d, Entergy 2006e). In response to the RAIs, Entergy provided: information regarding the findings of the BWROG peer review; a discussion of the process for assigning severe accident source terms for the Level 2 analysis; additional information regarding several specific SAMAs; and additional information pertaining to the cost estimates. Additionally, Entergy provided two attachments to the RAI responses, containing information on a later version of the PSA (version VY05R0) and a revised assessment of the SAMA benefits based on this later version of the PSA. This revised assessment utilizes a modified multiplier to account for external events exclusive of uncertainties, and a modified core inventory to account for plant-specific burn-up and enrichment. Entergy's responses addressed the NRC staff's concerns.

Appendix G

1 An assessment of SAMAs for VYNPS is presented below.
2

3 **G.2 Estimate of Risk for Vermont Yankee Nuclear Power Station**

4

5 Entergy's estimates of offsite risk at the VYNPS are summarized in Section G.2.1. The
6 summary is followed by the NRC staff's review of Entergy's risk estimates in Section G.2.2.
7

8 **G.2.1 Entergy's Risk Estimates**

9

10 Two distinct analyses are combined to form the basis for the risk estimates used in the SAMA
11 analysis: (1) the VYNPS Level 1 and 2 PSA model, which is an updated version of the IPE
12 (VYNPC 1993) that accounts for the Extended Power Uprate (EPU) conditions, and (2) a
13 supplemental analysis of offsite consequences and economic impacts (essentially a Level 3
14 PSA model) developed specifically for the SAMA analysis. The ER (Entergy 2006a) included a
15 SAMA analysis based on PSA version VY04R1. Subsequently, the SAMA analysis was revised
16 based on PSA version VY05R0, and submitted as part of Entergy's RAI response (Entergy
17 2006c). The scope of the VYNPS PSA does not include external events.

18 The baseline CDF for the purpose of the SAMA evaluation is approximately 8.0×10^{-6} per year.
19 The CDF is based on version VY05R0 of the PSA for internally-initiated events. Entergy did not
20 include the contribution from external events within the VYNPS risk estimates; however, it did
21 account for the potential risk reduction benefits associated with external events by effectively
22 multiplying the estimated benefits for internal events by a factor of 3.33⁽¹⁾. This is discussed
23 further in Sections G.2.2 and G.6.2.

24 The breakdown of CDF by initiating event is provided in Table G-1. The results from the earlier
25 PSA model (VY04R1) are also provided for information. As shown in this table, events initiated
26 by loss of offsite power, internal flooding, transients without the power conversion system, and
27 loss of an AC bus are the dominant contributors to CDF. Although not separately reported,
28 station blackout (SBO) sequences contribute 2.3×10^{-6} per year (about 29 percent of the total
29 internal events CDF) (Entergy 2006c), while anticipated transient without scram (ATWS)
30 sequences contribute 1.5×10^{-7} per year to CDF (about 2 percent of the total internal events
31 CDF). With the Loss of Offsite Power (LOOP) initiating event contributing 2.8×10^{-6} per year to
32 the CDF, the percentage of LOOP events resulting in SBO is high. This is because the
33 dominant LOOP initiator involves a regional blackout due to severe weather conditions (Entergy
34 2006d).

(1) In the ER, Entergy bounded the combined impact of external events and uncertainties by applying a multiplier of 10 to the estimated SAMA benefits for internal events. In response to an RAI, Entergy revised the analysis to include a multiplier of 3.33 to account for potential SAMA benefits in both internal and external events, and provided a separate accounting of uncertainties.

Table G-1. VYNPS Core Damage Frequency

PSA Model	VY04R1		VY05R0	
	CDF* (Per Year)	% Contribution to CDF	CDF* (Per Year)	% Contribution to CDF
Initiating Event				
Loss of offsite power	7.2×10^{-7}	14	2.8×10^{-6}	35
Internal Flooding	1.5×10^{-6}	29	1.4×10^{-6}	17
Transients without power conversion system	8.2×10^{-7}	16	8.4×10^{-7}	11
Loss of AC Bus 3	4.0×10^{-7}	8	7.9×10^{-7}	10
Loss of AC Bus 4	3.5×10^{-7}	7	7.3×10^{-7}	9
Loss of DC Bus 2	2.5×10^{-7}	5	2.8×10^{-7}	4
Loss of DC Bus 1	2.6×10^{-7}	5	2.8×10^{-7}	3
Inadvertently opened relief valve	2.7×10^{-7}	5	2.7×10^{-7}	3
Reactor trip	1.4×10^{-7}	3	1.7×10^{-7}	2
Anticipated Transient Without Scram	1.4×10^{-7}	3	1.5×10^{-7}	2
Loss of Coolant Accidents	3.7×10^{-8}	1	7.3×10^{-8}	1
Stuck-open relief valve	6.9×10^{-8}	1	6.5×10^{-8}	1
Total loss of service water	5.0×10^{-8}	1	5.2×10^{-8}	1
Interfacing System LOCA	1.6×10^{-8}	<1	3.9×10^{-8}	<1
LOCA outside containment	3.7×10^{-8}	1	3.4×10^{-8}	<1
Total CDF	5.0×10^{-6}	100	8.0×10^{-6}	100

* Point Estimate

1 Appendix G

2 The Level 2 VYNPS PSA model that forms the basis for the SAMA evaluation represents an
3 updated version of the original IPE Level 2 model. The current Level 2 model utilizes a single
4 containment event tree (CET), containing both phenomenological and systemic events, that is
5 directly linked with the Level 1 models. CET nodes are evaluated using supporting fault trees
6 and logic rules. Plant Damage States (also called core damage sequence functional classes)
7 were defined for the purposes of summarizing and reporting the results of the Level 1 and Level
8 2 analyses.

9 The result of the Level 2 PSA is a set of 14 release categories with their respective frequency
10 and release characteristics. The results of this analysis for VYNPS are provided in Table
11 RAI.2.b of the RAI responses (Entergy 2006c). The frequency of each release category was
12 obtained from the quantification of the linked Level 1 - Level 2 models and is the sum of the
13 frequency of the individual accident progression CET endpoints binned into the release
14 category. The release characteristics for each release category were obtained by
15 frequency-weighting the release characteristics for each CET endpoint contributing to the
16 release category (Entergy 2006c).

17 The offsite consequences and economic impact analyses use the MACCS2 code to determine
18 the offsite risk impacts on the surrounding environment and public. Inputs for these analyses
19 include plant-specific and site-specific input values for core radionuclide inventory, source term
20 and release characteristics, site meteorological data, projected population distribution (within an
21 80-kilometer (50-mile) radius) for the year 2032, emergency response evacuation modeling, and
22 economic data. The core radionuclide inventory is derived from an ORIGEN calculation
23 assuming a 4.65 percent enrichment and average burn-up (Entergy 2006b). The magnitude of
24 the onsite impacts (in terms of clean-up and decontamination costs and occupational dose) is
25 based on information provided in NUREG/BR-0184 (NRC 1997b).

26 In the revised SAMA analysis (Entergy 2006c), Entergy estimated the dose to the population
27 within 80 kilometers (50 miles) of the VYNPS site to be approximately 0.151 person-sievert (Sv)
28 (15.1 person-rem) per year. The breakdown of the total population dose by containment
29 release mode is summarized in Table G-2. Containment failures within the early time frame
30 (less than 6 hours following accident initiation) dominate the contributions to the population
31 dose risk at VYNPS.

32 **G.2.2 Review of Entergy's Risk Estimates**

33 Entergy's determination of offsite risk at VYNPS is based on the following three major elements
34 of analysis:

- 35 • The Level 1 and Level 2 risk models of the 1993 IPE submittal (VYNPC 1993), and the
36 external events analyses of the 1998 IPTEE submittal (VYNPC 1998),
37
38 • The major modifications to the IPE model that have been incorporated in the VYNPS
39 PSA, and

Table G-2. Breakdown of Population Dose by Containment Release Mode

Containment Release Mode	Population Dose (Person-Rem ¹ Per Year)	% Contribution
Early Containment Failure	12.8	85
Late Containment Failure	2.1	14
Containment Bypass	0.2	1
Intermediate Containment Failure	< 0.1	< 1
Intact Containment	negligible	negligible
Total	15.1	100

¹One person-Rem = 0.01 person-Sv

- The MACCS2 analyses performed to translate fission product source terms and release frequencies from the Level 2 PSA model into offsite consequence measures.

Each of these analyses was reviewed to determine the acceptability of Entergy's risk estimates for the SAMA analysis, as summarized below.

The NRC staff's review of the VYNPS IPE is described in an NRC report dated February 9, 1996 (NRC 1996). Based on a review of the IPE submittal, the NRC staff concluded that the IPE submittal met the intent of Generic Letter (GL) 88-20; that is, the licensee's IPE process is capable of identifying the most likely severe accidents and severe accident vulnerabilities. It was noted, however, that internal flooding and weather related LOOP initiators were to be included in the IPEEE, but not in the IPE. The current internal-event PSA, however, includes both internal flooding and weather-related LOOP initiators. No severe accident vulnerabilities associated with either core damage or poor containment performance were identified in the IPE.

While no vulnerabilities were identified in the IPE and no hardware modifications were proposed as a result of the IPE, several plant improvements were identified and implemented prior to and in conjunction with the IPE. These improvements included: replacement of uninterrupted power supply for the low pressure coolant injection system injection valves, improvement of the safety relief valve and main steam isolation valve (MSIV) pneumatic components, replacement of instrument air compressors and upgrade of the residual heat removal service water (RHRSSW) system (NRC 1996).

The VYNPS IPEEE analysis of internal flooding yielded a CDF of 9.0×10^{-6} per year. The NRC staff IPEEE SER (NRC 2001) concluded, with respect to the internal flooding, that while the analysis process is capable of identifying the most likely severe accidents, insufficient information was provided and that this weakness may inhibit its use in other regulatory applications. The internal flooding analysis has been subsequently updated, and the current CDF is 1.4×10^{-6} per year. The model has also been incorporated within the scope of the internal-events PSA. The internal flooding model is discussed further in Section G.3.2.

Appendix G

The VYNPS IPEEE listed 14 opportunities for improvements with respect to internal flooding. In response to an RAI, Entergy provided the status of these 14 improvements. Eleven have been implemented and credited in the current flooding risk analysis or were shown by analysis not to be required. The remaining three were judged to mitigate non-credible events or not have a significant impact on risk. In response to a staff RAI, Entergy described a review of the revised flooding risk analysis performed in 2002 to identify modifications that would further reduce the flooding risk (Entergy 2006e). A modification to provide spray shielding in two areas was identified and included in the current analysis as a candidate SAMA. No other modifications, short of major structural or relocation changes were identified. The NRC staff concludes that the opportunity for internal flood-related SAMAs has been adequately explored and that it is unlikely that there are any additional potentially cost-beneficial, internal flood-related SAMA candidates.

There have been numerous revisions to the IPE model since the 1993 IPE submittal. A comparison of internal events CDF between the 1993 IPE and the current PSA model (version VY05R0) indicates an increase of approximately 3.7×10^{-6} per year (from 4.3×10^{-6} per year to 8.0×10^{-6} per year). However, as indicated above, the 1993 IPE did not include internal flooding, which originally had an estimated CDF of 9.0×10^{-6} per year. If this is added to the 1993 IPE value for internal events, the resulting CDF is 1.3×10^{-5} per year. This indicates a reduction in the CDF between the 1993 IPE and the current PSA model of 5×10^{-6} per year (from 1.3×10^{-5} per year to 8.0×10^{-6} per year).

A comparison of the contributors to the total CDF indicates that some have increased while others have decreased from the IPE. The most notable changes are in the LOOP, which has increased from approximately 8.6×10^{-7} per year to 2.8×10^{-6} per year, internal flooding, which decreased from approximately 9.0×10^{-6} per year (from the IPEEE) to 1.4×10^{-6} per year and ATWS, which decreased from approximately 8×10^{-7} per year to 1.5×10^{-7} per year. A summary listing of those changes that resulted in the greatest impact on the internal events CDF made in the various revisions of the PSA was provided in response to a staff request for additional information and is summarized in Table G-3.

The CDF value from the 1993 IPE (1.3×10^{-5} per year, including the contribution from internal flooding events) is near the average of the CDF values reported in the IPEs for boiling-water reactor (BWR) 3/4 plants. Figure 11.2 of NUREG-1560 shows that the IPE-based total internal events CDF for BWR 3/4 plants ranges from 9×10^{-8} to 8×10^{-5} per year, with an average CDF for the group of 2×10^{-5} per year (NRC 1997a). It is recognized that other plants have updated the values for CDF subsequent to the IPE submittals to reflect modeling and hardware changes. The current internal events CDF results for VYNPS (8.0×10^{-6} per year) are comparable to or somewhat lower than that for other plants of similar vintage and characteristics.

The NRC staff considered the peer reviews performed for the VYNPS PSA, and the potential impact of the review findings on the SAMA evaluation. In the ER and in a response to a staff RAI (Entergy 2006a, 2006b), Entergy described the peer review by the BWROG of the 1998 model (Model VY118) conducted in September of 2000. Entergy also provided a list of

Table G-3. VYNPS PSA Historical Summary

PSA Version	Summary of Changes from Prior model ¹	CDF per year
1993	IPE Submittal - no internal flooding (With 1998 IPEEE internal flooding of 9.0×10^{-6} added)	4.3×10^{-6} (1.3×10^{-5})
1998 Model Update (VY118)	Reviewed by BWROG in 2000 (With 1998 IPEEE internal flooding of 9.0×10^{-6} added) - corrected modeling limitations found in IPE - incorporated impact of three design changes (ATWS rule instrumentation, normal position of LPCI/RHR minimum flow valve, and standby position of torus vent valve)	4.9×10^{-6} (1.4×10^{-5})
VY00R0	- Integrated individual models (transients, LOCAs, internal flooding, ISLOCA, LOCA outside containment and Level 2) into single model - updated component failure database	1.8×10^{-5}
VY02R0	- Incorporated major design changes (addition of fourth battery charger, replacement of 24VDC batteries with 125VDC to 24VDC converter, and containment nitrogen system model revised to reflect new piping and nitrogen supply) - Updated failure rate and unavailability data - Updated initiating event frequencies - Updated internal flooding model to include: two separate initiators for SW line break in torus room, revised human error probabilities, and additional credit for CRD system	4.2×10^{-6}
VY02R6	- Revised non-recovery factors for loss of service water and loss of offsite power - Revised model to have separate initiators for SORV and IORV - Removed credit for use of CRD for injection early in event sequences	7.8×10^{-6}
VY04R1	- Revised model to account for effects associated with Extended Power Uprate ² - Revised treatment of SW recovery to be based on system failure modes - Revised flooding analysis of SW line break at elevation 280' - Updated loss of vital DC bus initiating event frequency - Updated reactor protection system fault tree model	5.0×10^{-6}
VY05R0	- Increased mission time for emergency diesel generators from 8 to 24 hours - Updated frequency of loss of offsite power (LOOP) initiating event - Added LOOP due to severe weather - Revised model to include credit for use of John Deere diesel generator as an alternate power supply for the station battery chargers - Reevaluated human error associated with use of diesel driven fire pump - Added operator action to model the potential that the operator fails to adequately control the torus vent, leading to a net positive suction head (NPSH) loss and ECCS pump failure	8.0×10^{-6}

¹ Summary of changes includes the key changes made to previous model revisions not specifically listed in this table.² A sensitivity study associated with the EPU application indicated that the EPU increased the CDF by 3.3×10^{-7} per year (Entergy 2003)

strengths and weaknesses identified by the peer review, and a list of ten areas for improvement along with their resolution. The BWROG review concluded that the VYNPS PSA can be effectively used to support applications involving risk significance determinations supported by deterministic analysis, once the significant Facts and Observations (F&Os) are addressed. In response to the NRC staff's request for additional information concerning the application for

Appendix G

1 extended power uprate (Entergy 2004), Entergy indicated that a total of 104 F&Os were
2 identified during the BWROG peer review, and provided a listing of the single "Category A" and
3 the 51 "Category B" F&Os, along with their resolutions. The NRC staff reviewed this material
4 and concluded that the VYNPS PSA has sufficient scope, level of detail and technical adequacy
5 to support the risk evaluation of the proposed EPU (NRC 2005). In the context of the SAMA
6 application, Entergy stated that all significant F&Os (i.e., A and B priority) have been resolved
7 and that appropriate modeling changes have been implemented in the PSA version used to
8 support SAMA analysis.

9
10 The internal flooding analysis performed for the IPEEE was included within the BWROG peer
11 review. Entergy indicated that internal flooding was cited in the review as a strength and that
12 there were no recommended areas for improvement associated with internal flooding. In
13 response to an RAI (Entergy 2006b), Entergy described the significant changes subsequently
14 made in the internal flooding analysis to support the significant reduction in CDF due to internal
15 flooding.

16
17 Given that the VYNPS internal events PSA model has been peer-reviewed and the peer review
18 findings were either addressed or judged to have no adverse impact on the SAMA evaluation,
19 and that Entergy has satisfactorily addressed NRC staff questions regarding the PSA, the NRC
20 staff concludes that the internal events Level 1 PSA model is of sufficient quality to support the
21 SAMA evaluation.

22
23 As indicated above, the current VYNPS PSA does not include external events. In the absence
24 of such an analysis, Entergy used the VYNPS IPEEE to identify the highest risk accident
25 sequences and the potential means of reducing the risk posed by those sequences, as
26 discussed below.

27
28 The VYNPS IPEEE was submitted in June 1998 (VYNPC 1998), in response to Supplement 4
29 of GL 88-20. This submittal included internal flooding, as well as the usual external events
30 (seismic, fire and other external events). While no fundamental weaknesses or vulnerabilities to
31 severe accident risk in regard to the external events were identified, a listing of improvement
32 opportunities was developed. Improvements related to internal flooding were discussed above.
33 Additional improvements for seismic, fire, high winds and other external events are discussed
34 below. In a letter dated March 22, 2001, the NRC staff concluded that the submittals met the
35 intent of Supplement 4 to GL 88-20, and that the licensee's IPEEE process is capable of
36 identifying the most likely severe accidents and severe accident vulnerabilities (NRC 2001).

37
38 The VYNPS IPEEE uses a focused scope Electric Power Research Institute (EPRI) seismic
39 margins analysis. This method is qualitative and does not provide numerical estimates of the
40 CDF contributions from seismic initiators (EPRI 1991). The seismic IPEEE identified a number
41 of outliers of items within the scope of the Unresolved Safety Issue (USI) A-46 program.
42 Resolution of these outliers was to be accomplished in the context of USI A-46. Given the
43 satisfactory resolution of these outliers, VYNPS found that, based on the EPRI assessment
44 methodology, all high confidence low probability of failure values were greater than the 0.3g
45 review level earthquake used in the IPEEE except for the condensate storage tank (CST) with a
46 high confidence in low probability of failure (HCLPF) value of 0.25 and the Diesel Fuel Oil

1 Storage Tank with a HCLPF of 0.29. The NRC review and closure of USI A-46 for VYNPS is
2 documented in a letter dated March 20, 2000 (NRC 2000).

3
4 The IPEEE identifies seven opportunities for improvement related to seismic events, including
5 the improvements related to the CST and Diesel Fuel Oil Storage Tank. In response to an RAI,
6 Entergy confirmed that, with the exception of improvements related to the CST, all the
7 improvements identified in the IPEEE and in Tables 2.7 and 2.12 of NUREG-1742 (NRC 2002)
8 have been implemented or otherwise shown not to be required (Entergy 2006b). In response to
9 an RAI, Entergy evaluated a modification to raise the CST HCLPF value. This is discussed
10 further in Section G.3.2. Based on the information provided by the applicant, the NRC staff
11 finds the treatment of seismic events to be reasonable for the purposes of the SAMA analysis.

12
13 The VYNPS IPEEE fire analysis employed EPRI's fire-induced vulnerability evaluation
14 methodology to perform a qualitative and quantitative screening review and then a probabilistic
15 risk analysis to estimate the CDF contribution for the areas that did not screen. After qualitative
16 screening, fire event initiation frequencies were determined for the unscreened areas for use in
17 quantitative screening along with the assumption that all equipment in a compartment was
18 damaged by the fire. Using results from the IPE, a conservative CDF for the compartment was
19 determined and areas with a CDF of less than 1×10^{-6} per year were screened out. Fire
20 propagation and suppression analysis was then conducted on the unscreened compartments.
21 Fire induced CDFs were determined by propagating the fire initiating events and associated
22 equipment failures determined by the fire propagation and suppression analysis through event
23 trees similar to those in the IPE. The potential impact on containment performance and
24 isolation was evaluated following the core damage evaluation. The VYNPS fire CDF results,
25 after updating in response to IPEEE RAIs, are presented in Table E.1-11 of the ER. The total
26 fire CDF, found by summing the values for all compartments is 5.6×10^{-5} per year.

27
28 In the IPEEE, four opportunities for improvements with respect to fire events were identified.
29 These improvements were all credited in the IPEEE fire CDF. Three of the four improvements
30 involved improvements in the fire prevention inspection and barrier inspection and maintenance
31 programs. The fourth improvement involved relocating or protecting certain control cables for
32 offsite power breakers. In the ER, Entergy indicates that these improvements have been
33 implemented.

34
35 The NRC staff inquired about additional steps taken to reduce fire risk and the possibility of
36 additional SAMAs that might be feasible to reduce the fire risk. Entergy provided a listing of fire
37 related Phase I SAMAs that have been implemented. Most of these SAMAs are improvements
38 in the fire protection program, that while they would decrease the fire risk, are not explicitly
39 credited in the fire risk analysis. Entergy further argued that a number of the SAMAs, identified
40 based on internal events analysis, would also mitigate the fire risk and identified these SAMAs
41 and the affected fire zones (Entergy 2006c). In addition, all of the dominant fire zones are
42 equipped with fire detection systems and all but two of the zones have fire suppression systems
43 (Entergy 2006e). Each of the dominant contributors to the total fire CDF and the associated fire
44 detection and suppression system for those fire zones are shown below.

Appendix G

The feasibility of adding fire suppression to the two remaining fire zones was examined and it was concluded that this was inappropriate to do so because of inherent complexity and competing risks associated with possible fire suppression designs. Based on the above, Entergy concluded that no additional cost effective fire related SAMAs would be expected (Entergy 2006e). The NRC staff concludes that the opportunity for fire-related SAMAs has been adequately explored and that it is unlikely that there are any potentially cost-beneficial, fire-related SAMA candidates.

In the ER, Entergy states that the above CDF values are screening values and that a more realistic fire CDF may be about a factor of three lower (or 1.86×10^{-5} per year) based on the

<u>Fire Compartment</u>	<u>Description</u>	<u>CDF (per year)</u>	<u>Fire Detection</u>	<u>Fire Suppression Type</u>
CV	Cable Vault, El. 262'	1.5×10^{-5}	Yes	CO ₂
SGW	West Switchgear Room, El. 248'	9.0×10^{-6}	Yes	CO ₂
SGE	East Switchgear Room, El. 248'	7.0×10^{-6}	Yes	CO ₂
CR	Control Room, El. 272'	5.7×10^{-6}	Yes	None
RB3	Reactor Building, El. 252', Zone RB3 (north)	5.1×10^{-6}	Yes	Pre-action water
RB4	Reactor Building, El. 252', Zone RB4 (south)	3.3×10^{-6}	Yes	None
CVBT	Cable Vault Battery Room, El. 262'	3.2×10^{-6}	Yes	CO ₂
TURB	Turbine Building, All General Areas	1.1×10^{-6}	Yes	Pre-action water

NRC staff estimate for another license renewal application. In response to an NRC staff RAI to justify the factor of three reduction for VYNPS, Entergy identified seven general conservative assumptions applied to the fire analysis and eight conservatisms specific to fires scenarios in the control room or cable vault that are significant contributors to fire risk (Entergy 2006b). Of the fire scenario-specific conservatisms, most can be characterized by: (1) use of conservative fire frequency and severity factors, (2) no credit taken for certain plant operating procedures during fire events, and (3) use of a simple fire suppression analysis. Based on the existence of numerous conservatisms, the NRC staff finds the use of a fire CDF of 1.86×10^{-5} per year to be reasonable for the purposes of the SAMA analysis.

The IPPEE analysis of high winds, external floods and other external events followed the screening and evaluation approaches specified in Supplement 4 to GL 88-20 (NRC 1991) and did not identify any significant sequences or vulnerabilities (VYNPC 1998). Based on this result, Entergy concluded that these other external hazards would not be expected to impact the conclusions of the SAMA analysis and did not consider them further.

1 Based on the aforementioned results, the external events CDF is approximately 2.33 times the
2 internal events CDF (based on a negligible seismic CDF, a fire CDF of 1.86×10^{-5} per year, and
3 an internal events CDF of 8.0×10^{-6} per year). Accordingly, the total CDF from internal and
4 external events would be approximately 3.33 times the internal events CDF. In the revised
5 SAMA analyses submitted in response to an RAI, Entergy multiplied the benefit that was
6 derived from the internal events model by a factor of 3.33 to account for the combined
7 contribution from internal and external events. The NRC staff agrees with the applicant's overall
8 conclusion concerning the multiplier used to represent the impact of external events and
9 concludes that the applicant's use of a multiplier of 3.33 to account for external events is
10 reasonable for the purposes of the SAMA evaluation.

11
12 The NRC staff reviewed the general process used by Entergy to translate the results of the
13 Level 1 PSA into containment releases, as well as the results of the Level 2 analysis, as
14 described in the ER and in response to NRC staff requests for additional information (Entergy
15 2006a, 2006b, and 2006c). The current Level 2 model utilizes a single CET, containing both
16 phenomenological and systemic events, which is linked directly to the Level 1 event trees.

17
18 Entergy characterized the releases for the spectrum of possible radionuclide release scenarios
19 using a set of 14 release categories, defined based on the timing and magnitude of the release
20 and whether the containment remains intact or is bypassed. The frequency of each release
21 category was obtained from the quantification of a linked Level 1 - Level 2 model which
22 effectively evaluates a CET for each Level 1 accident sequence. Each CET accident
23 progression end state was assigned to one of the 14 release categories. The release
24 characteristics for each release category were obtained by frequency weighting the release
25 characteristics for each CET end state contributing to the release category. The source term
26 release fractions for the CET endstates were estimated based on the results of plant-specific
27 analyses of the dominant CET scenarios using the Modular Accident Analysis Program (MAAP,
28 Version 4.04) computer program. The release categories, their frequencies and release
29 characteristics are presented in Table RAI.2.b of Entergy's RAI responses (Entergy 2006c).

30
31 The NRC staff's review of the Level 2 IPE concluded that it addressed the most important
32 severe accident phenomena normally associated with the Mark I containment type, and
33 identified no significant problems or errors (NRC 1996). Based on the NRC staff's review of the
34 Level 2 methodology, and the fact that the Level 2 model was reviewed in more detail as part of
35 the BWROG peer review, the NRC staff concludes that the Level 2 PSA provides an acceptable
36 basis for evaluating the benefits associated with various SAMAs.

37
38 Even though Entergy used the MACCS2 code and scaled the reference BWR core inventory for
39 VYNPS plant-specific power level (1912 MWt), the NRC staff requested that Entergy evaluate
40 the impact on population dose if the core inventory were based on the plant-specific burn-up
41 and enrichment (NRC 2006a). In response to the NRC staff's request, Entergy derived a best
42 estimate inventory of long-lived isotopes (such as Sr-90, Cs-134 and Cs-137) from an ORIGEN
43 calculation assuming 4.65 percent enrichment and average burn-up based on expected fuel
44 management practices. This resulted in an increase of approximately 25 percent in the
45 inventories of the aforementioned radionuclides relative to those considered in the ER (Entergy
46 2006b). The increase in the inventories, combined with the increase in CDF in version VY05R0

Appendix G

1 of the PSA, resulted in an increase in total population dose from 9.2 to 15.1 person-rem per
2 year, and an increase in the annual offsite economic risk monetary equivalent (discussed later)
3 from \$21,000 to \$36,600 (Entergy 2006c). As part of their response, Entergy provided revised
4 benefit estimates for each SAMA based on the revised core inventory values and the revised
5 PSA model. The revised benefit estimates are presented and discussed in Section G.6.
6

7 The NRC staff reviewed the process used by Entergy to extend the containment performance
8 (Level 2) portion of the PSA to an assessment of offsite consequences (essentially a Level 3
9 PSA). This included consideration of the source terms used to characterize fission product
10 releases for the applicable containment release categories and the major input assumptions
11 used in the offsite consequence analyses. The MACCS2 code was utilized to estimate offsite
12 consequences. Plant-specific input to the code includes the source terms for each release
13 category and the reactor core radionuclide inventory (both discussed above), site-specific
14 meteorological data, projected population distribution within an 80-kilometer (50-mile) radius for
15 the year 2032, emergency evacuation modeling, and economic data. This information is
16 provided in Attachment E of the ER (Entergy 2006a) and Attachment B of the RAI responses
17 (Entergy 2006c).

18 Entergy used site-specific meteorological data for the 2002 calendar year as input to the
19 MACCS2 code. The hourly data were collected from the onsite meteorological tower. In
20 response to an RAI, Entergy stated that it considered the year 2002 data to be the most current
21 and complete set of data at the time of the SAMA analysis (Entergy 2006b). Missing data was
22 obtained from a backup meteorological system located on the VYNPS site. The NRC staff
23 notes that previous SAMA analyses results have shown little sensitivity to year-to-year
24 differences in meteorological data and concludes that the use of the 2002 meteorological data
25 in the SAMA analysis is reasonable.

26 The population distribution the applicant used as input to the MACCS2 analysis was estimated
27 for the year 2032, based on the U.S. Census population data for 2000 (Entergy 2006a). The
28 2000 population was adjusted to account for transient population. These data were used to
29 project county-level resident populations to the year 2032 using a least squares fit method. The
30 NRC staff considers the methods and assumptions for estimating population reasonable and
31 acceptable for purposes of the SAMA evaluation.

32 The emergency evacuation model was modeled as a single evacuation zone extending out 16
33 kilometers (10 miles) from the plant. Entergy assumed that 100 percent of the population would
34 move at an average speed of approximately 1.8 meters per second (4 miles per hour) with a
35 delayed start time of 1 hour and 20 minutes (Entergy 2006a). This assumption is similar to the
36 NUREG-1150 study (NRC 1990), which assumed evacuation of 99.5 percent of the population
37 within the emergency planning zone. Sensitivity analyses were performed in which the
38 evacuation delay time was set to 2 hours, and the evacuation speed was decreased to 1 meter
39 per second (2.2 miles per hour). The results of both sensitivity analyses showed that delayed
40 evacuation and lower evacuation speed have a small impact on the population dose. The NRC
41 staff concludes that the evacuation assumptions and analysis are reasonable and acceptable
42 for the purposes of the SAMA evaluation.

1 Site-specific economic data requiring spatial distributions as input to MACCS2 were prepared by
2 specifying the data for each of the 17 counties within 80 kilometers (50 miles) of the plant. The
3 values used in each of the 240 sectors surrounding the plant corresponded to the county that
4 made up a majority of the land in that sector. Generic economic data that are applied to the
5 region as a whole were revised from the MACCS2 sample problem input when better
6 information was unavailable. These included fraction of farm and non-farm wealth from
7 improvements (e.g., buildings, equipment). The agricultural economic data were extrapolated to
8 2002 using average values for the 50-mile radius area from the 1987, 1992, and 1997 Census
9 of Agriculture (USDA 1998). The recommended MACCS2 growing seasons duration was
10 assumed.

11
12 The NRC staff concludes that the methodology used by Entergy to estimate the offsite
13 consequences for VYNPS provides an acceptable basis from which to proceed with an
14 assessment of risk reduction potential for candidate SAMAs. Accordingly, the NRC staff based
15 its assessment of offsite risk on the CDF and offsite doses reported by Entergy.
16

17 **G.3 Potential Plant Improvements**

18

19 The process for identifying potential plant improvements, an evaluation of that process, and the
20 improvements evaluated in detail by Entergy are discussed in this section.
21

22 **G.3.1 Process for Identifying Potential Plant Improvements**

23

24 Entergy's process for identifying potential plant improvements (SAMAs) consisted of the
25 following elements:
26

- 27 • Review of the most significant basic events from the plant-specific PSA,
28
- Review of potential plant improvements identified in the VYNPS IPE and IPEEE,
30
- Review of Phase II SAMAs from license renewal applications for six other U.S. nuclear
32 sites, and
- Review of other NRC and industry documentation discussing potential plant
35 improvements.

37 Based on this process, an initial set of 302 candidate SAMAs, referred to as Phase I SAMAs,
38 was identified. In Phase I of the evaluation, Entergy performed a qualitative screening of the
39 initial list of SAMAs and eliminated SAMAs from further consideration using the following
40 criteria:
41

- 42 • The SAMA is not applicable at VYNPS due to design differences,
- 43 • The SAMA has already been implemented at VYNPS, or
- 45 • The SAMA is similar in nature and could be combined with another SAMA candidate.

Appendix G

Based on this screening, 236 SAMAs were eliminated, leaving 66 for further evaluation. The remaining SAMAs, referred to as Phase II SAMAs, are listed in Table E.2-1 of the ER (Entergy 2006a) and Revised Table E.2-1 of the RAI responses (Entergy 2006c). In Phase II, a detailed evaluation was performed for each of the 66 remaining SAMA candidates, as discussed in Sections G.4 and G.6 below. To account for the potential impact of external events, the estimated benefits based on internal events were multiplied by a factor of 3.33, as previously discussed.

G.3.2 Review of Entergy's Process

Entergy's efforts to identify potential SAMAs focused primarily on areas associated with internal initiating events. The initial list of SAMAs generally addressed the accident sequences considered to be important to CDF from functional, initiating event, and risk reduction worth perspectives at VYNPS, and included selected SAMAs from prior SAMA analyses for other plants.

In Table E.1-3 of the ER, Entergy provided a tabular listing of the risk significant terms or functions in the PSA sorted according to their risk reduction worth (RRW) in PSA version VY04R1 (Entergy 2006a). A revision to this table based on PSA version VY05R0 was provided in response to an RAI (Entergy 2006d). SAMAs impacting the risk significant terms would have the greatest potential for reducing risk. Entergy used a RRW cutoff of 1.005, which corresponds to about a one-half percent change in CDF given 100-percent reliability of the SAMA. This equates to a benefit (using PSA version VY05R0) of approximately \$15,000 (after the benefits have been multiplied to account for external events). Entergy correlated the terms with highest risk importance in the Level 1 PSA with the SAMAs evaluated in Phase I or Phase II, and showed that, with a few exceptions, all of the significant terms are addressed by one or more SAMAs (Entergy 2006a).

The exceptions (for which Entergy did not identify any SAMAs to address risk significant terms) are all operator action terms, in which procedure enhancements have already been implemented and further procedural changes would be of little benefit. Consequently, the only potential for reducing the risk would be to automate the operator action, if it has not already been automated. For most of these operator actions, automating the operator actions raises the potential for adverse risk impacts. For example, the operator action with the highest RRW involves aligning the John Deere diesel generator and the firewater system to provide alternate injection into the reactor for station blackout sequences. In response to NRC staff inquiries, Entergy stated that if these actions were automated and spurious operation occurred, potential serious adverse electrical and/or fluid system interaction would be possible. While it is possible to design around these interactions, this would complicate the modification and increase its cost (Entergy 2006e). Entergy concluded for this operator action that no Phase II SAMAs need be considered. With one exception, the same conclusion is reached for the other significant operator actions. The exception is automating the starting of turbine building closed cooling water (TBCCW) pumps after a loss of offsite power. For this case, the cost-benefit of automating this function was evaluated at the NRC staff's request and it was found not to be cost-beneficial (Entergy 2006c).

1 For a number of the Phase II SAMAs listed in the ER, the information provided did not
2 sufficiently describe the proposed modification. Therefore, the NRC staff asked the applicant to
3 provide more detailed descriptions of the modifications for several of the Phase II SAMAs
4 candidates (NRC 2006a). In response to the RAI, Entergy provided the requested information
5 (Entergy 2006b).

6
7 The NRC staff questioned the ability of some of the candidate SAMAs to accomplish their
8 intended objectives (NRC 2006a). In response to the RAIs, Entergy addressed the NRC staff's
9 concerns by either re-evaluating the existing SAMA using revised modeling assumptions, or by
10 evaluating an alternative (additional) SAMA (Entergy 2006c). This is discussed further in
11 Section G.6.2.

12
13 The NRC staff also questioned Entergy about lower cost alternatives to some of the SAMAs
14 evaluated, including revising operator procedures to provide additional space cooling to the
15 emergency diesel generator (EDG) room via the use of portable equipment, the use of a
16 portable generator to power the battery chargers, and providing an auto-start feature to start a
17 TBCCW pump automatically during a LOOP event (NRC 2006a). In response to the RAIs,
18 Entergy addressed the suggested lower cost alternatives, some of which are covered by an
19 existing procedure, or are addressed by a new SAMA (Entergy 2006b, 2006c, 2006d). This is
20 discussed further in Section G.6.2.

21
22 Internal flooding initiators contributes more than 17 percent of the internal events CDF (Entergy
23 2006c). In the ER, Entergy only evaluated one SAMA candidate, SAMA 47, which would
24 uniquely reduce the internal flooding contribution. In response to an RAI, Entergy indicated that
25 a number of the SAMAs identified to mitigate non-flooding sequences would also mitigate
26 flooding events. Fourteen opportunities were identified in the IPEEE for improvements for
27 internal flooding. In response to the RAI, Entergy described each of the 14 improvements and
28 confirmed that they were either implemented and credited in the PSA (10 of the 14) or were not
29 warranted for various reasons (4 of the 14) (Entergy 2006b). In response to further NRC staff
30 inquiry, Entergy stated that an internal flooding assessment was conducted by Entergy in 2002,
31 subsequent to the IPEEE assessment. The assessment indicated SAMA 47 as a potential
32 improvement and concluded that all other identified improvements to further reduce the internal
33 flooding impact were either not feasible or excessively costly (Entergy 2006e). SAMA 47 is
34 discussed further in Section G.6.2. Additionally, Entergy provided a revised Table E.1-3 of risk
35 significant terms, which had changed based on the use of PSA version VY05R0. It indicated
36 that the number of internal flooding risk significant terms had dropped as a result of the PSA
37 revision, from 17 to nine (Entergy 2006d).

38
39 Based on this information, the NRC staff concludes that the set of SAMAs evaluated in the ER,
40 together with those identified in response to NRC staff RAIs, addresses the major internal event
41 contributors to CDF (including internal flooding).

42
43 Entergy did not identify VYNPS-specific candidate SAMAs for seismic events. In the VYNPS
44 IPEEE seismic analysis, all high confidence low probability of failure (HCLPF) values were
45 greater than the 0.3g review level earthquake except for the CST, which had a HCLPF value of
46 0.25g. NRC requested that Entergy evaluate modifications that would raise the CST HCLPF to

Appendix G

1 0.3g (NRC 2006a). Entergy indicated that the combination of strengthening the lower portion of
2 the shell and additional anchorage would accomplish this goal. To assess the benefit, operator
3 failure to switch over from CST suction for high-pressure coolant injection (HPCI)/reactor core
4 isolation coolant (RCIC) to torus suction was eliminated. This resulted in a benefit (including the
5 impact of uncertainties) of \$17,000. Entergy estimated the cost of implementing this SAMA to
6 be \$1M (Entergy 2006c). This new SAMA would not be cost-beneficial at VYNPS. Therefore,
7 no cost-effective hardware changes were identified to address the CST. Furthermore, Entergy
8 states in the ER that several seismic-related enhancements beyond those identified in the
9 IPEEE were evaluated, and that these enhancements were included in the comprehensive list
10 of Phase I SAMA candidates. Entergy identified and described these SAMAs in response to an
11 RAI (Phase I SAMAs 205 through 224) and confirmed that all of these SAMAs have been
12 implemented (Entergy 2006b). Based on the licensee's IPEEE, the A-46 efforts to identify and
13 address seismic outliers, the modifications that have already been implemented, and the
14 expected cost associated with further seismic risk analysis and potential plant modifications, the
15 NRC staff concludes that the opportunity for seismic-related SAMAs has been adequately
16 explored and that it is unlikely that there are any cost-beneficial, seismic-related SAMA
17 candidates.

18
19 Entergy also did not identify VYNPS-specific candidate SAMAs for fire events. The fire risk at
20 VYNPS is dominated by eight fire areas, the largest contributor being the cable vault. The NRC
21 staff asked the applicant to explain what measures were taken to further reduce risk and why
22 the fire risk cannot be further reduced in a cost effective manner (NRC 2006a). In response to
23 this request, Entergy stated that most of the fire scenarios are mitigated by SAMAs responding
24 to internal risk contributors. Entergy also provided a list of fire-related Phase I SAMAs (282
25 through 284) that were previously implemented. In response to an RAI concerning the
26 possibility of SAMAs to address fire events, Entergy pointed out that many of the Phase II
27 SAMAs identified based on internal events risk also mitigate the fire risk. Entergy also stated
28 that all eight dominant risk significant fire areas are equipped with a fire detection system that
29 alarms in the control room, and that six of the eight areas are equipped with a fire suppression
30 system. Of the two areas not equipped with fire suppression systems, Entergy indicated that
31 installation of these systems is either not feasible or would entail excessive costs (Entergy
32 2006e). Therefore, no hardware changes or other modifications to further reduce the fire CDF
33 were found to be cost-effective (Entergy 2006b).

34
35 In the IPEEE, five opportunities for improvements related to external flooding were identified.
36 These improvements were all related to procedural enhancements to address site flooding or
37 the sealing of conduits or walls to prevent external flood penetration (NRC 2001). In the ER,
38 Entergy stated that all have been implemented and qualitatively discussed the residual risks
39 from high winds, external flooding, ice, hazardous chemical transportation and nearby facility
40 incidents. These external hazards are below the threshold screening frequency and are not
41 expected to impact the conclusions of the SAMA analysis. Accordingly, Entergy considered the
42 potential for SAMAs to further reduce these risks, but concluded that further modifications would
43 not be cost-beneficial (Entergy 2006a). The NRC staff concludes that the applicant's rationale
44 for eliminating these enhancements from further consideration is reasonable.

The NRC staff notes that the set of SAMAs submitted is not all inclusive, since additional, possibly even less expensive, design alternatives can always be postulated. However, the NRC staff concludes that the benefits of any additional modifications are unlikely to exceed the benefits of the modifications evaluated and that the alternative improvements would not likely cost less than the least expensive alternatives evaluated, when the subsidiary costs associated with maintenance, procedures, and training are considered.

The NRC staff concludes that Entergy used a systematic and comprehensive process for identifying potential plant improvements for VYNPS, and that the set of potential plant improvements identified by Entergy is reasonably comprehensive and therefore acceptable. This search included reviewing insights from the plant-specific risk studies, reviewing plant improvements considered in previous SAMA analyses. While explicit treatment of external events in the SAMA identification process was limited, it is recognized that the prior implementation of plant modifications for seismic and fire events and the absence of external event vulnerabilities reasonably justifies examining primarily the internal events risk results for this purpose.

G.4 Risk Reduction Potential of Plant Improvements

Entergy evaluated the risk-reduction potential of the 66 remaining SAMAs that were applicable to VYNPS. The majority of the SAMA evaluations were performed in a bounding fashion in that the SAMA was assumed to completely eliminate the risk associated with the proposed enhancement. Such bounding calculations over-estimate the benefit and are conservative.

Entergy used model re-quantification to determine the potential benefits. The CDF and population dose reductions were estimated using the VYNPS PSA model. The changes made to the model to quantify the impact of the SAMAs are detailed in Section E.2.3 of Attachment E to the ER (Entergy 2006a) and in Attachment B of the September 19, 2006 RAI responses (Entergy 2006c). Table G-4 lists the assumptions that were considered to estimate the risk reduction for each of the evaluated SAMAs, the estimated risk reduction in terms of percent reduction in CDF and population dose, and the estimated total benefit (present value) of the averted risk. The estimated benefits reported in Table G-4 reflect the combined benefit from both internal and external events, as well as a number of changes to the analysis methodology and revised VYNPS PSA subsequent to the ER. The determination of the benefits for the various SAMAs is further discussed in Section G.6.

The NRC staff questioned the assumptions used in evaluating the benefits or risk reduction estimates of certain SAMAs provided in the ER (NRC 2006a, 2006b). For SAMA 59, increase the reliability of safety relief valves by adding signals to open them automatically, the NRC staff questioned Entergy's modeling assumption that only medium LOCA would be impacted by this modification (NRC 2006a, 2006b). In response, Entergy re-evaluated the SAMA by eliminating the occurrence of all RCS overpressure events. This revision resulted in a negligible CDF reduction (Entergy 2006d). The NRC staff considers the revised assumptions for this SAMA to be reasonable and acceptable for purposes of the SAMA evaluation.

Table G-4. SAMA Cost/Benefit Screening Analysis for VYNPS^(a)

SAMA	Assumptions	% Risk Reduction ^(b)		Total Benefit Using 7% Discount Rate (\$) ^(c)	Total Benefit Using 3% Discount Rate (\$) ^(c)	Cost (\$)
		CDF	Population Dose			
Additional Service Water Pump 1 - Add a service water pump.	Eliminate CDF contribution due to loss of service water.	1	1	24,000	34,000	5,900,000
Redundant Train to EDG Building HVAC 2 - Provide a redundant train/means of EDG Room ventilation.	Eliminate CDF contribution from EDG failures.	24	26	750,000	1,000,000	2,200,000 ^(d)
Improvements Related to Diagnosis of EDG Building HVAC 3 - Add a diesel building high temperature alarm, or redundant louver and thermostat.	Reduce probability of EDG run failures by a factor of three.	18	19	560,000	760,000	1,300,000 ^(d)
Decay Heat Removal Capability 4 - Install and independent method of suppression pool cooling.	Completely eliminate loss of torus cooling mode of the RHR and RHRSP system events.	6	8	230,000	310,000	5,800,000
12 - Install a passive containment spray system						5,800,000
17 - Add dedicated suppression pool cooling.						5,800,000
Filtered Vent 5 - Install a filtered containment vent to provide fission product scrubbing. Option 1: Gravel Bed Filter. Option 2: Multiple Venturi Scrubber.	Bin successful torus venting sequences into the Low-Low release category	0	~0	400	500	3,000,000
22 - Install a filtered vent.						3,000,000

SAMA	Assumptions	% Risk Reduction ^(b)		Total Benefit Using 7% Discount Rate (\$) ^(c)	Total Benefit Using 3% Discount Rate (\$) ^(c)	Cost (\$)
		CDF	Population Dose			
Containment Vent for ATWS Decay Heat Removal	Eliminate CDF contribution from loss of torus cooling mode of RHR and RHRSW in ATWS event sequences.	~0	0	0	0	
6 - Install a containment vent large enough to remove ATWS decay heat.						>2,000,000
56 - Install an ATWS sized vent.						>2,000,000
Molten Core Debris Removal	Completely eliminate containment failures due to core-concrete interaction (not including liner failure).	0	11	280,000	390,000	
7 - Create a large concrete crucible with heat removal potential under the base mate to contain molten core debris.						>100,000,000
8 - Create a water-cooled rubble bed on the pedestal.						19,000,000
11 - Create a core melt source reduction system						>1,000,000
14 - Increase the depth of the concrete base mat or use an alternative concrete material to ensure melt-through does not occur.						>5,000,000
15 - Provide a reactor vessel exterior cooling system.						2,500,000
25 - Provide a means of flooding the rubble bed.						2,500,000

Table G-4. Continued

SAMA	Assumptions	% Risk Reduction ^(b)		Total Benefit Using 7% Discount Rate (\$) ^(c)	Total Benefit Using 3% Discount Rate (\$) ^(c)	Cost (\$)
		CDF	Population Dose			
26 - Install a reactor cavity flooding system.						8,750,000
Drywell Head Flooding	Completely eliminate drywell head failures due to high temperature.	0	0	0	0	
9 - Provide modification for flooding the drywell head.						>1,000,000
23 - Provide a method of drywell head flooding.						>1,000,000
Reactor Building Effectiveness	Bin sequences with releases into reactor building into the Low-Low release category.	0	39	940,000	1,300,000	
10 - Enhance fire protection system and standby gas treatment system hardware and procedures.						>2,500,000
16 - Construct a building connected to primary containment that is maintained at a vacuum.						>2,100,000 ^(d)
24 - Use alternate method of reactor building spray.						>>2,500,000 ^(f)
Strengthen Containment	Eliminate CDF contribution due to ATWS and loss of containment heat removal.	6	9	240,000	330,000	
13 - Strengthen primary and secondary containment.						12,000,000
18 - Create a larger volume in containment.						8,000,000
19 - Increase containment pressure capability (sufficient pressure to withstand severe accidents).						12,000,000

Table G-4. Continued

SAMA	Assumptions	% Risk Reduction ^(b)		Total Benefit Using 7% Discount Rate (\$) ^(c)	Total Benefit Using 3% Discount Rate (\$) ^(c)	Cost (\$)
		CDF	Population Dose			
27 - Add ribbing to the containment shell.						12,000,000
Vacuum Breakers	Eliminate vacuum breaker failures and suppression pool scrubbing failures.	~0	0	4,000	5,000	>1,000,000
20 - Install improved vacuum breakers (redundant valves in each line)						
Temperature Margin for Seals	Eliminate containment failure due to high temperature drywell seal failure.	0	0	0	0	12,000,000
21 - Increase the temperature margin for seals.						
DC Power	Increase time available to recover offsite power before HPCI and RCIC are lost from 4 to 24 hours during SBO scenarios	11	11	340,000	450,000	
28 - Provide additional DC battery capacity.						1,730,000 ^(d)
29 - Use fuel cells instead of lead-acid batteries.						>1,000,000 ^(e)
33 - Provide 16 hour station blackout injection.						1,730,000 ^(d)
40 - Install fuel cells.						>1,000,000 ^(e)
41 - Extended station blackout provisions.						1,730,000 ^(d)
Improved DC System	Completely eliminate failures of DC bus 1.	3	3	100,000	140,000	>500,000
30 - Provide auto-transfer of AC bus control power to a standby DC power source upon loss of the normal DC source						

Table G-4. Continued

SAMA	Assumptions	% Risk Reduction ^(b)		Total Benefit Using 7% Discount Rate (\$) ^(c)	Total Benefit Using 3% Discount Rate (\$) ^(c)	Cost (\$)
		CDF	Population Dose			
Dedicated DC Power and Additional Batteries and Divisions	Completely eliminate loss of DC bus 1 and one division of DC power events (battery and bus).	6	6	180,000	240,000	
38 - Add a dedicated DC power supply.						3,000,000
39 - Install additional batteries or divisions.						3,000,000
Turbine Generator	Eliminate CDF contribution due to failure of the Vernon Tie.	29	32	920,000	1,240,000	
31 - Install a gas turbine generator.						>>2,000,000 ^(f)
34 - Install a steam driven turbine generator.						>>2,000,000 ^(f)
35 - Provide an alternate pump power source.						>5,000,000 ^(e)
36 - Install a gas turbine.						>2,000,000
37 - Install a dedicated RHR (bunkered) power supply.						>2,000,000
Bypass Diesel Generator Trips	Reduce probability of EDG failing to run by a factor of three.	18	19	560,000	760,000	>1,200,000 ^(d)
32 - Change procedure to bypass diesel generator trips, or change trip set-points.						
Locate RHR Inside Containment	Bin ISLOCA accident sequences into the same end states as medium LOCA accident sequences.	<1	<1	20,000	28,000	>500,000
42 - Locate residual heat removal (RHR) inside containment.						
ISLOCA	Eliminate CDF contribution due to ISLOCA.	<1	<1	20,000	28,000	100,000
43 - Increase frequency of valve leak testing.						

Table G-4. Continued						
SAMA	Assumptions	% Risk Reduction ^(b)		Total Benefit Using 7% Discount Rate (\$) ^(c)	Total Benefit Using 3% Discount Rate (\$) ^(c)	Cost (\$)
		CDF	Population Dose			
ISLOCA Release	Bin ISLOCA sequences into the Low-Low release category.	0	1	32,000	45,000	>2,500,000
44 - Ensure all ISLOCA releases are scrubbed.						
Containment Isolation Valve Position Indication	Eliminate CDF contribution due to ISLOCA and make containment isolation successful in the level 2 model.	<1	<1	20,000	28,000	>1,000,000
45 - Add redundant and diverse limit switches to each containment isolation valve.						
MSIV Design	Eliminate CDF contribution due to main steam line LOCA outside containment.	~0	0	0	0	>1,000,000 ^(e)
46 - Improve MSIV design.						
Shield Electrical System fro Water Spray	Eliminate CDF contribution due to internal flooding initiators that could impact injection system electrical equipment.	3	2	68,000	90,000	250,000
47 - Shield injection system electrical equipment from potential water spray.						
Diesel to CST Makeup Pumps	Eliminate operator failure to switch over from CST to torus.	2	0	8,000	9,000	135,000
48 - Install an independent diesel for the condensate storage tank makeup pumps.						
High Pressure Injection System	Eliminate CDF contribution due to failure of the HPCI system.	28	25	740,000	1,000,000	
49 - Provide an additional high pressure injection pump with independent diesel.						5,000,000 ^(e)
50 - Install independent AC high pressure injection system.						5,000,000 ^(e)
51 - Install a passive high pressure system.						28,000,000 ^(e)

Table G-4. Continued

SAMA	Assumptions	% Risk Reduction ^(b)		Total Benefit Using 7% Discount Rate (\$) ^(c)	Total Benefit Using 3% Discount Rate (\$) ^(c)	Cost (\$)
		CDF	Population Dose			
53 - Install an additional active high pressure system.						4,400,000 ^(e)
54 - Add a diverse injection system.						4,000,000 ^(e)
Improve the Reliability of High Pressure Injection System	Reduce the HPCI system failure probability by a factor of three.	19	17	500,000	670,000	4,000,000 ^(e)
52 - Improved high pressure systems.						
SRV Reseat	Eliminate CDF contribution due to stuck open relief valves.	1	37	910,000	1,280,000	4,600,000 ^(e)
55 - Increase safety relief valve (SRV) reseat reliability.						
ATWS	Eliminate CDF contribution from ATWS sequences.	2	1	28,000	36,000	>500,000
57 - Improve ATWS coping capability.						
Diversity of Explosive Valves	Eliminate common cause failure of SLC explosive valves.	0	0	0	0	>200,000
58 - Diversify explosive valve operation.						
Reliability of SRVs ^(g)	Eliminate the occurrence of all RCS overpressure events.	~ 0	0	1,400	1,900	>1,500,000
59 - Increase the reliability of safety relief valves by adding signals to open them automatically.						
Improve SRV Design	Eliminate probability of SRV failure to open for vessel depressurization.	13	8	260,000	350,000	2,800,000 ^(e)
60 - Improve SRV design.						
Self-Cooled ECCS Pump Seals	Eliminate CDF contribution from sequences involving RHR pump failures.	<1	0	9,000	12,000	>200,000
61 - Provide self-cooled ECCS pump seals.						

Table G-4. Continued

SAMA	Assumptions	% Risk Reduction ^(b)		Total Benefit Using 7% Discount Rate (\$) ^(c)	Total Benefit Using 3% Discount Rate (\$) ^(c)	Cost (\$)
		CDF	Population Dose			
Large Break LOCA	Eliminate CDF contribution due to large break LOCA.	<1	0	9,000	12,000	>100,000
62 - Provide digital large break LOCA protection.						
Controlled Containment Venting ^(g)	Reduce probability of operator failing to vent by a factor of 3 and remove guaranteed failure of core spray and LPCI.	3	4	120,000	150,000	250,000
63 - Control containment venting within a narrow band of pressure.						
Cross-Tie of RHR System to RHR Loop B	Eliminate CDF contribution from failure of firewater crosstie to RHR System to RHR loop B.	<1	0	10,000	13,000	>500,000
64 - Provide a crosstie from the RHR System to RHR loop B.						
ECCS Low Pressure Interlock - Procedure Change	Eliminate probability of ECCS low pressure permissives failing.	16	17	500,000	670,000	50,000
65 - Improve operator action: Defeat low reactor pressure interlocks to open LPCI or core spray injection valves during transients with stuck open SRVs or LOCAs in which random failures prevent all low pressure injection valves from opening.						
ECCS Low Pressure Interlock - Hardware Modification	Eliminate probability of ECCS low pressure permissives failing.	16	17	500,000	670,000	1,000,000
66 - Install a bypass switch to bypass the low reactor pressure interlocks of LPCI or core spray injection valves.						

Table G-4. Continued

- 1
2
3
4
5
6
7
8
9
10
11
12
13
14
- (a) SAMAs in bold are potentially cost-beneficial
(b) CDF and population dose reductions taken from a revised assessment provided in Attachment B of the RAI responses (Entergy 2006c) based on a revised internal events PSA, model VY05R0
(c) Estimated benefits taken from a revised assessment provided in Attachment B of the RAI responses (Entergy 2006c). This assessment is based on: (1) internal events PSA version VY05R0, (2) a multiplier of 3.33 to account for potential risk reduction in both internal and external events, and (3) revised core inventories to reflect expected fuel management practices at VYNPS.
(d) Estimated costs reflect revised values provided in Attachment B of the RAI responses (Entergy 2006c)
(e) Estimated costs reflect revised values provided in response to RAI 6.b (Entergy 2006c)
(f) Estimated costs reflect revised values provided in response to RAI IV.d (Entergy 2006d)
(g) The assumptions, estimated benefits, CDF and population dose reductions reflect a revised analysis provided in the RAI clarifications (Entergy 2006d)

For Phase II SAMA 63, control containment venting within a narrow pressure band, Entergy estimated the benefit by reducing the probability of operator failure to vent by a factor of three (Entergy 2006a). The NRC staff noted that the benefit of controlled venting occurs for sequences involving successful venting, and that these sequences are not affected by reducing the operator failure to vent (NRC 2006a). In response to an RAI and a subsequent request for clarification, Entergy revised the PSA model binning rule to remove guaranteed failure of core spray and LPCI based upon successful venting of containment. This revision resulted in a CDF reduction of approximately 3.2 percent, which is slightly more than the 2.8 percent CDF reduction previously estimated, and an increase in the estimated benefit (Entergy 2006d). The NRC staff considers the revised assumptions for this SAMA to be reasonable and acceptable for purposes of the SAMA evaluation.

The NRC staff has reviewed Entergy's bases for calculating the risk reduction for the various plant improvements and concludes that the rationale and assumptions for estimating risk reduction are reasonable and generally conservative (i.e., the estimated risk reduction is higher than what would actually be realized). Accordingly, the NRC staff based its estimates of averted risk for the various SAMAs on Entergy's risk reduction estimates.

G.5 Cost Impacts of Candidate Plant Improvements

Entergy estimated the costs of implementing the 66 candidate SAMAs through the application of engineering judgement and use of other licensees' estimates for similar improvements. The cost estimates conservatively did not include the cost of replacement power during extended outages required to implement the modifications, nor did they include contingency costs associated with unforeseen implementation obstacles. The cost estimates provided in the ER also did not account for inflation, which is considered another conservatism. For those SAMAs whose implementation costs were originally developed for severe accident mitigation design alternative analyses (i.e., during the design phase of the plant), additional costs associated with performing design modifications to the existing plant were not included (Entergy 2006a).

The NRC staff reviewed the bases for the applicant's cost estimates (presented in Section E.2.3 of Attachment E to the ER). For certain improvements, the NRC staff also compared the cost estimates to estimates developed elsewhere for similar improvements, including estimates developed as part of other licensees' analyses of SAMAs for operating reactors and advanced light-water reactors. The NRC staff noted that several of the cost estimates provided by the applicant were drawn from previous SAMA analyses for a dual-unit site. As such, the cost estimates reflect implementation for two units. Also, some of the cost estimates provided (as taken from other SAMA analyses) are specific to a plant's design, such as the number of valves or batteries that would need to be replaced. Therefore, the NRC staff asked the applicant to provide appropriate cost estimates that are specific to VYNPS (NRC 2006a). In response to the NRC staff's request, Entergy provided revised cost estimates for several SAMAs (Entergy 2006c). For those cost estimates that were taken from a dual-unit SAMA analysis, Entergy reduced the estimated costs by half. For those SAMAs that required a more plant-specific cost estimate, Entergy provided new cost estimates along with a brief explanation of what the cost estimates include. Additionally, Entergy provided more refined cost estimates for other SAMAs, as a part of the revised benefit assessment. Refined cost estimates were used for SAMAs in which the revised benefits (using PSA version VY05R0) significantly changed from that provided

Appendix G

in the ER. Revision of these cost estimates had no impact on the original conclusions that these SAMAs were not cost-beneficial (Entergy 2006c). The NRC staff reviewed the costs and subsequent cost revisions and found them to be reasonable, and generally consistent with estimates provided in support of other plants' analyses.

The NRC staff concludes that the cost estimates provided by Entergy are sufficient and appropriate for use in the SAMA evaluation.

G.6 Cost-Benefit Comparison

Entergy's cost-benefit analysis and the NRC staff's review are described in the following sections.

G.6.1 Entergy's Evaluation

The methodology used by Entergy was based primarily on NRC's guidance for performing cost-benefit analysis, i.e., NUREG/BR-0184, *Regulatory Analysis Technical Evaluation Handbook* (NRC 1997b). The guidance involves determining the net value for each SAMA according to the following formula:

$$\begin{aligned} \text{Net Value} &= (\text{APE} + \text{AOC} + \text{AOE} + \text{AOSC}) - \text{COE} \text{ where,} \\ \text{APE} &= \text{present value of averted public exposure (\$)} \\ \text{AOC} &= \text{present value of averted offsite property damage costs (\$)} \\ \text{AOE} &= \text{present value of averted occupational exposure costs (\$)} \\ \text{AOSC} &= \text{present value of averted onsite costs (\$)} \\ \text{COE} &= \text{cost of enhancement (\$)}. \end{aligned}$$

If the net value of a SAMA is negative, the cost of implementing the SAMA is larger than the benefit associated with the SAMA and it is not considered cost-beneficial. Entergy's derivation of each of the associated costs is summarized below.

NUREG/BR-0058 has recently been revised to reflect the agency's policy on discount rates. Revision 4 of NUREG/BR-0058 states that two sets of estimates should be developed: one at three percent and one at seven percent (NRC 2004). Entergy provided both sets of estimates (Entergy 2006a).

Averted Public Exposure (APE) Costs

The APE costs were calculated using the following formula:

$$\begin{aligned} \text{APE} &= \text{Annual reduction in public exposure } (\Delta\text{person-rem/year}) \\ &\quad \times \text{monetary equivalent of unit dose } (\$2000 \text{ per person-rem}) \\ &\quad \times \text{present value conversion factor (10.76 based on a 20-year period with a} \\ &\quad \quad \text{7-percent discount rate).} \end{aligned}$$

As stated in NUREG/BR-0184 (NRC 1997b), it is important to note that the monetary value of the public health risk after discounting does not represent the expected reduction in public health risk due to a single accident. Rather, it is the present value of a stream of potential

losses extending over the remaining lifetime (in this case, the renewal period) of the facility. Thus, it reflects the expected annual loss due to a single accident, the possibility that such an accident could occur at any time over the renewal period, and the effect of discounting these potential future losses to present value. For the purposes of initial screening, which assumes elimination of all severe accidents due to internal events, Entergy calculated an APE of approximately \$325,000 for the 20-year license renewal period.

Averted Offsite Property Damage Costs (AOC)

The AOCs were calculated using the following formula:

$$\begin{aligned} \text{AOC} = & \text{Annual CDF reduction} \\ & \times \text{offsite economic costs associated with a severe accident (on a per-event basis)} \\ & \times \text{present value conversion factor.} \end{aligned}$$

For the purposes of initial screening which assumes all severe accidents due to internal events are eliminated, Entergy calculated an annual offsite economic risk of about \$36,600 based on the Level 3 risk analysis. This results in a discounted value of approximately \$393,000 for the 20-year license renewal period.

Averted Occupational Exposure (AOE) Costs

The AOE costs were calculated using the following formula:

$$\begin{aligned} \text{AOE} = & \text{Annual CDF reduction} \\ & \times \text{occupational exposure per core damage event} \\ & \times \text{monetary equivalent of unit dose} \\ & \times \text{present value conversion factor.} \end{aligned}$$

Entergy derived the values for averted occupational exposure from information provided in Section 5.7.3 of the regulatory analysis handbook (NRC 1997b). Best estimate values provided for immediate occupational dose (3300 person-rem) and long-term occupational dose (20,000 person-rem over a 10-year cleanup period) were used. The present value of these doses was calculated using the equations provided in the handbook in conjunction with a monetary equivalent of unit dose of \$2,000 per person-rem, a real discount rate of seven percent, and a time period of 20 years to represent the license renewal period. For the purposes of initial screening, which assumes all severe accidents due to internal events are eliminated, Entergy calculated an AOE of approximately \$3,000 for the 20-year license renewal period.

Averted Onsite Costs

Averted onsite costs (AOSC) include averted cleanup and decontamination costs and averted power replacement costs. Repair and refurbishment costs are considered for recoverable accidents only and not for severe accidents. Entergy derived the values for AOSC based on information provided in Section 5.7.6 of NUREG/BR-0184, the regulatory analysis handbook (NRC 1997b).

Appendix G

1 Entergy divided this cost element into two parts – the onsite cleanup and decontamination cost,
2 also commonly referred to as averted cleanup and decontamination costs, and the replacement
3 power cost.

4 Averted cleanup and decontamination costs (ACC) were calculated using the following formula:

5 ACC = Annual CDF reduction
6 x present value of cleanup costs per core damage event
7 x present value conversion factor.

8 The total cost of cleanup and decontamination subsequent to a severe accident is estimated in
9 NUREG/BR-0184 to be $\$1.1 \times 10^9$ (discounted over a 10-year cleanup period). This value is
10 integrated over the term of the proposed license extension. For the purposes of initial
11 screening, which assumes all severe accidents due to internal events are eliminated, Entergy
12 calculated an ACC of approximately \$92,600 for the 20-year license renewal period.

13 Long-term replacement power costs (RPC) were calculated using the following formula:

14 RPC = Annual CDF reduction
15 x present value of replacement power for a single event
16 x factor to account for remaining service years for which replacement power is
17 required
18 x reactor power scaling factor

19 For the purposes of initial screening, which assumes all severe accidents due to internal events
20 are eliminated, Entergy calculated an RPC of approximately \$63,000 for the 20-yr license
21 renewal period.

22 Entergy based its calculations on the value of 910 megawatt electrics, which is greater than the
23 current electrical output for VYNPS (after the extended power uprate). Therefore, Entergy
24 conservatively did not apply power scaling factors to determine the replacement power costs.
25 For the purposes of initial screening, which assumes all severe accidents are eliminated,
26 Entergy calculated the AOSC to be approximately \$156,000 for the 20-year license renewal
27 period.

28 Using the above equations, Entergy estimated the total present dollar value equivalent
29 associated with completely eliminating severe accidents due to internal events at VYNPS to be
30 about \$878,000. Use of a multiplier of 3.33 to account for external events increases the value
31 to \$2.9M and represents the dollar value associated with completely eliminating all internal and
32 external event severe accident risk at VYNPS.

33 Entergy's Results

34 If the implementation costs for a candidate SAMA exceeded the calculated benefit, the SAMA
35 was considered not to be cost-beneficial. In the baseline analysis contained in the ER (using
36 the PSA version VY04R1, a 7-percent discount rate, and considering the combined impact of

1 both external events and uncertainties), Entergy identified three potentially cost-beneficial
2 SAMAs:

- 4 • SAMA 47 – shield injection system electrical equipment from potential water spray. This
5 SAMA involves installing shields in two locations to address the impacts of breaks in
6 either of the two locations. At the 303' elevation, the shields would protect the
7 emergency core cooling system (ECCS) 24V DC distribution panel. At the 290'
8 elevation, the shields would protect the ECCS instrument panel 6B (S2), channels A and
9 C.
- 10 • SAMA 65 – modify procedures to allow operators to defeat the low reactor pressure
11 interlock circuitry that inhibits opening the low-pressure coolant injection (LPCI) or core
12 spray injection valves following sensor or logic failures that prevent all low pressure
13 injection valves from opening.
- 14 • SAMA 66 – install a bypass switch to allow operators to bypass the low reactor pressure
15 interlock circuitry that inhibits opening the LPCI or core spray injection valves following
16 sensor or logic failures that prevent all low pressure injection valves from opening.

19 Entergy performed an additional analysis to evaluate the impact of alternative discount rates on
20 the results of the SAMA assessment. No additional SAMA candidates were determined to be
21 potentially cost-beneficial (Entergy 2006a).

24 In response to an RAI, Entergy provided a revised assessment based on a separate accounting
25 of the impacts of external events and uncertainties and the use of PSA version VY05R0
26 (Entergy 2006c). The revised baseline assessment resulted in identification of only one
27 potentially cost-beneficial SAMA (SAMA 65). However, when accounting for uncertainties,
28 SAMA 66 was also potentially cost-beneficial. (SAMA 47, which was marginally cost-beneficial
29 in Entergy's original SAMA assessment, is not cost-beneficial in the revised assessment. This
30 shift is due to a reduction in the multipliers used in the revised assessment for external events
31 and uncertainties, which had multiple conservatisms in the ER.) However, in response to NRC
32 staff inquiries regarding estimated benefits for certain SAMAs and lower cost alternatives, four
33 additional potentially cost-beneficial SAMAs were identified. The potentially cost-beneficial
34 SAMAs, and Entergy's plans for further evaluation of these SAMAs are discussed in more detail
35 in Section G.6.2.

38 **G.6.2 Review of Entergy's Cost-Benefit Evaluation**

40 The cost-benefit analysis performed by Entergy was based primarily on NUREG/BR-0184
41 (NRC 1997b) and was executed consistent with this guidance.

43 In the ER, Entergy evaluated the reduction in risk for each SAMA in the context of an upper
44 bound analysis which combined the impact of external events with the impact of uncertainties.
45 Entergy bounded the combined impact of external events and uncertainties in the ER by
46 applying a multiplier of 10 to the estimated SAMA benefits in internal events.

Appendix G

The NRC staff requested that the baseline evaluation be revised to include only the impact of internal and external events (without uncertainties), and that the impact of analysis uncertainties on the SAMA evaluation results be considered separately (NRC 2006a). Given that a revised CDF was provided in the RAI response (using PSA version VY05R0), Entergy applied the NRC staff request to a revised set of CDF values. The impact of external events was considered by applying a multiplier of 3.33 to the estimated SAMA benefits in internal events ($1 + [\text{negligible seismic CDF} + \text{fire CDF of } 1.86 \times 10^{-5} \text{ per year}] / [\text{internal events CDF of } 7.98 \times 10^{-6} \text{ per year}]$). Additionally, Entergy revised the consequence analyses on which the benefit estimates are based to account for fuel enrichment and burn-up expected during the period of extended operation.

As a result of the revised baseline analysis (using PSA version VY05R0, a multiplier of 3.33 and a 7 percent real discount rate), Entergy found that only one SAMA candidate remained potentially cost-beneficial. SAMA 65 remained cost-beneficial, while SAMAs 47 and 66 were no longer cost-beneficial. When benefits were evaluated using a 3 percent discount rate, as recommended in NUREG/BR-0058, Revision 4 (NRC 2004), no additional SAMAs were determined to be potentially cost-beneficial.

Entergy considered the impact that possible increases in benefits from analysis uncertainties would have on the results of the SAMA assessment. In the revised ER, Entergy presents the results of an uncertainty analysis of the internal events CDF which indicates that the 95 percentile value is a factor of 2.15 times the mean CDF. Information regarding the uncertainty distribution of the internal events CDF of the revised analysis (using PSA version VY05R0) is summarized in Table G-5 (Entergy 2006c). Entergy re-examined the Phase II SAMAs in the revised assessment to determine if any would be potentially cost-beneficial if the revised baseline benefits were increased by an additional factor of 2.15. One additional potentially cost-beneficial SAMA was identified (SAMA 66). SAMA 47, which was marginally cost-beneficial in Entergy's original SAMA assessment, is not cost-beneficial in the revised assessment. This shift is due to a reduction in the multipliers used in the revised assessment for external events and uncertainties, which had multiple conservatisms in the ER.

Table G-5. Uncertainty in the Calculated CDF for VYNPS

Percentile	CDF (per year)
5 th	3.81×10^{-6}
50 th	6.78×10^{-6}
mean	8.42×10^{-6}
95 th	1.81×10^{-5}

Entergy has submitted the potentially cost-beneficial SAMAs 65 and 66 for engineering project cost-benefit analysis. Given that SAMA 47 was no longer found to be potentially cost-beneficial using PSA version VY05R0, Entergy does not plan to evaluate this SAMA for implementation (Entergy 2006d).

1 The NRC staff questioned the ability of some of the candidate SAMAs identified in the ER to
2 accomplish their intended objectives (NRC 2006a). This included Phase II SAMA 46, improved
3 MSIV design, Phase II SAMA 47, shield injection system electrical equipment from potential
4 water spray, and Phase II SAMA 63, control containment venting within a narrow pressure
5 band. In response, Entergy provided further clarification or revised evaluations (Entergy 2006b,
6 2006c, 2006d). Of particular note is the revised evaluation of Phase II SAMA 63.

7 Phase II SAMA 63, control containment venting within a narrow pressure band, was identified
8 as a potential SAMA to prevent rapid containment depressurization when venting, thus avoiding
9 adverse impacts on the ability of low pressure injection systems to take suction from the torus.
10 As described in Section G.4, Entergy revised the PSA model binning rule to remove guaranteed
11 failure of core spray and LPCI based upon successful venting of containment to address the
12 NRC staff's concerns with the benefit assessment. This revision resulted in a CDF reduction of
13 approximately 3.2 percent and Entergy estimated the benefit (not including the impact of
14 uncertainty) to be approximately \$116,000 (Entergy 2006d). The estimated cost of
15 implementing this SAMA is approximately \$250,000 (Entergy 2006c). The NRC staff notes that
16 when the impact of uncertainties is included, the benefit of SAMA 63 becomes approximately
17 \$250,000. Therefore, SAMA 63 is potentially cost-beneficial.

19 The NRC staff also requested that the applicant provide an evaluation of the costs and benefits
20 of converting the vent system to a passive design or adding redundant components. In
21 response, Entergy evaluated three new SAMAs. The benefit associated with conversion of the
22 existing torus to a passive torus vent was estimated to result in a CDF reduction of 4.5 percent,
23 and a benefit (including the impact of uncertainties) of \$370,000. However, Entergy estimated
24 the cost of implementing this SAMA to be approximately \$980,000 (Entergy 2006c).

25 Additionally, Entergy evaluated two new SAMAs associated with adding redundant components.
26 The first SAMA proposed providing an alternate power source to torus vent valve V-16-19-86.
27 The second SAMA proposed providing a redundant vent path. The cost of these modifications
28 were estimated at \$720,000 and \$1.5M, respectively. In an RAI clarification, Entergy stated that
29 the benefit associated with converting the existing torus vent to a passive design can be used
30 as a bounding (conservative) estimate for the two new SAMAs. While the two new SAMAs
31 mitigate the failure of specific components, operator failure to implement torus venting remains
32 the dominant contributor to CDF. As such, implementation of either of these alternative SAMAs
33 would provide a benefit less than \$370,000 (Entergy 2006d), and would not be cost-beneficial at
34 VYNPS.

36 The NRC staff noted that for certain SAMAs considered in the ER, there may be alternatives
37 that could achieve much of the risk reduction at a lower cost. The NRC staff asked the
38 applicant to evaluate several lower cost alternatives to the SAMAs considered in the ER,
39 including SAMAs that had been found to be potentially cost-beneficial at other BWR plants.
40 These alternatives included: (1) revising operator procedures to provide additional space
41 cooling to the EDG room via the use of portable equipment, (2) using a portable generator to
42 power the battery chargers, (3) providing an auto-start feature to start a TBCCW pump
43 automatically during a LOOP event, (4) providing alternate direct current (DC) feeds to panels

Appendix G

supplied only by DC bus, and several additional alternatives (NRC 2006a). Entergy provided a further evaluation of these alternatives, as summarized below.

- Operator procedure revisions to provide additional space cooling to the EDG room via the use of portable equipment (in lieu of a redundant train of EDG room ventilation considered in Phase II SAMA 2) – Based on a bounding analysis in which EDG failures were set to zero, Entergy estimated that this SAMA would result in a CDF reduction of about 24 percent, a population dose reduction of 26 percent and a benefit (including the impact of uncertainties) of \$1,610,000. Entergy estimated the cost of implementing this SAMA to be approximately \$50,000 (Entergy 2006c). Therefore, Entergy concluded that this low-cost alternative is potentially cost-beneficial for VYNPS.
- Use a portable generator to power the battery chargers -- in response to the NRC staff's inquiry regarding use of a portable generator, Entergy stated that upon a complete SBO, a portable generator could be used to extend the life of both 125 VDC batteries. To assess the benefit, the time available for recovery of offsite power was increased from 4 hours to 24 hours for SBO scenarios. This resulted in a benefit (with uncertainties) of approximately \$723,000 (Entergy 2006c). Entergy estimated the cost of implementing this SAMA to be \$712,000. Therefore, Entergy concluded that this low-cost alternative is potentially cost-beneficial for VYNPS.
- Provide an auto-start feature to start a TBCCW pump automatically during a LOOP event – to assess the benefit, Entergy created a model with the operator action to start a TBCCW pump set to guaranteed success. This resulted in a CDF reduction of 1.4 percent and a benefit (including the impact of uncertainties) of \$49,000. (Entergy 2006c). Entergy estimated the cost of implementing this SAMA to be greater than \$100,000. Therefore, this new SAMA would not be cost-beneficial at VYNPS.
- Use a portable generator to provide power to individual 125VDC motor control centers (MCCs) upon loss of a DC bus - To conservatively assess the benefit, Entergy set the failure of the HPCI system to zero. This is equivalent to the benefit assessment for SAMA 49, or approximately \$1.6M (including the impact of uncertainties). Entergy estimated the cost of implementing and using the portable generator to be \$712,000 (Entergy 2006d). Therefore, Entergy concluded that this low-cost alternative is potentially cost-beneficial for VYNPS.
- Entergy indicated that the remaining low cost alternatives identified by the NRC staff are either already addressed by existing plant procedures, or by a Phase II SAMA.

The NRC staff notes that Entergy has submitted SAMAs 65 and 66 for engineering project cost-benefit analysis. However, four additional potentially cost-beneficial SAMA were identified as a result of the NRC staff review, i.e., (1) control containment venting within a narrow pressure band (SAMA 63), (2) operator procedure revisions to provide additional space cooling to the EDG room via the use of portable equipment, (3) use a portable diesel generator to extend the life of the 125 VDC batteries, and (4) use a portable generator to provide power to individual

1 125VDC MCCs upon loss of a DC bus. These SAMAs should also be included in the set of
2 SAMAs to be further evaluated by Entergy.

3
4 The NRC staff concludes that, with the exception of the potentially cost-beneficial SAMAs
5 discussed above, the costs of the SAMAs evaluated would be higher than the associated
6 benefits.

7
8 **G.7 Conclusions**

9
10 Entergy compiled a list of 302 SAMAs based on a review of: the most significant basic events
11 from the plant-specific PSA, insights from the plant-specific IPE and IPEEE, Phase II SAMAs
12 from license renewal applications for other plants, and review of other NRC and industry
13 documentation concerning potential plant improvements. A qualitative screening removed
14 SAMA candidates that (1) were not applicable at VYNPS due to design differences, (2) had
15 already been implemented at VYNPS, or (3) were similar and could be combined with another
16 SAMA. Based on this screening, 236 SAMAs were eliminated leaving 66 candidate SAMAs for
17 evaluation.

18
19 For the remaining SAMA candidates, a more detailed design and cost estimate were developed
20 as shown in Table G-4. The cost-benefit analyses in the original ER showed that three SAMA
21 candidates were potentially cost-beneficial in the baseline analysis (Phase II SAMAs 47, 65 and
22 66). In a revised analysis, Entergy evaluated the same SAMA candidates using a later version
23 of the PSA, new multipliers to account for external events and uncertainties, and core inventory
24 values that better reflect plant-specific fuel management practices. This showed that one SAMA
25 was potentially cost-beneficial in the baseline analysis (Phase II SAMA 65), and one additional
26 SAMA was potentially-cost beneficial when analysis uncertainties are considered (SAMA 66).
27 (SAMA 47, which was marginally cost-beneficial in Entergy's original assessment, is not cost-
28 beneficial in the revised analysis.) Entergy has indicated that Phase II SAMAs 65 and 66 have
29 been submitted for engineering project cost-benefit analysis. The NRC staff concurs that these
30 two SAMAs are potentially cost-beneficial. In addition, as a result of the NRC staff review, four
31 additional SAMAs were also found to be potentially cost-beneficial, i.e., (1) control containment
32 venting within a narrow pressure band (SAMA 63), (2) operator procedure revisions to provide
33 additional space cooling to the EDG room via the use of portable equipment, (3) use a portable
34 diesel generator to extend the life of the 125 VDC batteries, and (4) use a portable generator to
35 provide power to individual 125VDC MCCs upon loss of a DC bus. These SAMAs should also
36 be included in the set of SAMAs to be further evaluated by Entergy.

37
38 The NRC staff reviewed the Entergy analysis and concludes that the methods used and the
39 implementation of those methods was sound. The treatment of SAMA benefits and costs
40 support the general conclusion that the SAMA evaluations performed by Entergy are reasonable
41 and sufficient for the license renewal submittal. Although the treatment of SAMAs for external
42 events was somewhat limited, the likelihood of there being cost-beneficial enhancements in this
43 area was minimized by improvements that have been realized as a result of the IPEEE process,
44 and inclusion of a multiplier to account for external events.

1 Appendix G

2 The NRC staff concurs with Entergy's identification of areas in which risk can be further reduced
3 in a cost-beneficial manner through the implementation of all the identified, potentially cost-
4 beneficial SAMAs. Given the potential for cost-beneficial risk reduction, the NRC staff agrees
5 that further evaluation of these SAMAs by Entergy is warranted. However, these SAMAs do not
6 relate to adequately managing the effects of aging during the period of extended operation.
7 Therefore, they need not be implemented as part of license renewal pursuant to Title 10 of the
Code of Federal Regulations, Part 54.

8 **G.8 References**

9 Electric Power Research Institute. 1991. *A Methodology for Assessment of Nuclear Power*
10 *Plant Seismic Margins*, Revision 1. EPRI Report NP-6041-SL.

11 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2003.
12 *Vermont Yankee Nuclear Power Station License No. DPR-28 (Docket No. 50-271) Technical*
13 *Specification Proposed Change No. 263 Extended Power Uprate*. Brattleboro, Vermont.
14 (September 10, 2003).

15 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2004.
16 *Vermont Yankee Nuclear Power Station License No. DPR-28 (Docket No. 50-271) Technical*
17 *Specification Proposed Change No. 263, Supplement No. 5 Extended Power Uprate -*
18 *Response to Request for Additional Information*. Brattleboro, Vermont. (January 31, 2004).

19 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006a.
20 *Applicant's Environmental Report – Operating License Renewal Stage, Vermont Yankee*
21 *Nuclear Power Station*. Docket No. 50-271. Brattleboro, Vermont. (January 25, 2006).

22 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006b.
23 *Vermont Yankee Nuclear Power Station License No. DPR-28 (Docket No. 50-271) License*
24 *Renewal Application, Amendment 7*. Entergy Nuclear Operations, Inc., Brattleboro, Vermont.
25 (August 1, 2006).

26 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006c.
27 *Vermont Yankee Nuclear Power Station License No. DPR-28 (Docket No. 50-271) License*
28 *Renewal Application, Amendment 13*. Entergy Nuclear Operations, Inc., Brattleboro, Vermont.
29 (September 19, 2006).

30 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006d.
31 *Vermont Yankee Nuclear Power Station License No. DPR-28 (Docket No. 50-271) License*
32 *Renewal Application, Amendment 18*. Entergy Nuclear Operations, Inc., Brattleboro, Vermont.
33 (October 20, 2006).

Appendix G

1 Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy). 2006e.
2 *Vermont Yankee Nuclear Power Station License No. DPR-28 (Docket No. 50-271) License*
3 *Renewal Application, Amendment 21.* Entergy Nuclear Operations, Inc., Brattleboro, Vermont.
4 (November 6, 2006).

5
6 U.S. Department of Agriculture. 1998. 1997 Census of Agriculture, National Agriculture
7 Statistics Service, 1998. Available URL:
8 <http://www.nass.usda.gov/census/census97/volume1/vol1pubs.htm> (Accessed September 1,
9 2006)

10
11 U.S. Nuclear Regulatory Commission (NRC). 1990. *Severe Accident Risks: An Assessment*
12 *for Five U.S. Nuclear Power Plants.* NUREG-1150, Washington, D.C.

13
14 U.S. Nuclear Regulatory Commission (NRC). 1991. *Procedural and Submittal Guidance for the*
15 *Individual Plant Examination of External Events for Severe Accident Vulnerabilities.*
16 NUREG-1407, Washington, D.C.

17
18 U.S. Nuclear Regulatory Commission (NRC). 1996. Letter from Daniel H. Dorman, U.S. NRC,
19 to Donald A. Reid, VYNPS. *Vermont Yankee Nuclear Power Station Individual Plant*
20 *Examination (IPE) - Internal Events (TAC No. M74484).* (February 9, 1996).

21
22 U.S. Nuclear Regulatory Commission (NRC). 1997a. *Individual Plant Examination Program:*
23 *Perspectives on Reactor Safety and Plant Performance.* NUREG-1560, Washington, D.C.

24
25 U.S. Nuclear Regulatory Commission (NRC). 1997b. *Regulatory Analysis Technical Evaluation*
26 *Handbook.* NUREG/BR-0184, Washington, D.C.

27
28 U.S. Nuclear Regulatory Commission (NRC). 2000. Letter from Richard P. Croteau, U.S. NRC
29 to Samuel L. Newton, VYNPS. *Vermont Yankee Nuclear Power Station - Safety Evaluation*
30 *Report for Unresolved Safety Issue (USI) A-46 Program Implementation (TAC No. M69490).*
31 (March 20, 2000).

32
33 U.S. Nuclear Regulatory Commission (NRC). 2001. Letter from Robert M. Pulsifer, U.S. NRC
34 to Michael A. Balduzzi, VYNPS. *Vermont Yankee Nuclear Power Station - Individual Plant*
35 *Examination of External Events (IPEEE) Submittal (TAC No. M83689).* (March 22, 2001).

36
37 U.S. Nuclear Regulatory Commission (NRC). 2002. *Perspectives Gained From the IPEEE*
38 *Program, Final Report, Vols. 1 and 2,* NUREG-1742, Washington, D.C.

39
40 U.S. Nuclear Regulatory Commission (NRC). 2003. Letter from Mark F. Reinhart, U.S. NRC, to
41 Stuart Richards and Patrick D. O'Reilly, U.S. NRC. *Results of the Vermont Yankee Nuclear*
42 *Power Station Phase 2 Notebook Benchmarking Visit.* (September 29, 2003).

43
44 U.S. Nuclear Regulatory Commission (NRC). 2004. *Regulatory Analysis Guidelines of the U.S.*
45 *Nuclear Regulatory Commission.* NUREG/BR-0058, Washington, D.C.

Appendix G

1 U.S. Nuclear Regulatory Commission (NRC). 2005. Letter from Mark P. Rubin, U.S. NRC to
2 Darrell J. Roberts, U.S. NRC. *Safety Evaluation Report Input Concerning the Risk Evaluation of*
3 *the Vermont Yankee Nuclear Power Station Extended Power Uprate Application (TAC No.*
4 *MC0761)*. (October 3, 2005).

5
6 U.S. Nuclear Regulatory Commission (NRC). 2006a. Letter from Richard L. Emch, U.S. NRC,
7 to Michael Kansler, Entergy. *Request for Additional Information Regarding Severe Accident*
8 *Mitigation Alternatives for the Vermont Yankee Nuclear Power Station (TAC No. MC9670)*.
9 (June 1, 2006).

10
11 U.S. Nuclear Regulatory Commission (NRC). 2006b. Email from Richard L. Emch, U.S. NRC,
12 to Michael Hamer, Entergy. *Request for Clarification Regarding Responses to RAIs for Severe*
13 *Accident Mitigation Alternatives for the Vermont Yankee Nuclear Power Station (TAC No.*
14 *MC9670)*. (September 27, 2006).

15
16 Vermont Yankee Nuclear Power Corporation (VYNPC). 1993. Letter from James P. Pelletier,
17 VYNPS to U.S. Nuclear Regulatory Commission Document Control Desk. *Vermont Yankee*
18 *Response to Generic Letter 88-20: Report on the Individual Plant Examination for Severe*
19 *Accident Vulnerabilities - 10CFR 50-54 (f)*. (December 21, 1993).

20
21 Vermont Yankee Nuclear Power Corporation (VYNPC). 1998. Letter from Don M. Leach,
22 VYNPS to NRC Document Control Desk. *Vermont Yankee Nuclear Power Station License No.*
23 *DPR-28 (Docket No. 50-271) Submittal of the Vermont Yankee Individual Plant Examination for*
24 *External Events (IPEEE) Report - Response to Generic Letter 88-20, Supplement 4*. (June 30,
25 1998).

26
27 Vermont Yankee Nuclear Power Corporation (VYNPC). 2000. Letter from Don M. Leach,
28 VYNPS to NRC Document Control Desk. *Vermont Yankee Nuclear Power Station License No.*
29 *DPR-28 (Docket No. 50-271) Closeout for Resolution of USI A-46 Outliers*. (January 28, 2000.)
30

BIBLIOGRAPHIC DATA SHEET

(See instructions on the reverse)

		1. REPORT NUMBER (Assigned by NRC, Add Vol., Supp., Rev., and Addendum Numbers, if any.)
		NUREG-1437, Supplement 30
2. TITLE AND SUBTITLE Generic Environmental Impact Statement for License Renewal of Nuclear Plants Supplement 30 Regarding Vermont Yankee Nuclear Power Station Draft Report		3. DATE REPORT PUBLISHED MONTH YEAR December 2006
		4. FIN OR GRANT NUMBER
5. AUTHOR(S) See Appendix B of report		6. TYPE OF REPORT Draft, Technical
		7. PERIOD COVERED (Inclusive Dates)
8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC, provide Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.) Division of License Renewal Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Washington, DC 20555-0001		
9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC, type "Same as above"; if contractor, provide NRC Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address.) Same as Block 8.		
10. SUPPLEMENTARY NOTES Docket No. 50-271		
11. ABSTRACT (200 words or less) This draft supplemental environmental impact statement (SEIS) has been prepared in response to an application submitted to the NRC by Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (Entergy) to renew the operating licenses for Vermont Yankee Nuclear Power Station (VYNPS) for an additional 20 years under 10 CFR Part 54. This draft SEIS includes the NRC staff's analysis that considers and weighs the environmental impacts of the proposed action, the environmental impacts of alternatives to the proposed action, and mitigation measures available for reducing or avoiding adverse impacts. It also includes the staff's preliminary recommendation regarding the proposed action. The NRC staff's preliminary recommendation is that the Commission determine that the adverse environmental impacts of license renewal for VYNPS are not so great that preserving the option of license renewal for energy-planning decision makers would be unreasonable. This recommendation is based on (1) the analysis and findings in the GEIS; (2) the Environmental Report submitted by Entergy; (3) consultation with Federal, State, and local agencies; (4) the staff's own independent review; and (5) the staff's consideration of public comments received during the scoping process.		
12. KEY WORDS/DESCRIPTORS (List words or phrases that will assist researchers in locating the report.) Vermont Yankee Nuclear Power Station VYNPS Vermont Yankee DSEIS Draft Supplement to the Generic Environmental Impact Statement GEIS NEPA Environmental License Renewal		13. AVAILABILITY STATEMENT unlimited
		14. SECURITY CLASSIFICATION (This Page) unclassified
		(This Report) unclassified
		15. NUMBER OF PAGES
		16. PRICE



Printed
on recycled
paper

Federal Recycling Program