

Utility Working Group

Working group charge

Roles

EPA expectations

Suggested ground rules

Sally Shaver

Emission Standards Division



Working group *charge*...

- *CHARGE* to the working group
 - Provide input to the EPA regarding Federal MACT regulations for coal-fired electric utility steam generating units that will maximize environmental and public health benefits in a flexible framework at a reasonable cost of compliance and within the constraints of the Clean Air Act

The central challenges in addressing the *charge* are...

- Obtaining active participation from all stakeholders
- Determining the most effective ways to address environmental issues
- Considering strategies for simplifying the regulations and allowing compliance flexibility while maintaining full environmental benefits

Questions that may be considered under the *charge*

- Are the available data adequate?
- How should the subcategories/floors be determined?
- What regulatory alternatives, including beyond-the-floor options, should be considered?
- What are the impacts of each alternative?
- What regulatory recommendations should be considered?

What is NOT part of the *charge*?

- This working group will not
 - Reconsider the basis for the Administration's finding that regulation of coal-fired electric utility steam generating units under section 112 of the CAA is necessary and appropriate
 - Discuss litigation issues
 - Make recommendations regarding any three-pollutant legislation or other non-CAA alternatives to regulation

Roles -- EPA

- EPA's role is to
 - Provide a forum in which all stakeholders may brainstorm
 - Encourage group to stay focused on the issues at hand so as to maximize the use of the available time
 - Provide support to working group by drafting and distributing materials
 - Provide feedback on policy issues/questions

Roles -- Stakeholders

- Each stakeholder's role is to
 - Provide feedback to EPA on the working group's charge
 - Come prepared to analyze and address issues in a productive manner
 - Respect the views of others

EPA's expectations

- Working group needs to
 - Make recommendations for a MACT standard for coal-fired electric utility units
 - Focus on relevant issues
 - Think outside the box...but inside the CAA
- Working group does not have to
 - Reach consensus -- desired but not required
 - Make decisions

Suggested ground rules

- Test assumptions and inferences
- Share all relevant information
- Be specific - use examples
- Agree on what important words mean
- Explain the reasons behind your statements, questions, and actions
- Make statements, then invite questions
- Keep the discussion focused

More ground rules

- Technical presentations by EPA and stakeholder groups to working group
- Working group discussion leading to a consensus recommendation, or a separate recommendation
- No venue for public participation during meetings
 - Positions may be made through members

How we'll proceed

- Today
 - Three background presentations on MACT process and utility background, current mercury control knowledge, and three-pollutant legislation activities
 - Discussion of future meetings
 - General discussion of how process will be structured and future schedule

Utility Working Group

Utility MACT background
MACT process

Bill Maxwell

Combustion Group/ESD



Purpose

- To provide background on utility MACT project
- To provide background on MACT process
 - Section 112 requirements
 - Issues
 - Timing
 - Process



Background -- Mandate

- Section 112(n)(1)(A) of CAA: EPA must perform study of, and report to Congress on, the hazards to the public health of HAP emissions from fossil fuel-fired electric utility steam generating units
- Based on the results of the study, Administrator must determine whether HAP regulations for such units are necessary and appropriate



Background -- Study

- Report to Congress issued in February 1998
 - HAP of greatest concern -- mercury from coal-fired units
 - Some concern from other HAP from coal-fired units and from oil-fired units



Background -- ICR

- Information collection request
 - Intended to inform electric utility regulatory determination along with health studies (e.g., NAS report), control option analyses, etc.
 - Intended to improve overall estimate of the amount and species of mercury being emitted from coal-fired utility units



Background -- ICR (conc.)

- Identified all coal-fired units meeting CAA definition and their control configuration
- Required all coal-fired units to analyze coal mercury content during calendar year 1999
- Required ~85 coal-fired units to test for speciated mercury emissions



Background -- Determination

- EPA announced finding on 12/14/2000
 - Regulation necessary for oil- and coal-fired boilers
 - Regulation not necessary for gas-fired boilers
 - Based on
 - Public health concerns
 - Mercury emissions from power plants
 - Information that mercury from power plants can be controlled



Section 112 rule

- “Best of the best” for new sources
- Average of the top performing 12 percent (e.g., top 6 percent) for existing sources
 - Recent court decisions will be examined
- Allows for subcategorization
- Listing decision triggers section 112(g) case-by-case MACT determinations for new coal- and oil-fired sources



Format of section 112 rule

- Emissions standard applicable to each source
- Trading not allowed in any consideration of the level(s) of control at the floor
 - Trading among units at given facility allowed



Section 112 focus

- Most of attention has been on mercury from coal-fired units
- Also concerned about
 - Other HAP from coal-fired units
 - Nickel from oil-fired units



Timing

- Settlement agreement provides for
 - Proposal of section 112 regulations by 12/15/2003
 - Promulgation of section 112 regulations by 12/15/2004
- Compliance date of 12/15/2007



Current activities

- Data analyses
- Coordination activities
- Additional activities



Data analyses

- Further analyze data for the purpose of establishing section 112 standards
 - Subcategories
 - Floor
 - Best performing
 - Adequacy of data
 - No data officially “thrown out” yet




Preliminary results

- Mercury content of coal is not an indicator of level of mercury emissions in all cases
- Mercury control on subbituminous and lignite coals is more problematic than on bituminous and waste coals
- NO_x control may enhance mercury control for some coals



1999 ICR Data Analyses - Mercury in Fuels

(Initial analyses)



Preliminary subcategory options

- Fuel type
 - All coal
 - Individual coals
 - Bituminous
 - Subbituminous
 - Lignite
 - Waste
- Boiler type
- Control device type
- Others - ?



Coordination activities

- Continue coordination with ORD, DOE, EPRI, UNDEERC, et al. on on-going mercury control research
 - More testing on existing control devices and enhancements
 - More testing on SCR/SNCR installations
 - Fly ash issues
 - Control device cost analyses



Additional activities

- More sophisticated deposition analyses using REMSAD and new mercury emissions data
- Analyses using IPM looking at the costs and market impacts of a variety of potential levels of mercury control



CONTROL OF MERCURY EMISSIONS FROM COAL-FIRED UTILITY BOILERS

James D. Kilgroe

Office of Research and Development
National Risk Management Research Laboratory
Air Pollution Prevention and Control Division
Research Triangle Park, NC

MACT Working Group Meeting
August 1, 2001



GLOSSARY

- **APCD - Air pollution control device**
- **CEMs - Continuous emission monitors**
- **CFBA - Circulating fluidized bed absorber**
- **ESP - Electrostatic precipitator for particulate control (CS-ESP = cold-side ESP, HS-ESP = hot-side ESP)**
- **FF - Fabric filter baghouse for particulate control**
- **FGD - Flue gas desulfurization**
- **GC - Cooling of flue gas**

cont'd



GLOSSARY

- **Hg or Hg(T) - Total mercury in coal or flue gas**
- **Hg[°] - Elemental mercury**
- **Hg²⁺ - Ionic mercury**
- **Hg(p) - Particulate bound mercury**
- **ICR - Information collection request**
- **LNB - Low NOx burner**
- **PAC - Powdered activated carbon**

cont'd



GLOSSARY

- **PC - Pulverized coal**
- **PM - Particulate matter**
- **SCR - Selective catalytic reduction for NO_x control**
- **SDA - Spray dryer absorber for SO_x control**
- **SI - Sorbent injection***
- **SNCR - Selective non-catalytic reduction for NO_x control**

* Sorbent injection may include flue gas cooling and increased duct lengths for increased residence times.





ORD MERCURY CONTROL TECHNOLOGY PROGRAM STRATEGY

- **Support OAR/OAQPS development of regulations**
- **Evaluate Hg measurement methods and Hg CEMs**
- **Characterize factors that effect mercury speciation and capture**
- **Work jointly with DOE, EPRI and the utility industry to develop cost-effective control technologies**
- **Characterize and control the stability of Hg in coal combustion residues and residue by-products**
- **Conduct performance, economic and control trade-off studies**



BEHAVIOR OF MERCURY IN COAL-FIRED BOILERS



Factors Affecting Speciation

- Type and properties of coal
- Time/temperature profile
- Composition of flue gas
- Fly ash and sorbent properties
- Flue gas cleaning conditions

MERCURY MEASUREMENTS

- **Manual measurement methods for Hg(T): Method 101A and Method 29**
- **Ontario-Hydro measurement method for mercury speciation**
 - Sampling probe
 - Sample filter to collect Hg(p)
 - Series of impingers to separate and collect Hg²⁺ and Hg[°]
- **CEMs for Hg(T) used in Europe and Japan on incinerators**
- **Speciating CEMs being developed for U.S. market**
 - Measures only gas-phase mercury
 - Measures Hg[°] and Hg(T)
 - Determines Hg²⁺ by difference



MERCURY CAPTURE

- **Hg(p) easily captured by ESPs and FFs**
- **Hg²⁺ exhibits high to low solubility and can generally be captured in scrubbers**
- **Hg⁰ is insoluble and must be adsorbed on to solids or converted to Hg²⁺ for capture by scrubbing**
- **Hg²⁺ is generally easier to adsorb than Hg⁰**
- **Adsorption is highly dependent on flue gas composition and temperature**
- **Typical Hg²⁺ to Hg⁰ ratio in flue gas: bituminous coal > subbituminous coal > lignite**



RESULTS OF DETERMINATION STUDY BOILER AND APCD INFORMATION

- **Types of Boilers (1140 units)**
 - **Pulverized coal-fired: 979 units**
 - **Cyclone-fired: 87 units**
 - **Fluidized-bed combustors: 42 units**
 - **Stoker-fired: 32**
- **Flue gas cleaning methods***
 - **ESPs only: 787 units**
 - **FFs only: 79 units**
 - **Dry scrubbers: 43**
 - **Wet FGD scrubbers: 143**
 - **Other: 88 units**

*38 units with SNCR and 6 units with SCR



MAJOR CONCLUSIONS OF DETERMINATION STUDIES

- **48 tons of Hg emitted from coal-fired units in 1999**
- **Capture by existing equipment ranges from 0 to > 90%**
- **Moderate to good capture for bituminous coals**
- **Poor capture for subbituminous coal and lignite**
- **Best capture for dry and wet FGD scrubbers**
- **Capture associated with PM controls:**
FF > ESPs > PM scrubbers & mechanical collectors
- **NOx controls may enhance ability to capture Hg**



MEAN MERCURY EMISSION REDUCTIONS FOR EXISTING PC- FIRED UNITS^a, %

Add-on Controls	Type of Coal ^b		
	Bituminous	Subbituminous	Lignite
PM Only			
CS-ESP	36	3	0
HS-ESP	11	12	NT
CS-FF	89	73	NT
PM Scrubber	12	0	33
Dry FGD Scrubbers			
SDA+ESP	NT	50	NT
SDA+FF	98	23	2
Wet FGD Scrubbers			
CS-ESP+Wet FGD	81	0	34
HS-ESP+Wet FGD	42	38	NT
CS-FF+Wet FGD	97	NT	NT

a. Based on OH train data. NT= not tested

b. Revised April 24



STABILITY OF MERCURY IN COAL COMBUSTION RESIDUES

- **No evidence that the mercury in residues pose a leaching problem**
- **Insufficient information to determine whether mercury will volatilize from normal disposal practices**
- **Major concern is the stability of mercury during the manufacturing, use, and disposal of residue by-products**
- **Residue research will be conducted in conjunction with mercury control technology development efforts**




CURRENT CONTROL TECHNOLOGY RESEARCH PRIORITIES

- **Develop controls for air toxics MACT regulations**
- **Develop Hg controls for NO_x SIP call units**
- **Develop combined Hg, NO_x, and SO₂ controls**
- **Coordinate Hg and fine PM control research**



MERCURY CONTROL RETROFIT OPTIONS



* ESP= electrostatic precipitator, FF=fabric filter, CFBA=circulating fluidized-bed absorber, SCR=selective catalytic reduction (6 units), SDA=Spray dry adsorber


** Selected control options--other options possible. Flue gas cooling and additional ducting may be used with sorbent injection (SI)



MERCURY CONTROL TECHNOLOGY

ESP RETROFIT PROBLEMS

- **Low flue gas concentrations of Hg° and Hg^{2+}**
- **Hg° is relatively inert and difficult to capture**
- **High flue gas flow rates and poor sorbent utilization**
- **Competition for surface active sites with other flue gas constituents**




CONTROL TECHNOLOGY CHALLENGES FOR MERCURY MACT REQUIREMENTS

- **Control of emissions for units with ESPs**
 - Poor carbon utilization
 - High carbon costs
 - Lowering flue gas temperatures to increase Hg capture results in corrosion problems
 - Excessive carbon in collected fly ash results in disposal/utilization problems
- **Control of Hg emissions from subbituminous coals and lignite**
- **Development of Hg⁰ oxidizing methods for wet FGD systems**
- **Optimization of NO_x controls for mercury control**
- **Evaluation of controls for non-PC fired units**
- **Use and evaluation of mercury CEMs**



TIME-LINE FOR MERCURY CONTROL TECHNOLOGY PROGRAM



STATUS OF CURRENT DOE-EPA-EPRI MERCURY CONTROL RESEARCH

- **Full-scale ESP sorbent injection projects at 4 sites**
- **One full-scale wet FGD project**
- **Project on effects of SCR/SNCR - 5 sites**
- **Six new pilot-scale DOE projects announced this May**
- **Evaluation and use of mercury CEMs**
- **On-going speciation and capture research**
- **DOE, EPRI, and EPA to commit additional resources for mercury, multi-pollutant control and residue research in FY2002 and FY2003**

