

RICE NESHAP Summary of Requirements¹

Limited Use

New & Reconstructed Stationary Engine >500 HP Located at Major Source of HAP

Construction commenced after December 19, 2002

NOTE: To refer to regulatory language as mentioned below, please go to [Subpart ZZZZ](#).

Your **compliance date** is upon startup.

Emission Limitations: No requirements

Operating Limitations: No requirements

Fuel Requirements: No requirements

Performance Tests: No requirements

Monitoring, Installation, Collection, Operation and Maintenance Requirements: No Requirements

Initial Compliance: No requirements

Continuous Compliance: 63.6605

§ 63.6605 (a) You must be in compliance with the emission limitations and operating limitations in this subpart that apply to you at all times.

(b) At all times you must operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require you to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source.

¹ Disclaimer: The content provided in this software tool is intended solely as assistance for potential reporters to aid in assessing requirements for compliance under the reciprocating internal combustion engines (RICE) National Emissions Standards for Hazardous Air Pollutants, 40 CFR Part 63 Subpart ZZZZ. Any variation between the rule and the information provided in this tool is unintentional, and, in the case of such variations, the requirements of the rule govern. Use of this tool does not constitute an assessment by EPA of the applicability of the rule to any particular facility. In any particular case, EPA will make its assessment by applying the law and regulations to the specific facts of the case.

Notification Requirements: 63.6645 (f)

§ 63.6645 (f) If you are required to submit an Initial Notification but are otherwise not affected by the requirements of this subpart, in accordance with §63.6590(b), your notification should include the information in §63.9(b)(2)(i) through (v), and a statement that your stationary RICE has no additional requirements and explain the basis of the exclusion (for example, that it operates exclusively as an emergency stationary RICE if it has a site rating of more than 500 brake HP located at a major source of HAP emissions).

Recordkeeping Requirements: No requirements

Reporting Requirements: No requirements

General Provisions (40 CFR part 63): No, except as specified in 63.6645(f) (see Notification Requirements above).