

RICE NESHAP Summary of Requirements¹

Non-Emergency Spark Ignition 4-Stroke Lean Burn

New & Reconstructed Stationary Engine ≥ 250 HP

Located at Major Source of HAP, constructed on or after June 12, 2006 and before January 1, 2008

Requirements: None.

¹ Disclaimer: The content provided in this software tool is intended solely as assistance for potential reporters to aid in assessing requirements for compliance under the reciprocating internal combustion engines (RICE) National Emissions Standards for Hazardous Air Pollutants, 40 CFR Part 63 Subpart ZZZZ. Any variation between the rule and the information provided in this tool is unintentional, and, in the case of such variations, the requirements of the rule govern. Use of this tool does not constitute an assessment by the EPA of the applicability of the rule to any particular facility. In any particular case, the EPA will make its assessment by applying the law and regulations to the specific facts of the case.