

US EPA ARCHIVE DOCUMENT

**REPORT ON RAILWAY-INDUCED
GROUND VIBRATIONS
FLY ASH DISPOSAL FACILITY AND
BOTTOM ASH DISPOSAL FACILITY
PHILIP SPORN POWER PLANT
NEW HAVEN, WEST VIRGINIA
NPDES NO. WV0001058**

**Prepared For:
American Electric Power Service Corporation
1 Riverside Plaza
Columbus, Ohio 43215**

**Prepared By:
Geo/Environmental Associates, Inc.
3502 Overlook Circle
Knoxville, Tennessee 37909**

**GA File No. 09-387
May 27, 2010**



**REPORT ON RAILWAY-INDUCED
GROUND VIBRATIONS
FLY ASH DISPOSAL FACILITY AND
BOTTOM ASH DISPOSAL FACILITY
PHILIP SPORN POWER PLANT
NEW HAVEN, WEST VIRGINIA
NPDES NO. WV0001058**

**Prepared For:
American Electric Power Service Corporation
1 Riverside Plaza
Columbus, Ohio 43215**

**Prepared By:
Geo/Environmental Associates, Inc.
3502 Overlook Circle
Knoxville, Tennessee 37909**

**GA File No. 09-387
May 27, 2010**



TABLE OF CONTENTS

BACKGROUND & SITE DESCRIPTION.....	1
General.....	1
Fly Ash Disposal Facility.....	2
Bottom Ash Disposal Facility.....	3
CSX Transportation Railway Network Line.....	3
RESPONSES TO USEPA REQUEST FOR INFORMATION – ITEMS 2a TO 2s.....	4

APPENDICES

USEPA LETTER DATED NOVEMBER 13, 2009 REQUESTING ADDITIONAL INFORMATION.....	APPENDIX I
VIBRATION MONITORING, GEOPHYSICAL DATA AND LABORATORY TESTING CONDUCTED BY DR. MICHAEL KALINSKI.....	APPENDIX II
FIELD AND LABORATORY TEST DATA.....	APPENDIX III
LEM SLOPE STABILITY ANALYSES	APPENDIX IV
FESM SLOPE STABILITY AND LIQUEFACTION ANALYSES	APPENDIX V
DRAWINGS.....	APPENDIX VI
REFERENCES	APPENDIX VII



Geo/Environmental Associates, Inc.

3502 Overlook Circle • Knoxville, TN 37909 • 865-584-0344 • Fax 865-584-0778 • www.geoe.com

May 27, 2010

American Electric Power
1 Riverside Plaza
Columbus, Ohio 43215-2373

Attn.: Mr. Pedro J. Amaya, P.E.

RE: Report on Railway-Induced Ground Vibrations for
Fly Ash Disposal Facility and Bottom Ash Disposal Facility
Philip Sporn Power Plant
New Haven, Mason County, West Virginia
NPDES No. WV0001058
GA File No. 09-387

Dear Mr. Amaya:

At the request of American Electric Power (AEP), Geo/Environmental Associates, Inc. (GA) has prepared a report summarizing the impact of railway-induced ground vibrations on the dikes for the Fly Ash Disposal Facility and the Bottom Ash Disposal Facility at the Philip Sporn Power Plant. Specifically, this report is in response to the United States Environmental Protection Agency's (USEPA) request for information, Items 2a through 2s, issued in a letter dated November 13, 2009. Provided herein is the response addressing each of the USEPA's information requests for Items 2a through 2s. A copy of the November 13, 2009 letter in which the USEPA requests information is provided in Appendix I. Additionally, railway information and vibration data, laboratory and field testing data, slope stability analyses, liquefaction analyses, drawings, and references are provided in Appendices II through VII.

BACKGROUND

General

The Sporn Fly Ash and Bottom Ash Disposal Facilities are maintained and operated by American Electric Power to support disposal of ash generated at the Philip Sporn Power Plant. The site is located near the town of New Haven in Mason County, West Virginia. The Fly Ash Disposal Facility (i.e., Section H-H crest on the Western Dike) is located at approximate coordinates North 38° 58' 18", West 81° 55' 59". The Fly Ash Disposal Facility is bounded by the Mountaineer Power Plant on its north side; the Ohio River on its east side; the Bottom Ash

Disposal Facility and coal yard on its south side; and the CSX Rail Line and West Virginia State Route 62 on its west side. The Bottom Ash Disposal Facility (i.e., Section A-A crest on the Western Dike) is located at approximate coordinates N 38° 58' 05", W 81° 55' 45". The Bottom Ash Disposal Facility is bounded by the Clearwater Pond and Fly Ash Disposal Facility on its north side; the coal yard and the Ohio River on its east side; Philip Sporn Power Plant on its south side; and the CSX Rail Line and West Virginia State Route 62 on its west side.

Fly Ash Disposal Facility

The Sporn Plant Fly Ash Disposal Facility generally consists of an above ground fly ash pond contained by four dikes (i.e., the Northern, Eastern, Southern, and Western dikes). Original construction of the dikes was conducted in 1959. Dike raisings and/or extensions were conducted at the Fly Ash Disposal Facility in 1965, 1968, and in 1972. The Southern, Western, and Northern Dikes are founded primarily on residual clay and silt materials. The original construction for the Eastern Dike is founded primarily on residual clay and silt materials. However, the upper portion of the Eastern Dike is constructed/founded primarily on fly ash that was hydraulically placed in the pond prior to 1972. Between 1996 and 2002, AEP implemented modifications to the Eastern Dike to address seepage observed on the exterior face of the dike and to improve the overall stability conditions of the slopes. In general, for the improvements, the company installed drainage collection provisions and regraded/butressed the exterior slopes. A detailed historical review and design related to the 1996 through 2002 modifications to the Fly Ash Disposal Facility were provided in the AEP report *Philip Sporn Electric Generation Plant, Unit 5 Fly Ash Facility*, prepared in 1996. As indicated by the as-built topography shown on the Site Map drawing in Appendix VI: (1) the Northern Dike has an as-built crest ranging in elevation from about 612 feet, NGVD to about 620 feet, NGVD; (2) the Eastern Dike has an as-built crest of about 620 feet, NGVD; (3) the Southern Dike has an as-built crest ranging in elevation from about 612 feet, NGVD to about 620 feet, NGVD; and (4) the Western Dike has an as-built crest ranging in elevation from about 610 feet, NGVD to about 612 feet, NGVD.

Fly ash generated at the Philip Sporn Power Plant – Unit 5 is sluiced to and temporarily disposed in the Fly Ash Disposal Facility; where after, it is excavated and hauled for dry disposal into AEP's Little Broad Run Landfill. AEP maintains an operating pool level of approximately 605 feet, NGVD in the fly ash pond. A plan view drawing (i.e., Site Map) of the Fly Ash Disposal Facility is provided in Appendix VI.

Bottom Ash Disposal Facility

The Bottom Ash Disposal Facility was built in 1948 to provide disposal capacity for bottom ash generated at the Philip Sporn Power Plant. In general, the Bottom Ash Disposal Facility consists of three dikes (i.e., the Northern, Eastern, and Western Dikes) which impound the bottom ash pond and the clearwater pond. The 1948 dikes were constructed on silty sand and/or silty clay original ground. Since the initial 1948 construction, the Bottom Ash Disposal Facility dikes have been raised/extended several times to achieve the as-built configuration shown on the plan view drawing provided in Appendix VI. Modifications to improve the overall stability of the Bottom Ash Disposal Facility dike slopes were implemented between 1996 and 2002. A detailed historical review and designs related to the 1996 through 2002 modifications are provided in the report *Philip Sporn Electric Generation Plant, Bottom Ash Facility*, prepared by AEP in 1996. As indicated by the as-built mapping shown on the plan view drawing in Appendix VI: (1) the Northern Dike (i.e., between the bottom ash pond and the clearwater pond) has an as-built crest ranging in elevation from about 593 feet, NGVD to about 598 feet, NGVD; (2) the Eastern Dike has an as-built crest ranging in elevation from about 594 feet, NGVD to about 598 feet, NGVD; (3) the Western Dike has an as-built crest elevation of about 594 feet, NGVD. The Bottom Ash Disposal Facility's bottom ash pond is generally maintained at or below an operating pool level of 583 feet, NGVD.

CSX Transportation Railway Network Line

A railway line is located adjacent to the exterior (i.e. downstream) toes of the Fly Ash Disposal Facility and the Bottom Ash Disposal Facility Western Dikes. The adjacent railway is a CSX Transportation (CSX) rail network line that extends from Huntington, West Virginia to Parkersburg, West Virginia. Railway traffic for this line ranges from light high-rail vehicles to trains transporting tanker cars, industrial cargo cars, and coal cars. Based on discussions with personnel at CSX Huntington Division Headquarters, 2 to 4 trains generally travel the rail line between Huntington and Parkersburg each day. This information is consistent with the amount of rail traffic that was observed by GA while conducting onsite field studies and based on general observations made by AEP site personnel. However, as described in a November 9, 2009 letter issued by CSX (provided in Appendix II), train schedules and frequencies are not available to the general public. The main railway line superstructure consists of a typical railway roadbed composed of ballast and a single standard railway track running adjacent to the toe of the western dikes. Siding splits occur just south of the Bottom Ash Disposal Facility and near the northwest corner of the Fly Ash Disposal Facility. The siding at the northwest corner of the Fly Ash Disposal Facility extends adjacent to the exterior toe along a portion of the Fly Ash



Disposal Facility Northern Dike. A maximum speed limit (i.e., a slow order) of 25 miles per hour is in effect for the railway lines adjacent to the ash disposal facilities. The locations of the railway and the associated sidings are shown on the plan view drawing provided in Appendix VI.

In order to provide additional information for the USEPA pursuant to their November 13, 2009 letter, AEP has requested that GA evaluate the impact of railway vibrations on the Fly Ash Disposal and Bottom Ash Disposal Facilities. Correspondingly, we have conducted detailed field testing and engineering analyses on three critical sections. Specifically, we have evaluated the impact of railway vibrations on the Fly Ash Disposal Facility Eastern Dike Section K-K, the Fly Ash Disposal Facility Western Dike Section H-H, and the Bottom Ash Disposal Facility Western Dike Section A-A. Provided herein are itemized responses to each of the USEPA's requests regarding the railway vibration assessment.

RESPONSES TO USEPA REQUEST FOR INFORMATION – ITEMS 2a TO 2s

Provided herein are USEPA Information Request Items 2a through 2s and corresponding responses prepared by GA. For completeness, the November 13, 2009 letter containing the information requests is provided in Appendix I. Background information, data, and analyses supporting the responses provided herein are included in Appendices II through VII.

Information Request Item 2a

Provide a description of the site including a site map depicting the location of the railway superstructure, embankments and other planimetric and topographic features.

Response to Item 2a

A site description is provided in the preceding Background & Site Description section of this document. A site map depicting the location of the railway superstructure, embankments, and other planimetric and topographic features is provided in Appendix VI.

Information Request Item 2b

Provide description, procedures and summary of field measurements of railway induced ground vibrations generated by loaded railway traffic under dynamic conditions at various speeds and stopping conditions.



Response to Item 2b

Railway vibration monitoring was conducted at the site on November 11, 2009, January 6, 2010, and January 7, 2010. The vibration monitoring was performed by Michael E. Kalinski, Ph.D. (Dr. Kalinski), from the University of Kentucky in Lexington, Kentucky. In general, the vibration monitoring was conducted using seismographs installed at the following six locations:

- Downstream (exterior) toe of Bottom Ash Disposal Facility Western Dike Section A-A (Location A).
- Crest of Bottom Ash Disposal Facility Western Dike Section A-A (Location B).
- Downstream (exterior) toe of Fly Ash Disposal Facility Western Dike Section H-H (Location C).
- Crest of Fly Ash Disposal Facility Western Dike Section H-H (Location D).
- Crest of Fly Ash Disposal Facility Eastern Dike Section K-K (Location E).
- Downstream (exterior) bench of Fly Ash Disposal Facility Eastern Dike Section K-K (Location F).

Vibration monitoring Locations A through F are shown on the site map and section drawings provided in Appendix VI. A detailed discussion of the monitoring procedures, a summary of field measurements, and digital data is provided in Appendix II. As shown in the vibration monitoring data, peak particle velocities and accelerations related to railway traffic were measured at Locations A and B on the Western Dike of the Bottom Ash Disposal Facility and at Locations C and D on the Western Dike of the Fly Ash Disposal Facility. No vibrations due to railway traffic were detected at Location E or at Location F on the Eastern Dike of the Fly Ash Disposal Facility. Therefore, the critical sections assessed herein are the Bottom Ash Disposal Facility Western Dike Section A-A and the Fly Ash Disposal Facility Western Dike Section H-H. No additional analyses are provided herein for the Eastern Dike of the Fly Ash Disposal Facility because railway induced vibrations are non-detectable for this dike.

Information Request Item 2c

Provide description, procedures and summary of field exploration and laboratory tests of in-situ subsurface conditions, including, but not limited to:

- i. soil test & instrumentation location map;*
- ii. cross-sectional geometry of embankment sections depicting phreatic surface; and*
- iii. soil test boring logs and laboratory analyses of soil testing.*

Response to Item 2c

GA coordinated/conducted subsurface exploration, instrumentation installation, field testing, and laboratory testing for the Bottom Ash Disposal Facility and the Fly Ash Disposal Facility to use in the vibration assessment. Specifically, GA coordinated subsurface exploration and instrumentation installation performed by Horn and Associates, Inc. (Horn) from December 10, 2009 through December 18, 2009. GA coordinated field geophysical testing (i.e., on January 6 and 7, 2010) and laboratory testing conducted by Dr. Kalinski. GA conducted on-site laboratory testing concurrent with the drilling operations, as well as laboratory testing at our office in Knoxville, Tennessee. Additionally, in our vibration assessment, we applied subsurface exploration data and laboratory testing data that was previously developed by AEP. A summary of the subsurface exploration, instrumentation, field testing, and laboratory testing as related to the vibration analyses is provided herein. Field and laboratory data developed by Dr. Kalinski is provided in Appendix II. Field data from the subsurface exploration conducted by Horn and laboratory data developed by GA is provided in Appendix III.

Subsurface Exploration

As coordinated by GA, Horn drilled nine boreholes at the site. Boreholes GA-1A, GA-1B, GA-1C, and GA-1D were drilled at the crest of the Fly Ash Disposal Facility in the general vicinity of Eastern Dike Section K-K. Boreholes GA-2 and GA-3 were drilled in the Fly Ash Disposal Facility Eastern Dike. Boreholes GA-4A, GA-4B, and GA-4C were drilled at the crest of the Bottom Ash Disposal Facility in the Western Dike, near Section A-A. Borehole locations are shown on the site map and section drawings provided in Appendix VI.

In general the boreholes were sampled in accordance with ASTM D1586 (Standard Test Method for Standard Penetration Test (SPT) and Split-Barrel Sampling of Soils) at varying sampling intervals. In addition, undisturbed soil samples were obtained in accordance with ASTM D6519 (Standard Practice for Sampling of Soil Using the Hydraulically Operated Stationary Piston Sampler). Upon retrieval, selected samples were immediately subjected to on-site laboratory testing. Thereafter, all samples were prepared and transported to GA's laboratory in Knoxville, Tennessee for further testing.

Detailed logs were developed for each of the boreholes and are provided in Appendix III. Additionally, graphical borehole logs are provided in Appendix III.



Instrumentation

At the completion of boreholes GA-1A, GA-1B, GA-1C, GA-4A, GA-4B, and GA-4C; Horn installed 70 mm Durham Geo Slope Indicator (DGSI) inclinometer casing in each hole in order to implement crosshole seismic testing. The DGSI inclinometer casing was installed and grouted full length (i.e., in accordance with ASTM D4428 - Standard Test Methods for Crosshole Seismic Testing) in order to accommodate the crosshole seismic testing. Thereafter, GA conducted a downhole inclinometer survey to evaluate the orientation and deviation in the boreholes. The results of the downhole inclinometer survey are provided in Appendix III. Additionally, Horn installed a 1-inch diameter standpipe piezometer in borehole GA-1D. In order to measure the potential piezometric level at any location in the fly ash deposit in which it was installed, standpipe piezometer GA-1D consisted of a pre-packed sand screen that extended through the length of the fly ash. Initial piezometric level readings for the standpipe piezometer are provided on the borehole logs provided in Appendix III.

Field Testing

In addition to the vibration monitoring, GA coordinated geophysical field testing conducted by Dr. Kalinski at the site on January 6 and 7, 2010. Specifically, Dr. Kalinski conducted crosshole seismic testing (i.e., in general accordance with ASTM D4428 - Standard Test Methods for Crosshole Seismic Testing) at boreholes GA-1A, GA-1B, and GA-1C through the Eastern Dike of the Fly Ash Disposal Facility and at boreholes GA-4A, GA-4B, and GA-4C through the Western Dike of the Bottom Ash Disposal Facility. The crosshole seismic testing was done to develop shear wave velocity and Poisson's ratio data for the embankment cross-sections. Results of the geophysical field testing conducted by Dr. Kalinski are provided in Appendix II.

Laboratory Testing

Laboratory testing was conducted on field samples obtained during the subsurface exploration phase of the program. Specifically, split-spoon and undisturbed piston samples obtained during the drilling operations were subjected to testing both at an on-site laboratory and at GA's Knoxville, Tennessee laboratory. In general, the laboratory testing consisted of:

1. in-place moisture and density determination of undisturbed fly ash piston samples;
2. specific gravity determination of undisturbed fly ash piston samples;
3. void ratio determination of undisturbed fly ash piston samples;
4. grain-size analyses on fly ash, bottom ash, and foundation soils;
5. Atterberg limit determination on fly ash and foundation soils;

6. Permeability testing on fly ash and foundation soils; and
7. Consolidated undrained triaxial strength testing with pore pressure measurements on fly ash and foundation soils.

Laboratory testing summary sheets and data developed by GA are provided in Appendix III. Additional laboratory testing data used in the vibration assessment included:

1. Damping ratio measurements conducted by Dr. Kalinski at the University of Kentucky. Specifically, Dr. Kalinski conducted free-free resonant column testing to measure the damping ratio for site fly ash and foundation soils. Measured damping ratios are presented in Dr. Kalinski's March 8, 2010 report provided in Appendix II.
2. Cyclic triaxial testing data developed by Ohio State University using reconstituted fly ash bulk samples obtained from the site. For the testing, the fly ash materials were reconstituted to an initial minimum density of 62 pounds per cubic feet, as measured for the in-place density during on-site laboratory testing of undisturbed fly ash piston tube samples. The Cyclic Stress Ratio (CSR) graph developed during the cyclic triaxial strength testing of the fly ash material is provided in Appendix III.
3. Pertinent laboratory data provided by AEP from historical sampling and laboratory testing performed on site materials. For reference, copies of the pertinent AEP laboratory data, as used in the vibration analyses, is provided in Appendix III.

Information Request Item 2d

Provide description, procedures and summary of slope stability analysis including but not limited to:

- i. soil strength parameters modeled and basis of values used;*
- ii. loading conditions modeled from measured railway-induced ground vibrations generated by railway traffic;*
- iii. factors of safety against shallow slope failures and global instability.*

Response to Item 2d

General

The computer programs *SLOPE/W* and *QUAKE/W* were used to analyze the slope stability along Section A-A of the Bottom Ash Disposal Facility Western Dike and along Section H-H of the Fly Ash Disposal Facility Western Dike. *SLOPE/W* and *QUAKE/W* are developed by GEO-SLOPE International, Ltd. of Calgary, Alberta, Canada. Specifically, the Morgenstern-Price



limit equilibrium method (LEM) and the *QUAKE/W* finite element stress method (FESM) were used to evaluate the shallow-seated and deep-seated (global) stability of each critical slope in both an upstream and downstream direction. Phreatic levels used in these analyses were provided by AEP, and are based on *SEEP/W* finite element analyses and field measured piezometric levels developed for slope stability reports prepared by the company in 2009.

The LEM slope stability analyses were conducted using pseudo-static loading conditions for the maximum railway induced ground accelerations measured at the vibration monitoring locations. We conservatively applied the accelerations from the dike exterior toe vibration monitoring locations (i.e., Location A for Section A-A and Location C for Section H-H) to the downstream direction LEM slope stability analyses and we applied the accelerations from the dike crest monitoring locations (i.e., Location B for Section A-A and Location D for Section H-H) to the upstream direction LEM slope stability analyses. A summary of the accelerations used in the LEM pseudo-static analyses is provided in Table 1.

TABLE 1			
SUMMARY OF ACCELERATIONS USED IN			
LIMIT EQUILIBRIUM METHOD PSEUDO-STATIC SLOPE STABILITY ANALYSES			
Critical Section	Vibration Monitoring Location	Maximum Acceleration (g's)	
		Horizontal	Vertical
Bottom Ash Disposal Facility Section A-A	Location A (Exterior Toe - Adjacent to Track) Downstream Direction Analyses	0.033	0.008
	Location B (Crest) Upstream Direction Analyses	0.013	0.002
Fly Ash Disposal Facility Section H-H	Location C (Exterior Toe - Adjacent to Track) Downstream Direction Analyses	0.046	0.008
	Location D (Crest) Upstream Direction Analyses	0.010	0.003



The FESM slope stability analyses were conducted by applying the time-acceleration history data generated during the railway induced vibration events (i.e., as measured by Dr. Kalinski, provided in Appendix II) to the initial stress conditions generated using the *QUAKE/W* finite element computer program. GA conducted the FESM slope stability analyses using the maximum vibration data from each monitoring location. We conservatively applied the maximum vibration data from the dike exterior toe vibration monitoring locations (i.e., Location A for Section A-A and Location C for Section H-H) to the downstream direction FESM slope stability analyses and we applied the maximum vibration data from the dike crest vibration monitoring locations (i.e., Location B for Section A-A and Location D for Section H-H) to the upstream direction FESM slope stability analyses. A summary of the railway induced vibration data as applied in the FESM slope stability analyses is provided in Table 2.

TABLE 2 SUMMARY OF RAILWAY INDUCED VIBRATION DATA USED IN FINITE ELEMENT STRESS METHOD SLOPE STABILITY ANALYSES		
Critical Section	Vibration Monitoring Location	Maximum Railway Induced Vibration Data Used
Bottom Ash Disposal Facility Section A-A	Location A (Exterior Toe - Adjacent to Track) Downstream Direction Analyses	November 11, 2009 12:12 pm Train 10 sec. to 20 sec.
	Location B (Crest) Upstream Direction Analyses	November 11, 2009 12:12 pm Train 16 sec. to 26 sec.
Fly Ash Disposal Facility Section H-H	Location C (Exterior Toe - Adjacent to Track) Downstream Direction Analyses	November 11, 2009 12:12 pm Train 36 sec. to 46 sec.
	Location D (Crest) Upstream Direction Analyses	November 11, 2009 12:12 pm Train 0 sec. to 5.5 sec.

Material Parameters

Material parameters used in the LEM and FESM slope stability analyses are based on site specific data or from using accepted reference materials in relation to the site specific soils/conditions. The strength properties used in the LEM slope stability analyses are based on the parameters AEP developed for Section A-A of the Bottom Ash Disposal Facility and Section H-H of the Fly Ash Disposal Facility, as provided in their 1998 and 2009 stability assessment



reports. A detailed summary of the material parameters used in the LEM analyses and the respective data sources are provided in Tables IV-2 and IV-3, in Appendix IV.

In general, the dynamic properties used in the FESM analyses were selected based on laboratory testing of site specific soil materials and/or field testing. A detailed summary of the material parameters used in the FESM analyses and the respective data sources are provided in Tables V-2 and V-3, in Appendix V.

Summary of Safety Factors and Stability Factors

SLOPE/W was used to calculate LEM slope stability analyses safety factors and FESM slope stability analyses stability factors. As described in *Stability Modeling with SLOPE/W*©2007, the LEM safety factor is defined as “the factor by which the shear strength of the soil must be reduced in order to bring the mass of the soil into a state of limiting equilibrium along a selected slip surface.” Whereas, the FESM stability factor is defined as “the ratio of the summation of the available resisting shear force S_r along a slip surface to the summation of the mobilized shear force S_m along a slip surface.” Slope stability safety factors and stability factors were generated for both the Bottom Ash Disposal Facility Section A-A and the Fly Ash Disposal Facility Section H-H. A summary of the stability analysis results for each of the evaluated conditions is provided in Table 3. *SLOPE/W* data and graphical plots generated for the LEM slope stability analyses are provided in Appendix IV. *SLOPE/W* data and graphical plots generated for the FESM slope stability analyses are provided in Appendix V.

As shown in Table 3, LEM safety factors and FESM stability factors were calculated for shallow-seated and deep-seated slip surface conditions. The LEM safety factors equal or exceed 1.70 for the Bottom Ash Disposal Facility Section A-A and 1.40 for the Fly Ash Disposal Facility Section H-H for the shallow-seated slip surface conditions. Moreover, the LEM safety factors equal or exceed 2.02 for the Bottom Ash Disposal Facility Section A-A and 1.65 for the Fly Ash Disposal Facility Section H-H for the deep-seated (global) slip surface conditions. The FESM stability factors equal or exceed 2.68 for the Bottom Ash Disposal Facility Section A-A and 1.78 for the Fly Ash Disposal Facility Section H-H for the shallow-seated slip surface conditions. The FESM safety factors equal or exceed 2.72 for the Bottom Ash Disposal Facility Section A-A and 2.12 for the Fly Ash Disposal Facility Section H-H for the deep-seated (global) slip surface conditions. Based on the results obtained in our stability assessment, we believe that the railway vibrations will not have a significant/consequential impact on the slope stability of the dikes for the Bottom Ash and Fly Ash Disposal Facilities.

TABLE 3
 SUMMARY OF LEM SAFETY FACTORS AND FESM STABILITY FACTORS

Critical Section	Analysis Method	Pseudo-static or Rail Induced Vibration Loading Condition	Slope and Slip Surface Condition	Safety Factor or Stability Factor
Bottom Ash Disposal Facility Section A-A	LEM	Location A (Exterior Toe) ($a_h = 0.033g$, $a_v = 0.008g$)	Downstream (Shallow)	2.96
			Downstream (Deep)	3.08
		Location B (Crest) ($a_h = 0.013g$, $a_v = 0.002g$)	Upstream (Shallow)	1.70
			Upstream (Deep)	2.02
	FESM	Location A (Exterior Toe) (11-11-09 12:12 pm Train)	Downstream (Shallow)	4.06
			Downstream (Deep)	4.25
		Location B (Crest) (11-11-09 12:12 pm Train)	Upstream (Shallow)	2.68
			Upstream (Deep)	2.72
Fly Ash Disposal Facility Section H-H	LEM	Location C (Exterior Toe) ($a_h = 0.046g$, $a_v = 0.008g$)	Downstream (Shallow)	1.84
			Downstream (Deep)	2.15
		Location D (Crest) ($a_h = 0.010g$, $a_v = 0.003g$)	Upstream (Shallow)	1.40
			Upstream (Deep)	1.65
	FESM	Location C (Exterior Toe) (11-11-09 12:12 pm Train)	Downstream (Shallow)	2.66
			Downstream (Deep)	2.75
		Location D (Crest) (11-11-09 12:12 pm Train)	Upstream (Shallow)	1.78
			Upstream (Deep)	2.12

Information Request Item 2e

Evaluate the potential liquefaction of fly ash under the raised eastern dike of the Fly Ash Pond from instantaneous, as well as long term exposure, to railway induced ground vibrations from the west side of the Fly Ash Pond.

Response to Item 2e

Vibration monitoring conducted at the crest and at the downstream bench of the Fly Ash Disposal Facility Eastern Dike (i.e., along Section K-K) yielded non-detectable vibration levels due to rail traffic during three monitoring events (i.e., on November 11, 2009; January 6, 2010; and January 7, 2010). As such, we conclude that the Eastern Dike of the Fly Ash Disposal Facility is not subjected to instantaneous exposure, nor will it be subjected to long-term exposure to railway induced vibrations. Correspondingly, we believe that liquefaction of the fly ash material under the raised Eastern Dike of the Fly Ash Disposal Facility, due to railway induced ground vibration, is improbable.



Information Request Item 2f

Evaluate the potential liquefaction of fly ash under the raised eastern dike of the Fly Ash Pond from train collision and derailment on the west side of the Fly Ash Pond.

Response to Item 2f

We understand that the USEPA has released AEP from the responsibility of addressing Item 2f of the information request. As such, GA has removed this item from the scope of our assessment.

Information Request Item 2g

Determine the root cause of apparent shallow sloughing of the dike slopes.

Response to Item 2g

GA has evaluated the shallow sloughing conditions that were observed on the exterior face of the Fly Ash Disposal Area Western Dike. Using *SLOPE/W*, we have modeled the shallow sloughing conditions along Section H-H. We have modeled four conditions to evaluate the possible root cause of the shallow sloughing. The evaluated conditions are as follows:

1. Section H-H with a *moist* topsoil material on the exterior dike facing exhibiting an assumed effective friction angle, ϕ' of 27° .
2. Section H-H with a *saturated* topsoil material on the exterior dike facing exhibiting an assumed effective friction angle, ϕ' of 27° .
3. Section H-H with a *moist* topsoil material on the exterior dike facing exhibiting an effective friction angle, ϕ' of 27° and pseudo-static train loadings of $a_h = 0.046g$ and $a_v = 0.008g$.
4. Section H-H with a *saturated* topsoil material on the exterior dike facing exhibiting an effective friction angle, ϕ' of 27° and pseudo-static train loadings of $a_h = 0.046g$ and $a_v = 0.008g$.

The results of the shallow sloughing assessment are summarized in Table 4. *SLOPE/W* data and graphical plots generated during our assessment are provided in Appendix IV. As shown in the results, for moist topsoil conditions and no railway induced vibration loadings (i.e., Condition 1), a safety factor in excess of 1.2 is calculated. However, for saturated topsoil conditions with no train loadings (Condition 2), a safety factor less than 1.0 is obtained. For moist topsoil conditions and applied train loadings (Condition 3), a safety factor of about 1.1 is calculated.

For saturated topsoil conditions with train loadings (i.e., Condition 4), a safety factor less than 1.0 is calculated. It should be noted that the slip surface calculated for each of these conditions is relatively thin (i.e., less than about 1-foot in thickness) and would not have a significant impact on the stability/integrity of the existing dike. Based on our assessment (i.e., as shown in the results for Conditions 2 and 4), it appears that the primary cause of the shallow sloughing observed at the site is likely due to saturated conditions of the topsoil material. These saturated conditions are possibly caused by infiltration of surface runoff and/or shallow interflow within the topsoil that may occur during precipitation and/or snow melt events.

Condition	Safety Factor
1. Section H-H with <i>moist</i> topsoil material.	1.23
2. Section H-H with <i>saturated</i> topsoil material.	0.54
3. Section H-H with <i>moist</i> topsoil material and train loadings.	1.08
4. Section H-H with <i>saturated</i> topsoil material and train loadings.	0.47

Information Request Item 2h

Evaluate the plans for the sloughing repairs in consideration of the determination of the root cause and description of potential changes, if any, that may need to be made to the plans to ensure long-term success of the repair.

Response to Item 2h

GA has evaluated the plans for the sloughing repairs using proposed repair drawings provided by AEP (provided in Appendix IV). Based on our review of the drawing, we believe that the rock fill repair zone and filter fabric will provide adequate drainage capacity to reduce the potential for saturating the exterior face materials on the dike. The *SLOPE/W* slope stability safety factor for the repaired Section H-H, with maximum railway induced loadings from Location C, is about 1.6. Based on our assessment, it is our opinion that the proposed repairs will significantly reduce the potential for shallow sloughing along the Fly Ash Disposal Facility Western Dike.



Information Request Item 2i

Provide conclusions regarding railway vibrations and their effect on slope stability and liquefaction potential at the Philip Sporn Fly Ash Pond dikes and on slope stability at the Bottom Ash Pond dike.

Response to Item 2i

GA used *SLOPE/W* to calculate slope stability safety factors and stability factors for Section A-A of the Bottom Ash Disposal Facility Western Dike and Section H-H of the Fly Ash Disposal Facility Western Dike (See Table 3 and Appendices IV and V, herein, for results). The safety factors were calculated by applying LEM pseudo-static loading conditions. The stability factors were calculated by applying FESM dynamic loading conditions. Both the LEM pseudo-static analyses and the FESM dynamic analyses were evaluated by conservatively applying vibration/acceleration data from the dike exterior toe vibration monitoring locations (i.e., Location A for Section A-A and Location C for Section H-H) to the downstream direction slope stability analyses and by applying the vibration/acceleration data from the dike crest vibration monitoring locations (i.e., Location B for Section A-A and Location D for Section H-H) to the upstream direction slope stability analyses.

As presented previously in Table 3, LEM safety factors and FESM stability factors were calculated for shallow-seated and deep-seated slip surface conditions. The LEM safety factors equal or exceed 1.70 for the Bottom Ash Disposal Facility Section A-A and 1.40 for the Fly Ash Disposal Facility Section H-H for the shallow-seated slip surface conditions. Moreover, the LEM safety factors equal or exceed 2.02 for the Bottom Ash Disposal Facility Section A-A and 1.65 for the Fly Ash Disposal Facility Section H-H for the deep-seated (global) slip surface conditions. The FESM stability factors equal or exceed 2.68 for the Bottom Ash Disposal Facility Section A-A and 1.78 for the Fly Ash Disposal Facility Section H-H for the shallow-seated slip surface conditions. The FESM safety factors equal or exceed 2.72 for the Bottom Ash Disposal Facility Section A-A and 2.12 for the Fly Ash Disposal Facility Section H-H for the deep-seated (global) slip surface conditions. The slope stability analyses indicate that adequate safety factors/stability factors are available for each of the conservatively modeled dike/train loading conditions. Based on the results obtained in our stability assessment, we believe that the railway vibrations will not have a significant/consequential impact on the slope stability of the dikes for the Bottom Ash and Fly Ash Disposal Facilities.



GA used *QUAKE/W* to evaluate liquefaction potential at Section A-A of the Bottom Ash Disposal Facility Western Dike and Section H-H of the Fly Ash Disposal Facility Western Dike. Site specific material parameters and railway induced loadings were applied in the *QUAKE/W* finite element analyses, as described in Appendix V. Given the material parameters and railway induced loadings, *QUAKE/W* dynamic analyses were conducted to delineate potential liquefaction zones. As shown in the liquefaction analysis results provided in Appendix V, no liquefaction zones are predicted for Section A-A of the Bottom Ash Disposal Facility Western Dike or for Section H-H of the Fly Ash Disposal Facility Western Dike. Furthermore, vibration monitoring conducted at the crest and at the downstream bench of the Fly Ash Disposal Facility Eastern Dike (i.e., along Section K-K) yielded non-detectable vibration levels due to rail traffic during three monitoring events (i.e., on November 11, 2009; January 6, 2010; and January 7, 2010). As such, we conclude that the Eastern Dike of the Fly Ash Disposal Facility is not subjected to instantaneous exposure, nor will it be subjected to long-term exposure to railway induced vibrations. Correspondingly, we believe that liquefaction of the fly ash material under the raised Eastern Dike of the Fly Ash Disposal Facility, due to railway induced ground vibration, is improbable.

Information Request Item 2j

Provide conclusions regarding train wreck and its effect on liquefaction potential at the raised eastern dike of the Philip Sporn Fly Ash Pond.

Response to Item 2j

We understand that the USEPA has released AEP from the responsibility of addressing Item 2j of the information request. As such, GA has removed this item from the scope of our assessment.

Information Request Item 2k

Provide recommendations for remedial action to enhance slope stability to acceptable safety margins and/or eliminate or minimize liquefaction potential, as may be required, depending on the results of the assessment.

Response to Item 2k

GA calculated adequate slope stability safety factors (i.e., in excess of 1.5) for Section A-A of the Bottom Ash Disposal Facility Western Dike and Section H-H of the Fly Ash Disposal Facility Western Dike. Furthermore, given the measured railway induced loadings, no



liquefaction zones were predicted in the dynamic analyses. Therefore, no remedial actions (i.e., other than routine maintenance and the ongoing repairs to reduce shallow sloughing) are currently recommended.

Information Request Item 2l

Provide a list of references.

Response to Item 2l

A list of references is provided in Appendix VII.

Information Request Item 2m

Provide tables as needed to facilitate presentation of data.

Response to Item 2m

Pertinent tables have been provided in the body of this document and as needed in the appendices to facilitate presentation of the data.

Information Request Item 2n

Provide figures as needed for illustration purposes.

Response to Item 2n

Applicable figures are provided in the appendices to the document.

Information Request Item 2o

Provide an appendix containing summary descriptions of field and laboratory test procedures that may be used to develop vibration data and additional soil and ash data as needed for the assessment.

Response to Item 2o

Summary descriptions related to the field geophysical studies and the vibration monitoring are provided in Appendix II. Laboratory testing procedures were conducted in accordance with ASTM standards. Laboratory testing data is provided in Appendix III. Listings of applicable ASTM standards used in the sampling and testing of site soil and ash materials are listed in the references provided in Appendix VII.



Information Request Item 2p

Provide an appendix containing the vibration monitoring data and all test boring logs and other field data considered in the study, including existing and additional data that may be obtained.

Response to Item 2p

Field geophysical data and the vibration monitoring data are provided in Appendix II. Test borings and other field data related to the study are included in Appendix III.

Information Request Item 2q

Provide an appendix containing all laboratory data considered in the assessment, including existing data and additional data developed for the assessment.

Response to Item 2q

Laboratory data considered in the assessment is provided in Appendix III.

Information Request Item 2r

Provide an appendix containing all calculations, including slope stability analyses and liquefaction analyses.

Response to Item 2r

SLOPE/W slope stability analyses are provided in Appendix IV. *QUAKE/W* dynamic/liquefaction analyses are provided in Appendix V.

Information Request for Item 2s

Provide certification of the assessment and report by a professional engineer registered in the state of West Virginia.

Response to Item 2s

A certification of the assessment and report presented herein is provided at the front of this document.

American Electric Power
May 27, 2010
Page 19

Geo/Environmental Associates, Inc. appreciates this opportunity to be of continuing service to American Electric Power. If you have questions regarding this response letter, feel free to contact me at (865) 584-0344 or email me at rogerc@geoe.com.

Respectfully Submitted,
Geo/Environmental Associates, Inc.

Roger W Cecil, For:

Seth W. Frank, E.I.
Project Coordinator

Roger W Cecil

Roger W. Cecil, P.E.
Senior Geotechnical Engineer
West Virginia Registered P.E. No. 14,367



APPENDIX I

**USEPA LETTER DATED NOVEMBER 13, 2009
REQUESTING ADDITIONAL INFORMATION**





UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
WASHINGTON, D.C. 20460

OFFICE OF
ENFORCEMENT AND
COMPLIANCE ASSURANCE

CERTIFIED MAIL-RETURN RECEIPT REQUESTED

Alan R. Wood, PE
Manager
Water & Ecological Resource Services Section
Environmental Services Division
American Electric Power
1 Riverside Plaza
Columbus, OH 43215-2373

NOV 13 2000

**Re: Request for Information Pursuant to Section 308 of the Clean Water Act
(33 U.S.C. § 1318)**

Dear Mr. Wood:

Enclosed is an Information Request issued pursuant to Section 308(a) of the Clean Water Act, 33 U.S.C. § 1318(a). Section 308 of the Clean Water Act authorizes the Administrator of the United States Environmental Protection Agency ("EPA") to require those subject to the Act to furnish information, conduct monitoring, provide entry to the Administrator or authorized representatives, and make reports as may be necessary to carry out the objectives of the Act. This authority has been re-delegated to the undersigned Director of the Water Enforcement Division in the Office of Enforcement and Compliance Assurance. The enclosures, which are hereby made part of this letter, provide details of the information the American Electric Power ("AEP") Philip Sporn Generating Plant ("Facility") must provide to EPA and contain instructions on how this information is to be submitted to EPA.

Section 308(a) of the Clean Water Act, 33 U.S.C. § 1318(a) authorizes EPA to require any person to provide information required to carry out the objectives of the Clean Water Act. Accordingly, you are requested to respond to the enclosed Information Request (Enclosure 1). Please read the instructions in the enclosure carefully before preparing your response. Answer each request as clearly and completely as possible. To the extent that AEP has any of the requested data currently on file, that data may be submitted in the requested format as part of your response. Your response to this request must be accompanied by a certificate that is signed and dated by you or the person who is authorized by you to respond to the request. The certification must state that the response is complete and contains all information and documentation available to you pursuant to the request. A Statement of Certification is enclosed with this letter (Enclosure 2).

Please submit your written responses in accordance with the deadlines set forth in the request to:

Ginny Phillips
U.S. Environmental Protection Agency
Water Enforcement Division
1200 Pennsylvania Avenue, NW
Mail Code 2243A; Room 4118A
Washington, DC 20460
(For deliveries by courier use the Zip Code 20004)

You are entitled to assert a business confidentiality claim pursuant to the regulations set forth in 40 C.F.R. Part 2, Subpart B. If EPA determines the information you have designated meets the criteria in 40 C.F.R. § 2.208, the information will be disclosed only to the extent and by means of the procedures specified in Subpart B. Unless a confidentiality claim is asserted at the time the requested information is submitted, EPA may make the information available to the public without further notice to you.

Compliance with the provisions of this Information Request is mandatory. If you do not respond fully and truthfully to this Information Request or adequately justify your failure to do so, you may be subject to civil penalties or criminal fines under Section 309 of the Clean Water Act, 33 U.S.C. § 1319.

We appreciate your cooperation and prompt attention to this matter. Please contact Ginny Phillips of my staff at 202-564-6139 (phillips.ginny@epa.gov) within 72 hours of receipt this Information Request to inform us of your intention to comply with this request. If you or your staff would like an opportunity to confer, have any questions, or would like to schedule a meeting relating to this Information Request, please contact Ginny Phillips. Thank you for your cooperation in this matter.

Sincerely,



Mark Pollins, Director
Water Enforcement Division

Enclosures

cc: Michael Zeto, West Virginia Department of Environmental Protection
Brian Long, West Virginia Department of Environmental Protection
Rick Rogers, EPA Region 3

Enclosure 1

INFORMATION REQUEST

I. STATUTORY AUTHORITY

1. This information is requested pursuant to Section 308 of the Clean Water Act, 33 U.S.C. § 1318.

II. INSTRUCTIONS

1. Respond to Each Request Completely. Provide a separate report for each of the three reports requested. Within each report, indicate the subpart of the request being addressed.
2. Provide the Best Information Available. If any request or subpart of the request cannot be responded to in full, respond to the extent possible along with an explanation of why the request cannot be responded to in full.
3. Source(s) of Response. Include with each report, the name, position, and title of each person(s) who participated in developing the report.
4. Source(s) of Data. Any existing field and laboratory data relied upon by you to develop the reports required by this Information Request must be identified in the report and include an explanation of how the data are representative of the conditions at the site.
5. Indicate Objections to Requests. While you may indicate that you object to certain requests contained in this Information Request, you must provide responsive information notwithstanding those objections. To object without providing responsive information may subject you to the penalties discussed in the cover letter.

6. Claims of Privilege. If you claim that an entire document submitted in response to this Information Request is privileged communication, identify the document and provide the basis for the privilege. If you claim that any particular section of a document is privileged communication, identify that section and provide the basis for the privilege. Regardless of the assertion of a privilege, you must respond to the Information Request in full.
7. New Information. If you become aware of any information not previously known or not available to you as of the date of submission of your response to this Information Request, you must supplement your response to EPA within five (5) business days. Moreover, should you find, at any time after the submission of your response, that any portion of the submitted information is false or misrepresents the truth, you must notify EPA of this fact immediately and provide a corrected response within two (2) business days.

8. Submission of Response by U.S. Mail. Submit a paper copy and an electronic .pdf file on CD of your response to:

Ginny Phillips
U.S. Environmental Protection Agency
Water Enforcement Division
1200 Pennsylvania Avenue, NW
Mail Code 2243A; Rm. 4118A
Washington, DC 20460
202-564-6139
(For deliveries by courier use the Zip Code 20004)

9. Submission of Response by E-mail. Submit an electronic .pdf file of your response to phillips.ginny@epa.gov.
10. Retention of Records. All records and documents that were created and/or relied upon in responding to any part of this request must be maintained until EPA informs you that maintenance is no longer required.
11. Inclusion of Statement of Certification. The Statement of Certification found in Enclosure 2 must be submitted along with each submission made pursuant to this Information Request. This statement must be signed by you or a person authorized by you to respond to the Information Request.

III. DEFINITIONS

Unless otherwise defined herein, terms used in this request shall have the meaning given to those terms in the Act, 33 U.S.C. § 1251 et seq., the regulations promulgated thereunder at 40 CFR § 122, and in AEP's NPDES Permit, No. WV0001058.

-
1. The terms "and" and "or" shall be construed either disjunctively or conjunctively as necessary to bring within the scope of this Information Request any information which might otherwise be construed to be outside its scope.
 2. The term "any," as in "any documents," for example, shall mean "any and all "
 3. The term "describe" means to detail, depict, or give an account of the requested information, or to report the content of any oral and/or written correspondence, communication, or conversation, or to report the contents of any document, including the title, the author, the position or title of the author, the addressee, the position or title of the addressee, indicated or blind copies, date, subject matter, number of pages, attachment or appendices, and all persons to whom the document was distributed, shown, or explained.
 4. "State" shall mean the State of West Virginia.

5. "Person" means an individual, trust, firm, joint stock company, corporation (including a government corporation), partnership, association, State, municipality, commission, political subdivision of a State, or an interstate body.
6. "Facility" is defined as:

AEP Philip Sporn, State Route 62, New Haven, WV 25265

7. "Permit" is defined as AEP Philip Sporn, National Pollutant Discharge Elimination System Permit Number WV0001058. Expiration Date: June 30, 2013.

IV. SUPPLEMENTAL REPORTS TO BE SUBMITTED

AEP shall develop supplemental reports for the requests below to ensure that the coal combustion waste impoundments at the Facility are structurally sound and will continue in safe and reliable operation. AEP shall develop and submit a supplemental report for the following requests in accordance with this section:

1. Site-specific study of the potential for liquefaction of foundation ash under design earthquake loading conditions for the raised eastern dike at the Fly Ash Pond;
 2. Site-specific assessment of the effect of railway-induced ground vibrations on the embankments at both the Fly Ash Pond and the Bottom Ash Pond; and
 3. Analysis of slope stability under design earthquake loading conditions for the upper sections of the eastern dike of the Fly Ash Pond.
1. Report on Earthquake-Induced Liquefaction for Eastern Dike of Fly Ash Pond: Within ninety (90) days of receipt of this request, AEP shall perform a study and submit an engineering report to EPA addressing the potential for earthquake-induced liquefaction of sluiced ash deposits upon which the raised eastern dike of the Fly Ash Pond was constructed at the Facility. The study shall be based on the specific site characteristics, subsurface conditions, material properties and parameters existing at the raised Fly Ash Pond dike, as determined by field exploration and laboratory tests. Existing field and laboratory data may be used to the extent that the data are representative of the conditions at the ash pond dike. Additional test borings and laboratory tests shall be performed if needed to adequately and accurately characterize the subsurface profiles and evaluate the densities, strengths, moisture contents, classification and index properties of the soil and ash layers that comprise the subsurface profiles. The Experimental Investigation approach used in The Ohio State University Research Project # 60005876 reported in "Draft Final Report of Evaluation of Liquefaction Potential of Impounded Fly Ash," dated October 17, 2005 and adapted from The Indian Institute of Technology (Madras, India) "Liquefaction Analysis of Pond Ash" contained in the Proceedings of the 15th International Conference on Solid Waste Technology & Management held on December 12-15, 1999 in Philadelphia, Pennsylvania, may be used in this study to evaluate the liquefaction potential of foundation ash supporting the raised dike of the Fly Ash

Pond at the Facility: However, the cyclic triaxial testing shall be on representative samples of Philip Sporn fly ash remolded to relative densities that bracket the in-situ relative densities of the fly ash. Alternatively, semi-empirical procedures may be used to evaluate liquefaction potential of the foundation ash, such as those presented in the paper "*Semi-Empirical Procedures for Evaluating Liquefaction Potential During Earthquakes*," by I. M. Idriss and R.W. Boulanger, Proceedings of The Joint 11th International Conference on Soil Dynamics & Earthquake Engineering (ICSDEE) & 3rd International Conference on Earthquake Geotechnical Engineering (ICEGE) (pp. 32-56), January 7-9, 2004. The design earthquake ground acceleration shall be at least 0.06g. At a minimum, the report shall include the following:

- (a) description of background information and approach of the study;
- (b) description of the methodology and procedures used in the analysis;
- (c) description of any additional field testing performed and the results obtained;
- (d) description of any additional laboratory testing performed and the results obtained;
- (e) description of the site(s) including site map(s) depicting planimetric and topographic features and the location of critical section(s) selected for analysis;
- (f) description of the subsurface conditions at the critical sections and illustration of the analysis profiles;
- (g) discussion of the design soil and ash properties and parameters and the basis of selection of these values or the source of the values;
- (h) presentation of analysis results, including appropriate charts and graphs illustrating the results, and discussion of the results;
- (i) conclusions regarding liquefaction potential under design earthquake loading conditions at the Philip Sporn Fly Ash Pond dike;
- (j) recommendations for remedial action to eliminate or minimize liquefaction potential should the foundation ash be found susceptible to liquefaction under design earthquake loading;
- (k) list of references;

- (l) tables as needed to facilitate presentation of data;
- (m) figures as needed for illustration purposes;
- (n) an appendix containing summary descriptions of field and laboratory test procedures that may be used to develop additional soil and ash data as needed for the study;
- (o) an appendix containing all test boring logs and other field data considered in the study, including existing data and additional data that may be obtained to fully characterize the analysis profiles;
- (p) an appendix containing all laboratory test data considered in the study, including existing data and additional data developed for the study;
- (q) an appendix containing calculations, including analysis calculations, e.g., program SHAKE runs, and calculations for calculated values used in the analysis, e.g., calculation of shear modulus values (G_{max}); and

- (r) certification of the study and report by a professional engineer registered in the state of West Virginia.

2 Report on Railway-Induced Ground Vibration for Fly Ash Pond Dike and Bottom Ash Pond Dike: Within ninety (90) days of receipt of this request, AEP shall perform assessment and submit a report to EPA addressing the effect of railway-induced ground vibrations on the slope stability at the Fly Ash Pond dike and the Bottom Ash Pond dike located at the Facility. In addition, the study shall evaluate the potential for liquefaction of foundation ash under the raised eastern dike of the Fly Ash Pond due to railway-induced ground vibrations. The study shall be based on the specific site characteristics, railway loading conditions, subsurface conditions, material properties and parameters existing at the Fly Ash Pond dike and at the Bottom Ash Pond dike, as determined by field measurement, field exploration and laboratory tests. Existing field and laboratory data may be used to the extent that the data are representative of the conditions at the ash pond dikes. The study shall also examine the cause of apparently shallow sloughing of the dike slopes and determine whether the root cause of the sloughing is railway-induced ground vibration or some other cause, such as saturation of the thick topsoil layer on the relatively steep slopes and consequential loss of its nominal cohesive strength, leading to failure due to insufficient frictional shearing resistance, or a combination of causes. In light of the results of this examination, the study shall review plans for repairs of the sloughing and determine whether modifications to the plans ought to be made to ensure long-term success of the repair. At a minimum, the report shall include the following:

- (a) a description of the site including a site map depicting the location of the railway superstructure, embankments and other planimetric and topographic features;
- (b) description, procedures and summary of field measurements of railway-induced ground vibrations generated by loaded railway traffic under dynamic conditions at various speeds and stopping conditions;
- (c) description, procedures and summary of field exploration and laboratory tests of in-situ subsurface conditions, including, but not limited to:
 - (i) soil test & instrumentation location map;
 - (ii) cross-sectional geometry of embankment sections depicting phreatic surface; and
 - (iii) soil test boring logs and laboratory analyses of soil testing.
- (d) description, procedures and summary of slope stability analysis including, but not limited to:
 - (i) soil strength parameters modeled and basis of values used;
 - (ii) loading conditions modeled from measured railway-induced ground vibrations generated by railway traffic;
 - (iii) factors of safety against shallow slope failures and global slope instability.
- (e) evaluation of the potential liquefaction of fly ash under the raised eastern dike of the Fly Ash Pond from instantaneous, as well as long term exposure, to railway induced ground vibrations from the west side of the Fly Ash Pond;

- (f) evaluation of the potential liquefaction of fly ash under the raised eastern dike of the Fly Ash Pond from train collision and derailment on the west side of the Fly Ash Pond;
- (g) determination of the root cause of apparently shallow sloughing of the dike slopes;
- (h) evaluation of the plans for sloughing repairs in consideration of the determination of the root cause and description of potential changes, if any, that may need to be made to the plans to ensure long-term success of the repair;
- (i) conclusions regarding railway vibrations and their effect on slope stability and liquefaction potential at the Philip Sporn Fly Ash Pond dikes and on slope stability at the Bottom Ash Pond dike;
- (j) conclusions regarding train wreck and its effect on liquefaction potential at the raised eastern dike of the Philip Sporn Fly Ash Pond;
- (k) recommendations for remedial action to enhance slope stability to acceptable safety margins and/or eliminate or minimize liquefaction potential, as may be required, depending on the results of the assessment;
- (l) list of references;
- (m) tables as needed to facilitate presentation of data;
- (n) figures as needed for illustration purposes;
- (o) an appendix containing summary descriptions of field and laboratory test procedures that may be used to develop vibration data and additional soil and ash data as needed for the assessment;
- (p) an appendix containing the vibration monitoring data and all test boring logs and other field data considered in the study, including existing data and additional data that may be obtained;
- (q) an appendix containing all laboratory test data considered in the assessment, including existing data and additional data developed for the assessment;
- (r) an appendix containing all calculations, including slope stability analyses and liquefaction analyses; and
- (s) certification of the assessment and report by a professional engineer registered in the state of West Virginia.

3. Report on Analysis of Seismic Slope Stability of Fly Ash Pond Eastern Dike Upper Section: Within ninety (90) days of receipt of this request, AEP shall submit a report to EPA of the "Seismic Slope Stability Analysis" to characterize the seismic stability of the Upper Section of the Fly Ash Pond eastern dike, which was constructed over sluiced fly ash deposits, at the Facility. The analysis shall be based on the specific site characteristics, subsurface conditions, material properties and parameters existing at the raised Fly Ash Pond dike, as determined by field exploration and laboratory tests. The analysis shall be based on a design earthquake ground acceleration of at least 0.06g. Pseudo-static design methodologies may be used. Existing field and laboratory data may be used to the extent that the data are representative of the conditions at the ash pond dike. A report of the analysis shall be prepared and at a minimum the report shall include:

- (a) a description of the geotechnical properties used for each soil and ash layer used in the analysis including total and effective shear strength parameters;
 - (b) a description of the data collection and modeling methodologies utilized by AEP in the evaluation of seismic slope stability;
 - (c) an analysis of embankment internal stresses, including static pore pressures under expected seepage conditions;
 - (d) an analysis of embankment internal stresses, including static pore pressures during normal and maximum waste placement conditions;
 - (e) analyses of embankment stability shall consider both slope and base sliding conditions;
 - (f) analyses of slope stability shall include evaluation of critical full height and partial height potential failure planes;
 - (g) computed minimum safety factors during the design earthquake event for both slope and base sliding conditions;
 - (h) conclusions regarding seismic slope stability under design earthquake loading conditions of upper section of the Fly Ash Pond eastern dike at the Facility;
 - (i) recommendations for remedial action to enhance seismic stability of the upper section of the Fly Ash Pond eastern dike to acceptable safety margins, as may be required, depending on the results of the assessment;
 - (j) list of references;
 - (k) tables as needed to facilitate presentation of data;
 - (l) figures as needed for illustration purposes;
 - (m) an appendix containing summary descriptions of field and laboratory test procedures that may be used to develop additional soil and ash data as needed for the analysis;
 - (n) an appendix containing all test boring logs and other field data considered in the analysis, including existing data and additional data that may be obtained;
 - (o) an appendix containing all laboratory test data considered in the analysis, including existing data and additional data developed for the analysis;
 - (p) an appendix containing all stability analysis calculations; and
 - (q) certification of the analysis by a professional engineer registered in the state of West Virginia.
-

Enclosure 2

STATEMENT OF CERTIFICATION

I certify that the information contained in or accompanying this submission is true, accurate, and complete.

As to the identified portion(s) of this submission for which I cannot personally verify its truth and accuracy, I certify as the company official having supervisory responsibility for the person(s) who, acting under my direct instructions, made the verification, that this information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment.

By _____
(Signature)

(Title)

(Date)

APPENDIX II

**VIBRATION MONITORING, GEOPHYSICAL DATA
AND LABORATORY TESTING
CONDUCTED BY DR. MICHAEL KALINSKI**



**DR. KALINSKI REPORT DATED NOVEMBER 30, 2009
RELATED TO NOVEMBER 11, 2009 VIBRATION MONITORING**

November 30, 2009

Mr. Roger Cecil, P.E.
Geo/Environmental Associates
3502 Overlook Circle
Knoxville, TN 37909

RE: Vibration monitoring at the AEP Sporn Power Plant, New Haven, West Virginia

Dear Roger,

Vibration monitoring was performed on November 11, 2009 at six points at the AEP Sporn Power Plant in New Haven, West Virginia. Vibration monitoring was performed from approximately 8:05 A.M. until 4:25 P.M. by myself, along with the assistance of Mr. Seth Frank. This letter report describes the methods used and results obtained, and is accompanied by a CD containing the vibration data in ASCII format.

Vibration monitoring was performed at six locations on the perimeter levees that contain the fly ash and bottom ash at the power plant. The locations are described as follows:

- Location A: outside toe of the bottom ash levee adjacent to the train tracks;
- Location B: outside crest of the bottom ash levee adjacent to the train tracks;
- Location C: outside toe of the fly ash levee adjacent to the train tracks;
- Location D: outside crest of the fly ash levee adjacent to the train tracks;
- Location E: outside crest of the fly ash levee adjacent to the Ohio River; and
- Location F: outside toe of the fly ash levee adjacent to the Ohio River.

Mr. Frank used GPS while on site to obtain accurate coordinate information for each location.

Vibration monitoring was performed using six Blastmate III seismographs, which are manufactured by Instantel. The Blastmate III seismographs record four channels simultaneously during each event; one air wave channel with a microphone, and three ground wave channels using three geophones. The three geophones are oriented orthogonal to each other so that one geophone detects vertical particle motion, and the other two detect horizontal particle motion in two perpendicular directions. The two horizontal geophones are identified as longitudinal and transverse, with the longitudinal geophone oriented towards the vibration source, and the transverse oriented perpendicular to the longitudinal.

The geophones that accompany the Blastmate III have a damped resonant frequency of approximately 2.0 Hz and the data are sampled in the instrument at a rate of 1,024 samples per second. This allows vibrations to be recorded between the bandwidth of 2.0-250 Hz with minimal distortion. The vibrations imparted to the geophones are converted into voltage, and the voltage is converted to particle velocity using a calibration factor. To minimize wind and surface noise, the geophones are buried in sand a few inches below the ground surface and covered with

a heavy weight such as a sand bag or water jug. The serial numbers of the seismographs used at each test location are as follows:

- Location A: Serial #BA11348;
- Location B: Serial #BA11347;
- Location C: Serial #BA10619;
- Location D: Serial #BA13539;
- Location E: Serial #BA13553; and
- Location F: Serial #BA11042.

Calibration certificates for each seismograph and its accompanying geophones are included in Appendix A of this report.

Vibration monitoring was performed on Nov. 11, 2009 from approximately 8:05 A.M. until 4:25 P.M. as indicated on the monitoring logs included in Appendix B of this report. During this period, three trains passed by the power plant at times of approximately 9:48 A.M., 12:12 P.M., and 1:36 P.M. The 9:48 and 1:36 trains were short trains. The 9:48 train consisted of an engine only, and the 1:36 train consisted of an engine and two empty lumber cars. The 12:12 train was a long train that consisted of two engines along with an estimated 95 cars (based on assumed train speed of 30 mph, vibration record length of 130 s, and average car length of 60 ft). The cars consisted of tank cars and coal cars.

The vibration monitoring logs included in Appendix B indicate when the seismographs were actively monitoring and when vibration events were recorded, including the three trains. The monitoring logs indicate that additional events were also recorded. These additional events correspond to occasional testing of the seismographs by stomping on the ground next to the geophones. Details regarding these additional test events are not included herein.

Vibrations from the 9:48 train were relatively small, and were only detected at Location C. For all logging, vibrations were only recorded when the vibration level exceeded 0.02 in./s. Below this level, vibrations were considered to be within the level of ambient noise. Summary reports for this and all other recorded vibration events are included in Appendix C of this report, and are also included in the attached CD (Appendix D). For each seismograph and vibration event, two reports are included: a time-domain Event Report and a frequency-domain FFT Report. Peak particle velocities (PPVs) can be found on the Event Reports. For the 9:48 event recorded at Location C, PPVs recorded by the transverse, vertical, and longitudinal geophones were 0.01, 0.02, and 0.02 in./s, respectively.

Vibrations from the 1:36 were also relatively small, and were only detected at Locations A and C. The Event Reports and FFT Reports for these two vibrations are also included in Appendix C. Peak Particle Velocities for this train at the two locations are summarized in the table below.

Peak particle velocities recorded at Locations A and C from the 1:36 train

Location	Tran. PPV (in./s)	Vert. PPV (in./s)	Long. PPV (in./s)
A (#BA11348)	0.02	0.02	0.02
C (#BA10619)	0.02	0.02	0.03

Vibrations from the 12:12 train were larger and longer in duration than the other two trains, and were detected at locations A, B, C, and D. The accompanying Event Reports and FFT Reports are also included in Appendix C. The overall duration of vibrations from the train was approximately 130 s. However, vibration levels at Locations B, C, and D fell below the 0.02-in./s threshold while the train passed, so the vibration records at these locations are either less than 130 s in duration, or separated into 2 or more recordings. Peak Particle Velocities for this train at the four locations are summarized in the table below.

Peak particle velocities recorded at Locations A, B, C, and D from the 12:12 train

Location	Tran. PPV (in./s)	Vert. PPV (in./s)	Long. PPV (in./s)
A (#BA11348)	0.03	0.06	0.05
B (#BA11347)	0.01	0.04	0.03
C (#BA10619)	0.05	0.06	0.07
D (#BA13539)	0.01	0.01	0.02

All of the vibration monitoring data are included in ASCII format on the attached CD. Given a sample rate of 1,024 samples/s, the vibration data should be plotted at a sample rate of 9.7656×10^{-4} s. Vibration data are presented in the ASCII files in units of particle velocity in mm/s. All Event Reports and FFT Reports are also included on the CD, along with photos taken during testing. Please note that the internal clocks on the six seismographs were only set to the nearest minute, so the time stamps on the monitoring logs and event records may be slightly out of synch between seismographs.

Thank you very much for providing me the opportunity to work with you on this project. Please do not hesitate to contact me if you have any questions or require any additional information.

Regards,



Michael E. Kalinski, Ph.D.

- Attachments: Appendix A – calibration certificates for seismographs and geophones
 Appendix B – vibration monitoring logs
 Appendix C -- event reports
 Appendix C – vibration data in ASCII format (on CD)

APPENDIX A

Calibration certificates for seismographs and geophones

Calibration Certificate

A

Part Number: 714A0801
Description: BLASTMATE III
Serial Number: BA11348
Calibration Date: December 18, 2008
Calibration Equipment: 718A1501

Instantel certifies that the above product was calibrated in accordance with the applicable Instantel procedures. These procedures are part of a quality system that is certified to the ISO9001:2000 quality standard, and are designed to assure that the product listed above meets or exceeds Instantel specifications.

Instantel further certifies that the measurement instruments used during the calibration of this product are traceable to the National Institute of Standards and Technology; or National Research Council of Canada. Evidence of traceability is on file at Instantel and is available upon request.

The environment in which this product was calibrated is maintained within the operating specifications of the instrument.

Please note that the sensor check function is intended to check that the sensors are connected to the unit, installed in the proper orientation and sufficiently level to operate properly. This function should not be confused with a formal calibration, which requires the sensors be checked against a reference that is traceable to a known standard. Instantel recommends that products be returned to Instantel or an authorized service and calibration facility for annual calibration.

Calibrated By: Martin Hogue
Martin Hogue

 Instantel

Calibration Certificate

A

Part Number: 714A9701
Description: TRIAXIAL GEOPHONE (ISEE)
Serial Number: BG10482
Calibration Date: December 18, 2008
Calibration Equipment: 714J7401


Instantel certifies that the above product was calibrated in accordance with the applicable Instantel procedures. These procedures are part of a quality system that is certified to the ISO9001:2000 quality standard, and are designed to assure that the product listed above meets or exceeds Instantel specifications.

Instantel further certifies that the measurement instruments used during the calibration of this product are traceable to the National Institute of Standards and Technology; or National Research Council of Canada. Evidence of traceability is on file at Instantel and is available upon request.

The environment in which this product was calibrated is maintained within the operating specifications of the instrument.

Please note that the sensor check function is intended to check that the sensors are connected to the unit, installed in the proper orientation and sufficiently level to operate properly. This function should not be confused with a formal calibration, which requires the sensors be checked against a reference that is traceable to a known standard. Instantel recommends that products be returned to Instantel or an authorized service and calibration facility for annual calibration.




Calibrated By:


Martin Hogue

 Instantel

Amplitude Frequency Response of BG10402

A



Calibration Certificate

B

Part Number: 714A0801
Description: BLASTMATE III
Serial Number: BA11347
Calibration Date: December 18, 2008
Calibration Equipment: 718A1501

Instantel certifies that the above product was calibrated in accordance with the applicable Instantel procedures. These procedures are part of a quality system that is certified to the ISO9001:2000 quality standard, and are designed to assure that the product listed above meets or exceeds Instantel specifications.

Instantel further certifies that the measurement instruments used during the calibration of this product are traceable to the National Institute of Standards and Technology, or National Research Council of Canada. Evidence of traceability is on file at Instantel and is available upon request.

The environment in which this product was calibrated is maintained within the operating specifications of the instrument.

Please note that the sensor check function is intended to check that the sensors are connected to the unit, installed in the proper orientation and sufficiently level to operate properly. This function should not be confused with a formal calibration, which requires the sensors be checked against a reference that is traceable to a known standard. Instantel recommends that products be returned to Instantel or an authorized service and calibration facility for annual calibration.

Calibrated By: _____

Martin Hogue

 **Instantel**

Calibration Certificate

B

Part Number: 714A9701
Description: TRIAXIAL GEOPHONE (ISEE)
Serial Number: BG10479
Calibration Date: December 18, 2008
Calibration Equipment: 714J7401

Instantel certifies that the above product was calibrated in accordance with the applicable Instantel procedures. These procedures are part of a quality system that is certified to the ISO9001:2000 quality standard, and are designed to assure that the product listed above meets or exceeds Instantel specifications.

Instantel further certifies that the measurement instruments used during the calibration of this product are traceable to the National Institute of Standards and Technology; or National Research Council of Canada. Evidence of traceability is on file at Instantel and is available upon request.

The environment in which this product was calibrated is maintained within the operating specifications of the instrument.

Please note that the sensor check function is intended to check that the sensors are connected to the unit, installed in the proper orientation and sufficiently level to operate properly. This function should not be confused with a formal calibration, which requires the sensors be checked against a reference that is traceable to a known standard. Instantel recommends that products be returned to Instantel or an authorized service and calibration facility for annual calibration.




Calibrated By: _____

Martin Hogue

 **Instantel**

Amplitude Frequency Response of BG10479

B



Calibration Certificate

C

Part Number: 714A0801
Description: BLASTMATE III
Serial Number: BA10619
Calibration Date: May 27, 2009
Calibration Equipment: 718A1501


Instantel certifies that the above product was calibrated in accordance with the applicable Instantel procedures. These procedures are part of a quality system that is certified to the ISO9001:2000 quality standard, and are designed to assure that the product listed above meets or exceeds Instantel specifications.

Instantel further certifies that the measurement instruments used during the calibration of this product are traceable to the National Institute of Standards and Technology; or National Research Council of Canada. Evidence of traceability is on file at Instantel and is available upon request.

The environment in which this product was calibrated is maintained within the operating specifications of the instrument.

Please note that the sensor check function is intended to check that the sensors are connected to the unit, installed in the proper orientation and sufficiently level to operate properly. This function should not be confused with a formal calibration, which requires the sensors be checked against a reference that is traceable to a known standard. Instantel recommends that products be returned to Instantel or an authorized service and calibration facility for annual calibration.

Calibrated By:


Dan Sawyer

 **Instantel**

Calibration Certificate

C

Part Number: 714A9701

Description: TRIAXIAL GEOPHONE (ISEE)

Serial Number: BG10510

Calibration Date: May 27, 2009

Calibration Equipment: 714J7402


Instantel certifies that the above product was calibrated in accordance with the applicable Instantel procedures. These procedures are part of a quality system that is certified to the ISO9001:2000 quality standard, and are designed to assure that the product listed above meets or exceeds Instantel specifications.

Instantel further certifies that the measurement instruments used during the calibration of this product are traceable to the National Institute of Standards and Technology; or National Research Council of Canada. Evidence of traceability is on file at Instantel and is available upon request.

The environment in which this product was calibrated is maintained within the operating specifications of the instrument.

Please note that the sensor check function is intended to check that the sensors are connected to the unit, installed in the proper orientation and sufficiently level to operate properly. This function should not be confused with a formal calibration, which requires the sensors be checked against a reference that is traceable to a known standard. Instantel recommends that products be returned to Instantel or an authorized service and calibration facility for annual calibration.




Calibrated By:


Dan Sawyer

 Instantel

Amplitude Frequency Response of BG10510

C



Calibration Certificate

D

Part Number: 714A0801

Description: BLASTMATE III

Serial Number: BA13539

Calibration Date: February 11, 2009

Calibration Equipment: 718A1501


InstanTel certifies that the above product was calibrated in accordance with the applicable InstanTel procedures. These procedures are part of a quality system that is certified to the ISO9001:2000 quality standard, and are designed to assure that the product listed above meets or exceeds InstanTel specifications.

InstanTel further certifies that the measurement instruments used during the calibration of this product are traceable to the National Institute of Standards and Technology; or National Research Council of Canada. Evidence of traceability is on file at InstanTel and is available upon request.

The environment in which this product was calibrated is maintained within the operating specifications of the instrument.

Please note that the sensor check function is intended to check that the sensors are connected to the unit, installed in the proper orientation and sufficiently level to operate properly. This function should not be confused with a formal calibration, which requires the sensors be checked against a reference that is traceable to a known standard. InstanTel recommends that products be returned to InstanTel or an authorized service and calibration facility for annual calibration.

Calibrated By:



Mark Benoit

 InstanTel

Calibration Certificate

D

Part Number: 714A9701

Description: TRIAXIAL GEOPHONE (ISEE)

Serial Number: BG12432

Calibration Date: February 11, 2009

Calibration Equipment: 714J7401


InstanTel certifies that the above product was calibrated in accordance with the applicable InstanTel procedures. These procedures are part of a quality system that is certified to the ISO9001:2000 quality standard, and are designed to assure that the product listed above meets or exceeds InstanTel specifications.

InstanTel further certifies that the measurement instruments used during the calibration of this product are traceable to the National Institute of Standards and Technology; or National Research Council of Canada. Evidence of traceability is on file at InstanTel and is available upon request.

The environment in which this product was calibrated is maintained within the operating specifications of the instrument.

Please note that the sensor check function is intended to check that the sensors are connected to the unit, installed in the proper orientation and sufficiently level to operate properly. This function should not be confused with a formal calibration, which requires the sensors be checked against a reference that is traceable to a known standard. InstanTel recommends that products be returned to InstanTel or an authorized service and calibration facility for annual calibration.

Calibrated By:






Mark Benoit

 InstanTel

Amplitude Frequency Response of BG12432

1



Calibration Certificate

E

Part Number: 714A0801

Description: BLASTMATE III

Serial Number: BA13553

Calibration Date: March 3, 2009

Calibration Equipment: 718A1501

InstanTel certifies that the above product was calibrated in accordance with the applicable InstanTel procedures. These procedures are part of a quality system that is certified to the ISO9001:2000 quality standard, and are designed to assure that the product listed above meets or exceeds InstanTel specifications.

InstanTel further certifies that the measurement instruments used during the calibration of this product are traceable to the National Institute of Standards and Technology; or National Research Council of Canada. Evidence of traceability is on file at InstanTel and is available upon request.

The environment in which this product was calibrated is maintained within the operating specifications of the instrument.

Please note that the sensor check function is intended to check that the sensors are connected to the unit, installed in the proper orientation and sufficiently level to operate properly. This function should not be confused with a formal calibration, which requires the sensors be checked against a reference that is traceable to a known standard. InstanTel recommends that products be returned to InstanTel or an authorized service and calibration facility for annual calibration.

Calibrated By:

Dan Sawyer
Dan Sawyer

 InstanTel

Calibration Certificate

E

Part Number: 714A9701

Description: TRIAXIAL GEOPHONE (ISEE)

Serial Number: BG12494

Calibration Date: March 3, 2009

Calibration Equipment: 714J7401

Instantel certifies that the above product was calibrated in accordance with the applicable Instantel procedures. These procedures are part of a quality system that is certified to the ISO9001:2000 quality standard, and are designed to assure that the product listed above meets or exceeds Instantel specifications.

Instantel further certifies that the measurement instruments used during the calibration of this product are traceable to the National Institute of Standards and Technology; or National Research Council of Canada. Evidence of traceability is on file at Instantel and is available upon request.

The environment in which this product was calibrated is maintained within the operating specifications of the instrument.

Please note that the sensor check function is intended to check that the sensors are connected to the unit, installed in the proper orientation and sufficiently level to operate properly. This function should not be confused with a formal calibration, which requires the sensors be checked against a reference that is traceable to a known standard. Instantel recommends that products be returned to Instantel or an authorized service and calibration facility for annual calibration.




Calibrated By:

Dan Sawyer
Dan Sawyer

 **Instantel**

E

Amplitude Frequency Response of BG12494



Calibration Certificate

F

Part Number: 714A0801
Description: BLASTMATE III
Serial Number: BA11042
Calibration Date: May 26, 2009
Calibration Equipment: 718A1501


InstanTEL certifies that the above product was calibrated in accordance with the applicable InstanTEL procedures. These procedures are part of a quality system that is certified to the ISO9001:2000 quality standard, and are designed to assure that the product listed above meets or exceeds InstanTEL specifications.

InstanTEL further certifies that the measurement instruments used during the calibration of this product are traceable to the National Institute of Standards and Technology; or National Research Council of Canada. Evidence of traceability is on file at InstanTEL and is available upon request.

The environment in which this product was calibrated is maintained within the operating specifications of the instrument.

Please note that the sensor check function is intended to check that the sensors are connected to the unit, installed in the proper orientation and sufficiently level to operate properly. This function should not be confused with a formal calibration, which requires the sensors be checked against a reference that is traceable to a known standard. InstanTEL recommends that products be returned to InstanTEL or an authorized service and calibration facility for annual calibration.

Calibrated By:


Dan Sawyer

 InstanTEL

Calibration Certificate

F

Part Number: 714A9701

Description: TRIAXIAL GEOPHONE (ISEE)

Serial Number: BG9432

Calibration Date: May 26, 2009

Calibration Equipment: 714J7402


Instantel certifies that the above product was calibrated in accordance with the applicable Instantel procedures. These procedures are part of a quality system that is certified to the ISO9001:2000 quality standard, and are designed to assure that the product listed above meets or exceeds Instantel specifications.

Instantel further certifies that the measurement instruments used during the calibration of this product are traceable to the National Institute of Standards and Technology; or National Research Council of Canada. Evidence of traceability is on file at Instantel and is available upon request.

The environment in which this product was calibrated is maintained within the operating specifications of the instrument.

Please note that the sensor check function is intended to check that the sensors are connected to the unit, installed in the proper orientation and sufficiently level to operate properly. This function should not be confused with a formal calibration, which requires the sensors be checked against a reference that is traceable to a known standard. Instantel recommends that products be returned to Instantel or an authorized service and calibration facility for annual calibration.




Calibrated By:


Dan Sawyer

 Instantel

F

Amplitude Frequency Response of BG9432



APPENDIX B

Vibration monitoring logs

ba11348_m1g

LOCATION A

Start Time	End Time	Status
Nov 11 /09 08:13:45	Nov 11 /09 08:13:55	Start Monitoring Trigger Level: Geo: 0.0200 in/s
Nov 11 /09 08:13:50	Nov 11 /09 08:13:55	Event recorded. Trigger Vert: 0.0200 in/s
Nov 11 /09 08:13:55	Nov 11 /09 08:14:18	Start Monitoring Trigger Level: Geo: 0.0200 in/s
Nov 11 /09 08:14:13	Nov 11 /09 08:14:18	Event recorded. Trigger Vert: 0.0200 in/s
Nov 11 /09 08:14:18	Nov 11 /09 08:14:32	Start Monitoring Trigger Level: Geo: 0.0200 in/s
Nov 11 /09 08:14:32	Nov 11 /09 08:14:40	Event recorded. Trigger Vert: 0.0200 in/s
Nov 11 /09 08:14:37	Nov 11 /09 08:14:40	No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s
Nov 11 /09 08:15:43	Nov 11 /09 08:15:55	Start Monitoring Trigger Level: Geo: 0.0200 in/s
Nov 11 /09 08:15:55	Nov 11 /09 08:16:01	Event recorded. Trigger Vert: 0.0200 in/s
Nov 11 /09 08:16:01	Nov 11 /09 08:17:39	No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s
Nov 11 /09 08:17:55	Nov 11 /09 09:24:23	No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s
Nov 11 /09 09:25:10	Nov 11 /09 09:48:10	No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s
Nov 11 /09 09:49:29	Nov 11 /09 10:02:09	Start Monitoring Trigger Level: Geo: 0.0200 in/s
Nov 11 /09 10:02:09	Nov 11 /09 10:02:15	Event recorded. Trigger Vert: 0.0200 in/s
Nov 11 /09 10:02:15	Nov 11 /09 10:02:19	No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s
Nov 11 /09 10:02:52	Nov 11 /09 11:56:07	No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s
Nov 11 /09 11:56:30	Nov 11 /09 12:13:10	Start Monitoring Trigger Level: Geo: 0.0200 in/s
Nov 11 /09 12:13:10	Nov 11 /09 12:15:27	Event recorded. Trigger Tran: 0.0200 in/s
Nov 11 /09 12:15:27	Nov 11 /09 13:36:44	Start Monitoring Trigger Level: Geo: 0.0200 in/s
Nov 11 /09 13:36:33	Nov 11 /09 13:36:44	Event recorded. Trigger Vert: 0.0200 in/s
Nov 11 /09 13:36:44	Nov 11 /09 16:17:16	No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s

SERIAL NUMBER: BA11348

LOCATION B

Printed: November 13, 2009 (V 8.01 - 8.01) Event Report: Monitor Log

ba11347_m1g

Start Time	End Time	Status
Nov 10 /09 23:59:14	Nov 10 /09 23:59:24	Start Monitoring Trigger Level: Geo: 0.0500 in/s
Nov 10 /09 23:59:18	Nov 10 /09 23:59:24	Event recorded. Trigger Vert: 0.0500 in/s
Nov 10 /09 23:59:24	Nov 10 /09 23:59:53	No events recorded. (Keyboard Exit) Trigger Geo: 0.0500 in/s
Nov 11 /09 08:06:28	Nov 11 /09 08:06:34	Start Monitoring Trigger Level: Geo: 0.0200 in/s
Nov 11 /09 08:06:34	Nov 11 /09 08:06:39	Event recorded. Trigger Vert: 0.0200 in/s
Nov 11 /09 08:06:39	Nov 11 /09 08:06:58	No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s
Nov 11 /09 08:17:41	Nov 11 /09 09:23:29	No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s
Nov 11 /09 09:24:07	Nov 11 /09 09:48:09	No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s
Nov 11 /09 09:48:35	Nov 11 /09 10:01:54	No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s
Nov 11 /09 10:02:33	Nov 11 /09 10:02:33	Start Monitoring Trigger Level: Geo: 0.0200 in/s
Nov 11 /09 12:13:48	Nov 11 /09 12:13:54	Event recorded. Trigger Vert: 0.0200 in/s
Nov 11 /09 12:13:54	Nov 11 /09 12:13:58	Start Monitoring Trigger Level: Geo: 0.0200 in/s
Nov 11 /09 12:13:58	Nov 11 /09 12:14:45	Event recorded. Trigger Vert: 0.0200 in/s
Nov 11 /09 12:14:45	Nov 11 /09 12:14:47	Start Monitoring Trigger Level: Geo: 0.0200 in/s
Nov 11 /09 12:14:47	Nov 11 /09 12:15:22	Event recorded. Trigger Vert: 0.0200 in/s
Nov 11 /09 12:15:22	Nov 11 /09 12:15:28	Start Monitoring Trigger Level: Geo: 0.0200 in/s
Nov 11 /09 12:15:28	Nov 11 /09 12:16:01	Event recorded. Trigger Vert: 0.0200 in/s
Nov 11 /09 12:16:01	Nov 11 /09 16:17:32	No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s

SERIAL NUMBER: BA11347

LOCATION C

Printed: November 13, 2009 (V 8.01 - 8.01) Event Report: Monitor Log

ba10619_mlg

Start Time	End Time	Status
Nov 11 /09 08:43:26	Nov 11 /09 08:43:36	Start Monitoring Trigger Level: Geo: 0.0200 in/s
Nov 11 /09 08:43:31	Nov 11 /09 08:43:42	Event recorded. Trigger Vert: 0.0200 in/s
Nov 11 /09 08:43:36	Nov 11 /09 08:43:42	No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s
Nov 11 /09 08:44:05	Nov 11 /09 09:18:19	No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s
Nov 11 /09 09:18:51	Nov 11 /09 09:18:51	Start Monitoring Trigger Level: Geo: 0.0200 in/s
Nov 11 /09 09:48:29	Nov 11 /09 09:48:35	Event recorded. Trigger Long: 0.0200 in/s
Nov 11 /09 09:48:35	Nov 11 /09 09:54:19	No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s
Nov 11 /09 09:57:45	Nov 11 /09 10:13:59	No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s
Nov 11 /09 10:14:22	Nov 11 /09 11:50:33	No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s
Nov 11 /09 11:51:14	Nov 11 /09 11:51:14	Start Monitoring Trigger Level: Geo: 0.0200 in/s
Nov 11 /09 12:12:59	Nov 11 /09 12:14:16	Event recorded. Trigger Vert: 0.0200 in/s
Nov 11 /09 12:14:16	Nov 11 /09 12:15:15	Event recorded. Trigger Tran: 0.0200 in/s
Nov 11 /09 12:15:15	Nov 11 /09 12:21:05	No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s
Nov 11 /09 12:27:00	Nov 11 /09 12:27:00	Start Monitoring Trigger Level: Geo: 0.0200 in/s
Nov 11 /09 13:36:22	Nov 11 /09 13:36:30	Event recorded. Trigger Tran: 0.0200 in/s
Nov 11 /09 13:36:30	Nov 11 /09 13:39:04	No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s
Nov 11 /09 13:40:31	Nov 11 /09 16:26:06	No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s

SERIAL NUMBER: BA10619

ba13539.mlg

LOCATION D

Start Time	End Time	Status
Nov 11 /09 08:33:28	Nov 11 /09 08:33:38	No events recorded.
Nov 11 /09 08:33:33	Nov 11 /09 08:33:43	No events recorded.
Nov 11 /09 08:33:38	Nov 11 /09 09:15:56	No events recorded.
Nov 11 /09 08:34:23	Nov 11 /09 09:52:23	No events recorded.
Nov 11 /09 09:16:27	Nov 11 /09 09:57:11	No events recorded.
Nov 11 /09 09:52:45	Nov 11 /09 12:12:30	No events recorded.
Nov 11 /09 09:57:49	Nov 11 /09 12:18:57	No events recorded.
Nov 11 /09 12:12:25	Nov 11 /09 16:24:46	No events recorded.
Nov 11 /09 12:12:30		No events recorded.
Nov 11 /09 12:19:24		No events recorded.

SERIAL NUMBER: BA13539

Start Monitoring Trigger Level: Geo: 0.0200 in/s
 Event recorded. Trigger Vert: 0.0200 in/s
 (Keyboard Exit) Trigger Geo: 0.0200 in/s
 No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s
 No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s
 No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s
 No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s
 Start Monitoring Trigger Level: Geo: 0.0200 in/s
 Event recorded. Trigger Long: 0.0200 in/s
 (Keyboard Exit) Trigger Geo: 0.0200 in/s
 No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s
 No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s

Printed: November 13, 2009 (V 8.01 - 8.01) Event Report: Monitor Log

LOCATION E

ba13553.mlg

Start Time End Time

Status

 SERIAL NUMBER: BAI3553

Start Time	End Time	Status
Nov 11 /09 08:59:54	Nov 11 /09 09:00:01	Start Monitoring Trigger Level: Geo: 0.0200 in/s
Nov 11 /09 08:59:56	Nov 11 /09 09:00:40	Event recorded. Trigger Tran: 0.0200 in/s
Nov 11 /09 09:00:38	Nov 11 /09 09:01:36	No events recorded. (keyboard Exit) Trigger Geo: 0.0200 in/s
Nov 11 /09 09:01:33	Nov 11 /09 10:06:08	No events recorded. (keyboard Exit) Trigger Geo: 0.0200 in/s
Nov 11 /09 09:01:54	Nov 11 /09 16:04:25	No events recorded. (keyboard Exit) Trigger Geo: 0.0200 in/s
Nov 11 /09 10:06:34		No events recorded. (keyboard Exit) Trigger Geo: 0.0200 in/s

Printed: November 13, 2009 (V 8.01 - 8.01) Event Report: Monitor Log

ba11042_mlg

LOCATION F

Start Time End Time

Status

SERIAL NUMBER: BA11042

Nov 11 /09 09:10:33	Nov 11 /09 09:10:45	Start Monitoring Trigger Level: Geo: 0.0200 in/s
Nov 11 /09 09:10:40	Nov 11 /09 09:10:52	Event recorded. Trigger Tran: 0.0200 in/s
Nov 11 /09 09:10:45	Nov 11 /09 10:08:06	No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s
Nov 11 /09 09:11:13	Nov 11 /09 16:08:52	No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s
Nov 11 /09 10:08:29		No events recorded. (Keyboard Exit) Trigger Geo: 0.0200 in/s

APPENDIX C

Event reports

A



Event Report

Date/Time Tran at 12:13:10 November 11, 2009
 Trigger Source Geo: 0.500 mm/s
 Range Geo: 31.7 mm/s
 Record Time 138.75 sec (Auto=5Sec) at 1024 sps

Serial Number BA11348 V 8.12-8.0 BlastMate III
 Battery Level 8.4 Volts
 Calibration December 18, 2008 by InstanTel Inc.
 File Name M348C23R.DYD

Notes
 Client:
 Project:
 Location:
 User:



Extended Notes:

Post Event Notes

Microphone Linear Weighting
 PBPL 9.25 ps (L) at 130.820 sec
 ZC Freq 3.4 Hz
 Channel Test Passed (Freq = 20.5 Hz Amp = 596 mV)

	Tran	Vert	Long	
PPV	0.683	1.52	1.33	mm/s
ZC Freq	14	7.1	27	Hz
Time (Rel. to Trig)	20.338	111.828	129.954	sec
Peak Acceleration	0.0215	0.0348	0.0331	g
Peak Displacement	0.0103	0.0240	0.0130	mm
Sensorcheck	Passed	Passed	Passed	
Frequency	7.7	7.6	7.4	Hz
Overwing Ratio	3.7	3.7	4.2	

Peak Vector Sum: 1.53 mm/s at 111.828 sec



Time Scale: 10.00 sec/div Amplitude Scale: Geo: 0.600 mm/s/div Mic: 10.00 ps (L)/div
 Trigger = >

Sensorcheck

A




FFT Report

Date/Time Tran at 12:13:10 November 11, 2009 Serial Number BA11348 V 8.12-8.0 BlastMate II
Trigger Source Geo: 0.508 mm/s Battery Level 6.4 Volts
Range Geo: 31.7 mm/s Calibration December 18, 2008 by Instantel Inc.
Record Time 136.75 sec (Auto=5Sec) at 1024 sps File Name M348CZ3R.SY0

Notes
Client:
Project:
Location:
User:

Extended Notes:

Post Event Notes



A



Event Report

Date/Time Vert at 13:38:33 November 11, 2009
 Trigger Source Geo: 0.508 mm/s
 Range Geo: 31.7 mm/s
 Record Time 10.75 sec (Auto=5Sec) at 1024 sps

Serial Number BA11348 V 8.12-8.0 BlastMate III
 Battery Level 6.5 Volts
 Calibration December 18, 2008 by Instantel Inc.
 File Name M348CZ3V.4X0



Notes
 Client:
 Project:
 Location:
 User:

Extended Notes:
 Post Event Notes

Microphone Linear Weighting
 PSPL 4.75 pa (L) at 4.383 sec
 ZC Freq 11 Hz
 Channel Test Passed (Freq = 20.5 Hz Amp = 598 mv)

	Tran	Vert	Long	
PPV	0.608	0.587	0.540	mm/s
ZC Freq	30	30	12	Hz
Time (Rel. to Trig)	5.245	2.150	5.401	sec
Peak Acceleration	0.0133	0.0148	0.0149	g
Peak Displacement	0.00267	0.00440	0.00415	mm
Sensorcheck	Passed	Passed	Passed	
Frequency	7.7	7.6	7.4	Hz
Overswing Ratio	3.7	3.7	4.2	

Peak Vector Sum 0.674 mm/s at 3.296 sec



Time Scale: 0.50 sec/div Amplitude Scale: Geo: 0.500 mm/s/div Mic: 10.00 pa (L)/div
 Trigger = >

Sensorcheck

A



FFT Report


Date/Time Vert at 13:36:33 November 11, 2009
Trigger Source Geo: 0.508 mm/s
Range Geo: 31.7 mm/s
Record Time 10.75 sec (Auto=56sec) at 1024 sps

Serial Number BA11348 V B.12-8.0 BlastMate III
Battery Level 6.5 Volts
Calibration December 18, 2008 by Instantel Inc.
File Name M348C23V.4XD

Notes
Client:
Project:
Location:
User:

Extended Notes:

Post Event Notes



B



Event Report

Date/Time: Vert at 12:13:48 November 11, 2009
 Trigger Source: Geo: 0.508 mm/s
 Range: Geo: 31.7 mm/s
 Record Time: 5.25 sec (Auto=5Sec) at 1024 sps

Serial Number: 8A11347 V 8.12-8.0 BlastMate III
 Battery Level: 8.5 Volts
 Calibration: December 18, 2008 by Instantel Inc.
 File Name: M347C23R.800

Notes
 Client:
 Project:
 Location:
 User:

Extended Notes:



Post Event Notes

Microphone: Linear Weighting
 PSPL: 8.25 ps (L) at 0.769 sec
 ZO Freq: 51 Hz
 Channel Test: Passed (Freq = 20.1 Hz Amp = 627 mv)

	Tran	Vert	Long	
PPV	0.254	0.586	0.333	mm/s
ZO Freq	37	27	32	Hz
Time (Rel. to Trig)	1.403	0.001	2.381	sec
Peak Acceleration	0.00829	0.00894	0.0116	g
Peak Displacement	0.00133	0.00833	0.00602	mm
Sensorcheck	Passed	Passed	Passed	
Frequency	7.3	7.7	7.6	Hz
Overwriting Ratio	4.3	3.6	4.1	

Peak Vector Sum: 0.578 mm/s at 0.002 sec

USBM R0807 And OSMRE



Time Scale: 0.50 sec/div Amplitude Scale: Geo: 0.500 mm/s/div Mic: 10.00 ps (L)X6V
 Trigger # 1




FFT Report

Date/Time	Vert at 12:13:48 November 11, 2009	Serial Number	8A11347 V 8.12-8.0 BlastMate III
Trigger Source	Geo: 0.808 mm/s	Battery Level	8.5 Volts
Range	Geo: 31.7 mm/s	Calibration	December 18, 2008 by InstanTel Inc.
Record Time	6.25 sec (Auto=5Sec) at 1024 sps	File Name	M347CZ3R B00

Notes
Client:
Project:
Location:
User:

Extended Notes:

Post Event Notes



B



Event Report

Date/Time Vert at 12:13:58 November 11, 2009
Trigger Source Geo: 0.508 mm/s
Range Geo: 31.7 mm/s
Record Time 48.75 sec (Auto=66sec) at 1024 sps

Serial Number BA11347 V 8.12-8.0 BlastMate III
Battery Level 8.4 Volts
Calibration December 18, 2008 by InstanTel Inc.
File Name M347CZ3R.BAO

Notes
Client:
Project:
Location:
User:



Extended Notes:

Post Event Notes

Microphone Linear Weighting
PSPL 7.00 ps (L) at 38.173 sec
ZC Freq 32 Hz
Channel Test Passed (Freq = 20.1 Hz Amp = 627 mv)

	Trans	Vert	Long	
PPV	0.302	0.887	0.671	mm/s
ZC Freq	43	22	7.2	Hz
Time (Rel. to Trig)	27.941	40.884	17.058	sec
Peak Acceleration	0.0149	0.0149	0.0149	g
Peak Displacement	0.00385	-0.0118	0.0116	mm
Sensorcheck	Passed	Passed	Passed	
Frequency	7.3	7.7	7.5	Hz
Overwing Ratio	4.3	3.6	4.1	

Peak Vector Sum 0.719 mm/s at 6.373 sec



Time Scale: 8.00 sec/div Amplitude Scale: Geo: 0.500 mm/s/Div Mic: 10.00 ps (L)/Div
Trigger =

Sensorcheck

B




FFT Report

Date/Time	Vert at 12:13:58 November 11, 2009	Serial Number	8A11347 V 8.12-8.0 BlastMate III
Trigger Source	Geo: 0.508 mm/s	Battery Level	6.4 Volts
Range	Geo: 31.7 mm/s	Calibration	December 18, 2008 by InstanTel Inc.
Record Time	46.76 sec (Auto-5Sec) at 1024 sps	File Name	M347CZ3R BA0

Notes
Client:
Project:
Location:
User:

Extended Notes:

Post Event Notes



B



Event Report

Date/Time: Vert at 12:14:47 November 11, 2009
 Trigger Source: Geo: 0.508 m/s
 Range: Geo: 31.7 m/s
 Record Time: 34.75 sec (Auto=5Sec) at 1024 sps

Serial Number: BA11347 V B.12-8.0 BlastMate III
 Battery Level: 8.4 Volts
 Calibration: December 18, 2008 by InstanTel Inc.
 File Name: M347CZ3R.CNO



Notes:
 Client:
 Project:
 Location:
 User:

Extended Notes:
 Post Event Notes:

Microphone: Linear Weighting
 SPL: 9.25 pa(L) at 5.778 sec
 ZC Freq: 7.8 Hz
 Channel Test: Passed (Freq = 20.1 Hz Amp = 627 mv)

	Tran	Vert	Long	
PPV	0.302	0.778	0.492	m/s
ZC Freq	26	32	30	Hz
Time (Rel. to Trig)	17.307	22.382	19.917	sec
Peak Acceleration	0.00894	0.0196	0.0110	g
Peak Displacement	0.00303	0.00691	0.00786	mm
Sensorcheck	Passed	Passed	Passed	
Frequency	7.3	7.7	7.6	Hz
Overswing Ratio	4.3	3.6	4.1	

Peak Vector Sum: 0.784 m/s at 22.354 sec



Time Scale: 1.00 sec/div Amplitude Scale: Geo: 0.500 m/s/div Mic: 10.00 pa(L)/div
 Trigger: [Symbol]




FFT Report

Date/Time Vert at 12:14:47 November 11, 2009 Serial Number 5A11347 V 8.12-8.0 BlastMate III
Trigger Source Geo: 0.508 mm/s Battery Level 6.4 Volts
Range Geo: 31.7 mm/s Calibration December 18, 2008 by Instanbel Inc.
Record Time 34.75 sec (Auto=5Sec) at 1024 sps File Name M347CZ3R.CNO

Notes
Client:
Project:
Location:
User:

Extended Notes:

Post Event Notes





Event Report

Date/Time: Veri at 12:15:28 November 11, 2009
 Trigger Source: Geo: 0.508 mm/s
 Range: Geo: 31.7 mm/s
 Record Time: 33.25 sec (Auto-SSec) at 1024 sps

Serial Number: BA11347 V 8.12-8.0 BlastMate III
 Battery Level: 6.4 Volts
 Calibration: December 18, 2008 by Instantel Inc.
 File Name: M347CZ3R.D60

Notes:
 Client:
 Project:
 Location:
 User:

Extended Notes:



Post Event Notes:

Microphone: Linear Weighing
 PBPL: 52.0 pa (L) at 27.188 sec
 ZC Freq: 8.1 Hz
 Channel Test: Passed (Freq = 20.1 Hz Amp = 627 mv)

	Tran	Vert	Long	
PRV	0.286	1.03	0.746	mm/s
ZC Freq	30	7.0	7.6	Hz
Time (Rel. to Trig)	22.454	9.063	8.844	sec
Peak Acceleration	0.00994	0.0182	0.0116	g
Peak Displacement	0.00462	0.0211	0.0143	mm
Sensorcheck	Passed	Passed	Passed	
Frequency	7.3	7.7	7.5	Hz
Overring Ratio	4.3	3.6	4.1	

Peak Vector Sum: 1.08 mm/s at 8.927 sec

USBM R18507 And OSMRE



B




FFT Report

Date/Time	Vert at 12:15:28 November 11, 2009	Serial Number	6A11347 V 8.12-8.0 BlastMate III
Trigger Source	Geo: 0.508 mm/s	Battery Level	8.4 Volts
Range	Geo: 31.7 mm/s	Calibration	December 18, 2008 by Instantel Inc.
Record Time	33.25 sec (Auto=55sec) at 1024 sps	File Name	M347CZ3R.D50

Notes
Client:
Project:
Location:
User:

Extended Notes:

Post Event Notes



C



Event Report

Date/Time Long at 09:48:29 November 11, 2009
 Trigger Source Geo: 0.508 mm/s
 Range Geo :254 mm/s
 Record Time 5.75 sec (Auto=5Sec) at 1024 sps

Serial Number BA10619 V 8.12-8.0 BlastMate III
 Battery Level 6.3 Volts
 Calibration May 27, 2009 by Instantel Inc.
 File Name L619CZ3K.KTO

Notes
 Client:
 Project:
 Location:
 User:



Extended Notes:

Post Event Notes

Microphone Linear Weighting
 PSPL 1.50 pa.(L) at 0.165 sec
 ZC Freq 51 Hz
 Channel Test Passed (Freq = 20.1 Hz Amp = 614 mv)

	Tran	Vert	Long	
PPV	0.381	0.508	0.508	mm/s
ZC Freq	51	47	37	Hz
Time (Rel. to Trig)	0.682	0.006	0.000	sec
Peak Acceleration	0.0133	0.0265	0.0265	g
Peak Displacement	0.00130	0.00192	0.00291	mm
Sensorcheck	Passed	Passed	Passed	
Frequency	7.2	7.4	7.5	Hz
Overswing Ratio	4.2	3.5	4.0	

Peak Vector Sum 0.568 mm/s at 0.002 sec



Time Scale: 0.50 sec/div Amplitude Scale: Geo: 2.00 mm/s/div Mic: 10.00 pa.(L)/div
 Trigger =

Sensorcheck

C



FFT Report


Date/Time Long at 09:48:29 November 11, 2009
Trigger Source Geo: 0.508 mm/s
Range Geo :254 mm/s
Record Time 5.75 sec (Auto=5Sec) at 1024 sps

Serial Number BA10619 V 8.12-8.0 BlastMate III
Battery Level 6.3 Volts
Calibration May 27, 2009 by InstanTel Inc.
File Name L619CZ3K.KT0

Notes
Client:
Project:
Location:
User:

Extended Notes:

Post Event Notes



C



Event Report

Date/Time Vert at 12:12:59 November 11, 2009
 Trigger Source Geo: 0.508 mm/s
 Range Geo :31.7 mm/s
 Record Time 77.25 sec (Auto=5Sec) at 1024 sps

Serial Number BA10619 V 8.12-8.0 BlastMate III
 Battery Level 6.3 Volts
 Calibration May 27, 2009 by Instantel Inc.
 File Name L619CZ3R.9N0

Notes

Client:
 Project:
 Location:
 User:



Extended Notes:

Post Event Notes

Microphone Linear Weighting
 PSPL 9.00 pa.(L) at 22.708 sec
 ZC Freq 39 Hz
 Channel Test Passed (Freq = 20.1 Hz Amp = 534 mv)

	Tran	Vert	Long	
PPV	0.905	1.16	1.40	mm/s
ZC Freq	14	17	47	Hz
Time (Rel. to Trig)	45.714	25.931	36.707	sec
Peak Acceleration	0.0298	0.0298	0.0464	g
Peak Displacement	0.00846	0.0152	0.00843	mm
Sensorcheck	Passed	Passed	Passed	
Frequency	7.2	7.4	7.5	Hz
Overswing Ratio	4.1	3.5	4.0	

Peak Vector Sum 1.61 mm/s at 36.707 sec



Time Scale: 5.00 sec/div Amplitude Scale: Geo: 0.500 mm/s/div Mic: 10.00 pa.(L)/div
 Trigger =

Sensorcheck

C



FFT Report


Date/Time: Vert at 12:12:59 November 11, 2009
Trigger Source: Geo: 0.508 mm/s
Range: Geo: 31.7 mm/s
Record Time: 77.25 sec (Auto=35sec) at 1024 sps

Serial Number: SA10819 V 8.12-8.0 BlastMate III
Battery Level: 6.3 Volts
Calibration: May 27, 2008 by Instante! Inc.
File Name: L619CZ3R.DWG

Notes:
Client:
Project:
Location:
User:

Extended Notes:

Post Event Notes



C



Event Report

Date/Time: Tran at 12:14:16 November 11, 2009
 Trigger Source: Geo: 0.608 mm/s
 Range: Geo: 31.7 mm/s
 Record Time: 58.76 sec (Auto=5Sec) at 1024 sps
 Serial Number: BA10619 V 8.12-8 0 BlastMate II
 Battery Level: 8.3 Volts
 Calibration: May 27, 2009 by Instantel Inc.
 File Name: L619C23R 890

Notes
 Client:
 Project:
 Location:
 User:

Extended Notes:



Post Event Notes

Microphone: Linear Weighting
 PSP: 7.00 ps (L) at 0.914 sec
 ZC Freq: 32 Hz
 Channel Test: Passed (Freq = 20.1 Hz, Amp = 534 mv)

	Tran	Vert	Long	
PPV	1.16	1.48	1.81	mm/s
ZC Freq	34	34	30	Hz
Time (Rel. to Trig)	3.227	82.262	61.972	sec
Peak Acceleration	0.0298	0.0331	0.0398	g
Peak Displacement	0.00788	0.0184	0.00942	mm
Sensorcheck	Passed	Passed	Passed	
Frequency	7.2	7.4	7.5	Hz
Overseeing Ratio	4.1	3.5	4.0	

Peak Vector Sum: 1.98 mm/s at 61.972 sec

USBM R18507 And O8MRE



Time Scale: 5.00 sec/div Amplitude Scale: Geo: 0.500 mm/s/div Mic: 10.00 ps (L)/div
 Trigger: [Symbol]

Sensorcheck

C



FFT Report


Date/Time: Tran at 12:14:16 November 11, 2009
Trigger Source: Geo: 0.508 mm/s
Range: Geo: 31.7 mm/s
Record Time: 58.75 sec (Auto-5Sec) at 1024 sps

Serial Number: BA10619 V 8.12-8.0 BlastMate II
Battery Level: 8.3 Volts
Calibration: May 27, 2009 by InstanTel Inc.
File Name: L619CZ3R.B80

Notes:
Client:
Project:
Location:
User:

Extended Notes:

Post Event Notes



C



Event Report

Date/Time: Trm at 13:36:22 November 11, 2009
 Trigger Source: Geo: 0.500 mm/s
 Range: Geo: 31.7 mm/s
 Record Time: 7.75 sec (Auto=5Sec) at 1024 sps
 Serial Number: BA10619 V 8.12-6.0 BlastMate III
 Battery Level: 6.4 Volts
 Calibration: May 27, 2009 by InstanTel Inc.
 File Name: L619C23V.4MO


Notes
 Client:
 Project:
 Location:
 User:

Extended Notes:
 Post Event Notes


Microphone: Linear Weighting
 PSPL: 4.25 pa (L) at 1.878 sec
 ZC Freq: >100 Hz
 Channel Test: Passed (Freq = 20.5 Hz, Amp = 533 mv)

	Tran	Vert	Long	
PPV	0.624	0.636	0.667	mm/s
ZC Freq	32	30	30	Hz
Time (Rel. to Trig)	0.000	1.762	0.270	sec
Peak Acceleration	0.0149	0.0149	0.0199	g
Peak Displacement	0.00318	0.00379	0.00378	mm
Sensorcheck	Passed	Passed	Passed	
Frequency	7.2	7.4	7.5	Hz
Overwring Ratio	4.1	3.6	4.0	

USBM R18507 And OSMRE



Peak Vector Sum: 0.736 mm/s at 2.612 sec



Time Scale: 0.60 sec/div Amplitude Scale: Geo: 0.500 mm/s/div Mic: 10.00 pa(L)/div
 Trigger = >-----<

Sensorcheck




FFT Report

Date/Time	Tran at 13:36:22 November 11, 2009	Serial Number	BA10619 V 8.12-8.0 BlastMate II
Trigger Source	Geo: 0.608 mm/s	Battery Level	6.4 Volts
Range	Geo: 31.7 mm/s	Calibration	May 27, 2009 by Instantel Inc.
Record Time	7.75 sec (Auto=5Sec) at 1024 sps	File Name	L619CZ3V.4MG

Notes
Client:
Project:
Location:
User:

Extended Notes:

Post Event Notes



D



FFT Report


Date/Time Long at 12:12:26 November 11, 2009
Trigger Source Geo: 0.608 mm/s
Range Geo: 31.7 mm/s
Record Time 5.25 sec (Auto=5Sec) at 1024 sps

Serial Number BA10538 V 8.12-8.0 BlastMate III
Battery Level 6.4 Volts
Calibration February 11, 2009 by Instantel inc.
File Name OS39CZ3R.8P0

Notes
Client:
Project:
Location:
User:

Extended Notes:

Post Event Notes



D



Event Report

Date/Time Long at 12:12:25 November 11, 2009
 Trigger Source Geo: 0.508 mm/s
 Range Geo: 31.7 mm/s
 Record Time 5.25 sec (Auto=5Sec) at 1024 sps
 Serial Number BA13539 V B.12-B.0 BlastMate III
 Battery Level 6.4 Volts
 Calibration February 11, 2009 by Instante! Inc.
 File Name 0539C23R.8P0

Notes
 Client:
 Project:
 Location:
 User:



Extended Notes:

Post Event Notes

Microphone Linear Weighting
 PSPL 7.00 ps (L) at 0.036 sec
 ZC Freq 8.0 Hz
 Channel Test Passed (Freq = 20.1 Hz Amp = 669 mv)

	Tran	Vert	Long	
PPV	0.222	0.368	0.508	mm/s
ZC Freq	24	13	9.1	Hz
Time (Rel. to Trig)	4.554	0.247	0.000	sec
Peak Acceleration	0.00663	0.00829	0.00994	g
Peak Displacement	0.00282	0.00582	0.00884	mm
Sensorcheck	Passed	Passed	Passed	
Frequency	7.5	7.5	7.4	Hz
Overwring Ratio	3.7	3.4	3.9	

Peak Vector Sum 0.594 mm/s at 0.000 sec



Time Scale: 0.60 sec/div Amplitude Scale: Geo: 0.500 mm/s/10V Mic: 10.00 ps (L)/div
 Trigger =

**DR. KALINSKI REPORT DATED MARCH 8, 2010
RELATED TO JANUARY 6 AND 7, 2010
VIBRATION MONITORING, GEOPHYSICAL TESTING,
AND LABORATORY DAMPING RATIO TESTING**

March 8, 2010

Mr. Roger Cecil, P.E.
Geo/Environmental Associates
3502 Overlook Circle
Knoxville, TN 37909

RE: Vibration monitoring crosshole seismic testing, and resonant column testing at the AEP Sporn Power Plant, New Haven, West Virginia (revised report)

Dear Roger,

OVERVIEW

Vibration monitoring and crosshole seismic testing were performed on January 6-7, 2010 at the AEP Sporn Power Plant in New Haven, West Virginia. Vibration monitoring was performed at the same six locations that were used in November 2009, and crosshole seismic testing was performed at two of these locations. Laboratory free-free resonant column testing was also performed on undisturbed fly ash specimens to estimate the material damping of the fly ash. This letter report describes the methods used and results, and is accompanied by a CD containing the data.

VIBRATION MONITORING

Vibration monitoring was performed continuously for 30 hours from approximately 9:00 A.M. on January 6 until 3:00 P.M. on January 7 at six locations on the perimeter levees that contain the fly ash and bottom ash at the power plant. The locations are described as follows:

- Location A: outside toe of the bottom ash levee adjacent to the train tracks;
- Location B: outside crest of the bottom ash levee adjacent to the train tracks;
- Location C: outside toe of the fly ash levee adjacent to the train tracks;
- Location D: outside crest of the fly ash levee adjacent to the train tracks;
- Location E: outside crest of the fly ash levee adjacent to the Ohio River; and
- Location F: outside toe of the fly ash levee adjacent to the Ohio River.

These are the same locations that were used for vibration monitoring during the November 2009 survey.

Vibration monitoring was performed using six Blastmate III seismographs, which are manufactured by Instantel. The Blastmate III seismographs record four channels simultaneously during each event: one air wave channel with a microphone, and three ground wave channels using three geophones. The three geophones are oriented orthogonal to each other so that one geophone detects vertical particle motion, and the other two detect horizontal particle motion in two perpendicular directions. The two horizontal geophones are identified as longitudinal and

transverse, with the longitudinal geophone oriented towards the vibration source, and the transverse oriented perpendicular to the longitudinal.

The geophones that accompany the Blastmate III have a damped resonant frequency of approximately 2.0 Hz and the data are sampled in the instrument at a rate of 1,024 samples per second. This allows vibrations to be recorded between the bandwidth of 2.0-250 Hz with minimal distortion. The vibrations imparted to the geophones are converted into voltage, and the voltage is converted to particle velocity using a calibration factor. To minimize wind and surface noise, the geophones are buried in sand a few inches below the ground surface and covered with a heavy weight such as a sand bag or water jug. The serial numbers of the seismographs used at each test location are as follows:

- Location A: Serial #BA11042;
- Location B: Serial #BA11291;
- Location C: Serial #BA10619;
- Location D: Serial #BA11821;
- Location E: Serial #BA11088; and
- Location F: Serial #BA11290.

Each instrument was calibrated according to ISO9001:2000 standards.

Vibration monitoring was performed on January 6-7, 2010 as indicated on the monitoring logs included in Appendix A of this report. During this period, four trains passed by the power plant:

- Train 1: January 6, 1:13 P.M.; approximately 95 seconds in duration;
- Train 2: January 7, 12:23 A.M.; approximately 132 seconds in duration;
- Train 3: January 7, 4:27 A.M.; approximately 120 seconds in duration; and
- Train 4: January 7, 12:05 P.M.; approximately 122 seconds in duration.

Trains 1 and 4 consisted of multiple (typically four) engines with mostly tank cars, and appeared to be traveling at a speed of around 25 mph. Trains 2 and 3 passed during the night and were not visually observed.

The vibration monitoring logs included in Appendix A indicate when the seismographs were actively monitoring and when vibration events were recorded, including the four trains. The monitoring logs indicate that additional events were also recorded. These additional events correspond to occasional testing of the seismographs by stomping on the ground next to the geophones. Details regarding these additional test events are not included herein.

For all logging, vibrations were only recorded when the vibration level exceeded 0.02 in./s. Below this level, vibrations were considered to be within the level of ambient noise. Peak particle velocities observed for each train and monitoring location are summarized in Table 1.

All of the vibration monitoring data are included in ASCII format in Appendix B on the attached CD. Given a sample rate of 1,024 samples/s, the vibration data should be plotted at a

sample rate of 9.7656×10^{-4} s. Vibration data are presented in the ASCII files text in units of particle velocity in mm/s. Please note that the internal clocks on the six seismographs were set to the nearest minute, so the time stamps on the monitoring data may be slightly out of synch between seismographs.

Excel files containing particle acceleration are also included in Appendix B. Acceleration is defined a change in velocity per unit time, and was derived by calculating the difference in particle velocity between successive points and dividing the difference by the sample rate. For example, if the particle velocity for a given sample time is 0.349 mm/s, the particle velocity for the next sample time is 0.302 mm/s, and the sample rate is 1.019×10^{-4} s, then the particle acceleration is $(0.302 \text{ mm/s} - 0.349 \text{ mm/s})/9.77 \times 10^{-4} \text{ s} = -4.81 \times 10^{-1} \text{ mm/s}^2$, or -4.90×10^{-3} g.

CROSSHOLE SEISMIC TESTING

Crosshole seismic testing was performed at vibration monitoring Locations B (in bottom ash) and E (in fly ash). Crosshole seismic testing was performed using a three-hole array with one source hole and two receiver holes. The spacing at the ground surface was 10.0 ft, and an inclinometer survey was performed by Mr. Seth Frank to derive borehole spacing information for calculation of wave velocities. A mechanical wedge was used as a borehole seismic source, and BHG-2 borehole geophones were used as receivers. The BHG-2 geophones contain three geophones positioned in three orthogonal directions (one vertical and two horizontal). For crosshole seismic testing, the vertical geophone measures S-waves, while the horizontal geophones measure P-waves. All of the data were recorded using a Geometrics Geode multi-channel seismograph.

A set of typical crosshole data is shown in Fig. 1. For this record, the S-waves and P-waves are apparent on each trace. Although the vertical geophones are intended to record S-waves, there is some leakage of P-wave energy onto the records. Conversely, there is also leakage of S-wave energy onto the horizontally oriented geophones, which are primarily intended to record P-wave energy.

Spreadsheets including the details of crosshole seismic testing are included on the attached CD. Calculated wave velocities and values for Poisson's ratio are summarized in Tables 2 and 3, and the data are graphed in Figs. 2 and 3.

FREE-FREE RESONANT COLUMN TESTING

Free-free resonant column testing was performed on 2 fly ash specimens and one clay foundation specimen recovered from the site to calculate material damping. Each specimen was approximately 6.0 in. long and 3.0 in. in diameter. Resonant column testing is performed by suspending the specimens horizontally. Accelerometers are glued to the outer perimeter of one end to detect torsional motion, while a torsional excitation device is fixed to the other end. The specimens are encased in a latex membrane with end caps during testing, and a vacuum pressure of approximately 9.0 psi is applied to provide confinement to the specimens.

When the specimen is excited in torsion, it resonates at a frequency f_n that is calculated by performing spectral analysis of the free vibration record measured with the accelerometers. The auto power spectrum is calculated, which is a curve of accelerometer power versus frequency. The half-power bandwidth method is then used to estimate material damping. Given a resonant frequency f_n and spectral power of A , frequencies f_1 and f_2 are identified as the frequencies corresponding to a power of $0.5A$. Material damping is then estimated as:

$$D = (f_2 - f_1) / (2 f_n).$$

Results are summarized in the table below.

Specimen description	Material damping (%)
FLY ASH: recovered from GA-1A-ST-7, depth = 48.5-51.0 ft	3.9
FLY ASH: recovered from GA-1A-ST-4, depth = 36.5-39.0 ft	5.1
FOUNDATION SOIL: recovered from GA-ST-2, depth = 59.0-61.5 ft	7.0

Please note that the material damping of 7.0% measured in the clay foundation soil specimen is higher than the typical range in material damping for clay specimens. Material damping of clay is typically around 2-4%. It was difficult to obtain a measurable signal in the clay specimen, which supports the observation that material damping in the clay is relatively high.

Thank you very much for providing me the opportunity to work with you on this project. Please do not hesitate to contact me if you have any questions or require any additional details or information.

Regards,

Michael E. Kalinski

Michael E. Kalinski, Ph.D.

Attachments: Tables 1-3

Figs. 1-3

Appendix A -- vibration monitoring logs (on CD)

Appendix B -- vibration data (on CD)

Appendix C -- crosshole seismic calculations (on CD)

Table 1. Peak particle velocities (PPVs) recorded for each train and location

Train	Location	Tran. PPV (in./s)	Vert. PPV (in./s)	Long. PPV (in./s)
1	A	0.007	0.035	0.016
	B	0.006	0.023	0.014
	C	0.044	0.042	0.047
	D	ND*	ND	ND
	E	ND	ND	ND
	F	ND	ND	ND
2	A	0.010	0.039	0.019
	B	0.007	0.024	0.010
	C	0.048	0.057	0.046
	D	ND	ND	ND
	E	ND	ND	ND
	F	ND	ND	ND
3	A	0.010	0.039	0.013
	B	ND	ND	ND
	C	0.055	0.054	0.053
	D	ND	ND	ND
	E	ND	ND	ND
	F	ND	ND	ND
4	A	0.009	0.039	0.016
	B	0.007	0.021	0.009
	C	0.043	0.049	0.047
	D	0.006	0.014	0.021
	E	ND	ND	ND
	F	ND	ND	ND

*ND = no vibrations detected above threshold level of 0.02 in./s

Table 2. Summary of results from crosshole seismic testing at Location B (bottom ash site)


Depth (ft)	S-wave velocity (ft/s)	P-wave velocity (ft/s)	Poisson's ratio	Interpretation
10.0	814	?*	?	unsaturated fill
12.5	825	?	?	unsaturated fill
15.0	1061	?	?	unsaturated fill
17.5	1188	?	?	unsaturated fill
20.0	1501	?	?	unsaturated fill
22.5	1122	?	?	unsaturated fill
25.0	1741	3489	0.33	unsaturated fill
27.5	453	3917	0.49	saturated fly ash
30.0	500	5178	0.50	saturated fly ash
32.5	350	3854	0.50	saturated fly ash
35.0	?	5750	?	foundation soil
37.5	1468	5072	0.45	foundation soil
40.0	1505	6471	0.47	foundation soil
42.5	849	5638	0.49	foundation soil
45.0	1120	6414	0.48	foundation soil
47.5	1944	6400	0.45	foundation soil

*Could not be reliably identified on the data.


Table 3. Summary of results from crosshole seismic testing at Location E (fly ash site)

Depth (ft)	S-wave velocity (ft/s)	P-wave velocity (ft/s)	Poisson's ratio	Interpretation
10.0	1242	?*	?	unsaturated fill
15.0	1178	2195	0.30	unsaturated fill
17.5	690	2541	0.46	unsaturated fill
20.0	862	1930	0.38	unsaturated fill
22.5	963	1784	0.29	unsaturated fill
25.0	875	1718	0.33	unsaturated fill
27.5	1041	?	?	unsaturated fill
30.0	554	993	0.27	unsaturated fly ash
32.5	392	3963	0.50	saturated fly ash
35.0	364	5267	0.50	saturated fly ash
37.5	415	4740	0.50	saturated fly ash
40.0	321	4295	0.50	saturated fly ash
42.5	461	4282	0.49	saturated fly ash
45.0	470	4710	0.49	saturated fly ash
47.5	480	5894	0.50	saturated fly ash
50.0	516	5233	0.50	saturated fly ash
52.5	811	5233	0.49	saturated fly ash
55.0	403	3917	0.49	saturated fly ash
57.5	555	3942	0.49	saturated fly ash
60.0	527	5907	0.50	saturated fly ash
62.5	744	2069	0.43	foundation soil
65.0	771	2518	0.45	foundation soil
67.5	567	2389	0.47	foundation soil

*Could not be reliably identified on the data.



a. S-wave arrivals



b. P-wave arrivals (rescaled view of Fig. 1a)

Fig. 1. Typical records from crosshole seismic testing (recorded at Location E at a depth of 40.0 ft below the ground surface in fly ash).




Fig. 2. Graph of wave velocities and Poisson's ratio from crosshole seismic testing at Location B (bottom ash site)





Fig. 3. Graph of wave velocities and Poissons ratios from crosshole seismic testing at Location E (fly ash site)

CD WITH VIBRATION MONITORING DATA



**PHILIP SPORN
BOTTOM ASH AND FLY ASH DISPOSAL FACILITIES**

**VIBRATION MONITORING DATA PREPARED BY:
DR. MICHAEL KALINSKI
NOVEMBER 2009 & JANUARY 2010**

CSX TRANSPORTATION LETTER
REGARDING RAILWAY FREQUENCIES AND SCHEDULES
BETWEEN HUNTINGTON, WV AND PARKERSBURG, WV



1-877-TellCSX
TellCSX@csx.com
www.csx.com > Contact Us

November 10, 2009

Mr. Seth Frank
Geo-Environmental Associates, Inc.
3502 Overlook Circle
Knoxville, Tennessee 37909

Dear Mr. Frank:

You recently contacted CSX to request information concerning a train schedule for New Haven, West Virginia.

We hope you will understand, but because of security concerns, we cannot disclose train schedules or frequency information to the public.

We apologize for not being able to provide the information you requested, and thank you for contacting CSX.

Sincerely,

TellCSX Team

ej

Ref: 9309v7469016

Did you know? CSX is the Railroad Industry's Charter Member of the EPA's SmartWay Program, an initiative to increase energy efficiency while reducing greenhouse gases and air pollution.

AEPSP003307


APPENDIX III
FIELD AND LABORATORY TEST DATA



FIELD DATA FROM:
***“PHILIP SPORN ELECTRIC GENERATING PLANT BOTTOM ASH
FACILITY – ENGINEERING REPORT”***

PREPARED/COMPILED BY:
**GEOTECH/HYDRO/SITE SECTION OF
AMERICAN ELECTRIC POWER CORPORATION**

DATED: 1996




Boring	North	East	Elev.	Depth
96-04	717954.157	38752.5	593.5	88.0
96-05	718463.157	36113.5	597.4	58.2
96-06	718519.117	36243.1	566.1	33.0

DISTANCES:
 Beginning 0.0
 Ending 765.1
 VIEWING ANGLES (degrees):
 Horizontal 0.0
 Vertical 0.0

Position	North	East
Left. Front		
Right. Front		
Left. Back		
Right. Back		

SUBSURFACE FENCE DIAGRAM
 Sporn ~~BY~~ ^{Both} ASH DIKE
 Sporn ~~BY~~ ^{Putman} ash pond dikes
 Sporn Plant
 PROJECT # 3966 DATE JUL 96 PLATE I



Boring	North	East	Elev.	Depth
96-02	718158.87	36270.7	594.6	58.4
96-05	718463.167	36113.5	597.4	58.2

DISTANCES:
 Beginning 0.0
 Ending 343.3
 VEILING ANGLES (degrees):
 Horizontal 0.0
 Vertical 0.0

Position	North	East
Left, Front		
Right, Front		
Left, Back		
Right, Back		

SUBSURFACE FENCE DIAGRAM

SPORN ~~ASH~~ ^{3070M} ASH DIKE

Sporn ~~ASH~~ ^{3070M} ash pond dikes

Sporn plant

PROJECT #	DATE	PLATE
3966	JUL 96	1

AMERICAN ELECTRIC POWER SERVICE CORPORATION
 AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER 3966
 COMPANY APPALACHIAN POWER COMPANY
 PROJECT Sporn fly ash pond dikes
 COORDINATES N 717,700.5 E 1,735,921.2
 GROUND ELEVATION 592.7 SYSTEM STATE PLANE

BORING NO. 96-01 DATE _____ SHEET 1 OF 2
 BORING START 06/14/96 BORING FINISH 06/20/96
 PIEZOMETER TYPE _____ WELL TYPE _____
 HGT. RISER ABOVE GROUND _____ DIA _____
 DEPTH TO TOP OF WELL SCREEN _____ BOTTOM _____
 WELL DEVELOPMENT _____ BACKFILL QUICK GROUT
 FIELD PARTY MCR-WEB RIG BK-81

WATER LEVEL	▽ 27.9	▽	▽
TIME			
DATE	6-20-96		

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD %	DEPTH IN FEET	GRAPH LOG	SS U	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO									
		0.0	1.5							<u>ROAD BASE</u>		
2	SS	3.0	4.5	11-10-7	1.5		5		SW	<u>BLACK BOTTOM ASH</u> Moist. <u>YELLOWISH ORANGE GRAVELLY SAND</u> Dry to moist, 3/4" max size.		
3	SS	5.0	6.5	8-9-11	1.3							
4	SS	8.5	10.0	10-25-30	1.2		10			<u>BLACK BOTTOM ASH</u> Moist.		
5	SS	11.7	13.2	11-12-16	1.5		15			<u>DARK BROWN SANDY SILT</u> Moist, v-fine grain sand.		
6	SS	16.7	18.2	7-7-11	1.5		20			<u>BLACK BOTTOM ASH</u> Dry.		
7	SS	21.7	23.2	7-3-2	1.5		25			<u>Moist this area</u>		
8	SS	26.7	28.2	1-1-1	1.5		30			<u>Saturated this area</u>	▽	
9	SS	31.7	33.2	1-2-2	1.5		35		CL	<u>GREENISH BROWN SANDY CLAY</u> Saturated, low plasticity.		
10	SS	36.7	38.2	3-2-2	1.2		40		CL	<u>MULTI-COLORED BROWN SANDY CLAY</u> Wet to saturated, low plasticity, v-fine sand.		
11	ST	41.7	43.7		0		45					Believe material to soft to pickup in tube.
12	ST	43.7	45.7		0							

TYPE OF CASING USED				<i>Continued Next Page</i>			
	NQ-2 ROCK CORE			PIEZOMETER TYPE: PT = OPEN TUBE POROUS TIP, SS = OPEN TUBE SLOTTED SCREEN, G = GEONOR, P = PNEUMATIC			
X	6" x 3.25 HSA			WELL TYPE: OW = OPEN TUBE SLOTTED SCREEN, GM = GEOMON			
	9" x 6.25 HSA			RECORDER <u>WEB</u>			
	HW CASING ADVANCER 4"						
	NW CASING 3"						
	SW CASING 6"						

AMERICAN ELECTRIC POWER SERVICE CORPORATION
 AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER 3966

COMPANY APPALACHIAN POWER COMPANY

BORING NO. 96-01 DATE _____ SHEET 2 OF 2

PROJECT Sporn fly ash pond dikes

BORING START 06/14/96 BORING FINISH 06/20/96

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD	DEPTH IN FEET	GRAPH LOG	U	S	C	S	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO			%									
13	SS	51.7	53.2	1-1-2	1.0								CL <u>DARK GRAY SANDY CLAY</u> Saturated, v-fine sand.		Stopped boring at 53.2' grouted from 53.2 to grade with approximately 60 gallons of quick grout.

AMERICAN ELECTRIC POWER SERVICE CORPORATION
AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER 3966
 COMPANY APPALACHIAN POWER COMPANY
 PROJECT Sporn fly ash pond dikes
 COORDINATES N 718,158.5 E 1,736,270.7
 GROUND ELEVATION 594.6 SYSTEM STATE PLANE

BORING NO. 96-02 DATE _____ SHEET 1 OF 2
 BORING START 06/13/96 BORING FINISH 06/13/96
 PIEZOMETER TYPE _____ WELL TYPE _____
 HGT. RISER ABOVE GROUND _____ DIA _____
 DEPTH TO TOP OF WELL SCREEN _____ BOTTOM _____
 WELL DEVELOPMENT _____ BACKFILL QUICK GROUT
 FIELD PARTY MCR-WEB RIG BK-81

WATER LEVEL	▽	▽	▽
TIME			
DATE			

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD %	DEPTH IN FEET	GRAPH LOG	S U C S S	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO									
1	SS	0.0	1.5	10-12-13	1.2					GRAY BOTTOM ASH Dry, with 2 to 3" of sandy clay.		
2	SS	3.0	4.5	10-13-13	1.5					GRAY BOTTOM ASH Dry.		
3	SS	5.0	6.5	9-8-7	1.3		5		CL	LIGHT BROWN CLAY Dry, medium to high plasticity.		
4	SS	8.5	10.0	16-16-12	1.1		10		GP	DARK BROWN SAND AND GRAVEL Dry, 3/4" max size, rounded with some fines.		
5	SS	11.9	13.4	8-10-8	1.4		15					
6	SS	16.9	18.4	6-11-9	1.3		20			DARK BROWN SAND AND GRAVEL Moist, quartz, 1/2" max size, rounded with some fines.		
7	SS	21.9	23.4	7-7-7	1.3		25			DARK BROWN SAND AND GRAVEL Saturated, rounded, 1" max size, quartz with some fines.		
8	SS	26.9	28.4	1-1-2	1.5		30			DARK GRAY FLY ASH Saturated.		
9	SS	31.9	33.4	1-1-1	1.5		35					
10	SS	36.9	38.4	1-1-1	1.5		40					
11	SS	41.9	43.4	4-4-6	1.3		45		CL	DARK GRAY CLAY Wet, medium to high plasticity, trace of organic material.		
12	ST	43.9	45.9		1.0							
13	ST	46.9	48.9		2.0							

TYPE OF CASING USED		<i>Continued Next Page</i>	
<input checked="" type="checkbox"/>	NQ-2 ROCK CORE	PIEZOMETER TYPE: PT = OPEN TUBE POROUS TIP, SS = OPEN TUBE SLOTTED SCREEN, G = GEONOR, P = PNEUMATIC	
	6" x 3.25 HSA	WELL TYPE: OW = OPEN TUBE SLOTTED SCREEN, GM = GEOMON	
	9" x 6.25 HSA	RECORDER <u>WEB</u>	
	HW CASING ADVANCER 4"		
	NW CASING 3"		
	SW CASING 6"		

AMERICAN ELECTRIC POWER SERVICE CORPORATION
 AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER 3966

COMPANY APPALACHIAN POWER COMPANY

BORING NO. 96-02 DATE _____ SHEET 2 OF 2

PROJECT Sporn fly ash pond dikes

BORING START 06/13/96 BORING FINISH 06/13/96

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD	DEPTH IN FEET	GRAPH LOG	S C S U	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO			%						
14	SS	51.9	53.4	3-3-4	1.5		55					
15	SS	56.9	58.4	1-3-4	1.5							Grouted hole from 58.4' to grade with approximately 75 gallons of quick grout.

AMERICAN ELECTRIC POWER SERVICE CORPORATION
 AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER 3966
 COMPANY APPALACHIAN POWER COMPANY
 PROJECT Sporn fly ash pond dikes
 COORDINATES N 718,215.9 E 1,736,382.8
 GROUND ELEVATION 566.9 SYSTEM STATE PLANE

BORING NO. 96-03 DATE _____ SHEET 1 OF 2
 BORING START 06/17/96 BORING FINISH 06/18/96
 PIEZOMETER TYPE _____ WELL TYPE _____
 HGT. RISER ABOVE GROUND _____ DIA _____
 DEPTH TO TOP OF WELL SCREEN _____ BOTTOM _____
 WELL DEVELOPMENT _____ BACKFILL QUICK GROUT
 FIELD PARTY MCR-WEB RIG BK-81

WATER LEVEL	▽ 22.2	▽	▽
TIME			
DATE	6-18-96		

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD %	DEPTH IN FEET	GRAPH LOG	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO								
1	SS	0.0	1.5	1-2-4	1.3				GRAY FLY ASH Moist.		
2	SS	3.0	4.5	6-5-4	1.5				GRAY BOTTOM ASH Moist.		
3	SS	5.0	6.5	3-2-2	1.5		5				
4	SS	8.5	10.0	4-6-6	1.5		10		BLACK COAL		
5	SS	11.7	13.2	4-3-3	1.5		10	SC	LIGHT BROWN SANDY CLAY Dry to moist, v-fine grain sand.		
6	SS	16.7	18.2	7-1-1	1.5		15	CL	DARK GRAY CLAY Wet, medium to high plasticity, trace of organic material.		
7	ST	21.7	23.7		2.0		20				
8	SS	26.7	28.2	1-1-1	1.5		25				
9	ST	31.7	33.7		2.0		30				
10	SS	36.7	38.2	1-2-2	1.5		35				
11	SS	41.7	43.2	7-14-19	.6		40	SP	DARK GRAY AND BROWN SILTY SAND Wet to saturated, quartz, fine grain.		
12	SS	46.7	47.6	37-50/4	.9		45	GW	GRAY SAND AND GRAVEL Saturated, quartz, 1/2" max size, rounded.		
									Brown		

TYPE OF CASING USED			Continued Next Page		
X	NQ-2 ROCK CORE	6" x 3.25 HSA	PIEZOMETER TYPE: PT = OPEN TUBE POROUS TIP, SS = OPEN TUBE SLOTTED SCREEN, G = GEONOR, P = PNEUMATIC		
	HW CASING ADVANCER	4"	WELL TYPE: OW = OPEN TUBE SLOTTED SCREEN, GM = GEOMON		
	NW CASING	3"	RECORDER <u>WEB</u>		
	SW CASING	6"			

AMERICAN ELECTRIC POWER SERVICE CORPORATION
 AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER 3966

COMPANY APPALACHIAN POWER COMPANY

BORING NO. 96-03 DATE _____ SHEET 2 OF 2

PROJECT Sporn fly ash pond dikes

BORING START 06/17/96 BORING FINISH 06/18/96

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD	DEPTH IN FEET	GRAPH LOG	U S C S	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO			%						
13	SS	51.7	53.2	18-19-20	1.5		55			Same with 3/4" max size.		
14	SS	56.7	57.0	50/3	.3		60			Brown		
15	SS	59.8	60.0	50/2	.2					LIGHT GRAY SANDSTONE Fine grain.		

AMERICAN ELECTRIC POWER SERVICE CORPORATION
 AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER 3966
 COMPANY APPALACHIAN POWER COMPANY
 PROJECT Sporn fly ash pond dikes
 COORDINATES N 717,954.5 E 1,735,752.5
 GROUND ELEVATION 593.5 SYSTEM STATE PLANE

BORING NO. 96-04 DATE _____ SHEET 1 OF 2
 BORING START 06/18/96 BORING FINISH 06/19/96
 PIEZOMETER TYPE _____ WELL TYPE _____
 HGT. RISER ABOVE GROUND _____ DIA _____
 DEPTH TO TOP OF WELL SCREEN _____ BOTTOM _____
 WELL DEVELOPMENT _____ BACKFILL QUICK GROUT
 FIELD PARTY MCR-WEB RIG BK-81

WATER LEVEL	▽	▽	▽
TIME			
DATE			

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD %	DEPTH IN FEET	GRAPH LOG	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO								
		0.0							ROAD BASE		
2	SS	3.0	4.5	11-12-13	1.3		5	SC	DARK BROWN CLAYEY SAND Moist, trace of small gravel.		
3	SS	5.0	6.5	11-19-16	1.5			SP	DARK BROWN GRAVELLY SAND Moist, 1/2" max size, rounded with fines.		
4	SS	8.5	10.0	9-12-10	1.5		10				
5	SS	11.6	13.1	16-22-17	1.5		15		BLACK BOTTOM ASH Moist with 1" layer of silty clay with slight plasticity.		
6	SS	16.6	18.1	9-9-7	.4		20		DARK BROWN, BLACK CLAYEY SAND Moist, some organic, may be older road base.		
7	SS	21.6	23.1	5-5-6	1.5		25		BLACK BOTTOM ASH Saturated. BLACK FLY ASH Saturated.		
8	SS	26.6	28.1	1-2-2	1.2		30				
9	SS	31.6	33.1	1-1-1	1.5		35				
10	SS	36.6	38.1	2-3-3	1.5		40	CL	ORANGE AND LIGHT BROWN MOTTLED SILTY CLAY Wet to saturated, medium to low plasticity.		
11	SS	41.6	43.1	3-3-3	1.5		45		Same as sample with trace of organic material.		
12	ST	46.6	48.6		2.0						

TYPE OF CASING USED				Continued Next Page			
X	NQ-2 ROCK CORE			PIEZOMETER TYPE: PT = OPEN TUBE POROUS TIP, SS = OPEN TUBE SLOTTED SCREEN, G = GEONOR, P = PNEUMATIC			
	6" x 3.25 HSA			WELL TYPE: OW = OPEN TUBE SLOTTED SCREEN, GM = GEOMON			
	9" x 6.25 HSA			RECORDER <u>WEB</u>			
	HW CASING ADVANCER	4"					
	NW CASING	3"					
	SW CASING	6"					

AMERICAN ELECTRIC POWER SERVICE CORPORATION
 AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER 3966

COMPANY APPALACHIAN POWER COMPANY

BORING NO. 96-04 DATE _____ SHEET 2 OF 2

PROJECT Sporn fly ash pond dikes

BORING START 06/18/96 BORING FINISH 06/19/96

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD %	DEPTH IN FEET	GRAPH LOG	S C S J	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO									
13	SS	51.6	53.1	1-1-1	1.5		55		SC	<u>GRAY AND BROWN CLAYEY SAND</u> Wet to saturated, v-fine grain sand, slight to non plasticity.		
14	SS	59.3	60.8	3-3-3	.8		60		SP	<u>DARK BROWN SAND</u> Saturated, fine grain, with some fines, quartz.		
15	SS	64.3	65.8	15-16-2	1.5		65			<u>DARK BROWN SAND</u> Saturated, v-fine grain with some fines, quartz.		
16	SS	69.3	70.8	8-9-11	1.5		70		SW	<u>DARK BROWN SAND</u> Saturated, quartz.		
17	SS	74.3	75.8	14-14-19	1.5		75					
18	SS	79.3	80.8	8-10-8	1.5		80		SP	<u>DARK BROWN AND GRAY SAND</u> Saturated, quartz, fine grain.		
19	SS	84.3	85.1	8-50/3	.8		85		GW	<u>BROWN SAND AND GRAVEL</u> Saturated, quartz, 1/2" max size, rounded.		
20	SS	87.7	87.9	50/2	.2					<u>GRAY CLAY SHALE</u> Dry.		

AMERICAN ELECTRIC POWER SERVICE CORPORATION
 AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER 3966
 COMPANY APPALACHIAN POWER COMPANY
 PROJECT Sporn fly ash pond dikes
 COORDINATES N 718,463.6 E 1,736,113.5
 GROUND ELEVATION 597.4 SYSTEM STATE PLANE

BORING NO. 96-05 DATE _____ SHEET 1 OF 2
 BORING START 06/12/96 BORING FINISH 06/12/96
 PIEZOMETER TYPE _____ WELL TYPE _____
 HGT. RISER ABOVE GROUND _____ DIA _____
 DEPTH TO TOP OF WELL SCREEN _____ BOTTOM _____
 WELL DEVELOPMENT _____ BACKFILL QUICK GROUT
 FIELD PARTY MCR-WEB RIG BK-81

WATER LEVEL	▽ 48.8	▽	▽
TIME			
DATE	6-12-96		

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD %	DEPTH IN FEET	GRAPH LOG	S U C S J	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO									
1	SS	0.0	1.5	14-22-35	1.0					GRAY BOTTOM ASH		
2	SS	3.0	4.5	11-12-15	1.2		5		SP	DARK BROWN GRAVELLY SAND Moist, 1/2" max size, some fines.		
3	SS	5.0	6.5	10-10-15	1.3				SM	BROWN CLAYEY SILT Moist, slight to non plasticity.		
5	SS	8.5	10.0	8-13-15	1.5		10		SC	LIGHT BROWN SILTY SAND Dry, v-fine grain. LIGHT AND DARK BROWN CLAYEY SAND Moist, trace of small gravel.		
6	SS	11.7	13.2	11-11-13	1.2		15		GP	DARK BROWN CLAYEY SAND AND GRAVEL Moist, quartz, 3/4" max size, rounded.		
7	SS	16.7	18.2	3-2-4	1.5		20		SM CL	LIGHT BROWN SILTY SAND Moist, v-fine grain sand. DARK GRAY SILTY CLAY Wet, medium to low plasticity, trace of organic material.		
8	SS	21.7	23.2	3-4-6	1.5		25		CL	LIGHT BROWN CLAYEY SILTY Moist to wet, slight plasticity.		
9	SS	26.7	28.2	2-2-1	1.1		30			GRAY BOTTOM ASH Saturated.		
10	SS	31.7	33.2	1-2-2	1.3		35		CL	DARK GRAY CLAY Wet to saturated, medium to low plasticity, trace of organic.		
11	SS	36.7	38.2	1-1-1	1.5		40			GRAY FLY ASH Saturated.		
12	SS	41.7	43.2	1-1-1	1.5		45		CL	DARK GRAY SILTY CLAY Moist, low to medium plasticity, trace of organic material.		
13	SS	46.7	48.2	1-1-2	1.5					BROWN CLAY Wet to saturated, medium to low plasticity.	▽	

TYPE OF CASING USED				Continued Next Page			
	NQ-2 ROCK CORE			PIEZOMETER TYPE: PT = OPEN TUBE POROUS TIP, SS = OPEN TUBE SLOTTED SCREEN, G = GEONOR, P = PNEUMATIC			
X	6" x 3.25 HSA			WELL TYPE: OW = OPEN TUBE SLOTTED SCREEN, GM = GEOMON			
	9" x 6.25 HSA			RECORDER <u>WEB</u>			
	HW CASING ADVANCER	4"					
	NW CASING	3"					
	SW CASING	6"					

AMERICAN ELECTRIC POWER SERVICE CORPORATION
 AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER 3966

COMPANY APPALACHIAN POWER COMPANY

BORING NO. 96-05 DATE _____ SHEET 2 OF 2

PROJECT Sporn fly ash pond dikes

BORING START 06/12/96 BORING FINISH 06/12/96

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD %	DEPTH IN FEET	GRAPH LOG	S U S S	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO									
14	ST	51.7	53.7		2.0		55					
15	SS	56.7	58.2	2-2-3	1.5					<u>DARK GRAY SILTY CLAY</u> Wet to saturated, low to medium plasticity, trace of v-fine grain sand lens.		Boring grouted from grade to 58 2'

AMERICAN ELECTRIC POWER SERVICE CORPORATION
 AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER 3966
 COMPANY APPALACHIAN POWER COMPANY
 PROJECT Sporn fly ash pond dikes
 COORDINATES N 718,519.1 E 1,736,243.1
 GROUND ELEVATION 566.1 SYSTEM STATE PLANE

BORING NO. 96-06 DATE _____ SHEET 1 OF 1
 BORING START 06/18/96 BORING FINISH 06/18/96
 PIEZOMETER TYPE _____ WELL TYPE _____
 HGT. RISER ABOVE GROUND _____ DIA _____
 DEPTH TO TOP OF WELL SCREEN _____ BOTTOM _____
 WELL DEVELOPMENT _____ BACKFILL QUICK GROUT
 FIELD PARTY MCR-WEB RIG BK-81

WATER LEVEL	▽ 23.6	▽	▽
TIME			
DATE	6-18-96		

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD %	DEPTH IN FEET	GRAPH LOG	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO								
1	SS	0.0	1.5	1-1-4	1.5				GRAY FLY ASH Moist.		
2	SS	3.0	4.5	5-6-4	1.5						
3	SS	5.0	6.5	3-3-2	1.5		5		GRAY BOTTOM ASH Saturated.		
4	SS	8.5	10.0	5-5-6	1.5		10	CL	BROWN SILTY CLAY Moist, low to medium plasticity (DIKE MATERIAL). DARK BROWN SILTY CLAY Saturated, medium to low plasticity, (DIKE MATERIAL).		
5	SS	11.5	13.0	3-4-2	1.5		15				
6	SS	16.5	18.0	4-4-3	1.5		20	SM	GRAY SILTY SAND Saturated, v-fine grain, quartz.		
7	SS	21.5	23.0	1-1-2	1.3		25				
8	SS	26.5	28.0	1-1-1	1.5		30	CL	DARK GRAY CLAY Saturated, medium to low plasticity with v-fine grain sand lens.		
9	SS	31.5	33.0	2-3-3	1.5						

TYPE OF CASING USED							
<input checked="" type="checkbox"/>	NQ-2 ROCK CORE			PIEZOMETER TYPE: PT = OPEN TUBE POROUS TIP, SS = OPEN TUBE SLOTTED SCREEN, G = GEONOR, P = PNEUMATIC			
	6" x 3.25 HSA			WELL TYPE: OW = OPEN TUBE SLOTTED SCREEN, GM = GEOMON			
	9" x 6.25 HSA			RECORDER <u>WEB</u>			
	HW CASING ADVANCER 4"						
	NW CASING 3"						
	SW CASING 6"						

FIELD DATA FROM:
***“PHILIP SPORN ELECTRIC GENERATING PLANT UNIT 5 ASH
FACILITY – ENGINEERING REPORT”***

PREPARED/COMPILED BY:
**THE GEOTECHNICAL ENGINEERING SECTION OF AMERICAN
ELECTRIC POWER SERVICE CORPORATION**

DATED: JULY 1998

AMERICAN ELECTRIC POWER SERVICE CORPORATION
AEP CIVIL ENGINEERING LABORATORY
LOG OF BORING



JOB NUMBER 3966
 COMPANY APPALACHIAN POWER COMPANY
 PROJECT Sporn fly ash pond dikes
 COORDINATES N 720,983.0 E 1,734,516.1
 GROUND ELEVATION 619.0 SYSTEM STATE PLANE

BORING NO. 96-101 DATE _____ SHEET 1 OF 2
 BORING START 06/05/96 BORING FINISH 06/05/96
 PIEZOMETER TYPE SS WELL TYPE _____
 HGT. RISER ABOVE GROUND _____ DIA _____
 DEPTH TO TOP OF WELL SCREEN 24.4 BOTTOM 33.4
 WELL DEVELOPMENT NO BACKFILL QUICK GROUT
 FIELD PARTY MCR-REB RIG BK-81

WATER LEVEL	▽	▽	▽
TIME			
DATE			

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD %	DEPTH IN FEET	GRAPH LOG	S S C S J	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO									
1		0.0			0					No sample taken boring in road way		
2	SS	3.0	4.5	12-13-16	1.1		5		SM	BROWN SILTY GRAVELLY SAND Dry to moist, 1/2" max size, rounded, quartz.		
3	SS	5.0	6.5	7-9-9	1.2							
3	SS	8.5	10.0	3-4-5	1.2		10		SC	BROWN CLAYEY SAND Moist, fine grain with trace of gravel.		
4	SS	11.5	13.0	17-27-38	1.2				SM	BROWN SILTY GRAVELLY SAND Moist, fine grain, trace of gravel, quartz.		
5	SS	16.5	18.0	12-19-26	1.1		15					
6	SS	21.5	23.0	16-21-27	1.1		20		SW	BROWN GRAVELLY SAND Moist, trace of small gravel, quartz, rounded.		20.0 Top of seal.
												22.0 Top of sand.
							25					24.4 Top of screen.
7	SS	26.5	28.0	12-20-23	1.2				GP	BROWN SAND AND GRAVEL Moist to wet, quartz, rounded, 3/4" max size, some fines.		
8	SS	31.5	33.0	4-5-7	1.1		30		SM	BROWN SILTY SAND Moist, 100% fine grain.		
9	ST	33.5	35.5		1.6		35		CL	Push 2.0 Time 5 sec. PSI 800 Top of sample, BROWN SILTY SAND Bottom of sample, LIGHT GRAY CLAY Moist, low to medium plasticity.		34.0 Bottom of pipe.
10	SS	36.5	38.0	4-6-8	1.1							34.4 Bottom of screen. 5B 4 1/4
												35.0 Bottom of sand.
11	SS	41.5	43.0	4-5-6	1.1		40		SM	DARK GRAY SILTY SAND Wet, non to slight plasticity, with reddish brown quartz sand lens.		
12	ST	43.5	45.5		1.5		45		ML	PUSH 2.0 TIME 5 SEC		
13	SS	46.5	48.0	7-9-11	1.1				SP	PSI 800 Bottom of sample, Drillers identification fly ash I believe it is a light gray clay		

TYPE OF CASING USED

	NQ-2 ROCK CORE
X	6" x 3.25 HSA
	9" x 6.25 HSA
	HW CASING ADVANCER 4"
	NW CASING 3"

Continued Next Page

PIEZOMETER TYPE: PT = OPEN TUBE POROUS TIP, SS = OPEN TUBE SLOTTED SCREEN, G = GEONOR, P = PNEUMATIC

WELL TYPE: OW = OPEN TUBE SLOTTED SCREEN, GM = GEOMON

RECORDER REB

AMERICAN ELECTRIC POWER SERVICE CORPORATION
 AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER 3966

COMPANY APPALACHIAN POWER COMPANY

BORING NO. 96-101 DATE _____ SHEET 2 OF 2

PROJECT Sporn fly ash pond dikes

BORING START 06/05/96 BORING FINISH 06/05/96

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD	DEPTH IN FEET	GRAPH LOG	S	C	S	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO			%								
												<p>????????????????????????????????????</p> <p>Top of sample, BROWN SILTY</p> <p>BROWN GRAVELLY SAND Moist, 1/2" max size, rounded, quartz.</p>		

AMERICAN ELECTRIC POWER SERVICE CORPORATION
 AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER 3966
 COMPANY APPALACHIAN POWER COMPANY
 PROJECT Sporn fly ash pond dikes
 COORDINATES N 720,707.5 E 1,734,001.7
 GROUND ELEVATION 619.6 SYSTEM STATE PLANE

BORING NO. 96-102 DATE _____ SHEET 1 OF 1
 BORING START 06/05/96 BORING FINISH 06/05/96
 PIEZOMETER TYPE _____ WELL TYPE _____
 HGT. RISER ABOVE GROUND _____ DIA _____
 DEPTH TO TOP OF WELL SCREEN _____ BOTTOM _____
 WELL DEVELOPMENT _____ BACKFILL QUICK GROUT
 FIELD PARTY MCR-REB RIG BK-81

WATER LEVEL	▽	▽	▽
TIME			
DATE			

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD %	DEPTH IN FEET	GRAPH LOG	S	SOIL / ROCK IDENTIFICATION	ITEM	DRILLER'S NOTES
		FROM	TO									
1		0.0			0					NO SAMPLE TAKEN BORING IN ROAD AUGER CUTTINGS INDICATE BROWN SAND AND GRAVEL		Boring was grouted from grade to 48.2' with quick grout.
2	SS	3.0	4.5	12-16-19	1.1		5		SP	BROWN GRAVELLY SAND Moist, 1/2" max size, rounder, quartz with fines.		
3	SS	5.0	6.5	17-21-26	1.2							
4	SS	8.5	10.0	13-16-19	1.2		10					
5	SS	11.7	13.2	15-28-32	1.2		15					
6	SS	16.7	18.2	17-21-26	1.2		20					
7	SS	21.7	23.2	19-21-24	1.1		25			Sample moist to wet.		
8	SS	26.7	28.2	9-9-11	1.1		30		SM	DARK BROWN SANDY SILT Moist, non-plastic.		
9	SS	31.7	33.2	3-4-5	1.1		35		SC	BROWN SANDY CLAY Moist, low plasticity, with v-fine sand lens. Time 5 sec. Push 2.0 PSI 1000		
10	ST	33.7	35.7		?							
11	SS	36.7	38.2	4-4-5	1.1		40		SM	BROWN SILTY SAND Moist, with very fine sand lens.		
12	SS	41.7	43.2	3-5-8	1.1		45		SP	BROWN GRAVELLY SAND Moist, 3/4" max size, rounded, quartz.		
13	SS	46.7	48.2	13-15-21	1.2							

TYPE OF CASING USED			PIEZOMETER TYPE: PT = OPEN TUBE POROUS TIP, SS = OPEN TUBE SLOTTED SCREEN, G = GEONOR, P = PNEUMATIC WELL TYPE: OW = OPEN TUBE SLOTTED SCREEN, GM = GEOMON RECORDER <u>REB</u>
X	NQ-2 ROCK CORE		
	6" x 3.25 HSA		
	9" x 6.25 HSA		
	HW CASING ADVANCER 4"		
	NW CASING 3"		
	SW CASING 6"		

AMERICAN ELECTRIC POWER SERVICE CORPORATION
AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER 3966
 COMPANY APPALACHIAN POWER COMPANY
 PROJECT Sporn fly ash pond dikes
 COORDINATES N 719,785.3 E 1,734,133.3
 GROUND ELEVATION 618.0 SYSTEM STATE PLANE

BORING NO. 96-103 DATE _____ SHEET 1 OF 1
 BORING START 06/04/96 BORING FINISH 06/04/96
 PIEZOMETER TYPE _____ WELL TYPE _____
 HGT. RISER ABOVE GROUND _____ DIA _____
 DEPTH TO TOP OF WELL SCREEN _____ BOTTOM _____
 WELL DEVELOPMENT _____ BACKFILL **QUICK GROUT**
 FIELD PARTY MCR-REB RIG BK-81

WATER LEVEL	▽	▽	▽
TIME			
DATE			

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH LOG CORRECTION	RQD %	DEPTH IN FEET	GRAPH LOG	USCS	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO									
1		0.0			0							Boring grouted from grade to 48.1 w\ 60 gallons of quick grout.
2	SS	3.0	4.5	12-19-24	1.1			SP		NO SAMPLE TAKEN BORING LOCATED IN ROAD CUTTINGS INDICATE BROWN SAND AND GRAVEL DARK BROWN GRAVELLY SAND Moist, rounded, quartz, with fines, 3/4" max size.		
3	SS	5.0	6.5	14-17-19	1.2							
4	SS	8.5	10.0	17-21-25	1.1							
5	SS	11.6	13.1	19-25-28	1.1							
6	SS	16.6	18.1	12-19-25	1.2							
7	SS	21.6	23.1	5-14-21	1.1							
8	SS	26.6	28.1	11-17-28	1.2							
9	SS	31.6	33.1	8-9-10	1.1			CL		BROWN SILTY CLAY Moist, with fine grain sand lens, low plasticity.		
10	ST	36.6	38.6		1.6			SP		time 5 sec. Push 2.0 PSI 700 LIGHT BROWN SAND Fine grain. BROWN SAND Moist, 100% fine grain, with fines.		
11	SS	41.6	43.1	4-5-6	1.1							
12	SS	46.6	48.1	6-6-5	?							

TYPE OF CASING USED		PIEZOMETER TYPE: PT = OPEN TUBE POROUS TIP, SS = OPEN TUBE SLOTTED SCREEN, G = GEONOR, P = PNEUMATIC WELL TYPE: OW = OPEN TUBE SLOTTED SCREEN, GM = GEOMON
X	NQ-2 ROCK CORE	
	6" x 3.25 HSA	
	9" x 6.25 HSA	
	HW CASING ADVANCER 4"	RECORDER REB
	NW CASING 3"	

AMERICAN ELECTRIC POWER SERVICE CORPORATION
AEP CIVIL ENGINEERING LABORATORY
LOG OF BORING



JOB NUMBER 3966
 COMPANY APPALACHIAN POWER COMPANY
 PROJECT Sporn fly ash pond dikes
 COORDINATES N 719,229.2 E 1,734,600.2
 GROUND ELEVATION 618.7 SYSTEM STATE PLANE

BORING NO. 96-104 DATE _____ SHEET 1 OF 2
 BORING START 06/04/96 BORING FINISH 06/04/96
 PIEZOMETER TYPE SS WELL TYPE _____
 HGT. RISER ABOVE GROUND _____ DIA _____
 DEPTH TO TOP OF WELL SCREEN 24.1 BOTTOM 33.1
 WELL DEVELOPMENT NO BACKFILL QUICK GROUT
 FIELD PARTY MCR-REB RIG BK-81

WATER LEVEL			
TIME			
DATE			

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD %	DEPTH IN FEET	GRAPH LOG	S C S U	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO									
1	SS	0.0		2-4-8	1.1				CL			
2	SS	3.0	4.5	9-14-18	1.2							
3	SS	5.0	6.5	73	1.1		5		SP GW	DARK BROWN CLAY Moist, medium to high plasticity trace of sand. BROWN GRAVELLY SAND Dry, quartz, 1/2" max, rounded.		
4	SS	8.5	10.0	9-18-25	1.2		10			DARK BROWN SAND AND GRAVEL Dry, quartz, 1/2" max, rounded. Same as above some fines, moist		
5	SS	11.7	13.2	19-26-31	1.2		15		SP	DARK BROWN GRAVELLY SAND Dry, 3/4" max, rounded, quartz.		
6	SS	16.7	18.2	18-21-26	1.2		20		SC	DARK BROWN CLAYEY SAND Moist, trace of gravel.		20.4 Top seal.
7	SS	21.7	23.2	17-21-25	1.2		25		SP	LIGHT BROWN GRAVELLY SAND Dry, quartz, 3/4" max, rounded.		22.5 Top of sand. 24.1 Top of screen.
8	SS	26.7	28.2	4-6-8	1.1		30		CL	LIGHT BROWN SILTY CLAY Moist, low to medium plasticity.		
9	ST	31.7	33.7		1.6		35			PUSH 2.0 PSI 900 TIME 6 SEC. BROWN CLAYEY SAND Fine grain? LIGHT BROWN SILTY CLAY Moist, low to medium plasticity.		33.1 Bottom of screen. 34.7 Bottom of sand.
10	SS	36.7	38.2	3-3-5	1.2		40					
11	SS	41.7	43.2	4-4-7	1.1		45		SM	LIGHT BROWN SILTY SAND Moist. v-fine grain 100%.		
12	ST	46.7	48.7		1.5					PUSH 2.0 PSI 1200 TIME 6 SEC.		

TYPE OF CASING USED		<i>Continued Next Page</i>	
X	NQ-2 ROCK CORE	PIEZOMETER TYPE: PT = OPEN TUBE POROUS TIP, SS = OPEN TUBE SLOTTED SCREEN, G = GEONOR, P = PNEUMATIC	
	6" x 3.25 HSA	WELL TYPE: OW = OPEN TUBE SLOTTED SCREEN, GM = GEOMON	
	9" x 6.25 HSA		
	HW CASING ADVANCER 4"		
	NW CASING 3"		

RECORDER **RFR**

AMERICAN ELECTRIC POWER SERVICE CORPORATION
 AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER 3966

COMPANY APPALACHIAN POWER COMPANY

BORING NO. 96-104 DATE _____ SHEET 2 OF 2

PROJECT Sporn fly ash pond dikes

BORING START 06/04/96 BORING FINISH 06/04/96

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD	DEPTH IN FEET	GRAPH LOG	U S C S	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO			%						
										DARK BROWN SANDY CLAY Fine grain.		

AMERICAN ELECTRIC POWER SERVICE CORPORATION
 AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER 3966
 COMPANY APPALACHIAN POWER COMPANY
 PROJECT Sporn fly ash pond dikes
 COORDINATES N 718,782.8 E 1,735,084.7
 GROUND ELEVATION 619.3 SYSTEM STATE PLANE

BORING NO. 96-105 DATE SHEET 1 OF 1
 BORING START 06/03/96 BORING FINISH 06/03/96
 PIEZOMETER TYPE WELL TYPE
 HGT. RISER ABOVE GROUND DIA
 DEPTH TO TOP OF WELL SCREEN BOTTOM
 WELL DEVELOPMENT BACKFILL QUICK GROUT
 FIELD PARTY MCR-REB RIG BK-81

WATER LEVEL			
TIME			
DATE			

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD %	DEPTH IN FEET	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO							
								No sample taken. Boring located in road bed. Auger cuttings sand and gravel.		Boring grouted from grade to 48.5' with 75 gallons of quick grout
1	SS	3.0	4.5	7-10-11	1.1		SW	BROWN SAND Dry, quartz, rounded with trace of gravel. BROWN GRAVELLY SAND Dry quartz, rounded, 1/2" max size. 3/4" max size trace of fines.		
2	SS	5.0	6.5	12-16-21	1.2	5				
3	SS	8.5	10.0	9-15-17	1.2	10				
4	SS	11.5	13.0	9-16-19	1.1	15				
5	SS	16.5	18.0	9-14-17	1.2	20		Moist		
6	SS	21.5	23.0	7-9-14	1.1	25	SM	DARK BROWN SILTY SAND Moist, with trace of small gravel.		
7	SS	26.5	28.0	5-6-7	1.2	30	CL	BROWN SILTY CLAY Moist, low to medium plasticity.		
8	ST	31.5	33.5		1.7	35		PUSH 2.0 PSI 700 TIME 8 SEC.		
9	SS	36.5	38.0	3-3-5	1.1	40				
10	SS	41.5	43.0	4-4-5	1.2	45	SP SC	LIGHT BROWN CLAYEY SAND Moist, 100% v-fine grain.		
11	ST	46.5	48.0		1.8			TIME 5 SEC PSI 800 PUSH 2.0		

TYPE OF CASING USED		
<input checked="" type="checkbox"/>	NQ-2 ROCK CORE	PIEZOMETER TYPE: PT = OPEN TUBE POROUS TIP, SS = OPEN TUBE SLOTTED SCREEN, G = GEONOR, P = PNEUMATIC WELL TYPE: OW = OPEN TUBE SLOTTED SCREEN, GM = GEOMON
	6" x 3.25 HSA	
	9" x 6.25 HSA	
	HW CASING ADVANCER 4"	
	NW CASING 3"	RECORDER REB

AMERICAN ELECTRIC POWER SERVICE CORPORATION
 AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER 3966
 COMPANY APPALACHIAN POWER COMPANY
 PROJECT Sporn fly ash pond dikes
 COORDINATES N 719,271.8 E 1,735,858.4
 GROUND ELEVATION 618.9 SYSTEM STATE PLANE

BORING NO. 96-106 DATE _____ SHEET 1 OF 2
 BORING START 05/28/96 BORING FINISH 05/28/96
 PIEZOMETER TYPE _____ WELL TYPE _____
 HGT. RISER ABOVE GROUND _____ DIA _____
 DEPTH TO TOP OF WELL SCREEN _____ BOTTOM _____
 WELL DEVELOPMENT _____ BACKFILL QUICK GROUT
 FIELD PARTY MCR-REB RIG BK-81

WATER LEVEL	▽ 60.2	▽	▽
TIME			
DATE	5-28-96		

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY %	RQD %	DEPTH IN FEET	GRAPH LOG	USCS	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO									
										NO SAMPLE TAKEN BORING IN ROAD BED.		
1	SS	3.0	4.5	15-17-21	1.1		5		GP	DARK BROWN SAND AND GRAVEL Moist, 1/2" max, rounded, quartz, some fines. 1" max size		
2	SS	5.0	6.5	17-24-30	1.1					1/2" max size		
3	SS	8.5	10.0	13-17-20	1.2		10			1/2" max size		
4	SS	11.5	13.0	11-11-14	1.2		15			1/2" max size		
5	SS	16.5	18.0	13-15-17	1.1		20					
6	SS	21.5	23.0	6-8-10	1.2		25		SC	BROWN SANDY CLAY Dry, slight to low plasticity.		
7	SS	26.5	28.0	4-6-6	1.2		30			GRAY FLY ASH Dry.		
8	SS	31.5	33.0	1-1-1	1.2		35			Saturated		
9	SS	36.5	38.0	1-1-1	1.2		40					
10	SS	41.5	43.0	1-1-1	1.2		45					
11	SS	46.5	48.0	3-2-2	1.1							

TYPE OF CASING USED				<i>Continued Next Page</i>			
X	NQ-2 ROCK CORE	PIEZOMETER TYPE: PT = OPEN TUBE POROUS TIP, SS = OPEN TUBE SLOTTED SCREEN, G = GEONOR, P = PNEUMATIC					
	6" x 3.25 HSA	WELL TYPE: OW = OPEN TUBE SLOTTED SCREEN, GM = GEOMON					
	9" x 6.25 HSA						
	HW CASING ADVANCER 4"						
	NW CASING 3"						

AMERICAN ELECTRIC POWER SERVICE CORPORATION
 AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER 3966

COMPANY APPALACHIAN POWER COMPANY

BORING NO. 96-106 DATE _____ SHEET 2 OF 2

PROJECT Sporn fly ash pond dikes

BORING START 05/28/96 BORING FINISH 05/28/96

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD %	DEPTH IN FEET	GRAPH LOG	S C U	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO									
12	SS	51.5	53.0	2-2-2	1.2		55					
13	SS	56.5	58.0	3-4-4	1.2		55		CL	<u>DARK GRAY SILTY CLAY</u> Wet, low to medium plasticity, trace of organic material.		
14	ST	61.5	63.5		1.6		60			<u>Time 7 sec.</u> <u>Push 2.0</u> <u>PSI 600</u>		
15	SS	66.5	68.0	3-4-5	1.2		65			<u>BROWN SILTY CLAY</u> Trace of fine sand. <u>BROWN CLAY</u> Wet, medium to high plasticity.		
												Boring grouted from 68.0' to grade with 125 gallons quick grout.

AMERICAN ELECTRIC POWER SERVICE CORPORATION
 AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER 3966
 COMPANY APPALACHIAN POWER COMPANY
 PROJECT Sporn fly ash pond dikes
 COORDINATES N 719,691.4 E 1,736,040.0
 GROUND ELEVATION 618.8 SYSTEM STATE PLANE

BORING NO. 96-107 DATE _____ SHEET 1 OF 2
 BORING START 05/29/96 BORING FINISH 05/29/96
 PIEZOMETER TYPE _____ WELL TYPE _____
 HGT. RISER ABOVE GROUND _____ DIA _____
 DEPTH TO TOP OF WELL SCREEN _____ BOTTOM _____
 WELL DEVELOPMENT _____ BACKFILL QUICK GROUT
 FIELD PARTY MCR-REB RIG BK-81

WATER LEVEL	∇ 39.1	∇	∇
TIME			
DATE	5-29-96		

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY %	RQD %	DEPTH IN FEET	GRAPH LOG	S U C S	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO									
1	SS	3.0	4.5	14-17-21	1.1		5			NO SAMPLE TAKEN BORING IN ROAD BED, AUGER CUTTINGS INDICATE BROWN SAND AND GRAVEL BROWN SAND AND GRAVEL Moist, quartz, rounded, some fine 3/4' max size.	Boring was grouted from 73.1 to grade w/approximately 100 gallons of quick grout.	
2	SS	5.0	6.5	17-21-28	1.2		5					
3	SS	8.5	10.0	14-18-24	1.1		10			1/2" max size		
4	SS	11.6	13.1	13-16-21	1.2		15					
5	SS	16.6	18.1	5-8-10	1.1		15	ML	BROWN SILT Moist, non to v-slight plasticity.			
6	SS	21.6	23.1	8-8-11	1.2		20	SM	Attempted shelly tube lifted rig BROWN SILT SAND Moist, 100% v-fine grain.			
7	SS	26.6	28.1	4-5-9	1.2		25		GRAY FLY ASH Moist.			
8	SS	31.6	33.1	5-8-11	1.2		30		Saturated			
9	SS	36.6	38.1	1-1-1	1.1		35					
10	SS	41.6	43.1	1-1-1	1.2		40					
11	SS	46.6	48.1	1-1-1	1.2		45					

TYPE OF CASING USED				Continued Next Page			
X	NQ-2 ROCK CORE	PIEZOMETER TYPE: PT = OPEN TUBE POROUS TIP, SS = OPEN TUBE SLOTTED SCREEN, G = GEONOR, P = PNEUMATIC					
	6" x 3.25 HSA	WELL TYPE: OW = OPEN TUBE SLOTTED SCREEN, GM = GEOMON					
	9" x 6.25 HSA						
	HW CASING ADVANCER 4"						
	NW CASING 3"						
RECORDER REB							

AMERICAN ELECTRIC POWER SERVICE CORPORATION
AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER 3966

COMPANY APPALACHIAN POWER COMPANY

BORING NO. 96-107 DATE _____ SHEET 2 OF 2

PROJECT Sporn fly ash pond dikes

BORING START 05/29/96 BORING FINISH 05/29/96

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD %	DEPTH IN FEET	GRAPH LOG	S U C S	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO									
12	SS	51.6	53.1	2-1-1	1.2		55	* * * * *				Weight of 140# hammer.
13	SS	56.6	58.1	0	1.3		60	* * * * *				
14	SS	61.6	63.1	4-7-10	1.2		65	* * * * *	CL	<u>DARK BROWN CLAY</u> Moist. medium to high plasticity.		
15	ST	66.6	68.6		1.5		70	* * * * *		<u>Push 2.0</u> <u>Time 5 sec.</u> <u>PSI 600</u> <u>BROWN CLAY</u>		
16	SS	71.6	73.1	4-6-7	1.2							

AMERICAN ELECTRIC POWER SERVICE CORPORATION
 AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER 3966
 COMPANY APPALACHIAN POWER COMPANY
 PROJECT Sporn fly ash pond dikes
 COORDINATES N 719,761.8 E 1,736,125.4
 GROUND ELEVATION 603.4 SYSTEM STATE PLANE

BORING NO. 96-108 DATE _____ SHEET 1 OF 2
 BORING START 06/11/96 BORING FINISH 06/11/96
 PIEZOMETER TYPE SS WELL TYPE _____
 HGT. RISER ABOVE GROUND _____ DIA _____
 DEPTH TO TOP OF WELL SCREEN 63.3 BOTTOM 72.3
 WELL DEVELOPMENT NO BACKFILL QUICK GROUT
 FIELD PARTY MCR-WEB RIG BK-81

WATER LEVEL	▽	▽	▽
TIME			
DATE			

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD %	DEPTH IN FEET	GRAPH LOG	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO								
									No sample road base		
1	SS	3.0	4.5	11-15-16	1.2		5		BLACK SAND AND BOTTOM ASH Moist.		
3	SS	5.0	6.5	12-17-21	1.5						
4	SS	8.5	10.0	12-16-29	.9		10	SC	DARK BROWN CLAYEY SAND Moist, with fine sand lens.		
5	SS	11.6	13.1	9-18-22	1.2		15	SP	DARK BROWN GRAVELLY SAND Moist, quartz, some fine, 1/2" max size.		
6	SS	16.6	18.1	18-24-21	.8		20	SC	DARK BROWN CLAYEY SAND Moist, trace of small gravel and ash.		
7	SS	21.6	23.1	6-6-8	1.5		25	CL	LIGHT BROWN SILTY CLAY Moist, low plasticity.		
8	SS	26.6	28.1	4-4-4	1.0		30		BLACK BOTTOM ASH Saturated.		
9	SS	31.6	33.1	2-1-2	1.1		35		GRAY FLY ASH Saturated.		
10	SS	36.6	38.1	2-1-1	1.5		40				
11	SS	41.6	43.1	3-5-7	.8		45	CL	LIGHT GRAY CLAY Moist to wet, medium to high plasticity.		
12	ST	46.6	48.6		2.0				PUSH 2.0 TIME 7 SEC, PSI 1000		

TYPE OF CASING USED	
X	NQ-2 ROCK CORE
	6" x 3.25 HSA
	9" x 6.25 HSA
	HW CASING ADVANCER 4"
	NW CASING 3"

Continued Next Page

PIEZOMETER TYPE: PT = OPEN TUBE POROUS TIP, SS = OPEN TUBE SLOTTED SCREEN, G = GEONOR, P = PNEUMATIC

WELL TYPE: OW = OPEN TUBE SLOTTED SCREEN, GM = GEOMON

RECORDER REB

AMERICAN ELECTRIC POWER SERVICE CORPORATION
AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER 3966

COMPANY APPALACHIAN POWER COMPANY

BORING NO. 96-108 DATE _____ SHEET 2 OF 2

PROJECT Sporn fly ash pond dikes

BORING START 06/11/96 BORING FINISH 06/11/96

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD %	DEPTH IN FEET	GRAPH LOG	U S C S	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO									
13	SS	51.6	53.1	2-2-3	?		55		CL	DARK GRAY SILTY CLAY Wet, low plasticity, trace of organic and sand.		
14	SS	56.6	58.1	2-2-3	1.5		60					57.0 Top of seal.
15	SS	61.6	63.1	3-4-5	1.5		65					60.6 Top of sand. 63.3 Top screen.
16	SS	66.6	68.1	4-4-5	1.5		70					72.3 Bottom of screen.
17	SS	71.6	73.1	4-5-6	1.5							74.0 Bottom of sand.

AMERICAN ELECTRIC POWER SERVICE CORPORATION
AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER 3966
 COMPANY APPALACHIAN POWER COMPANY
 PROJECT Sporn fly ash pond dikes
 COORDINATES N 720,227.5 E 1,735,579.0
 GROUND ELEVATION 619.6 SYSTEM STATE PLANE

BORING NO. 96-109 DATE _____ SHEET 1 OF 2
 BORING START 05/29/96 BORING FINISH 05/30/96
 PIEZOMETER TYPE _____ WELL TYPE _____
 HGT. RISER ABOVE GROUND _____ DIA _____
 DEPTH TO TOP OF WELL SCREEN _____ BOTTOM _____
 WELL DEVELOPMENT _____ BACKFILL QUICK GROUT
 FIELD PARTY MCR-REB RIG BK-81

WATER LEVEL	▽ 20.5	▽	▽
TIME			
DATE	5-30-96		

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY %	RQD %	DEPTH IN FEET	GRAPH LOG	USCS	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO									
1	SS	3.0	4.5	13-19-24	1.2		5		GP	NO SAMPLE TAKEN BORING LOCATED IN ROAD BASE. AUGER CUTTINGS INDICATE BROWN SAND AND GRAVEL. DARK BROWN SAND AND GRAVEL Moist, 1/2" max size, quartz, rounded, some fines.	▽	Boring grouted from 73.2 to grade with 150 gallons quick grout.
2	SS	5.0	6.5	15-18-21	1.1		5					
3	SS	8.5	10.0	15-18-21	1.2		10					
4	SS	11.7	13.2	12-13-14	1.0		15		SP	DARK BROWN SAND Moist, fine grain.		
5	SS	16.7	18.2	4-5-6	1.1		20		ML	BROWN SANDY SILT Moist, non plasticity.		
6	SS	21.7	23.2	4-6-8	1.2		25					
7	ST	26.7	28.7		1.5		30			Time 10 sec PSI 1200 Push 2.0 By watching rig psi possible .4 to .5 of fly ash in bottom of tube. GRAY FLY ASH Moist.		
8	SS	31.7	33.2	4-7-10	1.1		35					
9	SS	36.7	38.2	1-1-1	1.2		40			Saturated		
10	SS	41.7	43.2	1-1-1	1.2		45					
11	SS	46.7	48.2	1-1-3	?							

TYPE OF CASING USED

Continued Next Page

X	NQ-2 ROCK CORE	PIEZOMETER TYPE: PT = OPEN TUBE POROUS TIP, SS = OPEN TUBE SLOTTED SCREEN, G = GEONOR, P = PNEUMATIC
	6" x 3.25 HSA	
	9" x 6.25 HSA	
	HW CASING ADVANCER 4"	WELL TYPE: OW = OPEN TUBE SLOTTED SCREEN, GM = GEOMON
	NW CASING 3"	
	SW CASING 6"	RECORDER <u>REB</u>

AMERICAN ELECTRIC POWER SERVICE CORPORATION
 AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER 3966

COMPANY APPALACHIAN POWER COMPANY

BORING NO. 96-109 DATE _____ SHEET 2 OF 2

PROJECT Sporn fly ash pond dikes

BORING START 05/29/96 BORING FINISH 05/30/96

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD	DEPTH IN FEET	GRAPH LOG	S	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO			%						
12	SS	51.7	66.7	1-1-2	1.2		55					
13	SS	56.7	58.2	1-1-4	1.2		60					
14	SS	61.7	63.2	4-6-8	?		65		CL	DARK BROWN CLAY Moist, medium to high plasticity.		
15	ST	66.7	68.7		1.7		70			Time 8 sec. Push 2.0 PSI 1000 Material same as sample no. 14		
16	SS	71.7	73.2	3-4-5	1.2							

AMERICAN ELECTRIC POWER SERVICE CORPORATION
AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER 3966
 COMPANY APPALACHIAN POWER COMPANY
 PROJECT Sporn fly ash pond dikes
 COORDINATES N 720,277.1 E 1,735,665.6
 GROUND ELEVATION 602.3 SYSTEM STATE PLANE

BORING NO. 96-110 DATE _____ SHEET 1 OF 2
 BORING START 06/06/96 BORING FINISH 06/10/96
 PIEZOMETER TYPE SS WELL TYPE _____
 HGT. RISER ABOVE GROUND _____ DIA _____
 DEPTH TO TOP OF WELL SCREEN 43.7 BOTTOM 52.7
 WELL DEVELOPMENT NO BACKFILL QUICK GROUT
 FIELD PARTY MCR-REB RIG BK-81

WATER LEVEL	▽	DRY	▽	▽
TIME				
DATE		6-10-96		

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD %	DEPTH IN FEET	GRAPH LOG	S C S	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO									
										No sample taken, boring in road.		Grouted grade to 73.1' with approximately 80 gallons.
1	SS	3.0	4.5	13-18-24	1.1		5			DARK GRAY BOTTOM ASH Dry		
2	SS	5.0	6.5	10-11-14	1.2							
3	SS	8.5	10.0	5-7-9	1.1		10		GP	DARK BROWN SAND AND GRAVEL Dry, quartz, rounded, 3/4" max.		
4	SS	11.6	13.1	6-7-10	1.1		15					
5	SS	16.6	18.1	8-10-10	1.2				CL	BROWN CLAY Dry, low to medium plasticity with trace of v-fine sand.		
6	SS	18.6	20.1	9-11-12	1.2		20		SC	Attempted to push tube lifted drill, destroyed end of tube. BROWN SANDY CLAY Moist, low to medium plasticity with v-fine grain sand lens. Grading to more sand		
7	SS	21.6	23.1	5-7-11	1.2		25			Attempted to push tube, top hole broken in tube, pushed approximately 1' lifted rig.		
9	SS	26.6	28.1	5-7-11	1.2		30			GRAYISH BROWN SILTY CLAY Moist, low to medium plasticity.		
10	SS	31.6	33.1	7-10-9	1.3		35		CL	Could not move or knock tube off to the side of lead auger, pulled augers grouted hole moved approximately three feet down stream to start new hole. No spt taken on new hole until this point. SWL dry augers to 26.6'. Auger set all weekend at this point.		
11	SS	36.6	38.1		1.5				CL	REDDISH BROWN CLAY Dry to moist, medium to high plasticity.		
12	ST	38.6	40.6		2.0		40			MEDIUM GRAY CLAY Moist to dry, medium to high plasticity, with odor of organic.	39.1 Top of seal.	
13	SS	41.6	43.1	3-5-7	1.5					PUSH 2.0 PSI 1200 TIME 6 SEC.	41.7 Top of sand.	
14	SS	46.6	48.1	3-4-4	1.5		45			Top DARK BROWNISH GRAY SANDY CLAY Bottom BROWN SANDY CLAY DARK GRAY CLAY Moist to wet, medium to high plasticity, strong odor of organic.	43.7 Top of screen.	

TYPE OF CASING USED				Continued Next Page			
X	NQ-2 ROCK CORE			PIEZOMETER TYPE: PT = OPEN TUBE POROUS TIP, SS = OPEN TUBE SLOTTED SCREEN, G = GEONOR, P = PNEUMATIC			
	6" x 3.25 HSA			WELL TYPE: OW = OPEN TUBE SLOTTED SCREEN, GM = GEOMON			
	9" x 6.25 HSA			RECORDER REB			
	HW CASING ADVANCER	4"					
	NW CASING	3"					

AMERICAN ELECTRIC POWER SERVICE CORPORATION
AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER 3966

COMPANY APPALACHIAN POWER COMPANY

BORING NO. 96-110 DATE _____ SHEET 2 OF 2

PROJECT Sporn fly ash pond dikes

BORING START 06/06/96 BORING FINISH 06/10/96

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD	DEPTH IN FEET	GRAPH LOG	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO			%					
15	SS	51.6	53.1	3-3-5	1.5		55		<p><u>GRAY BROWN CLAY</u> Moist to wet, medium to high plasticity, odor of organic with v-fine grain sand lens, water on out side of spoon.</p> <p><u>PUSH 2.0</u> <u>TIME 7 SEC.</u> <u>PSI 770</u> <u>DARK GRAY SILTY CLAY</u> <u>DARK GRAY CLAY</u> Moist to wet, medium to high plasticity, strong odor of organic material.</p>		52.7 Bottom of screen. 53.3 Bottom of sand.
16	SS	56.6	58.1	3-4-4	1.5						
17	ST	58.6	60.6		2.0						
18	SS	61.6	63.1	10	?						
19	SS	66.6	68.1	3-4-5	1.5						
20	SS	71.6	73.1	4-7-11	1.4		70				

DUTCH CONE PENETROMETER

Field Data Form

Date: 7-30-96

Test No.: B-96106 DCP

Site: Sporn Plant

Location: FLY ASH Dike

Tested by: Roush + Barkes Remarks: _____

Test Procedure:

Rate of Feed: 2cm/sec or no more than 1 in/sec

Run test every 20 cm or approx. 8 inches

C = Cone F = Friction R = Resistance
 CR = Cone Resistance LF = Local Friction
 Weight of inner rod = 0.14 Kg/cm²/rod length

Depth ①	C Kg/cm ² ②	F + C Kg/cm ² ③	F ③ - ② Kg/cm ² ④	CR ② × 2 Kg/cm ² ⑤	LF ④ × 0.133 Kg/cm ² ⑥	Friction Ratio* ⑥ / ⑤ ⑦
24.40	16.0	24.0				
25.15	16.0	30.0				
25.70	16.0	50.0				
26.35	10.0	12.0				
27.00	6.4	14.4				
27.65	4.0	10.0				
28.30	4.2	6.6				
28.95	4.8	7.2				
29.60	4.0	6.2				
30.25	3.2	5.6				
30.90	2.8	4.7				
31.55	3.6	5.8				
32.20	2.8	4.8				
32.85	2.0	4.4				
33.50	3.2	6.3				
34.15	3.2	6.4				
34.80	2.8	5.6				
35.45	2.7	4.9				
36.10	2.9	4.7				
36.75	2.8	5.2				
37.40	2.9	4.3				
38.05	3.2	4.8				
38.70	2.8	4.7				
39.35	2.4	5.8				
40.00	4.0	6.4				

Friction Resistance
 Cone Resistance
 Friction Ratio

DEPTH	Friction Resistance																
	Cone Resistance																
	Friction Ratio																

Note: The friction ratio is computed by dividing the local friction by the cone resistance.

DUTCH CONE PENETROMETER
Field Data Form

Date: 7-30-96

Test No. B. 96106 DCP

Project: _____

Location: _____

Tested by: _____ Remarks: _____

Test Procedure:

Rate of Feed: 2cm/sec or no more than 1 in/sec
Run test every 20 cm or approx. 8 inches

C = Cone F = Friction R = Resistance
CR = Cone Resistance LF = Local Friction
Weight of inner rod = 0.14 Kg/cm²/rod length

Depth ①	C Kg/cm ² ②	F + C Kg/cm ² ③	F	CR	LF	Friction Ratio*
			③ - ② Kg/cm ² ④	② × 2 Kg/cm ² ⑤	④ × 0.133 Kg/cm ² ⑥	⑥ / ⑤ ⑦
40.65	2.9	5.4				
41.30	2.4	4.5				
41.95	3.2	5.3				
42.60	3.2	4.9				
43.25	2.8	5.1				
43.90	2.9	4.3				
44.55	3.1	4.8				
45.20	4.8	7.2				
45.85	6.3	8.8				
46.50	5.2	7.6				
47.15	4.0	5.9				
47.80	5.2	7.6				
48.45	3.2	6.0				
49.10	2.0	4.8				
49.75	2.4	4.6				
50.40	5.2	6.6				
51.05	2.7	5.7				
51.70	3.6	6.7				
52.35	2.1	4.6				
53.00	2.9	5.2				
53.65	2.5	4.7				
54.30	2.9	6.8				
54.95	2.7	7.6				

Friction Resistance _____
Cone Resistance _____
Friction Ratio _____

DEPTH

Friction Ratio																			

Note: The friction ratio is computed by dividing the local friction by the cone resistance.

Figure 8

DUTCH CONE PENETROMETER
Field Data Form

Date: 7-29-96

Test No.: B-96107 DCP

Object: Sponu Plant

Location: FLY ASH DIRT

Tested by: Roush-Bawles Remarks: _____

Test Procedure:

Rate of Feed: 2cm/sec or no more than 1 in/sec
Run test every 20 cm or approx. 8 inches

C = Cone F = Friction R = Resistance
CR = Cone Resistance LF = Local Friction
Weight of inner rod = 0.14 Kg/cm²/rod length

Depth <u>①</u>	C Kg/cm ² <u>②</u>	F + C Kg/cm ² <u>③</u>	F <u>③</u> - <u>②</u> Kg/cm ² <u>④</u>	CR <u>②</u> × 2 Kg/cm ² <u>⑤</u>	LF <u>④</u> × 0.133 Kg/cm ² <u>⑥</u>	Friction Ratio* <u>⑥</u> / <u>⑤</u> <u>⑦</u>
30.70	2.4	6.0				
31.35	2.8	6.0				
32.00	4.0	6.4				
32.65	2.4	4.5				
33.30	2.4	5.6				
33.95	3.8	6.0				
34.60	3.7	6.4				
35.25	2.4	5.6				
35.90	2.5	4.7				
36.55	3.8	6.2				
37.20	3.8	6.0				
37.85	2.4	4.8				
38.50	3.9	5.6				
39.15	2.4	4.5				
39.80	1.6	2.8				
40.45	2.0	4.0				
41.10	2.3	4.5				
41.75	2.5	4.8				
42.40	2.4	4.4				
43.05	3.4	5.6				
43.70	3.8	5.6				
44.35	4.0	6.0				
45.00	3.8	6.0				
45.65	3.2	5.2				
46.30	2.4	3.2				

Friction Resistance
Cone Resistance
Friction Ratio

Friction Resistance

Cone Resistance

Friction Ratio

Note: The friction ratio is computed as the local friction divided by the cone resistance.

DUTCH CONE PENETROMETER Field Data Form

Date: 7-29-96

Test No.: B-96107 DCP

Project: _____

Location: _____

Tested by: _____ Remarks: _____

Test Procedure:

Rate of Feed: 2cm/sec or no more than 1 in/sec

Run test every 20 cm or approx. 8 inches

C = Cone F = Friction R = Resistance
CR = Cone Resistance LF = Local Friction
Weight of inner rod = 0.14 Kg/cm²/rod length

Depth ①	C	F + C	F	CR	LF	Friction Ratio* ⑥ / ⑤
	Kg/cm ² ②	Kg/cm ² ③	③ - ② Kg/cm ² ④	② × 2 Kg/cm ² ⑤	④ × 0.133 Kg/cm ² ⑥	
46.95	2.4	3.2				
47.60	2.2	4.5				
48.25	2.4	5.7				
48.90	3.8	5.6				
49.55	2.4	6.4				
50.20	2.0	6.0				
50.85	3.6	5.6				
51.50	2.4	5.8				
52.15	2.8	5.2				
52.80	4.0	5.9				
53.45	2.0	3.6				
54.10	0.0	5.2				
54.75	0.0	4.4				
55.40	2.0	4.2				
56.05	2.4	5.2				
56.70	0.0	5.2				
57.35	1.8	4.4				
58.65	0.0	6.4				
59.30	3.6	6.4				
59.95	2.4	5.6				
60.60	2.4	4.4				
61.25	2.0	4.0				
61.90	1.6	3.2				
62.55	1.6	2.4				

Stopped Boring

Friction Resistance

Cone Resistance

Friction Ratio

DEPTH

Note: The friction ratio is computed by dividing the local friction by the cone resistance.

DUTCH CONE PENETROMETER
Field Data Form

Date: 7-30-96

Test No.: 96109 DCP

Project: Spawn Plant

Location: FLY Ash DiKE

Tested by: Roush + Bankes Remarks: _____

Test Procedure:

Rate of Feed: 2cm/sec or no more than 1 in/sec
Run test every 20 cm or approx. 8 inches

C = Cone F = Friction R = Resistance
CR = Cone Resistance LF = Local Friction
Weight of inner rod = 0.14 Kg/cm²/rod length

Depth ①	C Kg/cm ² ②	F + C Kg/cm ² ③	F ③ - ② Kg/cm ² ④	CR ② x 2 Kg/cm ² ⑤	LF ④ x 0.133 Kg/cm ² ⑥	Friction Ratio* ⑥ / ⑤ ⑦
	29.20	3.8	6.0			
29.85	4.0	7.6				
30.50	2.4	5.2				
31.15	9.6	10.4				
31.80	4.5	10.4				
32.45	5.6	6.4				
33.10	2.4	5.7				
33.75	3.2	5.2				
34.40	3.2	4.8				
35.05	3.9	5.9				
35.70	3.6	6.4				
36.35	3.2	5.6				
37.00	4.0	6.2				
37.65	3.2	5.7				
38.30	3.2	5.6				
38.95	4.0	6.4				
39.60	3.6	5.6				
40.25	2.4	5.2				
40.90	2.2	4.3				
41.55	2.5	4.4				
42.20	2.4	4.5				
42.85	2.2	5.6				
43.50	3.2	5.2				
44.15	2.4	5.6				
44.80	4.0	8.0				

Friction Resistance

Cone Resistance

Friction Ratio

DEPTH

Note: The friction ratio is computed by dividing the local friction by the cone resistance measured

DUTCH CONE PENETROMETER Field Data Form

Date: _____

Test No.: _____

Object: Sponw. Plant

Location: _____

Tested by: _____ Remarks: _____

Test Procedure:

Rate of Feed: 2cm/sec or no more than 1 in/sec

Run test every 20 cm or approx. 8 inches

C = Cone F = Friction R = Resistance
 CR = Cone Resistance LF = Local Friction
 Weight of inner rod = 0.14 Kg/cm²/rod length

Depth	C	F + C	F	CR	LF	Friction Ratio*
①	Kg/cm ² ②	Kg/cm ² ③	③ - ② Kg/cm ² ④	② × 2 Kg/cm ² ⑤	④ × 0.133 Kg/cm ² ⑥	⑥ / ⑤ ⑦
45.45	2.8	4.4				
46.10	2.2	4.8				
46.75	2.8	4.9				
47.4	3.2	5.6				
48.05	2.4	5.6				
49.0	2.0	4.9				
49.35	2.0	4.4				
50.00	2.4	5.3				
50.65	2.0	4.8				
51.30	2.0	4.5				
51.95	2.4	5.2				
52.60	2.2	4.3				
53.25	1.9	4.0				
53.90	2.0	4.3				
54.55	1.4	4.8				
55.20	1.8	4.4				
55.85	1.6	4.0				
56.30	2.0	4.7				
57.15	1.9	4.8				
57.80	1.6	4.7				
58.45	2.8	5.2				
59.10	3.2	5.8				
59.75	3.3	6.4				
60.40	3.6	6.0				
61.05	2.0	3.6				

Friction Resistance									
Cone Resistance									
Friction Ratio									

Note: The friction ratio is computed by dividing the local friction by the cone resistance measured 20 cm above the test point.

DUTCH CONE PENETROMETER Field Data Form

Date: _____

Test No.: _____

Object: Spoon Plant

Location: _____

Tested by: _____ Remarks: _____

Test Procedure:

Rate of Feed: 2cm/sec or no more than 1 in/sec

Run test every 20 cm or approx. 8 inches

C = Cone F = Friction R = Resistance
 CR = Cone Resistance LF = Local Friction
 Weight of inner rod = 0.14 Kg/cm²/rod length

Depth ①	C Kg/cm ² ②	F + C Kg/cm ² ③	F ③ - ② Kg/cm ² ④	CR ② x 2 Kg/cm ² ⑤	LF ④ x 0.133 Kg/cm ² ⑥	Friction Ratio * ⑥ / ⑤ ⑦
61.76	1.9	3.2				
62.35	1.2	2.3				
63.00	.9	1.7				

_____ Friction Resistance _____

_____ Cone Resistance _____

_____ Friction Ratio _____

D E P T H	Friction Ratio										

Note: The friction ratio is computed by dividing the local friction by the cone resistance measured 20 cm above the local friction measurement.

AEP CIVIL ENGINEERING LABORATORY
LOG OF BORING



JOB NUMBER 3015
 COMPANY APPALACHIAN POWER COMPANY
 PROJECT SPORN PLANT ASH HAUL ROAD
 DORDINATES _____
 GROUND ELEVATION _____ SYSTEM _____

BORING NO. 9301 DATE _____ SHEET 1 OF 2
 BORING START 09/13/93 BORING FINISH 09/14/93
 PIEZOMETER TYPE SS WELL TYPE _____
 HGT. RISER ABOVE GROUND 2.5 DIA 1"
 DEPTH TO TOP OF WELL SCREEN 3.5 BOTTOM 12.5
 WELL DEVELOPMENT _____ BACKFILL BENTONITE
 FIELD PARTY MCR-TLS RIG BK-81

WATER LEVEL	▽	DRY	▽	▽
TIME				
DATE		9-9-93		

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD %	DEPTH IN FEET	GRAPH LOG	U S C S	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO									
1	SS	0.0	1.5	3-3-4	1.2					BROWN SILTY CLAY Dry.		Inside of augers dry until hitting sand and gravel. 3.0 Top of gravel. 3.5 Top of screen.
2	SS	1.5	3.0	5-15-15	.9					BROWN SANDY CLAY Moist, with some gravel.		
3	SS	3.0	4.5	10-12-13	1.1					GRAY BOTTOM ASH Moist.		
4	SS	4.5	6.0	7-20-22	1.2		5					
5	SS	6.0	7.5	10-18-20	1.4							
6	SS	7.5	9.0	18-20-16	1.4							
7	SS	9.0	10.5	25-16-13	1.5		10			GRAY FLY ASH Moist.		
8	SS	10.5	12.0	1-11-10	1.4							
9	SS	12.0	13.5	13-12-13	1.3							
10	SS	13.5	15.0	14-11-5	1.4		15					
11	SS	15.0	16.5	5-4-2	1.3							
12	SS	16.5	18.0	1-1-1	1.5							
13	SS	18.0	19.5	0	1.5							
14	SS	19.5	21.0	1-1-4	1.5		20					
15	SS	21.0	22.5	8-7-8	1.5					BROWN SAND AND GRAVEL		
16	SS	22.5	24.0	6-5-6	.8					GRAY FLY ASH		
17	SS	24.0	25.5	7-10-10	1.2					BLACK BOTTOM ASH		
18	ST	25.5	27.5		1.3					BROWN SILTY CLAY Wet.		
19	SS	27.5	29.0	5-5-9	1.5					BLACK BOTTOM ASH Wet.		
20	ST	29.0	31.0		1.7					BROWN SILTY CLAY Moist.		
21	SS	31.0	32.5	5-7-9	1.2					BROWN SANDY CLAY Moist.		
22	ST	32.5	34.5		1.4					BROWN AND GRAY SILTY CLAY Mottled, moist		
23	SS	34.5	36.0	6-7-9	1.5					BROWN SILTY CLAY Moist.		
24	ST	36.0	38.0		2.0					BROWN AND GRAY SILTY CLAY Moist.		
25	SS	38.0	39.5	5-7-8	?					BROWN/GRAY CLAY		
26	ST	39.5	41.5		2.0					BROWN SILTY CLAY Moist.		
27	SS	41.5	43.0	4-5-5	?					BROWN SANDY CLAY Moist.		
28	ST	43.0	45.0		2.0					BROWN CLAYEY SAND Moist.		
29	SS	45.0	46.5	3-3-4	?							
30	ST	46.5	48.5		1.6					BROWN SAND AND GRAVEL Wet.		

TYPE OF CASING USED	
	NQ-2 ROCK CORE
X	6" x 3.25 HSA
	9" x 6.25 HSA
	HW CASING ADVANCER 4"
	NW CASING 3"

Continued Next Page

PIEZOMETER TYPE: PT = OPEN TUBE POROUS TIP, SS = OPEN TUBE SLOTTED SCREEN, G = GEONOR, P = PNEUMATIC

WELL TYPE: OW = OPEN TUBE SLOTTED SCREEN, GM = GEOMON

RECORDER _____

AMERICAN ELECTRIC POWER SERVICE CORPORATION
 AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER 3015
 COMPANY APPALACHIAN POWER COMPANY
 SUBJECT SPORN PLANT ASH HAUL ROAD
 COORDINATES _____
 GROUND ELEVATION 600.3 SYSTEM _____

BORING NO. SI-3 DATE _____ SHEET 1 OF 2
 BORING START 06/16/88 BORING FINISH 06/23/99
 PIEZOMETER TYPE _____ WELL TYPE _____
 HGT. RISER ABOVE GROUND _____ DIA 6"
 DEPTH TO TOP OF WELL SCREEN _____ BOTTOM _____
 WELL DEVELOPMENT _____ BACKFILL _____
 FIELD PARTY MCR/TJH RIG B-61

WATER LEVEL	▽ 28.0	▽ 49.0	▽
TIME		0710	
DATE	06/19/88	06/23/88	

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERED	RQD %	DEPTH IN FEET	GRAPH LOG	U S C S	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO									
1	SS	3.0	4.5	16-16-14	.83		5			BROWN SILTY SAND, moist, quartz, trace of small gravel		
2	SS	8.0	9.5	5-4-3	.17		10			LIMESTONE AND SAND		
3	SS	13.0	14.5	4-4-5	.5		15			SILTY SAND AND GRAVEL, wet to saturated, quartz, 1/2" max size, rounded		
4	SS	18.0	19.5	11-12-11	1.0		20			BROWN SANDY SILT, moist		
5	SS	23.0	24.5	5-6-8	1.0		25			BROWN SANDY SILT, moist		
6	SS	28.0	29.5	7-8-9	1.0		30			BROWN SANDY SILT, moist	▽	
7	SS	33.0	34.5	8-9-11	.83		35			BROWN CLAY, moist to wet, medium to low plasticity		
8	SS	38.0	39.5	7-8-10	1.0		40			GRAY ORGANIC SILT, moist		
9	SS	43.0	44.5	4-4-5	1.3		45			GRAY BROWN SILTY SAND, moist to wet w/ organic material		
10	ST	45.0	47.0		2.0							
11	ST	47.0	49.0		1.2							

SHELBY TUBE
 PUSH 2.0'
 REC 2.0'
 TIME 4 SEC

TYPE OF CASING USED	Continued Next Page
NQ-2 ROCK CORE	PIEZOMETER TYPE: PT = OPEN TUBE POROUS TIP, SS = OPEN TUBE SLOTTED SCREEN, G = GEONOR, P = PNEUMATIC
6" x 3.25 HSA	
9" x 6.25 HSA	
HW CASING ADVANCER 4"	WELL TYPE: OW = OPEN TUBE SLOTTED SCREEN, GM = GEOMON
NW CASING 3"	
	RECORDER _____

AMERICAN ELECTRIC POWER SERVICE CORPORATION
 AEP CIVIL ENGINEERING LABORATORY
 LOG OF BORING



JOB NUMBER 3015

COMPANY APPALACHIAN POWER COMPANY

BORING NO. SI-3 DATE _____ SHEET 2 OF 2

PROJECT SPORN PLANT ASH HAUL ROAD

BORING START 06/16/88 BORING FINISH 06/23/99

SAMPLE NUMBER	SAMPLE	SAMPLE DEPTH IN FEET		STANDARD PENETRATION RESISTANCE BLOWS / 6"	TOTAL LENGTH RECOVERY	RQD	DEPTH IN FEET	GRAPH LOG	USCS	SOIL / ROCK IDENTIFICATION	WELL	DRILLER'S NOTES
		FROM	TO			%						
12	SS	53.0	54.5	34-50/.2	.5		55			BROWN SILTY SAND AND GRAVEL, saturated, 3/4" max. size, rounded, quartz		PSI 550 SHELBY TUBE PUSH 1.2' REC 1.2' TIME 7 SEC PSI 750
13	SS	58.0	59.5	22-26-29	.67		60			BROWN SILTY SAND AND GRAVEL, saturated, 3/4" max. size, rounded, quartz		
14	SS	63.0	64.5	24-24-29	.83		65			BROWN SAND AND GRAVEL, saturated, 1/2" max size, rounded, quartz		
15	SS	68.0	69.5	19-14-10	.25		70			DARK BROWN SAND AND GRAVEL, saturated, 3/4" max. size, rounded, quartz, some fines		
16	SS	73.0	74.5	22-19-10	.67		75			BROWN SILTY SAND, saturated, w/ some 1" max. size quartz		
17	SS	78.0	79.5	8-8-9	.5		80			BROWN SAND, saturated, quartz, trace of fines		
18	SS	83.0	84.5	12-12-15	.25		85			BROWN SAND, saturated, quartz, trace of fines		
19	SS	88.0	89.5	14-17-17	.75		90			BROWN SANDS, saturated, quartz, trace of fines		
20	SS	93.0	94.5	12-19-16	1.2		95			BROWN SILTY SAND AND GRAVEL, saturated, 1" max. size, quartz		
							100			GRAY SANDSTONE Auger Refusal 95.2' Set HW casing at 95' Used 3 7/8" roller bit to cut gray sandstone to 101.7' Cut rock to 99' Casing not on rock, Set casing at 96' Cut rock to 101.7' Void in sandstone at 99.2' and 100.1', both voids approx .3 to .4' Lost water 99,2 Tip of slope indicator at 101.7' Indicator casing installed in 10' lengths		

FIELD DATA FROM:
“PHILIP SPORN POWER PLANT – STABILITY ANALYSIS”

PREPARED/COMPILED BY:
**THE GEOTECHNICAL ENGINEERING SECTION OF AMERICAN
ELECTRIC POWER SERVICE CORPORATION**

DATED: MARCH 2009

GEOTECHNICAL DATA COLLECTION REPORT

**AEP SPORN FLY ASH AND BOTTOM ASH POND COMPLEX
NEW HAVEN, WEST VIRGINIA**

**HCN/TERRACON PROJECT NO. N2095019
March 3, 2009**

Prepared For:

AMERICAN ELECTRIC POWER

Prepared by:

**H.C. NUTTING
A Terracon Company
Charleston, West Virginia**



H. C. NUTTING

A Terracon COMPANY

March 3, 2009

912 Morris Street
Charleston, West Virginia 25301
304-344-0821 Fax:304-342-4711

HCN/Terracon Project No. N2095019

Mr. Tim Howdyshell
American Electric Power
1 Riverside Plaza – 22nd Floor
Columbus, OH 43215

**Re: Geotechnical Data Collection Report
AEP Sporn Fly Ash and Bottom Ash Pond Complex
New Haven, West Virginia**

Dear Mr. Howdyshell:

H. C. Nutting Company (HCN), a Terracon company is pleased to present our geotechnical data collection report for the geotechnical services associated with the maintenance of the American Electric Power (AEP) Sporn Fly Ash and Bottom Ash Pond Complex in New Haven, West Virginia. This work was performed in general accordance with our proposal dated February 9, 2009 and AEP Letter of Authorization dated February 10, 2009.

SCOPE OF WORK

HCN's scope of work for this project included performing a total of five (5) test borings, installation of observation wells at all 5 boring locations, inspection of drilling activities, preparation of boring logs based on visual classification, and preparation of this report.

FIELD EXPLORATION

Test Borings

A total of five (5) Standard Penetration Test (SPT) borings were drilled for this project. The test borings were selected and staked in the field by AEP and HCN personnel and later surveyed in the field by AEP surveyor (to be provided).

DELIVERING SUCCESS FOR CLIENTS AND EMPLOYEES SINCE 1965
MORE THAN 95 OFFICES NATIONWIDE

AEPSPP003355

The test borings were performed utilizing a drill rig mounted on an All-Terrain Vehicle. The field operations were performed between February 16, 2009 through February 23, 2009. Boreholes were advanced and stabilized using hollow-stem augers. The drilling activities were performed under the supervision of HCN personnel.

Sampling was accomplished using the Standard Penetration Test (ASTM D 1586) and Shelby tube (ASTM D 1587) methods. Split-spoon samples were obtained at 2.5 ft. intervals. Shelby tube samples were collected at within cohesive soils. The borings were completed at depths of 50 feet below the existing ground surface.

After completion of drilling activities, all of the five test borings were converted into observation wells. All wells were constructed from 1.92-inch OD (1.5-inch ID) threaded PVC with #10 slot screen and 5-foot solid PVC section at the top. The PVC casing was constructed to just below the existing ground surface and protected with a "Global HRB 141412-F H20" locking steel protective cover. The well pad was then constructed around the observation well with approximate dimensions of 3 feet by 3 feet and a minimum of 8 inch thickness.

Each well was developed using a surge block and evacuated until the discharge water stabilized. All development data and estimated purge volumes were recorded and are shown on the attached well development logs.

On the following table we have indicated the beginning and ending depths of the screening sections.

Observation Well Screen Depths

Boring	Screening Section	
	Beginning Depth (feet)	Ending Depth (feet)
PZ-09-01	6	50.3
PZ-09-02	5.5	35
PZ-09-03	6	50.4
PZ-09-04	5.5	49.8
PZ-09-05	5.2	50.2


The observation well logs are included with this report.


CLOSING


We appreciate the opportunity of working with you on this project. Please contact us concerning any questions that may arise during review of the report, or if you require additional information as you proceed into the final design and construction stage of this project.

Thank you for your consideration.

Respectfully submitted,
H. C. NUTTING COMPANY


Lewis E. Eplin
Staff Geologist




Yogesh S. Rege, P.E.
Department Manager
Geotechnical Services

APPENDIX

**FIGURE 1: BORING LOCATION DIAGRAM
LOG OF TEST BORINGS
WELL DEVELOPMENT LOGS
OBSERVATION WELL LOGS
GENERAL NOTES
UNIFIED SOIL CLASSIFICATION SYSTEM**




FIG. No. **1**

Boring Location Diagram
 Sporn Fly Ash and Bottom Ash Pond Complex
 New Haven, West Virginia
 American Electric Power

Terracon
 Consulting Engineers and Scientists
 Charleston, West Virginia

Project No.	12082019
Scale	NTS
File No.	12082019
Date	2/25/2009

Prepared By:	Year:
Drawn By:	Year:
Checked By:	Year:
Approved By:	Year:



Approximate Boring Location

LOG OF BORING NO. PZ-09-01

CLIENT American Electric Power		PROJECT Sporn Fly Ash and Bottom Ash Pond Complex									
SITE Philip Sporn Power Plant New Haven, West Virginia											
GRAPHIC LOG	Boring Location: 721043.509, 1735345.011		SAMPLES				TESTS				
	DESCRIPTION		DEPTH, ft.	USCS SYMBOL	NUMBER	TYPE	RECOVERY, in.	SPT - N** BLOWS / ft.	WATER CONTENT, %	DRY UNIT WT pcf	UNCONFINED STRENGTH, psf
	Approx. Surface Elev.: 600.817 ft										
	0.5 ASPHALT 600.5										
	1 FILL , stabilized and compacted bottom ash 600			SM	1	SS	18	24			
	1 FILL , silty sand with bottom ash, trace gravel, gray, medium dense, dry to moist - Geogrid observed at 4'			SM	2	SS	18	17			
	8.5 592.5		5	SM	3	SS	18	16			
	8.5 FILL , silty sand with bottom ash, gray to dark gray, medium dense, moist			SM	4	SS	18	14			
	12 589		10	SM	5	SS	18	12			
	12 FILL , silty sand with gravel, light brown, medium dense, moist			CL	6	SS	12	16			9000*
14 587		15	CL	7	SS	12	10			4000*	
14 FILL , lean clay with sand, light brown, stiff, moist			SM	8	SS	18	14				
18.5 582.5		20		9	SS	18	18				
18.5 FILL , silty sand with gravel, dark brown, loose, moist			CL	10	SS	18	19			7000*	
21 580		25	CL	11	ST	24				800 psi/24 sec	
21 FILL , bottom ash with coal fragments, black, medium dense, wet			CL	12	SS	18	20			7000*	
23.5 577.5		30	CL	13	SS	18	16			6500*	
23.5 LEAN CLAY with SAND light brown, stiff, moist											
28.5 572.5											
28.5 SANDY LEAN CLAY , brown to gray, stiff, moist											

Continued Next Page

The stratification lines represent the approximate boundary lines between soil and rock types: in-situ, the transition may be gradual.

*Calibrated Hand Penetrometer
**CME 140H SPT automatic hammer

WATER LEVEL OBSERVATIONS, ft				BORING STARTED 2-20-09			
WL	21	WD	18.1	4 hr		BORING COMPLETED 2-21-09	
WL	18	48 hr		RIG Track FOREMAN			
WL				LOGGED LE JOB # N2095019			



REVISED BORING LOGS: SPORN BOTTOM ASH POND COMPLEX.GPJ TERRACON.GDT 3/3/09

LOG OF BORING NO. PZ-09-01

CLIENT American Electric Power		PROJECT Sporn Fly Ash and Bottom Ash Pond Complex							
SITE Philip Sporn Power Plant New Haven, West Virginia		SAMPLER							
GRAPHIC LOG	DESCRIPTION	DEPTH, ft.	USCS SYMBOL	SAMPLER				TESTS	
				NUMBER	TYPE	RECOVERY, in.	SPT - N** BLOWS / ft.	WATER CONTENT, %	DRY UNIT WT pcf
47 50	SANDY LEAN CLAY, brown to gray, stiff, moist CLAYEY SAND, brown, dense, very moist, fine grained sand - with gravel at 49' BORING COMPLETED	35	CL 14	SS	18	18			6500*
			CL 15	SS	18	10			4500*
		40	CL 16	SS	18	18			4000*
			CL 17	SS	18	14			3500*
		45	CL 18	SS	18	18			5000*
			CL 19	SS	18	13			3000*
		50	SC 20	SS	18	47			

REVISED BORING LOGS SPORN BOTTOM ASH POND COMPLEX.GPJ TERRACON.GDT 3/2/09

The stratification lines represent the approximate boundary lines between soil and rock types: in-situ, the transition may be gradual. *Calibrated Hand Penetrometer
**CME 140H SPT automatic hammer

WATER LEVEL OBSERVATIONS, ft.			
WL	∇ 21	WD	∇ 18.1 4 hr
WL	∇ 18	48 hr	∇
WL			



BORING STARTED		2-20-09
BORING COMPLETED		2-21-09
RIG	Track	FOREMAN
LOGGED	LE	JOB # N2095019

LOG OF BORING NO. PZ-09-02

CLIENT American Electric Power										
SITE Philip Sporn Power Plant New Haven, West Virginia		PROJECT Sporn Fly Ash and Bottom Ash Pond Complex								
GRAPHIC LOG	Boring Location: 720306.293, 1735648.836		SAMPLES			TESTS				
	DESCRIPTION		DEPTH, ft.	USCS SYMBOL	NUMBER	TYPE	RECOVERY, in.	SPT - N** BLOWS / ft.	WATER CONTENT, %	DRY UNIT WT pcf
	Approx. Surface Elev.: 601.345 ft									
	0.5	ASPHALT	601							
	2	FILL , stabilized and compacted bottom ash	599.5	1	SS	12	52			
		FILL , silty sand with bottom ash and gravel, dark gray to brown, very dense, moist		2	SS	18	65			
	7	FILL , silty sand with gravel, light brown, dense, moist	594.5	3	SS	18	51			
				4	SS	18	36			
				5	SS	18	47			
				6	SS	18	45			
	16	FILL , silty sand, light brown, very dense, dry to moist, fine grained	585.5	7	SS	18	37			9000*
				8	ST	12				1000 psi/24 sec
				9	SS	18	33			9000*
	23.5	FILL , silty sand, light brown, dense, moist, fine grained	578	10	SS	18	38			
	26	FILL , bottom ash with coal fragments, black, medium dense, wet	575.5	11	SS	18	21			
	28.5	LEAN CLAY , trace to with sand, gray to light brown, very stiff to stiff, moist - Trace organics (roots) at 28.5 - 29'	573	12	SS	18	16			8000*
				13	ST	24				1200 psi/30 sec

Continued Next Page

The stratification lines represent the approximate boundary lines between soil and rock types: in-situ, the transition may be gradual.

*Calibrated Hand Penetrometer
**CME 140H SPT automatic hammer

WATER LEVEL OBSERVATIONS, ft.			
WL	∇ 26	WD	∇ 16 24 hr
WL	∇ 21.1		72 hr ∇
WL			



BORING STARTED		2-19-09	
BORING COMPLETED		2-20-09	
RIG	Track	FOREMAN	
LOGGED	LE	JOB #	N2095019

REVISED BORING LOGS. SPORN BOTTOM ASH POND COMPLEX.GPJ TERRACON.LGDT 3/3/09

LOG OF BORING NO. PZ-09-02

CLIENT American Electric Power		PROJECT Sporn Fly Ash and Bottom Ash Pond Complex									
SITE Philip Sporn Power Plant New Haven, West Virginia		SAMPLER									
GRAPHIC LOG	DESCRIPTION LEAN CLAY , trace to with sand, gray to light brown, very stiff to stiff, moist	DEPTH, ft.	USCS SYMBOL	SAMPLES				TESTS			
				NUMBER	TYPE	RECOVERY, in.	SPT - N** BLOWS / ft.	WATER CONTENT, %	DRY UNIT WT pcf	UNCONFINED STRENGTH, psf	
				35	CL 14	SS	18	34			8000*
					CL 15	SS	12	19			3000*
				40	CL 16	SS	18	17			8000*
					CL 17	SS	18	24			7000*
				45	CL 18	SS	18	23			4000*
					CL 19	SS	18	12			2500*
				50	CL 20	SS	18	13			3000*
				BORING COMPLETED		551.5					

REVISED BORING LOGS SPORN BOTTOM ASH POND COMPLEX.GPJ TERRACON.GDT 3/3/09

The stratification lines represent the approximate boundary lines between soil and rock types: in-situ, the transition may be gradual. *Calibrated Hand Penetrometer
**CME 140H SPT automatic hammer

WATER LEVEL OBSERVATIONS, ft			
WL	∇ 26	WD	∇ 16 : 24 hr
WL	∇ 21.1	72 hr	∇
WL			



BORING STARTED		2-19-09	
BORING COMPLETED		2-20-09	
RIG	Track	FOREMAN	
LOGGED	LE	JOB #	N2095019

LOG OF BORING NO. PZ-09-03

CLIENT American Electric Power												
SITE Philip Sporn Power Plant New Haven, West Virginia		PROJECT Sporn Fly Ash and Bottom Ash Pond Complex										
GRAPHIC LOG	Boring Location: 718396.378, 1736131.654				SAMPLES			TESTS				
	DESCRIPTION		DEPTH, ft.	USCS SYMBOL	NUMBER	TYPE	RECOVERY, in.	SPT - N** BLOWS / ft.	WATER CONTENT, %	DRY UNIT WT pcf	UNCONFINED STRENGTH, psf	
	Approx. Surface Elev.: 596.521 ft											
	FILL , silty sand with gravel, yellowish brown to dark brown, medium dense to dense, moist, fine to coarse grained sand, rounded gravel 11 585.5		5	SM	1	SS	14	30				
			5	SM	2	SS	18	29				
			5	SM	3	SS	18	45				
			5	SM	4	SS	14	70				
	FILL , silty sand with gravel, yellowish brown to dark brown, medium dense, moist, fine to coarse grained sand, rounded gravel 13.5 583		10	SM	5	SS	18	22				
			10	CL	6	SS	18	8				
	FILL , sandy lean clay, light brown to gray, medium stiff, very moist, fine grained sand 18 578.5		15	CL	7	ST	21.5				800 psi/30 sec	
			15	CL	8	SS	18	20				9000*
	FILL , lean clay with sand, brown and gray mottled, very stiff, moist, fine grained sand 23.5 573		20	CL	9	SS	18	24				9000*
			20	SM	10	SS	10	15				
FILL , coal and bottom ash, black, medium dense, wet, sand to gravel size particles 28.5 568		25	SM	11	SS	14	12					
		25	SM	12	SS	18	4					
		25	SM	13	SS	18	6					
FILL , coal and bottom ash, black to dark gray, loose, wet, fine sand to silt size particles with gravel size coal fragments 31 565.5		30										

Continued Next Page

The stratification lines represent the approximate boundary lines between soil and rock types: in-situ, the transition may be gradual.

*Calibrated Hand Penetrometer
**CME 140H SPT automatic hammer



WATER LEVEL OBSERVATIONS, ft			
WL	∇ 23	WD	∇ 16.8 24 hr
WL	∇	∇	
WL			



BORING STARTED		2-17-09
BORING COMPLETED		2-18-09
RIG	Track	FOREMAN
LOGGED	LE	JOB # N2095019

REVISED BORING LOGS: SPORN BOTTOM ASH POND COMPLEX.GPJ TERRACON.GDT 3/3/09

LOG OF BORING NO. PZ-09-03

CLIENT American Electric Power									
SITE Philip Sporn Power Plant New Haven, West Virginia		PROJECT Sporn Fly Ash and Bottom Ash Pond Complex							
GRAPHIC LOG	DESCRIPTION	DEPTH, ft.	SAMPLES				TESTS		
			USCS SYMBOL	NUMBER	TYPE	RECOVERY, in.	SPT - N** BLOWS / ft.	WATER CONTENT, %	DRY UNIT WT pcf
	FILL, coal and bottom ash, black to dark gray, loose to very loose, wet, fine sand to silt size particles	35	SM	14	SS	12	5		
			SM	15	SS	18	4		
			SM	16	SS	18	3		
		40	SM	17	SS	6	4		
	SANDY LEAN CLAY, dark gray, stiff to very soft, moist to wet, fine grained sand	43.5	CL	18	SS	18	9		500*
			CL	19	ST	22			800 psi/15 sec
		50	CL	20	SS	18	W.H.		500*
BORING COMPLETED		50							

REVISED BORING LOGS, SPORN BOTTOM ASH POND COMPLEX.GPJ TERRACON.GDT 3/3/09

The stratification lines represent the approximate boundary lines between soil and rock types: in-situ, the transition may be gradual.

*Calibrated Hand Penetrometer
**CME 140H SPT automatic hammer

WATER LEVEL OBSERVATIONS, ft			
WL	∇ 23	WD	∇ 16.8 24 hr
WL	∇		∇
WL			



BORING STARTED	2-17-09
BORING COMPLETED	2-18-09
RIG	Track FOREMAN
LOGGED	LE JOB # N2095019

LOG OF BORING NO. PZ-09-04

CLIENT American Electric Power		PROJECT Sporn Fly Ash and Bottom Ash Pond Complex									
SITE Philip Sporn Power Plant New Haven, West Virginia		Boring Location: 718148.27, 1736259.447									
GRAPHIC LOG	DESCRIPTION	DEPTH, ft.	USCS SYMBOL	NUMBER	TYPE	RECOVERY, in.	SPT - N** BLOWS / ft.	WATER CONTENT, %	DRY UNIT WT pcf	UNCONFINED STRENGTH, psf	
	Approx. Surface Elev.: 593.692 ft										
	FILL , silty sand with gravel, gray, medium dense, moist, medium to coarse grained sand	3.5	590	SM	1	SS	17	27			
	FILL , silty sand, trace gravel and clay, light brown, dense to medium dense, moist	8	585.5	SM	2	SS	18	43			
	FILL , lean clay, light brown	11	582.5	SM	3	SS	18	28			
	FILL , well graded sand with gravel, light brown, medium dense, moist, coarse to fine grained sand, rounded gravel	18.5	575	CL	4	ST	20				800 psi/34 sec
	FILL , silty sand with gravel, trace clay, dark brown to gray, dense, very moist, coarse to fine grained sand, rounded gravel	21	572.5	SW	5	SS	18	21			
	FILL , well graded gravel with sand, brown, dense to medium dense, wet, rounded gravel	27	566.5	SW	6	SS	12	23			
	FILL , bottom ash, gray to black, medium dense to very loose, wet, fine sand to silt size particles			SW	7	SS	14	26			
				SM	8	SS	18	30			
				GW	9	SS	18	35			
				GW	10	SS	18	16			
				GW	11	SS	18	10			
				SP	12	SS	18	9			
			SP	13	SS	18	6				

Continued Next Page



The stratification lines represent the approximate boundary lines between soil and rock types: in-situ, the transition may be gradual.

*Calibrated Hand Penetrometer
**CME-140H SPT automatic hammer

WATER LEVEL OBSERVATIONS, ft		BORING STARTED		2-18-09
WL	23	WD	14.5	24 hr
WL		WD		
WL				
		BORING COMPLETED		2-19-09
		RIG	Track	FOREMAN
		LOGGED	LE	JOB # N2095019

REVISED BORING LOGS: SPORN BOTTOM ASH POND COMPLEX.GPJ TERRACON.GET 3/8/09

LOG OF BORING NO. PZ-09-04

CLIENT American Electric Power		PROJECT Sporn Fly Ash and Bottom Ash Pond Complex								
SITE Philip Sporn Power Plant New Haven, West Virginia										
GRAPHIC LOG	DESCRIPTION	DEPTH, ft.	USCS SYMBOL	SAMPLES				TESTS		
				NUMBER	TYPE	RECOVERY, in.	SPT - N** BLOWS / ft.	WATER CONTENT, %	DRY UNIT WT pcf	UNCONFINED STRENGTH, psf
 	FILL , bottom ash, gray to black, medium dense to very loose, wet, fine sand to silt size particles	35	SP 14	SS	18	9				
			SP 15	SS	18	11				
			40	SP 16	SS	18	WOT			
				CL 17	SS	18	9			
			45	CL 18	ST					800 psi/15 sec
	LEAN CLAY , dark gray, stiff, very moist to wet, high silt content		CL 19	SS	18	9				
			CL 20	SS	18	10				
	BORING COMPLETED	50								

REVISED BORING LOGS: SPORN BOTTOM ASH POND COMPLEX.GPJ, TERRACON.LGDT, 3/3/09

The stratification lines represent the approximate boundary lines between soil and rock types: in-situ, the transition may be gradual. *Calibrated Hand Penetrometer
**CME 140H SPT automatic hammer

WATER LEVEL OBSERVATIONS, ft		
WL	∇ 23	WD ∇ 14.5 24 hr
WL	∇	∇
WL		



BORING STARTED	2-18-09	
BORING COMPLETED	2-19-09	
RIG	Track	FOREMAN
LOGGED	LE	JOB # N2095019

LOG OF BORING NO. PZ-09-05

CLIENT American Electric Power		PROJECT Sporn Fly Ash and Bottom Ash Pond Complex									
SITE Philip Sporn Power Plant New Haven, West Virginia		Boring Location: 717959.368, 1735750.984									
GRAPHIC LOG	DESCRIPTION		DEPTH, ft.	SAMPLES				TESTS			
	Approx. Surface Elev.: 593.453 ft			USCS SYMBOL	NUMBER	TYPE	RECOVERY, in.	SPT - N** BLOWS / ft.	WATER CONTENT, %	DRY UNIT WT pcf	UNCONFINED STRENGTH, psf
	0.5	ASPHALT		593							
	1.4	FILL, stabilized and compacted bottom ash		592							
	2.5	FILL, silty sand with gravel, yellowish brown and gray, dense, dry to moist		591	SM 1	SS	15	47			
		FILL, silty sand with bottom ash, trace gravel, dark brown to black, medium dense, moist			SM 2	SS	18	25			
	5										
	6.5	FILL, silty sand with gravel, trace bottom ash and coal, yellowish brown, dense, moist, fine to coarse grained sand		587	SM 3	SS	18	46			
	9.5	Trace clay at 8.5'		584	CL 4	SS	17	43			
	10										
	11	FILL, silty sand with bottom ash and gravel, reddish brown to black, dense to medium dense, moist to wet, fine to coarse grained sand, cobbles present		582.5	SM 5	SS	17	50/5			
	15				SM 6	SS	2	50/2			
		Clay seam at 17'			SM 7	SS	18	32			
	20				SM 8	SS	18	15			
					SM 9	SS	18	22			
25			SM 10	SS	18	12					
			SM 11	SS	18	6					
30			SM 12	SS	18	8					
			SM 13	SS	18	3					
26	FILL, silty sand with bottom ash, trace gravel, dark gray to black, loose to very loose, wet, fine grained sand, silt size particles	567.5									

Continued Next Page

The stratification lines represent the approximate boundary lines between soil and rock types: in-situ, the transition may be gradual.

*Calibrated Hand Penetrometer
**CME 140H SPT automatic hammer

REVISED BORING LOGS - SPORN BOTTOM ASH POND COMPLEX.GPJ TERRACON.GDT 2/16/09

WATER LEVEL OBSERVATIONS, ft		
WL	▽ 15	WD
		▽ 20
WL	▽ 29.8	20 hr
		▽
WL		



BORING STARTED		2-16-09
BORING COMPLETED		2-16-09
RIG	Track	FOREMAN
LOGGED	LE	JOB # N2095019

LOG OF BORING NO. PZ-09-05

CLIENT		American Electric Power		PROJECT							
SITE		Philip Sporn Power Plant New Haven, West Virginia		Sporn Fly Ash and Bottom Ash Pond Complex							
GRAPHIC LOG	DESCRIPTION	DEPTH, ft.	SAMPLES					TESTS			
			USCS SYMBOL	NUMBER	TYPE	RECOVERY, in.	SPT - N** BLOWS / ft.	WATER CONTENT, %	DRY UNIT WT pcf	UNCONFINED STRENGTH, psf	
	34.5 LEAN CLAY with SAND, light brown and gray mottled to brown and gray mottled, soft to stiff, wet to very moist Sand content increase with depth	559	SM	14	SS	18	2				
		35	CL	15	SS	18	14		2000*		
		40	CL	16	ST	17.5				800-psi/10 sec	
				CL	17	SS	6	6		500*	
				CL	18	SS	18	14			
				SC	19	SS	18	8			
	45 CLAYEY SAND, reddish brown and gray mottled, medium dense to loose, very moist to wet, fine grained sand	548.5									
			SC	20	SS	18	8				
	50 BORING COMPLETED	543.5									

REVISED BORING LOGS: SPORN BOTTOM ASH POND COMPLEX.GPJ TERRACON.GDT 3/3/09

The stratification lines represent the approximate boundary lines between soil and rock types: In-situ, the transition may be gradual.

*Calibrated Hand Penetrometer
**CME 140H SPT automatic hammer

WATER LEVEL OBSERVATIONS, ft			
WL	∇ 15	WD	∇ 20 AB
WL	∇ 29.8	20 hr	∇
WL			



BORING STARTED	2-16-09
BORING COMPLETED	2-16-09
RIG	Track FOREMAN
LOGGED	LE JOB # N2095019

Well Development Log



H. C. NUTTING

A Terracon COMPANY

790 Morrison Road • Columbus, OH 43230 • (614) 883-3113

JOB **N2095019**

SHEET NO. _____ OF _____

CALCULATED BY **JCE** DATE **2/21/09**

CHECKED BY _____ DATE _____

SCALE **NTS**


American Electric Power

Sporn Plant

Date Well Installed: **Feb. 21, 2009**

PZ-09-01

Initial GW Elev. Prior to Well Development **18.1' B.G.S.**



2/21/09

- 6:15 pm Initial H₂O Rdy - Water @ 18.1' BGS
- Surge Well w/ 3' long by 1" PVC Surge Block
- 6:20 Initial Pumping - No Sediment Noted
- 6:30 - 6:35 pm Pump 15 ± gals Dark brown heavily silted H₂O w/ fine sand - Well Depleted

*** Well Volume ***
 • 1 1/2" ID screen & riser
 0.09 gals/L.F.
 • 32.2' x 0.09 = 2.9 gals.
 Min. development volume
 3 x 2.9 gals = 8.7 gals.

- 6:35 - 6:45 pm Pump 10 ± gals Brown heavily silted H₂O w/ fine sand while adding 20 ± gals potable H₂O to top of well
- 6:45 - 6:50 pm Pump 5 ± gals Brown moderately to slightly silty H₂O w/ some fine sand
- 6:50 - 7:00 pm Allow well to recharge
- 7:00 - 7:10 pm Pump 10 ± gals Brown moderately silty H₂O w/ some fine sand
- 7:10 - 7:35 pm Allow well to recharge
- 7:35 pm H₂O Rdy - Water @ 22.5' BGS

7:40 - 7:55 pm Pump 10 ± gals Brown moderately to slightly silty H₂O w/ some trace fine sand. Well nearly depleted.
 Well Development Complete 8:00 pm

2/23/09

7:45 pm H₂O @ **18.0' B.G.S.**

• 20 ± gals potable H₂O added to well during development.
 • 50 ± gals H₂O pumped from well during development.

H₂O Rdy 2/25/09 11:30 am 18.0' BGS

Bottom of Well **50.3' B.G.S.**

Well Development Log



H. C. NUTTING

A Terracon Company

790 Morrison Road • Columbus, OH 43230 • (614) 863-3113

JOB **N20950.19**

SHEET NO. 1

CALCULATED BY **JCE**

CHECKED BY

SCALE **NTS**

OF 1

DATE **2/21/09**

DATE

American Electric Power

Sporn Plant

(PZ-09-02)

Date Well Installed: Feb. 20, 2009

Initial GW Elev. Prior to Well Development **16.0' B.G.S.**



Level surface / Top of Vault
 Top of well Riser

0.0' B.G.S.

0.44' B.G.S. (5 1/4")

2/21/09

• 4:35 PM Initial H₂O Rdy 16.0' BGS

Sediment noted in Bottom of Well

• Well surged w/ 3' long by 1" Ø PVC surge block

• 4:45 PM Initiate Pumping

4:45 - 5:00 pm Pumped 15± gals of Dark

Brown heavily silted H₂O w/ fine sand

- Well depleted - Recharge for 5 mins.

* 5:05 - 5:15 pm Pumped 10± gals Brown heavily silted H₂O w/ fine sand while adding 15± gals potable H₂O to top of well

• 5:15 - 5:25 pm Pump 10± Brown moderately silty then back to heavily silted H₂O w/ fine sand - Well depleted.

* 5:25 to 5:30 pm Pump 5± gals Br. heavily silted H₂O while adding 5± gals potable H₂O to top of well.

* 5:30 to 5:35 pm Add 10± gals potable H₂O to top of well.

• 5:35 - 5:45 pm Pump 10± gals Brown moderately to slightly silty H₂O w/ some fine sand - Suspend Pumping

▼ 5:45 pm H₂O @ 18.8' BGS

▼ 5:50 pm H₂O @ 18.0' BGS

▼ 6:05 pm H₂O @ 17.2' BGS

Development Complete

2/23/09

▼ 2:30 pm H₂O @ 21.2' BGS

▼ H₂O Rdy 2/25/09 12:00 pm 22.3' BGS

- Bottom of Well 34.7' B.G.S.

* Well Volume *

• 1 1/2' ID Screen & Riser

0.09 gals/L.F.

• 18.7' x 0.09 = 1.7 gals.

Min. development volume

3 x 1.7 gals = 5.1 gals.

30± gals H₂O Added to well during development

50± Total gals H₂O pumped from well during development

Well Development Log



H. C. NUTTING

A Terracon Company

790 Morrison Road • Columbus, OH 43230 • (614) 863-3113

JOB **N2095019**

SHEET NO. 1 OF 1

CALCULATED BY **JCE** DATE **2/19/09**

CHECKED BY _____ DATE **2/20/09**

SCALE **NTS**

American Electric Power


Sporn Plant

Date Well Installed: Feb. 18, 2009

PZ-09-03

Initial GW Elev. Prior to Well Development

16.8' B.G.S.



0.0' B.G.S.

1.04' B.G.S. (13 5/8")

2/19/09

- 9:00 AM Initial H₂O Rdy - water @ 16.8' B.G.S. Surged well w/ 3' long PVC 1" Ø Surge Blade. Sediment in well to 47.6' ± B.G.S.

- 11:00 AM Intake pumping set up. 11:00 - 11:30 AM Pump 15 ± gals Gray heavily silted H₂O w/ fine sand - Agitate well.

- 11:30 - 12:00 PM Pump 15 ± gals Gray heavily silted H₂O w/ fine sand.
- 12:00 - 12:45 PM Pump 45 ± gals Gray heavily to moderately silty H₂O w/ fine sand - Sand content diminishing.

▼ H₂O reading 2:00 pm after allowing well to settle. 17.0' ± B.G.S.

- 2:00 - 2:30 PM Pump 20 ± gals Gray heavily to moderately silty H₂O w/ fine sand.

▼ H₂O Rdy 2:30 pm 16.9' ± B.G.S. Suspend development

2/20/09

▼ H₂O Rdy 5:30 pm 16.9' ± B.G.S. Sediment in well to 48.0' ±

* Jetted well to suspend sediment w/ 5 to 10 gals potable H₂O

- Resume pumping - All sediment in suspension.

- 5:40 - 6:00 PM Pump 20 ± gals Heavily silted H₂O w/ fine sand.

- 6:00 - 6:30 PM Pump 30 gals Gray heavily then moderately silty H₂O w/ fine sand - Sand content diminishing.

- 6:30 - 6:45 PM Pump 15 ± gals Gray moderately to slightly silty H₂O w/ some fine sand.

▼ H₂O level @ completion 6:50 pm 17.0' ± B.G.S.

5 to 10 gals H₂O added to well during jetting / 16.0' ± total gals H₂O pumped during development

- Bottom of Well

50.4' B.G.S.

* Well Volume *

- 1 1/2" ID Screen & Riser

0.09 gals/L.F.

- 34.2' X 0.09 = 3.1 gals.

Min. development volume

3 X 3.1 = 9.3 gals.

Well Development Log



H. C. NUTTING

A Terracon COMPANY

790 Morrison Road • Columbus, OH 43230 • (614) 863-3113

JOB **N2095019**

SHEET NO. **1** OF **1**

CALCULATED BY **JCE**

DATE **2/21/09**

CHECKED BY **-**

DATE **-**

SCALE **NTS**


American Electric Power

Sporn Plant

Date Well Installed: Feb. 19, 2009

PZ-09-04

Initial GWElev. Prior to Well Development **14.1' B.G.S.**



0.0' B.G.S.
0.59' B.G.S. (17.18")

2/21/09

- 2:50 pm Initial H₂O Rdg. Water @ 14.1' B.G.S. Surge well w/ 3' long by 1" Ø PVC surge block
- 2:55 pm Initiate Pumping
- 2:55 - 3:05 pm Pumped 10 gals. Dark gray very heavily silted H₂O w/ fine sand
- 3:05 - 3:25 pm Pumped 25 ± gals Gray heavily silted H₂O w/ fine sand
- 3:25 pm - 3:40 pm Pumped 20 ± gals Gray to Lt. gray moderately silty H₂O w/ some fine sand
- 3:40 - 4:05 pm Pumped 25 ± gals Lt. gray moderately to slightly silty H₂O w/ some fine sand
- 4:05 - 4:15 pm Pumped 10 ± gals Lt. gray slightly silty H₂O w/ some fine sand

* Well Volume *	
• 1 1/2' ID Screen & Riser	0.09 gals/L.F.
• 35.7' x 0.09	= 3.2 gals.
Min. development volume	3' x 3.2' = 9.6 gals.

H₂O Rdg. 4:25 pm Water @ 14.5' B.G.S.

90 ± Total gals. H₂O pumped from well during development

Development complete 4:25 pm

Bottom of Well **49.8' B.G.S.**

Well Development Log



H. C. NUTTING

A TERRACON COMPANY

790 Morrison Road • Columbus, OH 43230 • (614) 863-3113

JOB **N2095019**

SHEET NO. 1 OF 1

CALCULATED BY JCE DATE 2/20/09

CHECKED BY --- DATE ---

SCALE NTS


American Electric Power

Sporn Plant

Date Well Installed: Feb. 17, 2009

PZ-09-05

Initial GW Elev. Prior to Well Development **15.7' B.G.S.**



*** Well Volume ***
 • 1 1/2' ID screen & riser
 0.09 gals/L.F.
 • 3 1/2' x 0.09 = 3.1 gals.
 Min. development volume
 3 x 3.1 = 9.3 gals.

- 2:20 pm Initial H₂O Rdn - water @ 15.7' B.G.S. Surge well w/ 3' long PVC 1" Ø surge block
- 2:35 pm Initiate Pumping
 2:35 - 3:00 pm Pump 20 gals Brown/Gray heavily silted H₂O w/ fine sand
- ▶ Sediment in well to 46.5' ± B.G.S.
- * Jetted well w/ 5 to 10 gallons potable H₂O to suspend sediment
- Resume Pumping
 3:25 pm - 3:40 pm Pumped 15 ± gallons Brown/gray heavily silted H₂O w/ fine sand
- 3:40 pm - 4:00 pm Pumped 20 ± gallons Brown to light brown moderately silty H₂O w/ some fine sand
- 4:00 pm - 4:20 pm Pumped 20 ± gallons light brown moderately to slightly silty H₂O w/ trace fine sand
- 4:20 pm - 4:35 pm Pumped 15 ± gallons light brown slightly silty H₂O w/ trace fine sand

▼ H₂O level immediately after pumping **15.9' B.G.S.**

▶ 5 to 10 gallons H₂O added to well during jetting.

90 ± gals. Total H₂O Pumped from well during development

(2/20/09 4:40 pm Development Complete)

Bottom of Well **50.2' B.G.S.**

TERRACON PROJECT NO. N2095019

PROJECT SPORN FLY ASH AND BOTTOM ASH POND COMPLEX

SUMMARY ELEVATIONS
(FT. NGVD)


COORDINATES 721044.45 N/1735346.82 E (NAD 27)(NGVD29 WV N)

DATE INSTALLED 02/21/09

PIEZOMETER NO. PZ-09-01

REF. DATUM PT.:
TOP OF PROTECTIVE
VAULT/GROUND SURFACE

REF. DATUM PT. _____



- 1 GROUT SEAL MATERIAL: CEMENT BENTONITE
- 2 BENTONITE SEAL MATERIAL: BENTONITE CHIPS
- 3 SCREEN SIZE: 0.010" SLOT
- 4 GRAVEL PACK MATERIAL: #5 QUARTZ SAND
- 5 BOREHOLE DIAMETER 7"
6" MIN.
- 6 1.92" DIA. PVC CASING (O.D.)
- 7 CONCRETE PAD DIMENSIONS: 3'x3'x8" THICK (MIN.)
- 8 PROTECTIVE STEEL H2 RATED VAULT COVER

GRADE 0' (600.82')

DEPTH (ELEV.)

TOP OF BENTONITE SEAL 4.0' (596.82')

TOP OF GRAVEL PACK 5.0' (595.82')

TOP OF SCREEN 6.0' (594.82')

BOTTOM OF SCREEN 50.3' (550.52')

BOTTOM OF BLANK SEC. N/A

BOTTOM OF GRAVEL PACK 51.0' (549.82')

BOTTOM OF BOREHOLE 51.0' (549.82')

NOTE: DEPTHS OF MATERIALS ARE TAKEN FROM TOP OF VAULT/GROUND SURFACE

SCALE: NTS

GEOTECHNICAL ENGINEERING SECTION CIVIL DESIGN STANDARD		REVISION 0		OBSERVATION WELL	
APP'D.	DR.	C.K.	DATE		
AMERICAN ELECTRIC POWER SERVICE CORP.				CDS-04A	SH.

AMERICAN ELECTRIC POWER
SPORN FLY ASH AND BOTTOM ASH POND COMPLEX

GEOLOGIST/ENGINEER:
LEWIS EPLIN H.C. NUTTING CO.

TERRACON PROJECT NO. N2095019

PROJECT SPORN FLY ASH AND BOTTOM ASH POND COMPLEX

SUMMARY ELEVATIONS
(FT. NGVD)


COORDINATES 720305.06 N/1735649.89 E (NAD 27)(NGVD29 WV N)

DATE INSTALLED 02/20/09

PIEZOMETER NO. PZ-09-02

REF. DATUM PT.:
TOP OF PROTECTIVE
VAULT/GROUND SURFACE

REF. DATUM PT. _____



- 1 GROUT SEAL MATERIAL: CEMENT BENTONITE
- 2 BENTONITE SEAL MATERIAL: BENTONITE CHIPS
- 3 SCREEN SIZE: 0.010" SLOT
- 4 GRAVEL PACK MATERIAL: #5 QUARTZ SAND
- 5 BOREHOLE DIAMETER 7"
6" MIN.
- 6 1.92" DIA. PVC CASING (O.D.)
- 7 CONCRETE PAD DIMENSIONS: 3'x3'x8" THICK (MIN.)
- 8 PROTECTIVE STEEL H2 RATED VAULT COVER

NOTE: DEPTHS OF MATERIALS ARE TAKEN FROM TOP OF VAULT/GROUND SURFACE

SCALE: NTS

GEOTECHNICAL ENGINEERING SECTION
CIVIL DESIGN STANDARD

REVISION

0

OBSERVATION WELL

APP'D.

DR.

C.K.

DATE

AMERICAN ELECTRIC POWER SERVICE CORP.

CDS-04A

SH.

AMERICAN ELECTRIC POWER
SPORN FLY ASH AND BOTTOM ASH POND COMPLEX

GEOLOGIST/ENGINEER:

LEWIS EPLIN H.C. NUTTING CO.

AEPSPP003376

TERRACON PROJECT NO. N2095019

PROJECT SPORN FLY ASH AND BOTTOM ASH POND COMPLEX

SUMMARY ELEVATIONS
(FT. NGVD)


COORDINATES 718399.12 N/1736131.92 E (NAD 27)(NGVD29 WV N)

PIEZOMETER NO. PZ-09-03

DATE INSTALLED 02/18/09

REF. DATUM PT. _____

REF. DATUM PT.:
TOP OF PROTECTIVE
VAULT/GROUND SURFACE



- 1 GROUT SEAL MATERIAL: CEMENT BENTONITE
- 2 BENTONITE SEAL MATERIAL: BENTONITE CHIPS
- 3 SCREEN SIZE: 0.010" SLOT
- 4 GRAVEL PACK MATERIAL: #5 QUARTZ SAND
- 5 BOREHOLE DIAMETER 7"
6" MIN.
- 6 1.92" DIA. PVC CASING (O.D.)
- 7 CONCRETE PAD DIMENSIONS: 3'x3'x8" THICK (MIN.)
- 8 PROTECTIVE STEEL H2 RATED VAULT COVER

- DEPTH (ELEV.)
- TOP OF BENTONITE SEAL 4.0' (592.52')
- TOP OF GRAVEL PACK 5.0' (591.52')
- TOP OF SCREEN 6.0' (590.52')
- BOTTOM OF SCREEN 50.4' (546.12')
- BOTTOM OF BLANK SEC. N/A
- BOTTOM OF GRAVEL PACK 51.0' (545.52')
- BOTTOM OF BOREHOLE 51.0' (545.52')

NOTE: DEPTHS OF MATERIALS ARE TAKEN FROM TOP OF VAULT/GROUND SURFACE

SCALE: NTS

GEOTECHNICAL ENGINEERING SECTION CIVIL DESIGN STANDARD		REVISION 0		OBSERVATION WELL	
APP'D.	DR.	C.K.	DATE		
AMERICAN ELECTRIC POWER SERVICE CORP.				CDS-04A	SH.

AMERICAN ELECTRIC POWER
SPORN FLY ASH AND BOTTOM ASH POND COMPLEX

GEOLOGIST/ENGINEER:
LEWIS EPLIN H.C. NUTTING CO.

TERRACON PROJECT NO. N2095019

PROJECT SPORN FLY ASH AND BOTTOM ASH POND COMPLEX

SUMMARY ELEVATIONS
(FT. NGVD)

COORDINATES 718150.72 N/1736258.64 E (NAD 27)(NGVD29 WV N)


PIEZOMETER NO. PZ-09-04

DATE INSTALLED 02/19/09

REF. DATUM PT. _____

REF. DATUM PT.:
TOP OF PROTECTIVE
VAULT/GROUND SURFACE

GROUND SURFACE/TOP OF PAD _____ GRADE 0' (593.69')



- 1 GROUT SEAL MATERIAL: CEMENT BENTONITE
- 2 BENTONITE SEAL MATERIAL: BENTONITE CHIPS
- 3 SCREEN SIZE: 0.010" SLOT
- 4 GRAVEL PACK MATERIAL: #5 QUARTZ SAND
- 5 BOREHOLE DIAMETER 7"
6" MIN.
- 6 1.92" DIA. PVC CASING (O.D.)
- 7 CONCRETE PAD DIMENSIONS: 3'x3'x8" THICK (MIN.)
- 8 PROTECTIVE STEEL H2 RATED VAULT COVER

DEPTH (ELEV.)

TOP OF BENTONITE SEAL 3.5' (590.19')

TOP OF GRAVEL PACK 4.5' (589.19')

TOP OF SCREEN 5.5' (588.19')

BOTTOM OF SCREEN 49.8' (543.89')

BOTTOM OF BLANK SEC. N/A

BOTTOM OF GRAVEL PACK 51.0' (542.69')

BOTTOM OF BOREHOLE 51.0' (542.69')

NOTE: DEPTHS OF MATERIALS ARE TAKEN FROM TOP OF VAULT/GROUND SURFACE

SCALE: NTS

GEOTECHNICAL ENGINEERING SECTION CIVIL DESIGN STANDARD		REVISION <u>0</u>		OBSERVATION WELL	
APP'D.	DR.	C.K.	DATE		
AMERICAN ELECTRIC POWER SERVICE CORP.				CDS-04A	SH.

AMERICAN ELECTRIC POWER
SPORN FLY ASH AND BOTTOM ASH POND COMPLEX

GEOLOGIST/ENGINEER:
LEWIS EPLIN H.C. NUTTING CO.

TERRACON PROJECT NO. N2095019

PROJECT SPORN FLY ASH AND BOTTOM ASH POND COMPLEX

SUMMARY ELEVATIONS
(FT. NGVD)

COORDINATES 717961.56 N/1735749.39 E (NAD 27)(NGVD29 WV N)


DATE INSTALLED 02/17/09

PIEZOMETER NO. PZ-09-05

REF. DATUM PT.:
TOP OF PROTECTIVE
VAULT/GROUND SURFACE

REF. DATUM PT. _____

GROUND SURFACE/TOP OF PAD _____ GRADE 0' (593.45')



- 1 GROUT SEAL MATERIAL: CEMENT BENTONITE
- 2 BENTONITE SEAL MATERIAL: BENTONITE CHIPS
- 3 SCREEN SIZE: 0.010" SLOT
- 4 GRAVEL PACK MATERIAL: #5 QUARTZ SAND
- 5 BOREHOLE DIAMETER 7"
6" MIN.
- 6 1.92" DIA. PVC CASING (O.D.)
- 7 CONCRETE PAD DIMENSIONS: 3'x3'x8" THICK (MIN.)
- 8 PROTECTIVE STEEL H2 RATED VAULT COVER

DEPTH (ELEV.)

TOP OF BENTONITE SEAL 3.2' (590.25')

TOP OF GRAVEL PACK 4.2' (589.25')

TOP OF SCREEN 5.2' (588.25')

BOTTOM OF SCREEN 50.2' (543.25')

BOTTOM OF BLANK SEC. N/A

BOTTOM OF GRAVEL PACK 51.0' (542.45')

BOTTOM OF BOREHOLE 51.0' (542.45')

NOTE: DEPTHS OF MATERIALS ARE TAKEN FROM TOP OF VAULT/GROUND SURFACE.

SCALE: NTS

GEOTECHNICAL ENGINEERING SECTION CIVIL DESIGN STANDARD		REVISION 0		OBSERVATION WELL	
APP'D.	DR.	C.K.	DATE		
AMERICAN ELECTRIC POWER SERVICE CORP.				CDS-04A	SH.

AMERICAN ELECTRIC POWER
SPORN FLY ASH AND BOTTOM ASH POND COMPLEX

GEOLOGIST/ENGINEER:
LEWIS EPLIN H.C. NUTTING CO.

GENERAL NOTES

DRILLING & SAMPLING SYMBOLS:

SS:	Split Spoon - 1-3/8" I.D., 2" O.D., unless otherwise noted	HS:	Hollow Stem Auger
ST:	Thin-Walled Tube - 2" O.D., unless otherwise noted	PA:	Power Auger
RS:	Ring Sampler - 2.42" I.D., 3" O.D., unless otherwise noted	HA:	Hand Auger
DB:	Diamond Bit Coring - 4", N, B	RB:	Rock Bit
BS:	Bulk Sample or Auger Sample	WB:	Wash Boring or Mud Rotary

The number of blows required to advance a standard 2-inch O.D. split-spoon sampler (SS) the last 12 inches of the total 18-inch penetration with a 140-pound hammer falling 30 inches is considered the "Standard Penetration" or "N-value".

WATER LEVEL MEASUREMENT SYMBOLS:

WL:	Water Level	WS:	While Sampling	N/E:	Not Encountered
WCI:	Wet Cave in	WD:	While Drilling		
DCI:	Dry Cave in	BCR:	Before Casing Removal		
AB:	After Boring	ACR:	After Casing Removal		

Water levels indicated on the boring logs are the levels measured in the borings at the times indicated. Groundwater levels at other times and other locations across the site could vary. In pervious soils, the indicated levels may reflect the location of groundwater. In low permeability soils, the accurate determination of groundwater levels may not be possible with only short-term observations.

DESCRIPTIVE SOIL CLASSIFICATION: Soil classification is based on the Unified Classification System. Coarse Grained Soils have more than 50% of their dry weight retained on a #200 sieve; their principal descriptors are: boulders, cobbles, gravel or sand. Fine Grained Soils have less than 50% of their dry weight retained on a #200 sieve; they are principally described as clays if they are plastic, and silts if they are slightly plastic or non-plastic. Major constituents may be added as modifiers and minor constituents may be added according to the relative proportions based on grain size. In addition to gradation, coarse-grained soils are defined on the basis of their in-place relative density and fine-grained soils on the basis of their consistency.

CONSISTENCY OF FINE-GRAINED SOILS

<u>Unconfined Compressive Strength, Qu, psf</u>	<u>Standard Penetration or N-value (SS) Blows/Ft.</u>	<u>Consistency</u>
< 500	0 - 1	Very Soft
500 - 1,000	2 - 4	Soft
1,000 - 2,000	4 - 8	Medium Stiff
2,000 - 4,000	8 - 15	Stiff
4,000 - 8,000	15 - 30	Very Stiff
8,000+	> 30	Hard

RELATIVE DENSITY OF COARSE-GRAINED SOILS

<u>Standard Penetration or N-value (SS) Blows/Ft.</u>	<u>Relative Density</u>
0 - 3	Very Loose
4 - 9	Loose
10 - 29	Medium Dense
30 - 49	Dense
> 50	Very Dense

RELATIVE PROPORTIONS OF SAND AND GRAVEL

<u>Descriptive Term(s) of other constituents</u>	<u>Percent of Dry Weight</u>
Trace	< 15
With	15 - 29
Modifier	> 30

GRAIN SIZE TERMINOLOGY

<u>Major Component of Sample</u>	<u>Particle Size</u>
Boulders	Over 12 in. (300mm)
Cobbles	12 in. to 3 in. (300mm to 75 mm)
Gravel	3 in. to #4 sieve (75mm to 4.75 mm)
Sand	#4 to #200 sieve (4.75mm to 0.075mm)
Silt or Clay	Passing #200 Sieve (0.075mm)

RELATIVE PROPORTIONS OF FINES

<u>Descriptive Term(s) of other constituents</u>	<u>Percent of Dry Weight</u>
Trace	< 5
With	5 - 12
Modifiers	> 12

PLASTICITY DESCRIPTION

<u>Term</u>	<u>Plasticity Index</u>
Non-plastic	0
Low	1-10
Medium	11-30
High	> 30.

Terracon

UNIFIED SOIL CLASSIFICATION SYSTEM

Criteria for Assigning Group Symbols and Group Names Using Laboratory Tests^A

				Soil Classification		
				Group Symbol	Group Name ^B	
Coarse Grained Soils More than 50% retained on No. 200 sieve	Gravels More than 50% of coarse fraction retained on No. 4 sieve	Clean Gravels Less than 5% fines ^C	$Cu \geq 4$ and $1 \leq Cc \leq 3^E$	GW	Well-graded gravel ^F	
			$Cu < 4$ and/or $1 > Cc > 3^E$	GP	Poorly graded gravel ^F	
		Gravels with Fines More than 12% fines ^C	Fines classify as ML or MH Fines classify as CL or CH	GM	GC	Silty gravel ^{F,G,H} Clayey gravel ^{F,G,H}
	Sands 50% or more of coarse fraction passes No. 4 sieve	Clean Sands Less than 5% fines ^C	$Cu \geq 6$ and $1 \leq Cc \leq 3^E$	SW	Well-graded sand ^I	
			$Cu < 6$ and/or $1 > Cc > 3^E$	SP	Poorly graded sand ^I	
		Sands with Fines More than 12% fines ^C	Fines classify as ML or MH Fines classify as CL or CH	SM	SC	Silty sand ^{F,H,I} Clayey sand ^{F,H,I}
Fine-Grained Soils 50% or more passes the No. 200 sieve	Silt and Clays Liquid limit less than 50	inorganic	$PI > 7$ and plots on or above "A" line ^I $PI < 4$ or plots below "A" line ^I	CL	ML	Lean clay ^{K,L,M} Silt ^{K,L,M}
		organic	Liquid limit - oven dried	< 0.75	OL	Organic clay ^{K,L,M,N}
			Liquid limit - not dried		OH	Organic silt ^{K,L,M,O}
		Silt and Clays Liquid limit 50 or more	inorganic	PI plots on or above "A" line PI plots below "A" line	CH	MH
	organic		Liquid limit - oven dried	< 0.75	OH	Organic clay ^{K,L,M,P}
			Liquid limit - not dried		OH	Organic silt ^{K,L,M,Q}
	Highly organic soils		Primarily organic matter, dark in color, and organic odor			PT

^ABased on the material passing the 3-in. (75-mm) sieve

^BIf field sample contained cobbles or boulders, or both, add "with cobbles or boulders, or both" to group name.

^CGravels with 5 to 12% fines require dual symbols: GW-GM well-graded gravel with silt, GW-GC well-graded gravel with clay, GP-GM poorly graded gravel with silt, GP-GC poorly graded gravel with clay.

^DSands with 5 to 12% fines require dual symbols: SW-SM well-graded sand with silt, SW-SC well-graded sand with clay, SP-SM poorly graded sand with silt, SP-SC poorly graded sand with clay

^E $Cu = D_{60}/D_{10}$ $Cc = \frac{(D_{30})^2}{D_{10} \times D_{60}}$

^FIf soil contains $\geq 15\%$ sand, add "with sand" to group name.

^GIf fines classify as CL-ML, use dual symbol GC-GM, or SC-SM.

^HIf fines are organic, add "with organic fines" to group name.

^IIf soil contains $\geq 15\%$ gravel, add "with gravel" to group name.

^JIf Atterberg limits plot in shaded area, soil is a CL-ML, silty clay.

^KIf soil contains 15 to 29% plus No. 200, add "with sand" or "with gravel," whichever is predominant.

^LIf soil contains $\geq 30\%$ plus No. 200 predominantly sand, add "sandy" to group name.


^MIf soil contains $\geq 30\%$ plus No. 200, predominantly gravel, add "gravelly" to group name.

^N $PI \geq 4$ and plots on or above "A" line.

^O $PI < 4$ or plots below "A" line.

^P PI plots on or above "A" line.

^Q PI plots below "A" line.



Terracon

**FIELD DATA COLLECTED BY:
GEO/ENVIRONMENTAL ASSOCIATES, INC.**

DATED: DECEMBER 2009 & JANUARY 2010

GeoEnvironmental Associates, Inc.

Boring No. GA-1A

Page 1 Of 2

PROJECT: AEP Philip Sporn

PROJECT NO: 09-387

Start Date: 12-10-09

Drilling Contractor: Horn and Associates

Finish Date: 12-10-09

Driller: Tom Leininger

Logged By: Seth Frank

Helper: Robert, George

Location: FAP – East Dike section K-K

Drill Type: Diedrich D120 Truck Mounted

Ground Elevation: 619.13' NGVD29

AEP Contacts: Mark King and Ginger MacKnight

Notes: woven fabric approx 0.5' bgs

Thickness of Soil:

NAD27 Coordinates Provided by AEP

Depth Drilled In Rock:

N 719696.84 E 1736037.33

Total Depth of Boring: 69.0'

DEPTH (FEET)		SAMPLE NOS., & SPLIT SPOON RECOVERY	SOIL/BEDROCK DESCRIPTION	BLOW COUNTS AND COMMENTS
FROM	TO			
2.0	2.5	S-1 / 0.4'	Sand, gravel, brown, very dense, damp	50 / 0.5'
4.0	4.6	S-2 / 0.5'	Sand, gravel, brown, very dense, damp	35-50 / 0.1'
6.5	7.0	S-3 / 0.4'	Sand, gravel, brown, very dense, damp	50 / 0.5'
9.0	10.5	S-4 / 0.4'	Sand, gravel, brown, very dense, damp	33-37-31
11.5	13.0	S-5 / 1.4'	Sand, gravel, brown, very dense, damp	35-36-29
14.0	14.5	S-6 / 0.4'	Sand, gravel, brown, very dense, damp	50 / 0.5'
16.5	18.0	S-7 / 1.5'	Sand, clay, brown, medium dense, damp	17-17-13
19.0	20.5	S-8 / 1.5'	Sand, clay, brown, medium dense, damp	20-12-11
20.5	22.0	S-9 / 1.3'	Sand, clay, brown, medium dense, damp	11-14-15
22.0	23.5	S-10 / 1.5'	0 -1.1' Sand, clay, brown / 1.1-1.5' Bottom Ash, sand, black, dense, damp	23-26-20
23.5	25.0	S-11 / 1.5'	Sand, bottom ash streaks, clay, brown streaked black, dense, damp	17-20-17
25.0	26.5	S-12 / 1.5'	Bottom Ash, fly ash, grey-black, dense, moist (approximate start of fly ash)	17-16-16

GeoEnvironmental Associates, Inc.

Project Name/ Job Number: 09-387

Boring Log No.: GA-1A

Page 2 of 2

DEPTH (FEET)		SAMPLE NO., SAMPLE INTERVAL & SPLIT SPOON RECOVERY	SOIL/BEDROCK DESCRIPTION	BLOW COUNTS AND COMMENTS
FROM	TO			
26.5	27.2	ST-1 / 0.7'	Fly Ash, bottom ash, grayish black, wet	W/L ≈ 27' bgs
28.5	31.0	ST-2 / 2.66'	Fly Ash, gray, wet	
31.0	32.5	S-13 / 1.5'	Fly Ash, gray, loose, wet	3-2-3
32.5	35.0	ST-3 / 2.50'	Fly Ash, gray, wet	
35.0	36.5	S-14 / 1.5'	Fly Ash, gray, loose wet	3-3-3
36.5	39.0	ST-4 / 2.60'	Fly Ash, gray, wet	
39.0	40.5	S-15 / 1.5'	Fly Ash, gray, loose, wet	2-3-2
40.5	43.0	ST-5 / 2.55'	Fly Ash, gray, wet	
43.0	44.5	S-16 / 1.5'	Fly Ash, gray, loose, wet	1-3-3
44.5	47.0	ST-6 / 2.55'	Fly Ash, gray, wet	
47.0	48.5	S-17 / 1.5'	Fly Ash, gray, loose, wet	5-4-4
48.5	51.0	ST-7 / 2.41'	Fly Ash, gray, wet	
51.0	52.5	S-18 / 1.5'	Fly Ash, gray, loose, wet	7-2-4
52.5	55.0	ST-8 / 2.55'	Fly Ash, gray, wet	
55.0	56.5	S-19 / 1.5'	Fly Ash, gray, loose, wet	1-3-4
56.5	59.0	ST-9 / 2.37'	Fly Ash, gray, wet	
59.0	60.5	S-20 / 1.5'	0-1.0' Fly Ash, clay, gray 1.0-1.5' Clay, silt, brown, stiff, wet (approximate end of fly ash)	3-4-8
60.5	63.0	ST-10 / 2.49'	Clay, silt, brown	
69.0	70.5	S-21 / 1.5'	Silt, clay, brown, very stiff, moist-wet	6-8-8
			Set Inclinometer at ≈ 69' bgs. Back fill with grout mix: approx 1 unit pcc, 1 unit bentonite, 6.25 units water by weight.	

Geo'Environmental Associates, Inc.

Boring No. GA-1B

Page 1 Of 1

PROJECT: AEP Philip Sporn

PROJECT NO: 09-387

Start Date: 12-11-09

Drilling Contractor: Horn and Associates

Finish Date: 12-14-09

Driller: Tom Leininger

Logged By: Seth Frank

Helper: Robert, George, Jared

Location: FAP – East Dike section K-K

Drill Type: Diedrich D120 Truck Mounted

Ground Elevation: 619.04' NGVD29

AEP Contacts: Mark King and Ginger MacKnight

Notes: woven fabric approx 0.5' bgs

Thickness of Soil:

NAD27 Coordinates Provided by AEP

Depth Drilled In Rock:

N 719704.38 E 1736031.96

Total Depth of Boring: 69.0'

DEPTH (FEET)		SAMPLE NOS., & SPLIT SPOON RECOVERY	SOIL/BEDROCK DESCRIPTION	BLOW COUNTS AND COMMENTS
FROM	TO			
9.0	10.5	S-1 / 1.2'	Sand, gravel, brown, very dense, damp	32-37-35
19.0	20.5	S-2 / 1.5'	Sand, clay, brown – mottled black, medium dense, damp	12-7-9
29.0	30.5	S-3 / 1.5'	Fly Ash, gray, loose, wet	5-4-5
39.0	40.5	S-4 / 1.5'	Fly Ash, gray, very loose, wet	0-1-0
49.0	50.5	S-5 / 1.5'	Fly Ash, gray, loose, wet	2-3-5
59.0	60.5	S-6 / 1.5'	0-1.0 Fly Ash, gray, very loose, wet 1.0-1.5 Clay, silty, brown, soft, damp-moist	0-0-3
69.0	70.5	S-7 / 1.5'	Clay, silty, brown, very stiff, damp-moist	9-10-10
			Set Inclinometer at ≈ 69' bgs. Back fill with grout mix: approx 1 unit pcc, 1 unit bentonite, 6.25 units water by weight.	

GeoEnvironmental Associates, Inc.

Boring No. GA-1C

Page 1 Of 1

PROJECT: AEP Philip Sporn

PROJECT NO: 09-387

Start Date: 12-16-09

Drilling Contractor: Horn and Associates

Finish Date: 12-16-09

Driller: Tom Leininger

Logged By: Seth Frank

Helper: Robert, George, Jared

Location: FAP – East Dike section K-K

Drill Type: Diedrich D120 Truck Mounted

Ground Elevation: 619.03' NGVD29

AEP Contacts: Mark King and Ginger MacKnight

Notes: woven fabric approx 0.5' bgs

Thickness of Soil:

NAD27 Coordinates Provided by AEP

Depth Drilled In Rock:

N 719712.67 E 1736026.24

Total Depth of Boring: 79.0'

DEPTH (FEET)		SAMPLE NOS., & SPLIT SPOON RECOVERY	SOIL/BEDROCK DESCRIPTION	BLOW COUNTS AND COMMENTS
FROM	TO			
9.0	10.5	S-1 / 1.4'	Sand, gravel, brown, very dense, damp	29-30-31
19.0	20.5	S-2 / 1.5'	Sand, clay, brown streaked black, medium dense, damp-moist	9-11-7
29.0	30.5	S-3 / 1.5'	Fly Ash, grayish black, medium dense, wet	9-8-7
35.0		Vane Shear 1	30 lb-ft / 60° 10 lb-ft / 360°	
39.0	41.5	ST-1 / 0.98'	Fly Ash, grey, wet	
42.5		Vane Shear 2	100 lb-ft / 90° 60 lb-ft / 360°	
50.0'		Vane Shear 3	40 lb-ft / 60° 20 lb-ft / 360°	
59.0	60.5	S-4 / 1.5'	Fly Ash, clay, organic material, silty, brownish black, soft, moist-wet	1-1-3
69.0	71.5	ST-2 / 2.58'	Clay, silty, sandy, brown, moist-wet	
79.0	80.5	S-5 / 1.5'	Clay, silty, brown, stiff, wet	5-8-7 1.75 tsf

Set Inclinometer at ≈ 79' bgs. Back fill with grout mix; approx 1

Geo/Environmental Associates, Inc.

Boring No. GA-1D
 Page 1 Of 2

PROJECT: AEP Philip Sporn	PROJECT NO: 09-387
Start Date: 12-16-09	Drilling Contractor: Horn and Associates
Finish Date: 12-17-09	Driller: Tom Leininger
Logged By: Seth Frank	Helper: Robert, George, Jared
Location: FAP – East Dike section K-K	Drill Type: Diedrich D120 Truck Mounted
Ground Elevation: 619.21' NGVD29	AEP Contacts: Mark King and Ginger MacKnight
Notes: woven fabric approx 0.5' bgs	Thickness of Soil:
NAD27 Coordinates Provided by AEP	Depth Drilled In Rock:
N 719729.38 E 1736015.38	Total Depth of Boring: 59.0'

DEPTH (FEET)		SAMPLE NOS., & SPLIT SPOON RECOVERY	SOIL/BEDROCK DESCRIPTION	BLOW COUNTS AND COMMENTS
FROM	TO			
9.0	9.4	S-1 / 0.3'	Sand, gravel, brown, very dense, damp	50 / 0.4'
19.0	20.5	S-2 / 1.4'	Sand, clay, brown streaked black, medium dense, damp-moist	21-14-12
29.0	30.5	ST-1 / 1.17'	Fly Ash, gray, wet	
32.5		Vane Shear 1	10 lb-ft / 60° 10 lb-ft / 360°	
39.0	41.5	ST-2 / 2.48'	Fly Ash, gray, wet	
42.5		Vane Shear 2	30 lb-ft / 60° 20 lb-ft / 360°	
50.5'		Vane Shear 3	30 lb-ft / 60° 20 lb-ft / 360°	
59.0	61.5	ST-3 / 2.36'	Fly Ash, clay, grayish black	

Geo/Environmental Associates, Inc.

Project Name/ Job Number: 09-387

Boring Log No.: GA-1D

Page 2 of 2

DEPTH (FEET)		SAMPLE NO., SAMPLE INTERVAL & SPLIT SPOON RECOVERY	SOIL/BEDROCK DESCRIPTION	BLOW COUNTS AND COMMENTS
FROM	TO			
			Set Piezometer at approximately 60' bgs	
0	0.5		Flush Mount Piezometer Cover	
0.5	23.0		Grout	
23.0	25.0		Bentonite	
25.0	60.0		Prepak Screen Backfilled With Sand	
60.0	61.5		Bentonite mix	
			Water Elevation December 17, 2009: 25.2' bgs	
			Water Elevation January 8, 2010: 25.6' bgs	

Geo'Environmental Associates, Inc.

Boring No. GA-2

Page 1 Of 2

PROJECT: AEP Philip Sporn

PROJECT NO: 09-387

Start Date: 12-17-09

Drilling Contractor: Horn and Associates

Finish Date: 12-18-09

Driller: Tom Leininger

Logged By: Seth Frank

Helper: Robert, George, Jared

Location: FAP – East Dike section M-M

Drill Type: Diedrich D120 Truck Mounted

Ground Elevation: 619.76' NGVD29

AEP Contacts: Mark King and Ginger MacKnight

Notes: woven fabric approx 0.5' bgs

Thickness of Soil:

NAD27 Coordinates Provided by AEP

Depth Drilled In Rock:

N 721075.13 E 1735262.04

Total Depth of Boring: 69.0'

DEPTH (FEET)		SAMPLE NOS., & SPLIT SPOON RECOVERY	SOIL/BEDROCK DESCRIPTION	BLOW COUNTS AND COMMENTS
FROM	TO			
4.0	4.5	S-1 / 0.3'	Sand, gravel, brown, very dense, damp	50 / 0.5'
9.0	9.8	S-2 / 0.5'	Sand, gravel, brown, very dense, damp-moist	35-50 / 0.3'
14.0	14.8	S-3 / 0.6'	Sand, gravel, clay, brown, very dense, damp-moist	29-50 / 0.3'
19.0	20.5	S-4 / 1.4'	Sand, brown, dense, damp	27-22-18
24.0	25.5	S-5 / 1.5'	Sand, bottom ash, black, dense, damp	22-18-14
29.0	30.5	S-6 / 1.5'	Fly Ash, gray, loose, moist-wet	2-4-5
34.0	35.5	S-7 / 1.5'	Fly Ash, gray, very loose, wet	2-1-2
39.0	41.5	ST-1 / 1.10'	Fly Ash, gray, wet	
44.0	45.5	S-8 / 1.5'	Fly Ash, gray, very loose, wet	1-0-2
49.0	50.5	S-9 / 1.5'	Fly Ash, gray, very loose, wet	1-0-0
54.0	55.5	S-10 / 1.5'	Fly Ash, gray, very loose, wet	0-0-0
59.0	61.5	ST-2 / 2.50'	Fly Ash at top of sample – Transition to Silt, clay, sand, brown, moist	

Geo/Environmental Associates, Inc.

Project Name/ Job Number: 09-387

Boring Log No.: GA-2

Page 2 of 2

DEPTH (FEET)		SAMPLE NO., SAMPLE INTERVAL & SPLIT SPOON RECOVERY	SOIL/BEDROCK DESCRIPTION	BLOW COUNTS AND COMMENTS
FROM	TO			
64.0	65.5	S-11 / 1.5'	Sand, clay, brown, medium dense, moist	6-9-8
69.0	71.5	ST-3 / 1.70'	Sand, clay, brown, some gravel at bottom of tube	
			Backfill hole with grout mix	

GeoEnvironmental Associates, Inc.

Boring No. GA-3

Page 1 Of 2

PROJECT: AEP Philip Sporn

PROJECT NO: 09-387

Start Date: 12-17-09

Drilling Contractor: Horn and Associates

Finish Date: 12-17-09

Driller: Tom Leininger

Logged By: Seth Frank

Helper: Robert, George, Jared

Location: FAP – East Dike section L-L

Drill Type: Diedrich D120 Truck Mounted

Ground Elevation: 619.83' NGVD29

AEP Contacts: Mark King and Ginger MacKnight

Notes: woven fabric approx 0.5' bgs

Thickness of Soil:

NAD27 Coordinates Provided by AEP

Depth Drilled In Rock:

N 720258.79 E 1735560.40

Total Depth of Boring: 79.0'

DEPTH (FEET)		SAMPLE NOS., & SPLIT SPOON RECOVERY	SOIL/BEDROCK DESCRIPTION	BLOW COUNTS AND COMMENTS
FROM	TO			
4.0	4.5	S-1 / 0.4'	Sand, gravel, dark brown, very dense, damp	50 / 0.5'
9.0	10.5	S-2 / 1.1'	Sand, gravel, brown, dense, moist	37-31-17
14.0	15.5	S-3 / 1.4'	Sand, clay, brown, dense, damp	23-24-12
19.0	20.5	S-4 / 1.5'	Clay, sand, silt, brown, very stiff, moist-wet	14-13-12 2.5 tsf
24.0	25.5	S-5 / 1.5'	Clay, sand, silt, brown, hard, wet	22-18-14 2.25 tsf
29.0	31.5	ST-1 / 1.51'	Fly Ash, gray	
34.0	35.5	S-6 / 1.5'	Fly Ash, gray, medium dense, wet	6-7-8
39.0	41.5	S-7 / 1.5'	Fly Ash, gray, very loose, wet	3-0-1
44.0	45.5	S-8 / 1.5'	Fly Ash, gray, loose, wet	0-2-3
49.0	51.5	ST-2 / 2.34'	Fly Ash, gray	
54.0	55.5	S-9 / 1.5'	Fly Ash, gray, loose, wet	5-5-5
59.0	60.5	S-10 / 1.5'	0.0-0.1' Ash, clay, gray 0.1-1.5' Clay, silty, sandy, brown, very stiff, moist-wet	7-10-14

Geo'Environmental Associates, Inc.

Boring No. GA-4A

Page 1 Of 2

PROJECT: AEP Philip Sporn

PROJECT NO: 09-387

Start Date: 12-14-09

Drilling Contractor: Horn and Associates

Finish Date: 12-15-09

Driller: Tom Leininger

Logged By: Seth Frank

Helper: Robert, George, Jared

Location: BAP – West Dike section A-A

Drill Type: Diedrich D120 Truck Mounted

Ground Elevation: 593.40' NGVD29

AEP Contacts: Mark King and Ginger MacKnight

Notes: asphalt surface approx 0.5' thick

Thickness of Soil:

NAD27 Coordinates Provided by AEP

Depth Drilled In Rock:

N 717984.64 E 1735736.82

Total Depth of Boring: 49.0'

DEPTH (FEET)		SAMPLE NOS., & SPLIT SPOON RECOVERY	SOIL/BEDROCK DESCRIPTION	BLOW COUNTS AND COMMENTS
FROM	TO			
2.0	2.3	S-1 / 0.3'	Sand, gravel, brown, very dense, damp	50 / 0.3'
4.0	5.5	S-2 / 0.9'	Sand, gravel, clay, brown, medium dense, damp	13-12-13
6.5	8.0	S-3 / 1.5'	0-1.0' Sand, gravel, brown / 1.0-1.5 Bottom Ash, grey-black, dense, damp	33-22-17
9.0	10.5	S-4 / 1.4'	0-1.1' Sand, gravel, bottom ash, brown-black / 1.1-1.4' Sand, clay, dense, damp	25-30-20
11.5	11.9	S-5 / 0.4'	Bottom Ash, clay, black, very dense, damp	50 / 0.4'
14.0	15.5	S-6 / 1.5'	0.5 Sand, gravel, brown, medium dense, damp 0.5 Bottom Ash, clayey, grayish black, medium dense, moist 0.5 Sand, clay, brown, medium dense, wet	19-14-14 W/L ≈ 15' bgs
16.5	18.0	S-7 / 1.4'	Sand, clay, gravel, dark brown, medium dense, wet	15-14-8
19.0	20.5	S-8 / 1.5'	Sand, clay, dark brown, medium dense, wet	18-15-14
20.5	22.0	S-9 / 1.3'	Sand, bottom ash, gravel, brown-black, medium dense, moist	13-11-10
22.0	23.5	S-10 / 1.5'	Sand, brown, medium dense, wet	5-11-12
23.5	25.0	S-11 / 1.5'	Sand, clay, brown-black, loose, wet	3-2-3

GeoEnvironmental Associates, Inc.

Project Name/ Job Number: 09-387

Boring Log No.: GA-4A

Page 2 of 2

DEPTH (FEET)		SAMPLE NO., SAMPLE INTERVAL & SPLIT SPOON RECOVERY	SOIL/BEDROCK DESCRIPTION	BLOW COUNTS AND COMMENTS
FROM	TO			
26.5	28.0	S-13 / 1.5'	Fly Ash, bottom ash mix at top, black transition to grey, very loose, wet (approximate start of fly ash)	4-2-2
28.0	30.5	ST-1 / 2.55'	Fly Ash, gray, wet	
30.5	32.0	S-14 / 1.5'	Fly Ash, gray, very loose, wet	1-1-2
32.0	34.5	ST-2 / 2.24'	Fly Ash, gray, wet	
34.5	36.0	S-15 / 1.5'	0.5' Fly Ash, gray, medium dense, wet (approximate end of fly ash) 0.5' Fly Ash, clay, gray, medium dense, wet 0.5' Clay, sand, brown, very stiff, moist-wet	9-11-9
36.0	38.0	ST-3 / 1.52'	Clay, red-brown, moist	
44.0	45.5	S-16 / 1.5'	Clay, sand, red-brown, very stiff, moist	20-12-10 1.75 tsf
49.0	50.5	S-17 / 1.5'	Clay, sand, brown-gray, stiff, wet	0-3-7 0.75 tsf
			Set inclinometer at ≈ 49' bgs. Back fill with grout mix: approx 1 unit pcc, 1 unit bentonite, 6.25 units water by weight.	

Geo/Environmental Associates, Inc.

Boring No. GA-4B

Page 1 Of 1

PROJECT: AEP Philip Sporn

PROJECT NO: 09-387

Start Date: 12-15-09

Drilling Contractor: Horn and Associates

Finish Date: 12-15-09

Driller: Tom Leininger

Logged By: Seth Frank

Helper: Robert, George, Jared

Location: BAP West Dike section A-A

Drill Type: Diedrich D120 Truck Mounted

Ground Elevation: 593.37' NGVD29

AEP Contacts: Mark King and Ginger MacKnight

Notes: asphalt surface approx 0.5' thick

Thickness of Soil:

NAD27 Coordinates Provided by AEP

Depth Drilled In Rock:

N 717992.94 E 1735731.64

Total Depth of Boring: 49.0'

DEPTH (FEET)		SAMPLE NOS., & SPLIT SPOON RECOVERY	SOIL/BEDROCK DESCRIPTION	BLOW COUNTS AND COMMENTS
FROM	TO			
9.0	10.5	S-1 / 0.4'	Sand, gravel, brown, dense, damp	30-25-18
19.0	20.5	S-2 / 0.5'	Sand, clay, brown – mottled black, medium dense, damp	12-12-14
29.0	31.5	ST-1 / 2.38'	Fly Ash, gray, wet	
32.5		Vain Shear	30 lb-ft / 60° 10 lb-ft / 360°	
39.0	40.5	S-3 / 1.5'	Clay, silty, sandy, grayish brown streaked red, very stiff, moist-wet	4-8-9 1.25 tsf
49.0	50.5	S-4 / 1.5'	Sand, clay, silt, grayish brown, soft, wet	1-1-1
			Set Inclinator at ≈ 49' bgs. Back fill with grout mix: approx 1 unit pcc, 1 unit bentonite, 6.25 units water by weight.	

Geo'Environmental Associates, Inc.

Boring No. GA-4C

Page 1 Of 1

PROJECT: AEP Philip Sporn

PROJECT NO: 09-387

Start Date: 12-15-09

Drilling Contractor: Horn and Associates

Finish Date: 12-15-09

Driller: Tom Leininger

Logged By: Seth Frank

Helper: Robert, George, Jared

Location: BAP West Dike section A-A

Drill Type: Diedrich D120 Truck Mounted

Ground Elevation: 593.34' NGVD29

AEP Contacts: Mark King and Ginger MacKnight

Notes: asphalt surface approx 0.5' thick

Thickness of Soil:

NAD27 Coordinates Provided by AEP

Depth Drilled In Rock:

N 718001.45 E 1735726.53

Total Depth of Boring: 49.0'

DEPTH (FEET)		SAMPLE NOS., & SPLIT SPOON RECOVERY	SOIL/BEDROCK DESCRIPTION	BLOW COUNTS AND COMMENTS
FROM	TO			
9.0	10.5	S-1 / 1.4'	Sand, bottom ash, clay, brownish black, dense, damp	28-19-19
19.0	20.5	S-2 / 1.5'	Bottom Ash, black, medium dense, moist-wet	5-5-10
30.0		Vain Shear	40 lb-ft / 60° 20 lb-ft / 360°	
32.5		Vain Shear	30 lb-ft / 60° 10 lb-ft / 360°	
49.0	50.5	S-3 / 1.5'	Clay, sand, reddish gray, stiff, wet	6-6-4 0.5 tsf
			Set Inclinometer at ≈ 49' bgs. Back fill with grout mix: approx 1 unit pcc, 1 unit bentonite, 6.25 units water by weight.	



Geo/Environmental Associates, Inc.

GA-1A, 1B, & 1C Inclinometer Survey



Project: Fly Ash Pond East Dike Cross Borehole Seismic
GA Job No.: 09-387
Title: Down Hole Inclinometer Survey
Performed By: SWF
Location: N 38.97292 W 081.92823
Date: January 6-7, 2010

Depth (feet)	GA-1A	←Distance (ft)→	GA-1B	←Distance (ft)→	*GA-1C		
	A-Axis Cumulative Deviation (inches)	Based on Top of Pipe Distance = 9.42'	A-Axis Cumulative Deviation (inches)	Based on Top of Pipe Distance = 10.08'	A-Axis Cumulative Deviation (inches)	B-Axis Cumulative Deviation (inches)	Combined A&B Axis Deviation (inches)
2.5	-0.91	9.51	0.22	10.02	0.27	-0.48	-0.53
4.5	-1.81	9.60	0.38	9.96	0.57	-0.98	-1.10
6.5	-2.59	9.67	0.42	9.91	0.88	-1.44	-1.64
8.5	-3.19	9.71	0.29	9.87	1.22	-1.88	-2.19
10.5	-3.57	9.71	-0.14	9.87	1.50	-2.27	-2.66
12.5	-3.95	9.69	-0.71	9.88	1.80	-2.64	-3.14
14.5	-4.40	9.68	-1.27	9.88	2.12	-2.99	-3.62
16.5	-4.92	9.68	-1.83	9.89	2.45	-3.34	-4.09
18.5	-5.49	9.68	-2.40	9.90	2.82	-3.67	-4.59
20.5	-6.03	9.67	-3.08	9.91	3.20	-3.98	-5.08
22.5	-6.58	9.65	-3.79	9.93	3.62	-4.30	-5.60
24.5	-7.17	9.64	-4.57	9.96	3.96	-4.61	-6.06
26.5	-7.75	9.62	-5.34	9.99	4.25	-4.91	-6.47
28.5	-8.14	9.59	-6.04	10.01	4.59	-5.14	-6.89
30.5	-8.41	9.55	-6.87	10.05	4.89	-5.40	-7.27
32.5	-8.74	9.51	-7.70	10.07	5.22	-5.76	-7.77
34.5	-9.22	9.48	-8.45	10.09	5.56	-6.20	-8.31
36.5	-9.82	9.48	-9.11	10.10	5.83	-6.65	-8.83
38.5	-10.46	9.48	-9.78	10.12	6.09	-7.10	-9.33
40.5	-10.91	9.45	-10.55	10.14	6.33	-7.50	-9.78
42.5	-11.35	9.42	-11.29	10.17	6.67	-7.85	-10.27
44.5	-11.93	9.42	-11.99	10.18	7.15	-8.16	-10.82
46.5	-12.64	9.43	-12.57	10.18	7.71	-8.45	-11.43
48.5	-13.35	9.43	-13.18	10.17	8.31	-8.77	-12.07
50.5	-13.91	9.42	-13.95	10.19	8.81	-9.12	-12.67
52.5	-14.41	9.42	-14.37	10.17	9.28	-9.52	-13.30
54.5	-14.94	9.44	-14.67	10.14	9.72	-9.97	-13.93
56.5	-15.55	9.45	-15.17	10.14	10.09	-10.42	-14.50
58.5	-16.20	9.48	-15.50	10.12	10.39	-10.80	-14.98
60.5	-16.82	9.51	-15.72	10.12	10.46	-11.08	-15.23
62.5	-17.42	9.54	-15.96	10.11	10.63	-11.37	-15.56
64.5	-17.98	9.57	-16.23	10.09	11.05	-11.76	-16.12
66.5	-18.46	9.58	-16.53	10.05	11.62	-12.25	-16.87
68.5					12.19	-12.78	-17.66
70.5					12.57	-13.31	-18.30
72.5					12.98	-13.82	-18.95
74.5					13.46	-14.34	-19.66
76.5					14.01	-14.89	-20.43

PHILIP SPORN FLY ASH POND EAST DIKE
 BOREHOLES: GA-1A, 1B, AND 1C
 APPROXIMATE TOP OF PIPE ORIENTATION

(NOT TO SCALE)

TO SPORN UP STREAM (FLY ASH POND) TO MOUNTAINEER





Geo/Environmental Associates, Inc.

GA-4A, 4B, & 4C Inclinator Survey



Project: Bottom Ash Pond West Dike Cross Borehole Seismic
GA Job No.: 09-387
Title: Down Hole Inclinator Survey
Performed By: SWF
Location: N 38.96816 W 081.92926
Date: January 6-7, 2010


GA-4A		←Distance (ft)→	GA-4B		←Distance (ft)→	GA-4C	
Depth (feet)	A-Axis Cumulative Deviation (inches)	Based on Top of Pipe Distance = 9.67'	Depth (feet)	A-Axis Cumulative Deviation (inches)	Based on Top of Pipe Distance = 10.04'	Depth (feet)	A-Axis Cumulative Deviation (inches)
2.5	-0.11	9.67	4	-0.13	10.03	4	-0.24
4.5	-0.17	9.66	6	-0.26	10.02	6	-0.45
6.5	-0.21	9.66	8	-0.35	10.02	8	-0.64
8.5	-0.21	9.65	10	-0.46	10.01	10	-0.76
10.5	-0.15	9.62	12	-0.73	10.03	12	-0.85
12.5	-0.12	9.59	14	-1.06	10.05	14	-0.90
14.5	-0.16	9.57	16	-1.34	10.07	16	-0.97
16.5	-0.18	9.54	18	-1.70	10.10	18	-0.98
18.5	-0.16	9.51	20	-2.11	10.17	20	-0.58
20.5	-0.14	9.47	22	-2.50	10.25	22	-0.03
22.5	-0.05	9.45	24	-2.73	10.29	24	0.22
24.5	0.06	9.42	26	-2.89	10.32	26	0.43
26.5	0.06	9.41	28	-3.09	10.35	28	0.57
28.5	0.12	9.38	30	-3.34	10.37	30	0.63
30.5	0.41	9.32	32	-3.78	10.42	32	0.75
32.5	0.84	9.25	34	-4.19	10.47	34	0.97
34.5	1.18	9.20	36	-4.50	10.52	36	1.27
36.5	1.55	9.15	38	-4.70	10.56	38	1.57
38.5	1.98	9.11	40	-4.79	10.59	40	1.78
40.5	2.42	9.06	42	-4.89	10.60	42	1.82
42.5	2.85	9.02	44	-4.99	10.61	44	1.86
44.5	3.29	8.98	46	-4.96	10.62	46	1.99
46.5	3.82	8.96	48	-4.65	10.62	48	2.27

PHILIP SPORN BOTTOM ASH POND WEST DIKE
BOREHOLES: GA-4A, 4B, AND 4C
APPROXIMATE TOP OF PIPE ORIENTATION

(NOT TO SCALE)

TO SPORN DOWN STREAM (WV 62) TO MOUNTAINEER





GA-1A 619.7
59/0.5 1 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.1 2 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 3 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 4 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 5 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 6 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 7 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 8 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 9 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 10 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 11 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 12 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 13 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 14 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 15 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 16 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 17 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 18 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 19 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 20 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 21 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 22 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 23 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 24 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 25 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 26 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 27 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 28 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 29 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 30 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 31 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 32 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 33 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 34 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 35 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 36 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 37 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 38 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 39 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 40 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 41 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 42 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 43 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 44 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 45 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 46 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 47 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 48 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 49 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 50 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 51 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 52 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 53 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 54 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 55 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 56 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 57 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 58 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 59 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 60 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 61 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 62 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 63 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 64 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 65 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 66 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 67 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 68 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 69 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 70 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 71 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 72 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 73 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 74 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 75 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 76 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 77 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 78 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 79 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 80 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 81 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 82 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 83 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 84 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 85 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 86 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 87 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 88 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 89 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 90 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 91 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 92 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 93 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 94 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 95 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 96 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 97 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 98 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 99 SAND, GRAVEL, BROWN, VERY DENSE, DAMP
59/0.5 100 SAND, GRAVEL, BROWN, VERY DENSE, DAMP

LEGEND

SAMPLED HOLE
100.0 HOLE NUMBER
SURFACE ELEVATION


DRIVE-SAMPLE #1 WITH 7/8" VALVE AS PER A.S.T.M. D1586 UNLESS OTHERWISE NOTED
WATER FIRST ENCOUNTERED DURING DRILLING
WATER LEVEL AT COMPLETION OF DRILLING
WATER LEVEL ON DATE SHOWN

APPROX CHANGE IN TYPE OF MATERIAL
UNSTURBED SAMPLE

BOTTOM ELEVATION OF HOLE
TYPE OF MATERIAL OF HOLE
NO. FEET - NO. FEET OF AUGERS OR SAMPLE TUBE
DRY - DRY UPON COMPLETION
NOTE: THE GRAIN / WATER / NATURAL WATER LEVEL MEASUREMENT.

ABBREVIATIONS

AP - SAND, GRAVEL, BROWN, VERY DENSE, DAMP
AS - SAND, GRAVEL, BROWN, VERY DENSE, DAMP
BS - SAND, GRAVEL, BROWN, VERY DENSE, DAMP
CS - SAND, GRAVEL, BROWN, VERY DENSE, DAMP
DS - SAND, GRAVEL, BROWN, VERY DENSE, DAMP
ES - SAND, GRAVEL, BROWN, VERY DENSE, DAMP
FS - SAND, GRAVEL, BROWN, VERY DENSE, DAMP
GS - SAND, GRAVEL, BROWN, VERY DENSE, DAMP
HS - SAND, GRAVEL, BROWN, VERY DENSE, DAMP
IS - SAND, GRAVEL, BROWN, VERY DENSE, DAMP
JS - SAND, GRAVEL, BROWN, VERY DENSE, DAMP
KS - SAND, GRAVEL, BROWN, VERY DENSE, DAMP
LS - SAND, GRAVEL, BROWN, VERY DENSE, DAMP
MS - SAND, GRAVEL, BROWN, VERY DENSE, DAMP
NS - SAND, GRAVEL, BROWN, VERY DENSE, DAMP
OS - SAND, GRAVEL, BROWN, VERY DENSE, DAMP
PS - SAND, GRAVEL, BROWN, VERY DENSE, DAMP
QS - SAND, GRAVEL, BROWN, VERY DENSE, DAMP
RS - SAND, GRAVEL, BROWN, VERY DENSE, DAMP
SS - SAND, GRAVEL, BROWN, VERY DENSE, DAMP
TS - SAND, GRAVEL, BROWN, VERY DENSE, DAMP
US - SAND, GRAVEL, BROWN, VERY DENSE, DAMP
VS - SAND, GRAVEL, BROWN, VERY DENSE, DAMP
WS - SAND, GRAVEL, BROWN, VERY DENSE, DAMP
XS - SAND, GRAVEL, BROWN, VERY DENSE, DAMP
YS - SAND, GRAVEL, BROWN, VERY DENSE, DAMP
ZS - SAND, GRAVEL, BROWN, VERY DENSE, DAMP



THESE DRAWINGS ARE PART OF A SET OF DESIGN DOCUMENTS WHICH ALSO CONTAIN A WRITTEN TEXT, THAT TEXT SUPPLIES THE NECESSARY INFORMATION FOR THE DESIGN. THESE DRAWINGS SHOULD ONLY BE USED IN CONNECTION WITH THE TEXT.

BOREHOLE LOGS
FLY ASH & BOTTOM ASH DISPOSAL FACILITIES
PHILIP SPORN PLANT
NEW HAVEN, WEST VIRGINIA

REVISIONS

DATE	BY

SCALE: AS SHOWN
PREPARED FOR: AEP SERVICE CORPORATION

PREPARED BY: Geo/Environmental Associates, Inc.
10000 OLD BRIDGE ROAD
NEW HAVEN, WEST VIRGINIA 25801
DATE: 5-27-10 SHEET 1 OF 1

LABORATORY DATA FROM:
***“PHILIP SPORN ELECTRIC GENERATING PLANT BOTTOM ASH
FACILITY – ENGINEERING REPORT”***

PREPARED/COMPILED BY:
**GEOTECH/HYDRO/SITE SECTION OF
AMERICAN ELECTRIC POWER CORPORATION**

DATED: 1996

SUMMARY OF MATERIAL PROPERTIES

PROJECT: SPORN PLANT - FLY ASH POND DIKES
 NUMBER:


Borehole or Excav No.	Depth ft.	ASTM Description	ASTM Classification	Soil Type	Maximum Dry Density pcf	Optimum Moisture %	Liquid Limit %	Plastic Limit %	Gravel Sand <#200			Specific Gravity	Prmbly Moisture %	Natural Moisture %
									Sieve %	mm %	mm %			
96-01	0.0	SIIT	ML			NP	0.0	10.6	89.4	18.4				13.1
96-01	5.0													5.1
96-01	8.5	SILTY SAND	SM			NP	13.5	54.1	32.4	2.9				
96-01	16.7	SILTY SAND	SM			NP	11.0	57.3	31.7	1.6				
96-01	21.7													
96-01	26.7	SIIT with SAND	ML			NP	0.1	15.7	84.2	0.8				46.4
96-01	36.7													
96-01	51.7													24.7
96-02	0.0													25.2
96-02	5.0													30.5
96-02	16.9													15.5
96-02	31.9													6.6
96-02	51.9													49.7
96-03	26.7													28.8
96-04	5.0	SILTY SAND with GRAVEL	SM			NP	31.9	49.6	18.5	5.1				29.3
96-04	11.6	SILTY SAND	SM											
96-04	16.6	SILTY SAND with GRAVEL	SM			NP	4.1	58.1	37.8	4.8				12.0
96-04	26.6													
96-04	31.6	SILTY SAND	SM			NP	6.9	47.3	45.8	1.8				63.4
96-04	41.6													
96-04	51.6													22.1
96-05	0.0													24.5
96-05	5.0													18.5
96-05	21.7													11.6
96-05	26.7													15.3
96-05	31.7													70.6
96-05	36.7													38.4
96-05	41.7													52.5
96-05	56.7													40.9
96-06	11.5													28.0
														25.0

ASP Civil Engineering Laboratory, Groveport, Ohio.

SUMMARY OF MATERIAL PROPERTIES

PROJECT: SPORN PLANT - FLY ASH POND DIKES
 NUMBER:

Borehole or Excav No.	Depth ft.	ASTM Description	ASTM Classification	ASTM Soil Type	Maximum		Optimum		Liquid Plastic		Gravel Sand <#200 <.002		Specific		Prmbly		Natural		
					Dry Density pcf	Dry Density %	Moisture %	Limit %	Limit %	Sieve mm	Gravity %	Gravity %	Gravity %	Gravity %	Moisture %	Moisture %			
96-06	31.5						33.0		21.8										29.9



COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-01 0.0	SILT	13.1	NP	NP	NP	

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	%<.002
● 96-01 0.0	0.600	0.047	0.012		0.0	10.6	89.4	18.4

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 08/29/96

GRADATION CURVES
 American Electric Power Service Corp.
 Civil Engineering Laboratory





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-01 8.5	SILTY SAND		NP	NP	NP	


Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-01 8.5	19.000	0.483	0.069	0.020	13.5	54.1	32.4	2.9

PROJECT SPORN PLANT - FLY ASH POND DIKES

JOB NO. _____
DATE 08/29/96

GRADATION CURVES
American Electric Power Service Corp.
Civil Engineering Laboratory





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-01 16.7	SILTY SAND		NP	NP	NP	


Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	%<.002
● 96-01 16.7	19.000	0.262	0.071	0.030	11.0	57.3	31.7	1.6

PROJECT SPORN PLANT - FLY ASH POND DIKES

JOB NO. _____
DATE 08/29/96

GRADATION CURVES
American Electric Power Service Corp.
Civil Engineering Laboratory






COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.		
● 96-01 26.7	SILT with SAND		NP	NP	NP			
Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	%<.002
● 96-01 26.7	9.500	0.039	0.020	0.012	0.1	15.7	84.2	0.8

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____
DATE _____ 08/29/96

GRADATION CURVES
American Electric Power Service Corp.
Civil Engineering Laboratory





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-04 5.0	SILTY SAND with GRAVEL		NP	NP	NP	

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	%<.002
● 96-04 5.0	19.000	2.072	0.267	0.025	31.9	49.6	18.5	5.1

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____
 DATE 08/29/96

GRADATION CURVES
 American Electric Power Service Corp.
 Civil Engineering Laboratory





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-04 11.6	SILTY SAND	12.0	NP	NP	NP	

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	%<.002
● 96-04 11.6	9.500	0.252	0.059	0.013	4.1	58.1	37.8	4.8

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 08/29/96

GRADATION CURVES
 American Electric Power Service Corp.
 Civil Engineering Laboratory






COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.		
● 96-04 16.6	SILTY SAND with GRAVEL		NP	NP	NP			
Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	%<.002
● 96-04 16.6	37.500	0.738	0.078	0.011	24.9	45.7	29.4	5.9

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 08/29/96

GRADATION CURVES
 American Electric Power Service Corp.
 Civil Engineering Laboratory





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-04 31.6	SILTY SAND		NP	NP	NP	

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	%<.002
● 96-04 31.6	19.000	0.162	0.044	0.014	6.9	47.3	45.8	1.8

PROJECT **SPORN PLANT - FLY ASH POND DIKES**

JOB NO. _____
DATE **08/29/96**

GRADATION CURVES
American Electric Power Service Corp.
Civil Engineering Laboratory





H. C. NUTTING COMPANY

EMPLOYEE OWNED

GEOTECHNICAL, ENVIRONMENTAL AND TESTING ENGINEERS
SINCE 1921

CORPORATE CENTER
4120 AIRPORT ROAD
CINCINNATI, OHIO 45226
(513) 321-5816
FAX (513) 321-0294

Order No. 90979.027

August 29, 1996

Mr. P.J. Amaya
American Electric Power Corporation
1 Riverside Plaza
Columbus, Ohio 45315

Re: **Laboratory Tests**
Project: **Sporn Plant-Bottom Ash Pond
Complex Testing-Contract No.
C-9117, LOA-001-96**

Dear Mr. Amaya:

Submitted herewith is our report covering the results of nine (9) **Consolidated Un-drained Triaxial** tests with pore pressure measurements, four (4) **Moisture Contents** and **Atterberg Limits**. Tests were performed per your request by letter dated August 14, 1996. All samples were obtained and shipped to our laboratory from the referenced project by your representative. Cost for these tests were as outlined per Contract No. C-9117.

Should any discussion be required concerning this report, please feel free contact the undersigned. The H.C. Nutting Company **thanks** American Electric Power for allowing them this opportunity to be of service. Attached are the tabulated and plotted results.

H.C. NUTTING COMPANY

Robert L. House,
Vice President/Lab. Director

H.C. Nutting Company
 4120 Airport Road
 Cincinnati, Ohio 45226



American Electric Power
 Sporn Plant-Bottom Ash Pond Complex
 New Haven, WV
 HCN W.O. # 90979.027

8/27/96smo

TABLE II

TABULATION OF UNDISTURBED TEST DATA

Boring No.	Sample No.	Depth (Ft.)	Triaxial Compressive Strength (TSF)	Confining Pressure P.S.I.	Failure Strain (%)	Dry Density (Lbs./Cu. Ft.)	Water Content (%)	Lab No.
9602-12	ST-12	43.9-45.9	1.82	10	20.2	96.4	26.9	5623
9602-13	ST-13	45.9-48.9	1.96	20	6.9	91.0	30.0	5624
			2.65	40	5.8	91.2	31.3	5624
9603-7	ST-7	21.7-23.7	0.96	5	9.0	95.7	29.2	5625
			1.54	10	8.0	96.3	27.8	5625
			1.20	20	7.6	96.6	28.4	5625
9604-12	ST-12	46.6-48.6	2.65	10	19.1	103.8	21.8	5626
			2.93	20	20.7	100.6	24.2	5626
			6.22	40	14.6	99.6	24.8	5626



	1	2	3	
SAMPLE NO.				
INITIAL	WATER CONTENT, %	21.8	24.2	24.8
	DRY DENSITY, pcf	103.8	100.6	99.6
	SATURATION, %	93.3	95.6	95.5
	VOID RATIO	0.637	0.688	0.705
	DIAMETER, in	2.84	2.85	2.85
	HEIGHT, in	5.60	5.60	5.60
AT TEST	WATER CONTENT, %	21.0	22.9	20.0
	DIAMETER, in	2.81	2.75	2.79
	HEIGHT, in	5.55	5.41	5.49
Strain rate, %/min	0.001	0.001	0.001	
BACK PRESSURE, tsf	5.04	5.04	5.04	
CELL PRESSURE, tsf	5.76	6.48	7.92	
FAILURE STRESS, tsf	2.65	2.93	6.22	
PORE PRESSURE, tsf	4.81	5.72	5.64	
ULTIMATE STRESS, tsf				
PORE PRESSURE, tsf				
$\bar{\sigma}_1$ FAILURE, tsf	3.60	3.69	8.50	
$\bar{\sigma}_3$ FAILURE, tsf	0.95	0.76	2.28	

TYPE OF TEST:
 CU with pore pressures

SAMPLE TYPE:
 DESCRIPTION: Br & GR LEAN CLAY
 w/sand layers

LL= 25 PL= 18 PI= 7.0

SPECIFIC GRAVITY= 2.72

REMARKS: Lab No. 5626

CLIENT: American Electric Power

PROJECT: Sporn Pit-Bott. Ash Pond Complex
 New Haven, WV



SAMPLE LOCATION: Borlng: 9604-1¹³
 Depth: 46.6-48.6' Sample: ST-1¹³

PROJ. NO.: 90979.027 DATE: 8/27/96



TRIAxIAL SHEAR TEST REPORT

H. C. NUTTING COMPANY

FIG. NO.



Client: American Electric Power
 Project: Sporn Plt-Bott. Ash Pond Complex New Haven, WV
 Location: Boring: 9604-12 Depth: 46.6-48.6' Sample: ST-12
 File: 5626 Project No.: 90979.027 Page 2/2 Fig. No. _____





SAMPLE NO.		1
INITIAL	WATER CONTENT, %	26.9
	DRY DENSITY, pcf	96.4
	SATURATION, %	96.3
	VOID RATIO	0.761
	DIAMETER, in	2.84
	HEIGHT, in	5.60
AT TEST	WATER CONTENT, %	27.4
	DIAMETER, in	2.81
	HEIGHT, in	5.54
	Strain rate, %/min	0.001
	BACK PRESSURE, tsf	5.04
	CELL PRESSURE, tsf	5.76
	FAILURE STRESS, tsf	1.82
	PORE PRESSURE, tsf	5.09
	ULTIMATE STRESS, tsf	
	PORE PRESSURE, tsf	
	$\bar{\sigma}_1$ FAILURE, tsf	2.49
	$\bar{\sigma}_3$ FAILURE, tsf	0.67



TYPE OF TEST:
 CU with pore pressures
 SAMPLE TYPE:
 DESCRIPTION: Br LEAN CLAY

 LL = 33 PL = 23 PI = 10.0
 SPECIFIC GRAVITY = 2.72 (Assumed)
 REMARKS: Lab No. 5629
 $\frac{\bar{\sigma}_1}{\bar{\sigma}_3} = \tan^2 \theta_{cr} \therefore \frac{2.49}{0.67} = 3.71 \Rightarrow \theta_{cr} = 62.6^\circ$
 $2\theta_{cr} \approx 125^\circ$
 FIG. NO.

CLIENT: American Electric Power
 PROJECT: Sporn Pit-Bott. Ash Pond Complex
 New Have, WV
 SAMPLE LOCATION: Boring: 9602-12
 Depth: 43.9-45.9' Sample: ST-12
 PROJ. NO.: 90979.027 DATE: 8/27/96
 TRIAXIAL SHEAR TEST REPORT
H. C. NUTTING COMPANY



Client: American Electric Power
 Project: Sporn Pit-Bott. Ash Pond Complex New Have, WV
 Location: Boring:9602-12 Depth:43.9-45.9' Sample:ST-12
 File: 5623 Project No.: 90979.027 Page 2/2 Fig. No. _____





	1	2
SAMPLE NO.	1	2
INITIAL	WATER CONTENT, %	30.0 31.3
	DRY DENSITY, pcf	91.0 91.2
	SATURATION, %	100.0 98.8
	VOID RATIO	0.865 0.861
	DIAMETER, in	2.84 2.84
	HEIGHT, in	5.60 5.56
AT TEST	WATER CONTENT, %	32.6 30.2
	DIAMETER, in	2.79 2.79
	HEIGHT, in	5.51 5.47
Strain rate, %/min	0.001 0.001	
BACK PRESSURE, tsf	5.04 5.04	
CELL PRESSURE, tsf	6.48 7.92	
FAILURE STRESS, tsf	1.96 2.65	
PORE PRESSURE, tsf	5.98 7.03	
ULTIMATE STRESS, tsf		
PORE PRESSURE, tsf		
$\bar{\sigma}_1$ FAILURE, tsf	2.46 3.55	
$\bar{\sigma}_3$ FAILURE, tsf	0.5 0.89	

TYPE OF TEST:
 CU with pore pressures
 SAMPLE TYPE:
 DESCRIPTION: Br LEAN CLAY
 LL = 31 PL = 24 PI = 7.0
 SPECIFIC GRAVITY = 2.72 (Assumed)
 REMARKS: Lab No. 5624



CLIENT: American Electric Power
 PROJECT: Sporn Pit-Bott. Ash Pond Complex
 New Haven, WV
 SAMPLE LOCATION: BorIng:9602-13
 Depth: 46.9-48.9' Sample: ST-13
 PROJ. NO.: 90979.027 DATE: 8/27/96

TRIAxIAL SHEAR TEST REPORT
H. C. NUTTING COMPANY

FIG. NO.



Client: American Electric Power
 Project: Sporn Pit-Bott. Ash Pond Complex New Haven, WV
 Location: Boring: 9602-13 Depth: 46.9-48.9' Sample: ST-13
 File: 5624 Project No.: 90979.027 Page 2/2 - Fig. No. _____



	1	2	3	
SAMPLE NO.				
INITIAL	WATER CONTENT, %	29.2	27.8	28.4
	DRY DENSITY, pcf	95.7	96.3	96.6
	SATURATION, %	100.0	98.9	100.0
	VOID RATIO	0.775	0.763	0.759
	DIAMETER, in	2.84	2.84	2.84
	HEIGHT, in	5.60	5.60	5.60
AT TEST	WATER CONTENT, %	28.9	27.5	25.6
	DIAMETER, in	2.82	2.78	2.81
	HEIGHT, in	5.55	5.49	5.55
Strain rate, %/min	0.001	0.001	0.001	
BACK PRESSURE, tsf	5.04	5.04	5.04	
CELL PRESSURE, tsf	5.40	6.48	5.76	
FAILURE STRESS, tsf	0.96	1.54	1.20	
PORE PRESSURE, tsf	5.03	5.79	5.32	
ULTIMATE STRESS, tsf				
PORE PRESSURE, tsf				
$\bar{\sigma}_1$ FAILURE, tsf	1.33	2.23	1.64	
$\bar{\sigma}_3$ FAILURE, tsf	0.97	0.69	0.44	



TYPE OF TEST:
 CU with pore pressures
 SAMPLE TYPE:
 DESCRIPTION: Gr LEAN CLAY
 LL= 33 PL= 22 PI= 11.0
 SPECIFIC GRAVITY= 2.72 (Assumed)
 REMARKS: Lab No. 5625

CLIENT: American Electric Power
 PROJECT: Sporn Pit-Bott. Ash Pond Complex
 New Haven, WV
 SAMPLE LOCATION: BorIng:9603-7
 Depth:21.7-23.7' Sample:ST-7
 PROJ. NO.: 90979.027 DATE: 8/27/96



FIG. NO.

TRIAxIAL SHEAR TEST REPORT
H. C. NUTTING COMPANY


Excess Pore Pressure ---
 Deviator Stress —
 tsf



Excess Pore Pressure ---
 Deviator Stress —
 tsf



Stress Path legend: Total — Effective - - - - End +



Client: American Electric Power

Project: Sporn Plt-Bott. Ash Pond Complex New Haven, WV

Location: Boring: 9603-7 Depth: 21.7-23.7'

Sample: ST-7

File: 5625

Project No.: 90979.027

Page 2/2 . Fig. No. —



October 30, 1995
T-533D

American Electric Power Service Corporation

1 Riverside Plaza
Columbus, Ohio 43215

Attention : Mr. M. T. Daman

RE: Laboratory Testing
BBC&M JOB NO. T-533D
Bottom Ash Testing - Sporn Fly Ash Pond Dike Remediation
New Haven, West Virginia

Gentlemen :

Enclosed are the results of the laboratory testing on the BOTTOM ASH sample for the Sporn Fly Ash Pond Dike Remediation project. Included are the appropriate curves, summary sheets with listed numerical values, as well as the laboratory test data sheets and notes.

We are pleased to have been of service to you. If you have any questions regarding this work please contact this office.

Very Truly Yours ,

BBC&M ENGINEERING, INC.

A handwritten signature in dark ink, appearing to read 'John D. Jenkins, Jr.', is written over the typed name.


John D. Jenkins, Jr.
Laboratory Supervisor

SUMMARY OF TRIAXIAL COMPRESSION TESTS

SATURATED, CONSOLIDATED, DRAINED

(PEAK STRESSES PLOTTED)

SHEAR STRESS VS NORMAL STRESS



EFFECTIVE STRESS ———

Specimen Identification	Classification	DD	MC%
SPORN PLANT BUCKET (Bottom Ash)	Dark-gray and gray fine to coarse sand, little fine to coarse gravel, trace silt.	60	42
SPORN PLANT BUCKET (Bottom Ash)	Dark-gray and gray fine to coarse sand, little fine to coarse gravel, trace silt.	60	36
SPORN PLANT BUCKET (Bottom Ash)	Dark-gray and gray fine to coarse sand, little fine to coarse gravel, trace silt.	60	40
SPORN PLANT BUCKET (Bottom Ash)	Dark-gray and gray fine to coarse sand, little fine to coarse gravel, trace silt.	60	37




PROJECT Bottom Ash Testing - Sporn Plant
 LOCATION New Haven, West Virginia
 JOB NO. T533D DATE 10/29/95

PLATE


TRIAXIAL COMPRESSION TESTS

SATURATED, CONSOLIDATED, DRAINED



EFFECTIVE STRESS ——— ● EFFECTIVE AXIAL STRESS


Specimen Identification	Classification	DD	MC%
● SPORN PLANT BUCKET (Bottom Ash)	Dark-gray and gray fine to coarse sand, little fine to coarse gravel, trace silt.	60	42

	PROJECT	Bottom Ash Testing - Sporn Plant	
	LOCATION	New Haven, West Virginia	
	JOB NO.	T533D	DATE

PLATE

TRIAXIAL COMPRESSION TESTS

SATURATED, CONSOLIDATED, DRAINED



EFFECTIVE STRESS ——— ● EFFECTIVE AXIAL STRESS


Specimen Identification	Classification	DD	MC%
● SPORN PLANT BUCKET (Bottom Ash)	Dark-gray and gray fine to coarse sand, little fine to coarse gravel, trace silt.	60	36

	PROJECT	Bottom Ash Testing - Sporn Plant	
	LOCATION	New Haven, West Virginia	
	JOB NO.	T533D	DATE

PLATE

TRIAxIAL COMPRESSION TESTS

SATURATED, CONSOLIDATED, DRAINED




Specimen Identification	Classification	DD	MC%
● SPORN PLANT BUCKET (Bottom Ash)	Dark-gray and gray fine to coarse sand, little fine to coarse gravel, trace silt.	60	40

	PROJECT	Bottom Ash Testing - Sporn Plant	
	LOCATION	New Haven, West Virginia	
	JOB NO.	T533D	DATE

PLATE


TRIAXIAL COMPRESSION TESTS

SATURATED, CONSOLIDATED, DRAINED



EFFECTIVE STRESS ——— ● EFFECTIVE AXIAL STRESS

Specimen Identification	Classification	DD	MC%
● SPORN PLANT BUCKET (Bottom Ash)	Dark-gray and gray fine to coarse sand, little fine to coarse gravel, trace silt.	60	37

	PROJECT	Bottom Ash Testing - Sporn Plant	
	LOCATION	New Haven, West Virginia	
	JOB NO.	T533D	DATE

PLATE

TRIAXIAL COMPRESSION TEST DATA AND COMPUTATION SHEET

PROJECT : BOTTOM ASH TESTING - SPORN PLANT JOB NO. : T-533D DATE : 10/8-12/95

JRING : _____ SAMPLE : 75% DR (4psi) DEPTH : _____

MATERIAL : _____

Circ. : <u>8.97"</u>	Moisture Content	Before	After
Height : <u>5.60"</u> Diam. : <u>2.855"</u> Area : <u>6.402 in²</u>		Test	Test
Volume : <u>35.850 in³ = 587.48 cm³</u>	Pan No. :		<u>0M-36</u>
Dry Wt. of Sple. : <u>565.55 gms.</u>	Wet Wt. Sple. + Pan :		<u>927.72</u>
	Dry Wt. Sple. + Pan :	<u>NA</u>	<u>691.66</u>
UDW : <u>60.1 pcf</u>	Wt. of Pan :		<u>129.74</u>
Vol. Change - cc :	Wt. of Dry Soil :		<u>561.92</u>
Type of Test : <u>CD</u>	Wt. of Water :		<u>236.06</u>
Load Cell : <u>SK</u>	% Moisture		<u>42.0</u>

H_c = 5.596" A_c = 6.397 in² Loading Rate = .004" min

Dial Defl. Inch x 10 ⁻³	Strain	I - Strain	Average Area	Load lbs.	Incremental Deviator Stress		Total Vert. Stress ksf
					psf	ksf	
0	.0000	1.0000	6.40	0	0.00	0.00	0.58
25	.0045	.9955	6.43	93	14.46	2.08	2.66
50	.0089	.9911	6.46	132	20.43	2.94	3.52
75	.0134	.9866	6.49	162	24.96	3.59	4.17
100	.0179	.9821	6.52	185	28.37	4.09	4.67
25	.0223	.9777	6.55	204	31.15	4.48	5.06
50	.0268	.9732	6.58	221	33.59	4.84	5.42
75	.0313	.9687	6.61	230	34.80	5.01	5.59
200	.0357	.9643	6.64	242	36.95	5.25	5.83
50	.0447	.9553	6.70	252	37.61	5.42	6.00
300	.0536	.9464	6.76	256	37.87	5.45	6.03
50	.0625	.9375	6.83	252	36.90	5.31	5.89
400	.0715	.9285	6.89	247	35.85	5.16	5.74
50	.0804	.9196	6.96	240	34.48	4.97	5.55
500	.0893	.9107	7.03	235	33.43	4.81	5.39
50	.0983	.9017	7.10	227	31.97	4.60	5.18
600	.1072	.8928	7.17	209	30.54	4.40	4.98
50	.1162	.8838	7.24	215	29.70	4.28	4.86
700	.1251	.8749	7.32	212	28.96	4.17	4.75
50	.1340	.8640	7.41	209	28.21	4.06	4.64
800	.1430	.8570	7.47	207	27.71	3.99	4.57
50	.1519	.8481	7.55	207	27.42	3.95	4.53
900	.1608	.8392	7.63	206	27.00	3.89	4.47
50	.1698	.8302	7.71	205	26.59	3.83	4.41
1000	.1787	.8213	7.79	204	26.19	3.77	4.35
50	.1876	.8124	7.88	205	26.02	3.75	4.33
1100	.1966	.8034	7.97	204	25.60	3.69	4.27
50	.2055	.7945	8.06	203	25.19	3.63	4.21
1200	.2144	.7856	8.15	202	24.79	3.57	4.15

2.725
0.58
3.305

TRIAXIAL SHEAR TEST
(back pressure and pore pressure data)
saturation

PROJECT : BOTTOM ASH TESTING - SPORN PLANT JOB NO. : T-5332 DATE : 10/8/95

BORING : _____ SAMPLE : 75% DR (4 PSI) DEPTH : _____

Increment Number	Time	Elapsed Time Minutes	Chamber Pressure psi	Applied Back Pressure psi	Measured Pore Pressure psi	Pipette Reading cc	Volume Inflow cc	Dial Indicator Reading Inches
1	3:12 PM	0	4	0	0	0.0	0	0.100
		4	✓	✓	0.6-0.3	39.0	+39.0	
2	3:20 PM	0	4	0	0.3	0	+39.0	
		5	✓	✓	✓	41.5	+80.5	
3	3:27 PM	0	10.0	6.0	0.3	0	+80.5	
		2	✓	✓	6.0	50.0	+130.5	
4	3:32 PM	0	20.0	16.0	6.0	0	+130.5	
		2	✓	✓	16.0	41.1	+171.6	
5	3:40 PM	0	20.0	19.0	16.0	0	+171.6	
		1	✓	✓	19.0	3.3	+174.9	
6	3:41 PM	0	30.0	29.0	19.0	3.3	+174.9	
		2	✓	✓	29.0	17.2	+188.8	
7	3:44 PM	0	40.0	39.0	29.0	17.2	+188.8	
		1	✓	✓	39.0	24.3	+195.9	
8	3:46 PM	0	41.0	40.0	39.0	24.3	+195.9	
		1	✓	✓	40.0	22.5	+194.1	
		5	✓	✓	✓	20.0	+191.6	
9	3:57 PM	0	40.5	40.0	40.0	20.0	+191.6	
		1	✓	✓	✓	22.5	+194.1	
10	4:00	0	41.0	40.0	40.0	22.5	+194.1	
		1	✓	✓	✓	21.5	+193.1	
		12	✓	✓	✓	15.0	+186.6	
		20	✓	✓	✓	10.0	+181.6	
		RESET PIPETTE		✓	✓	42.5	+181.6	
						16.3	+170.4	26.2+35.0 = 61.2

Dial Indicator reading before saturation 0.100 in.
 Dial Indicator reading after saturation 0.100 in.
 Change in height during saturation (ΔH_s) 0.000 in.

REMARKS : B = 70/100 = 70% @ 4:00 PM RESET to 41 psi & 40 psi. (CONNECTED TOP & BOTTOM TO BACK-PRESSURE BURETTES)
10/12/95 B = 9.8/10.0 = 98%

TRIAXIAL SHEAR TEST

Preliminary Consolidation

PROJECT : BOTTOM ASH TESTING - SPEN PLANT JOB NO. : T-533D DATE : 10/8-12/95

BORING : _____ SAMPLE : 75% D_r (4Psi) DEPTH : _____

Increment Number	Time	Elapsed Time Minutes	Chamber Pressure psi	Applied Back Pressure psi	Measured Pore Pressure psi	Pipette Reading cc	Volume Change (ΔV) cc	Dial Indicator Reading Inches
1	9:17 PM	0	44.0	40.0	40.0	50.0	0	0.100
		1	✓	✓	✓	49.0	-1.0	
10/9/95	7:25 AM							
10/10/95	12:15 PM		✓	✓	40.1	49.0	-1.0	
10/11/95	10:25 AM		✓	✓	40.1	49.1	-0.9	
10/12/95	10:50 AM		✓	✓	40.0	49.1	-0.9	0.104

Dial Indicator reading before consolidation 0.100 in.
 Dial Indicator reading after consolidation 0.104 in.
 Change in height during consolidation (ΔH₀) 0.004 in.

REMARKS : _____

TRIAXIAL SHEAR TEST
CONSOLIDATION/SATURATION CALCULATIONS

PROJECT : Bottom Ash Testing - Sporn Plant JOB NO. : T-533 D DATE : 10/12/95

BORING : _____ SAMPLE : 75% Dr (4psi) DEPTH : _____

ASTM D-4767

$H_c = H_o - \Delta H_o$
where :

H_o - Initial height of specimen - in.
 ΔH_o - change of height in specimen after consolidation - in.

$A_c = (V_o - \Delta V_{sat} - \Delta V_c) / H_c$
where :

V_o - Initial volume of specimen - in.³
 ΔV_c - change in volume during consolidation (burette) - in.³
 ΔV_{sat} - change in volume during saturation - in.³ as follows :
 $\Delta V_{sat} = 3V_o \Delta H_s / H_o$

where :
 ΔH_s - change in height during saturation - in.

$H_o = 5.600"$
 $\Delta H_o = 0.004"$
 $V_o = 35.850 \text{ in}^3$
 $\Delta V_c = 0.0549 \text{ in}^3$
 $\Delta V_{sat} = 0.00 \text{ in}^3$
 $\Delta H_s = 0.00"$


therefore :
 $H_c = 5.596"$
 $A_c = 6.397 \text{ in}^2$

Piston Load (SATURATION) $44 \text{ psi} \times 1.963 \text{ in}^2 = 8.64 \# = 3918 \text{ gms.}$

Piston Load (SHEAR) $4 \text{ psi} \times 1.963 \text{ in}^2 = 0.79 \# = 356 \text{ gms.}$

$\Delta V_c = 0.900 = 0.0549 \text{ in}^3$

$A_c = (35.850 \text{ in}^3 - 0.00 \text{ in}^3 - 0.0549 \text{ in}^3) / 5.596" = 35.7952 \text{ in}^3 / 5.596" = 6.397 \text{ in}^2$



TRIAXIAL COMPRESSION TEST DATA AND COMPUTATION SHEET

PROJECT : BOTTOM ASH TESTING - SPURV PLANT JOB NO : T-533D DATE : 10/12-22/95

JURING : _____ SAMPLE : 75% DR (8 PSI) DEPTH : _____

MATERIAL : _____

Circ. : <u>8.97"</u>	Moisture Content	Before	After
Height : <u>5.60"</u> Diam. : <u>2.855"</u> Area : <u>6.402 in²</u>		Test	Test
Volume : <u>35.850 in³ = 587.48 cm³</u> Pan No. :			<u>A-12</u>
Dry Wt. of Sple. : <u>565.55 gms.</u>	Wet Wt. Sple. + Pan :		<u>928.74</u>
	Dry Wt. Sple. + Pan :		<u>728.92</u>
UDW : <u>60.1 pcf</u>	Wt. of Pan :	<u>N.A.</u>	<u>166.16</u>
Vol. Change - cc :	Wt. of Dry Soil :		<u>562.76</u>
Type of Test : <u>CD</u>	Wt. of Water :		<u>199.82</u>
Load Cell : <u>5K</u>	% Moisture		<u>35.5</u>

Hc = 5.594" Ac = 6.33 in² Loading Rate = .005"/min.

Dial Defl. Inchx10 ⁻³	Strain	1 - Strain	Average Area	Load lbs.	Incremental Deviator Stress		Total Vert. Stress ksf	
					psf	ksf		
0	.0000	1.0000	6.33	0	0.00	0.00	1.15	
25	.0045	.9955	6.36	122	19.18	2.76	3.91	
50	.0089	.9911	6.39	162	25.35	3.65	4.80	
75	.0134	.9866	6.42	201	31.51	4.51	5.66	
100	.0179	.9821	6.45	239	37.05	5.34	6.49	
25	.0223	.9777	6.47	270	41.73	6.01	7.16	
50	.0268	.9732	6.50	295	45.38	6.54	7.69	
75	.0313	.9687	6.53	320	49.00	7.06	8.21	
200	.0358	.9642	6.57	340	51.75	7.45	8.60	
50	.0447	.9553	6.63	368	55.51	7.99	9.14	
300	.0536	.9464	6.69	386	57.70	8.31	9.46	
50	.0626	.9374	6.75	399	59.11	8.51	9.66	4.29
400	.0715	.9285	6.82	406	59.53	8.57	9.72	1.15
50	.0804	.9196	6.88	410	59.59	8.58	9.73	5.44
500	.0894	.9106	6.95	406	58.42	8.41	9.56	
50	.0983	.9017	7.02	408	58.12	8.37	9.52	
600	.1073	.8927	7.09	409	57.69	8.31	9.46	
50	.1162	.8838	7.16	407	56.84	8.19	9.34	
700	.1251	.8749	7.24	406	56.08	8.08	9.23	
50	.1341	.8659	7.31	405	55.40	7.98	9.13	
800	.1430	.8570	7.39	401	54.26	7.81	8.96	
50	.1519	.8481	7.46	399	53.49	7.70	8.85	
900	.1609	.8391	7.54	398	52.79	7.60	8.75	
50	.1698	.8302	7.62	396	51.97	7.48	8.63	
1000	.1788	.8212	7.71	396	51.31	7.40	8.55	
50	.1877	.8123	7.79	394	50.58	7.28	8.43	
1100	.1966	.8034	7.88	389	49.37	7.11	8.26	
50	.2056	.7944	7.97	388	48.68	7.01	8.16	
1200	.2145	.7855	8.06	383	47.52	6.84	7.99	

TRIAxIAL SHEAR TEST
(back pressure and pore pressure data)
saturation

PROJECT : BOTTOM ASA TESTING - SPORN PLANT JOB NO. : T-533D DATE : 10/12-19/95

BORING : _____ SAMPLE : 75% DR (8psi) DEPTH : _____

Increment Number	Time	Elapsed Time Minutes	Chamber Pressure psi	Applied Back Pressure psi	Measured Pore Pressure psi	Pipette Reading cc		Volume Inflow cc (TOTAL)	Dial Indicator Reading Inches
						TOP	B.T.		
1	9:35 PM	0	8.0	0	0	3.5	20.5	0	0.100
		2	✓	0	0.6	10.0	25.8	+11.8	
2	9:37 PM	0	8.0	4	0.6	10.0	25.8	+11.8	
		2	✓	✓	3.7	37.0	50.0	+63.0	
3	9:44 PM	0	8.0	6.0	4.0	40.5	50.0	+66.5	
		3	✓	✓	6.0	29.5	0.0	+96.0	
4	9:48 PM	0	15.0	13.0	6.0	29.0	0.0	+96.0	
		3	✓	✓	13.0	37.0	50.0	+154.0	
5	9:55 PM	0	25.0	23.0	13.0	0.0	0.0	+154.0	
		2	✓	✓	23.0	0.0	47.0	+201.0	
6	9:57 PM	0	35.0	33.0	23.0	0.0	47.0	+221.0	
		2	✓	✓	33.0	26.6	47.0	+227.6	
7	10:00 PM	0	47.0	40.0	33.0	26.6	47.0	+227.6	
		1	✓	✓	40.0	39.5	47.0	+240.5	
RESET				TO SATURATE					
	10:05 PM	0	41.0	40.0 / 40.0	40.0	41.5	20.4	+240.5	
10/13/95	7:05 AM		✓	✓	✓	44.2	23.7	+246.5	
10/15/95	10:30 AM		✓	✓	✓	45.0	43.7	+267.3	
10/16/95	8:05 PM		✓	✓	✓	✓	49.5	+273.1	
10/17/95	1:30 PM		✓	✓	✓	48.0	49.5	+276.1	
10/17/95	1:32 PM		✓	✓	✓	20.8	20.0	+276.1	RESET
10/19/95	8:05 AM		✓	✓	✓	20.7	22.5	+278.5	+2.4
10/19/95	10:20 AM		✓	✓	✓	✓	23.4	+279.4	+0.9

Dial Indicator reading before saturation 0.100 In.
 Dial Indicator reading after saturation 0.100 In.
 Change in height during saturation (ΔH_s) 0.000 In.

MARKS : - USED FOR 4 BOTTOM PIPETTES - $B = \frac{2.5}{5.0} = 50\%$ 10/19/95

TRIAXIAL SHEAR TEST
CONSOLIDATION/SATURATION CALCULATIONS

PROJECT: BOTTOM ASH TESTING - SPORN PLANT JOB NO.: T-533D DATE: 10/22/95

BORING: _____ SAMPLE: TS40 DR (8psi) DEPTH: _____

ASTM D-4767

$H_c = H_o - \Delta H_o$

where :

H_o - Initial height of specimen - in.

ΔH_o - change of height in specimen after consolidation - in.

$A_c = (V_o - \Delta V_{sat} - \Delta V_c) / H_c$

where :

V_o - Initial volume of specimen - in.³

ΔV_c - change in volume during consolidation (burette) - in.³

ΔV_{sat} - change in volume during saturation - in.³ as follows :

$\Delta V_{sat} = 3V_o \Delta H_s / H_o$

where :

ΔH_s - change in height during saturation - in.

$H_o = 5.600''$

$\Delta H_o = 0.006''$

$V_o = 35.8501 \text{ in}^3$

$\Delta V_c = 0.4394 \text{ in}^3$

$\Delta V_{sat} = 0.00 \text{ in}^3$

$\Delta H_s = 0.00''$

therefore :

$H_c = 5.594''$

$A_c = 6.33 \text{ in}^2$


PISTON LOAD = (SATURATION) $48 \text{ psi} \times 1.963 \text{ in}^2 = 9.42 \# = 4274 \text{ gms.}$

PISTON LOAD = (SHEAR) $8 \text{ psi} \times 1.963 \text{ in}^2 = 1.57 \# = 712 \text{ gms.}$

$\Delta V_c = 7.200 = 0.4394 \text{ in}^3$

$\Delta V_{SAT} = 3 \times 35.8501 \text{ in}^3 \times 0.00'' / 5.60'' = 0.00 \text{ in}^3$

$A_c = (35.8501 \text{ in}^3 - 0.00 \text{ in}^3 - 0.4394 \text{ in}^3) / 5.594'' = 35.4107 \text{ in}^3 / 5.594 \text{ in} = 6.33 \text{ in}^2$



TRIAxIAL COMPRESSION TEST DATA AND COMPUTATION SHEET

PROJECT : BOTTOM ASH TESTING - SPAN PLANT JOB NO. : T-533D DATE : 10/22-25/95
 BORING : _____ SAMPLE : 75% Dr (16 psi) DEPTH : _____
 MATERIAL : _____

Circ. : <u>8.97"</u>	Moisture Content	Before	After
Height : <u>5.60"</u> Diam. : <u>2.855"</u> Area : <u>6.402 in²</u>		Test	Test
Volume : <u>35.8501 in³ = 587.48 cm³</u>	Pan No. :		<u>JJ-6</u>
Dry Wt. of Sp. : <u>565.55 gms.</u>	Wet Wt. Sp. + Pan :		<u>912.58</u>
	Dry Wt. Sp. + Pan :		<u>685.48</u>
UDW : <u>60.1 pct</u>	Wt. of Pan :	<u>NA</u>	<u>122.18</u>
Vol. Change - cc :	Wt. of Dry Soil :		<u>563.30</u>
Type of Test : <u>CD</u>	Wt. of Water :		<u>227.10</u>
Load Cell : <u>SK</u>	% Moisture		<u>40.3</u>

Hc = 5.594" Ac = 6.37 in² LOADING RATE = 0.005"/min.

Dial Defl. Inchx10 ⁻³	Strain	I - Strain	Average Area	Load lbs.	Incremental Deviator Stress		Total Vert. Stress ksf	
					psi	ksf		
0	.0000	1.0000	6.37	0	0.00	0.00	2.30	
25	.0045	.9955	6.40	178	27.81	4.01	6.31	
50	.0089	.9911	6.43	248	38.57	5.55	7.85	
75	.0134	.9866	6.46	299	46.28	6.67	8.97	
100	.0179	.9821	6.49	341	52.54	7.57	9.87	
25	.0223	.9777	6.52	382	58.59	8.44	10.74	
50	.0268	.9732	6.55	414	63.21	9.10	11.40	
75	.0313	.9687	6.58	443	67.33	9.69	11.99	
200	.0358	.9642	6.61	477	72.16	10.39	12.69	
50	.0447	.9553	6.67	524	78.56	11.31	13.61	
300	.0536	.9464	6.73	561	83.36	12.00	14.30	
50	.0626	.9374	6.80	585	86.03	12.39	14.69	6.34
400	.0715	.9285	6.86	600	87.46	12.59	14.89	2.30
50	.0804	.9196	6.93	610	88.02	12.68	14.98	<u>8.64</u>
500	.0894	.9106	7.00	616	98.00	12.67	14.97	
50	.0983	.9017	7.06	616	87.25	12.56	14.86	
600	.1073	.8927	7.14	612	85.71	12.34	14.64	
50	.1162	.8838	7.21	612	84.88	12.22	14.52	
700	.1251	.8749	7.28	607	83.38	12.01	14.31	
50	.1341	.8659	7.36	607	82.47	11.88	14.18	
800	.1430	.8570	7.43	606	81.56	11.74	14.04	
50	.1519	.8481	7.51	606	80.69	11.62	13.92	
900	.1609	.8391	7.59	605	79.71	11.48	13.78	
50	.1698	.8302	7.67	605	78.88	11.36	13.66	
1000	.1788	.8212	7.76	604	77.84	11.21	13.51	
50	.1877	.8123	7.84	604	77.04	11.09	13.39	
1100	.1966	.8034	7.93	603	76.04	10.95	13.25	
50	.2056	.7944	8.02	603	75.19	10.83	13.13	
1200	.2145	.7855	8.11	602	74.23	10.69	12.99	

BBC&M ENGINEERING, INC.

TRIAxIAL SHEAR TEST
(back pressure and pore pressure data)
saturation

PROJECT : Bottom Ash Testing - Sporn Plant JOB NO. : F-533D DATE : 10/22-24/95

BORING : _____ SAMPLE : TS%_D (16 psi) DEPTH : _____

Increment Number	Time	Elapsed Time Minutes	Chamber Pressure psi	Applied Back Pressure psi	Measured Pore Pressure psi	Pipette Reading cc	Volume Inflow cc	Dial Indicator Reading Inches
1	2:19 PM	0	4.0	0.00	0.00	0.07 / 0.05	0	0.100
		1				6.7	50.0	+53.3
						39.0	0.0	+32.3
						39.0	50.0	+50.0
						0.0	0.0	135.6 TOTAL
						40.5	50.0	+90.5
						0.0	0.0	225.5 TOTAL
	2:50 PM	31	4.0	0.0	0.00	4.3	22.0	+31.3 = 256.8 TOTAL
	9:50 PM		✓	✓	✓	15.3	16.0	266.8 TOTAL
2	9:50 PM	0	10.0	8.0	0.0	15.3	16.0	
		5	✓	✓	8.0	20.0	34.5	+38.2 = 295.0 TOTAL
3	9:55 PM	0	20.0	18.0	8.0	20.0	34.5	295.0
		2	✓	✓	18.0	36.8	35.0	+17.3 = 312.3 TOTAL
4	9:57 PM	0	30.0	28.0	18.0	36.8	35.0	312.3
		2	✓	✓	28.0	40.9	36.5	+5.6 = 317.9 TOTAL
5	9:59 PM	0	40.0	38.0	28.0	40.9	36.5	317.9
		3			38.0	41.2	41.1	+4.9 = 322.8 TOTAL
6	10:02 PM	0	40.0	40.0	38.0	41.2	41.1	322.8
		1	✓	✓	40.0	40.6	44.6	+2.9 = 325.7 TOTAL
10/23/95	9:00 AM		✓	✓	✓	43.5	47.2	+5.5 = 331.2 TOTAL
	8:00 PM		✓	✓	✓	51.3	41.2	+1.8 = 333.0 TOTAL
		RESET	✓	✓	✓	20.0	41.2	333.0
	1:00 PM		✓	✓	✓	29.7	29.7	+1.8 = 334.8 0.100

Dial Indicator reading before saturation 0.100 in.
Dial Indicator reading after saturation 0.100 in.
Change in height during saturation (Δh_s) 0.000 in.

MARKS : 10/25/95 B = 3.8/5.0 = 76% @ 8:15 PM B = 4.2/5.0 = 84% @ 1:00 PM B = 4.4/5.0 = 88%

TRIAXIAL SHEAR TEST
CONSOLIDATION/SATURATION CALCULATIONS

PROJECT : Bottom Ash Testing - Sporn Plant JOB NO. : T-533D DATE : 10/25/95

BORING : _____ SAMPLE : 75% Dr (16 psi) DEPTH : _____

ASTM D-4767

$H_c = H_o - \Delta H_o$

where :

H_o - Initial height of specimen - in.

ΔH_o - change of height in specimen after consolidation - in.

$A_c = (V_o - \Delta V_{sat} - \Delta V_c) / H_c$

where :

V_o - Initial volume of specimen - in.³

ΔV_c - change in volume during consolidation (burette) - in.³

ΔV_{sat} - change in volume during saturation - in.³ as follows :

$\Delta V_{sat} = 3V_o \Delta H_s / H_o$

where :

ΔH_s - change in height during saturation - in.

$H_o = 5.600''$

$\Delta H_o = 0.006''$

$V_o = 35.8501 \text{ in}^3$

$\Delta V_c = 0.2197 \text{ in}^3$

$\Delta V_{sat} = 0.000 \text{ in}^3$

$\Delta H_s = 0.00 \text{ in}^3$

therefore :

$H_c = 5.594''$


$A_c = 6.369 \text{ in}^2$

Piston Load (SATURATION) = $56 \text{ psi} \times 1.963 \text{ in}^2 = 10.99 \text{ \#} = 49869 \text{ ms.}$

Piston Load (SHEAR) = $16 \text{ psi} \times 1.963 \text{ in}^2 = 3.14 \text{ \#} = 14259 \text{ ms.}$

$\Delta V_c = 3.6 \text{ cc} = 0.2197 \text{ in}^3$

$A_c = (35.8501 \text{ in}^3 - 0.000 \text{ in}^3 - 0.2197 \text{ in}^3) / 5.594'' = 35.6304 \text{ in}^3 / 5.594'' = 6.37 \text{ in}^2$



TRIAXIAL COMPRESSION TEST DATA AND COMPUTATION SHEET

PROJECT : BOSTON ASH TESTING - SPORN PLANT JOB NO : T-533D DATE : 10/25-28/95

BORING : _____ SAMPLE : T5%DR (32 Psi) DEPTH : _____

MATERIAL : _____

Circ. : 8.97"
 Height : 5.60" Diam. : 2.855" Area : 6.402 in²
 Volume : 35.85 in³ = 587.48 cm³
 Dry Wt. of Sple. : 585.55 gms.
 UDW : 60.1 pcp
 Vol. Change - cc : _____
 Type of Test : CD
 Load Cell : SK
 Moisture Content Before Test : _____ After Test : _____
 Pan No. : _____
 Wet Wt. Sple. + Pan : _____
 Dry Wt. Sple. + Pan : _____
 Wt. of Pan : NA
 Wt. of Dry Soil : _____
 Wt. of Water : _____
 % Moisture : _____
 TOG-10
 893.2 +
 686.38
 124.56
 561.82
 206.86
 36.8
 H_c = 5.558" A_c = 6.227 in² LOADING RATE = 0.005"/min.

Dial Defl. Inch x 10 ⁻³	Strain	1 - Strain	Average Area	Load lbs.	Incremental Deviator Stress		Total Vert. Stress ksf	
					psi	ksf		
0	.0000	1.0000	6.23	0	0.00	0.00	4.61	
25	.0045	.9955	6.26	129	20.61	2.97	7.58	
50	.0090	.9910	6.29	193	30.68	4.42	9.03	
75	.0135	.9865	6.32	260	41.14	5.92	10.53	
100	.0180	.9820	6.34	318	50.16	7.22	11.83	
25	.0225	.9775	6.37	376	59.03	8.50	13.11	
50	.0270	.9730	6.40	424	66.25	9.54	14.15	
75	.0315	.9685	6.43	472	73.41	10.57	15.18	
200	.0360	.9640	6.46	520	80.50	11.59	16.20	
50	.0450	.9550	6.52	607	93.10	13.41	18.02	
300	.0540	.9460	6.59	689	104.55	15.06	19.67	
50	.0630	.9370	6.65	770	115.79	16.67	21.28	
400	.0720	.9280	6.71	840	125.19	18.03	22.64	
50	.0810	.9190	6.78	875	129.06	18.58	23.19	
500	.0900	.9100	6.85	910	132.85	19.13	23.74	
50	.0990	.9010	6.91	946	136.90	19.71	24.32	
600	.1080	.8920	6.98	991	141.98	20.94	25.05	
50	.1169	.8831	7.05	1020	144.68	20.83	25.44	
700	.1259	.8741	7.13	1040	145.86	21.00	25.61	
50	.1349	.8651	7.20	1063	147.64	21.26	25.87	
800	.1439	.8561	7.28	1083	148.76	21.42	26.03	
50	.1529	.8471	7.35	1105	150.34	21.65	26.26	
900	.1619	.8381	7.43	1125	151.41	21.80	26.41	10.95
50	.1709	.8291	7.51	1140	151.80	21.86	26.47	4.61
1000	.1799	.8201	7.60	1150	152.11	21.90	26.51	15.56
50	.1889	.8111	7.68	1150	149.74	21.56	26.17	
1100	.1979	.8021	7.77	1140	146.72	21.13	25.74	
50	.2069	.7931	7.86	1122	142.75	20.56	25.17	
1200	.2159	.7841	7.95	1111	139.75	20.12	24.73	

TRIAxIAL SHEAR TEST
(back pressure and pore pressure data)
saturation

PROJECT : BOTTOM ASH TESTING - SPORN PLANT JOB NO. : T-533D DATE : 10/25-27/95

BORING : _____ SAMPLE : 75% D_p (32 PSI) DEPTH : _____

Increment Number	Time	Elapsed Time Minutes	Chamber Pressure psi	Applied Back Pressure psi	Measured Pore Pressure psi	Pipette Reading cc		Volume Inflow cc	Dial Indicator Reading Inches
						TOP	BOT.		
1	8:51 PM	0	4.0	0.00	0.00	5.0	6.3	0.00	0.100
			✓	✓	✓	42.8	50.0	(+37.8) + (+43.7) = (81.5)	
						-	0	81.5	
						-	50.0	(0) + (132.0) = 131.5	
						-	-	131.5	
						0	0		
						43.3	46.8	(+43.3) + (+46.8) = 90.1	
								221.6 TOTAL	
2	9:20 PM		10.0	8.0	0.00	0	0	221.6 TOTAL	
			✓	✓	8.0	19.5	19.5	+ 39.0	
3			20.0	18.0	8.0	19.5	19.5	260.6 TOTAL	
			✓	✓	18.0	27.2	25.2	+ 13.4	
4			30.0	28.0	18.0	27.2	25.2	279.0 TOTAL	
			✓	✓	28.0	30.5	30.5	+ 8.6	
5			40.0	40.0	28.0	30.5	30.5	282.6 TOTAL	
			✓	✓	40.0	33.5	33.2	+ 5.7	
	9:34 PM		✓	✓	✓			288.3 TOTAL	
10/26/95	7:10 AM		✓	✓	✓	37.0	37.8	+ 8.1 = 296.4 TOTAL	
10/27/95	7:25 AM		✓	✓	✓	38.0	21.0	+ 1.0 - 16.5 = -15.5	
								280.9 TOTAL	0.100

Dial Indicator reading before saturation 0.100 in.
 Dial Indicator reading after saturation 0.100 in.
 Change in height during saturation (ΔHs) 0.00 in.

REMARKS : 10/26/95 @ 7:10 AM S = 3.7/5.0 = 74% 10/27/95 @ 7:30 AM S = 4.3/5.0 = 86%

TRIAXIAL SHEAR TEST

CONSOLIDATION/SATURATION CALCULATIONS

PROJECT : BOTTOM SHEAR TESTING - SPORN PLANT JOB NO. : T-533D DATE : 10/28/95

BORING : _____ SAMPLE : 75% DR (32 PSI) DEPTH : _____

ASTM D-4767

$H_c - H_o - \Delta H_o$

where :

H_o - Initial height of specimen - in.

ΔH_o - change of height in specimen after consolidation - in.

$A_c = (V_o - \Delta V_{sat} - \Delta V_c) / H_c$

where :

V_o - Initial volume of specimen - in.³

ΔV_c - change in volume during consolidation (burette) - in.³

ΔV_{sat} - change in volume during saturation - in.³ as follows :

$\Delta V_{sat} = 3V_o \Delta H_s / H_o$

where :

ΔH_s - change in height during saturation - in.

$H_o = 5.600''$

$\Delta H_o = 0.042''$

$V_o = 35.8501 \text{ in}^3$

$\Delta V_c = 1.2388 \text{ in}^3$

$\Delta V_{sat} = 0.0001 \text{ in}^3$

$\Delta H_s = 0.00''$

therefore :

$H_c = 5.558''$


$A_c = 6.227 \text{ in}^2$

Piston Load (SATURATION) = $72 \text{ psi} \times 1.963 \text{ in}^2 = 141.3 \# = 6411 \text{ gm}$.

Piston Load (SHEAR) = $32 \text{ psi} \times 1.963 \text{ in}^2 = 6.28 \# = 2849 \text{ gm}$.

$\Delta V_c = 20.3 \text{ cc} = 1.2388 \text{ in}^3$

$A_c = (35.8501 \text{ in}^3 - 0.0001 \text{ in}^3 - 1.2388 \text{ in}^3) / 5.558'' = 34.6113 \text{ in}^3 / 5.558'' = 6.227 \text{ in}^2$



SUMMARY OF MATERIAL PROPERTIES

PROJECT: SPOCK PLANT ASH HAUL ROAD - ASH HAUL ROAD SLIP
 NUMBER: 3015

Borehole or Excav No.	Depth ft.	ASTM Classification	Soil Type	Maximum Dry Density pcf	Optimum Moisture %	Liquid Limit %	Plastic Limit %	Gravel mm %	Sand mm %	Gravel mm %	Specific Gravity	Permeability cm/sec	Natural Moisture %	
S-5619	0.0	FAT CLAY	CH	105.2	20.6	51.6	22.3	0.3	7.0	92.7	40.3	2.75	5.44E-09	20.2

97%


614 836 4168

AUG-21-1996 14:23

P.02

AEP Civil Engineering Laboratory, Groveport, Ohio

August 18, 1996 page 1 of 1



COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● S-5619 0.0	FAT CLAY CH	20.2	51.6	22.3	29.3	2.75

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% <.002
● S-5619 0.0	9.500	0.007			0.3	7.0	92.7	40.3

PROJECT SPORN PLANT ASH HAUL ROAD - ASH HAUL ROAD SLIP JOB NO. 3015
 DATE 08/18/94

GRADATION CURVES

American Electric Power Service Corp.
 GROVEPORT, OHIO



JOB NO. 3015
 PROJECT SPORN PLANT ASH HAUL ROAD
 LOCATION: ASH HAUL ROAD SLIP

DATE: AUG 18 94

SOURCE OF MATERIAL S-5619 DEPTH 0.0 ft.
 DESCRIPTION OF MATERIAL _____
 ASTM DESCRIPTION FAT CLAY CH

MAX. DRY DENSITY, pcf	105.2	OPTIMUM MOISTURE, %	20.6
SPECIFIC GRAVITY	2.75		
SAMPLE HGT., mm	49.670	SAMPLE DIA., mm	70.130
CHAMBER PRESSURE, psi	80.0	BACK PRESSURE, psi	70.0
B-PARAMETER	0.98	EFFECTIVE PRESSURE, psi	10.0
INITIAL HEAD, mm	1778.8		

	<u>BEFORE</u>	<u>AFTER</u>
WATER CONTENT, %	22.0	24.2
WET DENSITY, pcf	125.5	
DRY DENSITY, pcf	102.8	
SATURATION, %	90.60	
VOID RATIO	0.6693	

PERMEABILITY COEFFICIENT K, cm/sec 5.44E-09

FLEXIBLE-MEMBRANE PERMEABILITY TEST

American Electric Power Service Corp.
 Groveport, Ohio




JOB NO. 3015
 PROJECT SPORN PLANT ASH HAUL ROAD
 LOCATION: ASH HAUL ROAD SLIP

DATE: 08/18/94

SOURCE OF MATERIAL S-5619 DEPTH 0.0 FT.
 DESCRIPTION OF MATERIAL _____
 ASTM DESCRIPTION FAT CLAY CH

METHOD ASTM D698-91 MTHDA MAX. DRY DENSITY 105.2 PCF OPTIMUM MOISTURE 20.6 %



MOISTURE-DENSITY RELATIONSHIP

American Electric Power Service Corp.
 Groveport, Ohio



RELATIVE DENSITY - MAX/MIN METHOD


Project : Sporn Fly Ash Pond Dike Remediation

Location : New Haven, West Virginia

Sample : Bucket

Material : Bottom Ash : Dark-gray and gray fine to coarse sand,
 little fine to coarse gravel, trace silt.

JOB NO. T-333D



RELATIVE DENSITY TEST DATA AND COMPUTATION SHEET

PROJECT : _____ JOB NO. : T-533D DATE : 10/7/95

DRILLING : _____ SAMPLE : _____ DEPTH : _____

MATERIAL : _____

MAXIMUM DENSITY DETERMINATION (0% RELATIVE DENSITY)		
Test No.	1	2
Wt. Soil + Mold , gms.	9227	* 9214
Wt. Mold , gms.	6688	6688
Wt. Soil (Ws) , gms	2539	2526
Volume of Mold (Vc) , ft ³	.1145	.1145
Minimum Density (PCF) - $\frac{W_s(\min)}{V_c(\min)} \times 453.6$	48.9	(48.64)

MAXIMUM DENSITY DETERMINATION (100% RELATIVE DENSITY)			
Test No.	-	1	2
Method	-	INT. HT.	
Avg. Void Reading , inches	Rf	2.53	
Final Ht. of Soil , inches	Hf	4.47	
Area of Sample Surface, ft ²	A	.1963	
Calib. Vol. of Mold , ft ³	Vc	.1145	
Soil Volume - $\frac{H_f}{12} \times A$	Vs	.0731	
Wt. Wet Soil + Mold , gms.	-	9667	
Wt. Mold , gms.	-	6688	
Wt. Wet Soil , gms	Ww	2979	
Wt. Dry Soil , gms.	Ws	2162	
Maximum Density (PCF) - $\frac{W_s(\max)}{V_s(\max)} \times 453.6$	-	65.2	

RELATIVE DENSITY COMPUTATION		
Test No.	1	
In-place density , pcf	()	
maximum lab. density , pcf	65.20	
minimum lab. density , pcf	48.64	
Relative Density - %	$\frac{65.20}{48.64} = 75\%$	

Molsture Content	After Test
Pan No. :	DW-1
Wet Wt. Sp. + Pan :	3257
Dry Wt. Sp. + Pan :	2453
Wt. of Pan :	324
Wt. of Dry Soil :	2129
Wt. of Water :	804
% Molsture (mc)	37.76

@ 75% DR : Dry Soil For Tx = 565.95 gms.
(Vol. of specimen = 35.85 in³)

$$W_s = \frac{W_w}{1 + mc}$$

Bottom Insert Thickness : 0.25 inches

H_f = Ht. of Mold - Bottom Insert Thickness - Average Top Void Reading (Rf) .

H_f = 6.75 inches

Tested By : D.W. Computed By : JS Checked By : _____

SPECIFIC GRAVITY DETERMINATION

Dry 469.07

- Steps:
1. Weigh flask partly filled with distilled water.
 2. Add dry soil and weigh again; difference in weights = weight of soil added (W_s)
 3. After soaking period, evacuate for 15 minutes, then add distilled water to calibration line.
 4. Weigh flask, soil and H_2O (W_{bws}) (Record temperature)
 5. Determine from calibration chart, weight of flask and H_2O for temperature recorded (W_{bw})
 6. Specific gravity = $\frac{W_s}{W_s + W_{bw} - W_{bws}}$

Job. No T-533 D

Date

Boring: Sample: Depth:

Material:			
Flask No.	3		
A: Flask + H_2O + Soil	536.03		
B: Flask + H_2O	469.98		
C: $W_s = A - B$	66.05		
Temp. °C	28.6		
D: W_{bw} (from chart)	649.57		
E: $(C+D) = W_{bw} + W_s$	715.62		
F: W_{bws}	689.58		
G = $(E - F) = W_s + W_{bw} - W_{bws}$	26.04		
Specific Gravity = $\frac{C}{G}$	2.54		

F A: L-15

Tested By: JB Computed By: JB Checked By:



TABLE 3.7
COMMON PROPERTIES OF CLAY SOILS[†]

Consistency	N	Hand test	γ_{sat} ^a g/cm ³	Strength ^b U_c kN/cm ²
Hard	>30	Difficult to indent	>2.0	>4.0
Vary stiff	15-30	Indented by thumb nail	2.08-2.24	2.0-4.0
Stiff	8-15	Indented by thumb	1.92-2.08	1.0-2.0
Medium (firm)	4-8	Molded by strong pressure	1.76-1.92	0.5-1.0
Soft	2-4	Molded by slight pressure	1.60-1.76	0.25-0.5
Very soft	<2	Extrudes between fingers	1.44-1.60	0-0.25

^a $\gamma_{sat} = \gamma_{dry} + \gamma_w \left(\frac{e}{1+e} \right)$

^bUnconfined compressive strength U_c is usually taken as equal to twice the cohesion c or the undrained shear strength s_u . For the drained strength condition, most clays also have the additional strength parameter ϕ , although for most normally consolidated clays $c = 0$ (Lambe and Whitman (1969)[†]). Typical values for s_u and drained strength parameters are given in Table 3.50, Hunt (1984)[†].
[†]From Hunt (1984).[†] Reprinted with permission of McGraw-Hill Book Company.




FIG. 3.35 Correlations of SPT N values with U_c for cohesive soils of varying plasticities. [From NAVFAC 1971[†]]

TABLE 3.5
COMMON PROPERTIES OF COHESIONLESS SOILS**

Material	Compactness	D_R , %	N^*	γ_{dry} , g/cm ³	Void ratio e	Strength [†] ϕ
GW: well-graded gravels, gravel-sand mixtures	Dense	75	90	2.21	0.22	40
	Medium dense	50	55	2.08	0.28	36
	Loose	25	>28	1.97	0.36	32
GP: poorly graded gravels, gravel-sand mixtures	Dense	75	70	2.04	0.33	38
	Medium dense	50	50	1.92	0.39	35
	Loose	25	>20	1.83	0.47	32
SW: well-graded sands, gravelly sands	Dense	75	65	1.89	0.43	37
	Medium dense	50	35	1.79	0.49	34
	Loose	25	>15	1.70	0.57	30
SP: poorly graded sands, gravelly sands	Dense	75	50	1.76	0.52	36
	Medium dense	50	30	1.67	0.60	33
	Loose	25	>10	1.59	0.65	29
SM: silty sands	Dense	75	45	1.65	0.62	35
	Medium dense	50	25	1.55	0.74	32
	Loose	25	>8	1.49	0.80	29
ML: inorganic silts, very fine sands	Dense	75	35	1.49	0.80	33
	Medium dense	50	20	1.41	0.90	31
	Loose	25	>4	1.35	1.0	27

* N is blows per foot of penetration in the SPT. Adjustments for gradation are after Burmister (1962).²⁴ See Table 6.4 for general relationships of D_R vs. N .

[†]Density given is for $G_s = 2.68$ (quartz grains).

[‡]Friction angle ϕ depends on mineral type, normal stress, and grain angularity as well as D_R and gradation (see Fig. 3.29).

**From Hunt (1984).[†] Reprinted with permission of McGraw-Hill Book Company.

"**GEOTECHNICAL ENGINEERING TECHNIQUES AND PRACTICES**", ROY. E. HUNT,
McGraw-Hill, Inc., 1986, USA

Figure 8-6 gives the approximate range of k values one may expect to obtain. The coefficient of permeability is plotted on a log scale, since the range of permeabilities is so large. No other engineering property of any material exhibits such a large range of values as does the permeability of soil.

An empirical equation relating the coefficient of permeability to the effective grain size (D_{10}) from a sieve analysis was reported by A. Hazen (ca. 1892) based on work with rapid sand filters in water treatment plants. He found that for sands with D_{10} sizes between 0.1 and 3.0 mm, the coefficient of permeability could be expressed approximately† as

$$k = C(D_{10}^2) \quad \text{cm/s} \quad (8-9)$$




Figure 8-6 Typical ranges of permeability coefficients and suggested test methods.

Is this equation D_{10} is the effective grain size in centimeters, with C such that k is in centimeters per second. The coefficient C varies, according to Hazen, from about 40 to 150 and the values may be taken as follows:

C	Sand (any or all of the following applies)
40-80	Very fine, well graded or with appreciable fines [(-) No. 200]
80-120	Medium coarse, poorly graded: clean, coarse but well graded
120-150	Very coarse, very poorly graded, gravelly, clean

One would expect that poorly graded sand would have a larger coefficient than well-graded materials, since the void spaces would be more ordered and larger with poorly graded soil.

An estimate of the permeability k_2 at a void ratio of e_2 when a test was performed with results of k_1 at void ratio e_1 may be made as

$$k_2 = k_1 \left(\frac{e_2}{e_1} \right)^2$$

Other equations more complicated than this have been suggested, but in the range of void ratios (0.5 to 1.1) likely to be used, this equation is considerably simpler and the results are sufficiently precise considering the precision with which k_1 can be determined.

|| PHYSICAL AND GEOTECHNICAL PROPERTIES OF SOILS,
JOSEPH E. BOWLES, McGRAW-HILL, Inc. 1984 Second Edition pg 251 & 252

LABORATORY DATA FROM:
***“PHILIP SPORN ELECTRIC GENERATING PLANT UNIT 5 ASH
FACILITY – ENGINEERING REPORT”***

PREPARED/COMPILED BY:
**THE GEOTECHNICAL ENGINEERING SECTION OF AMERICAN
ELECTRIC POWER SERVICE CORPORATION**

DATED: JULY 1998



H. C. NUTTING COMPANY

EMPLOYEE OWNED

GEOTECHNICAL, ENVIRONMENTAL AND TESTING ENGINEERS
SINCE 1921

CORPORATE CENTER
4120 AIRPORT ROAD
CINCINNATI, OHIO 45226
(513) 321-5816
FAX (513) 321-0294

Order No. 90979.030

December 19, 1996

Mr. J.P. Amaya
American Electric Power Corporation
1 Riverside Plaza
Columbus, OH 45315

Re: **Laboratory Tests**
Project: **Sporn Plt-Bott. Ash Pond**
Certification-C-9117
LOA-002-96

Dear Mr. Amaya:

Submitted herewith is our report covering the results of seventeen (17) consolidated undrained triaxial tests with pore pressure measurements, seven (7) mechanical sieve and hydrometer and (7) Atterberg Limits. Tests were performed per your request by letter dated November 22, 1996. All samples were obtained and shipped to our laboratory from the referenced project by your representative. Cost for these tests were as outlined per Contract No. C-9117.

Should any discussion be required concerning this report, please feel free contact the undersigned. The H.C. Nutting Company thanks American Electric Power for allowing them this opportunity to be of service.

Respectfully submitted,

H.C. NUTTING COMPANY

Robert L. House,
Vice President/Lab. Director

AEPSP003457

H.C. Nutting Company
 4120 Airport Road
 Cincinnati, Ohio 45226

American Electric Power
 Sporn Pit-Bott. Ash Pond Certification LOA-002-96
 New Haven, WV
 HCN W.O. #90979.030

12/19/69sno

TABLE I

CLASSIFICATION TEST DATA

Lab No.	Boring No.	Sample No.	Depth (Ft.)	Mechanical Analysis				Atterberg Limits			U.S.C.S Classification
				% Gravel	% Sand	% Silt	% Clay	Liquid Limit (%)	Plastic Limit (%)	Plasticity Index	
8563	96-101	ST-10	---	0	18	58	24	27	20	7	CL-ML
8564	96-104	ST-9	31.7-33.7	16	46	26	12	NP	NP	NP	SM
8565	96-106	ST-15	61.5-63.5	0	7	58	35	38	24	14	CL
8566	96-107	ST-16	66.6-68.6	0	16	52	32	43	26	17	CL
8567	96-108	ST-10	41.6-43.6	0	7	52	42	44	30	14	ML
8568	96-109	ST-8	26.7-28.7	0	54	43	3	NP	NP	NP	SM
8569	96-110	ST-18	58.6-60.6	0	19	50	31	39	27	12	ML

H.C. NUTTING COMPANY



Robert L. House,
 Vice President/Lab. Director

H.C. Nutting Company
 4120 Airport Road
 Cincinnati, Ohio 45226

American Electric Power
 Sporn Pit-Bott. Ash Pond Certification LOA-002-96
 New Haven, WV
 HCN W.O. # 90979.030

12/19/96smo

TABLE II
TABULATION OF UNDISTURBED TEST DATA

PAGE 1 OF 2

Boring No.	Sample No.	Depth (Ft.)	Triaxial Compressive Strength (TSF)	Confining Pressure P.S.I.	Failure Strain (%)	Dry Density (Lbs./Cu. Ft.)	Water Content (%)	Lab No.
96-101	ST-10	---	4.31	14	13.4	106.5	18.5	8563
			5.69	28	15.9	113.5	16.8	"
			9.15	56	21.8	114.3	15.4	"
96-104	ST-9	31.7-33.7	3.67	14	23.4	119.4	8.2	8564
			3.22	28	24.6	113.3	9.2	"
			---	56	---	---	9.9	"
96-106	ST-15	61.5-63.5	2.17	21	17.5	97.1	26.5	8565
			3.69	42	15.8	98.1	26.5	"
			3.64	84	20.4	99.1	26.5	"
96-107	ST-16	66.6-68.6	2.18	21	15.7	98.3	26.0	8566
			3.40	42	11.7	97.2	27.4	"
			5.83	84	12.1	96.5	28.4	"

H.C. NUTTING COMPANY

Robert L. House

Robert L. House,
 Vice President/Lab. Director

H.C. Nutting Company
 4120 Airport Road
 Cincinnati, Ohio 45226

12/19/96smo


American Electric Power
 Sporn Plt-Bott. Ash Pond Certification LOA-002-96
 New Haven, WV
 HCN W.O. # 90979.030

TABLE II
TABULATION OF UNDISTURBED TEST DATA

PAGE 2 OF 2


Boring No.	Sample No.	Depth (Ft.)	Triaxial Compressive Strength (TSF)	Confining Pressure P.S.I.	Failure Strain (%)	Dry Density (Lbs./Cu. Ft.)	Water Content (%)	Lab No.
96-108	ST-10	41.6-43.6	1.77	14	7.4	88.1	34.6	8567
			2.25	28	12.8	85.1	38.4	"
			3.82	56	15.8	84.7	36.9	"
96-109	ST-8	26.7-28.7	UNIT WT.	---	---	74.3	4.1	8568
96-110	ST-18	58.6-60.6	2.55	21	6.3	94.3	28.9	8569
			2.70	42	9.3	93.9	28.8	"
			5.22	84	5.7	94.5	27.5	"

H.C. NUTTING COMPANY



Robert L. House,
 Vice President/Lab. Director

GRAIN SIZE DISTRIBUTION TEST REPORT



% +75 mm	% GRAVEL	% SAND	% SILT	% CLAY
0.0	0.0	18.3	57.3	24.4

LL	PI	D ₈₅	D ₆₀	D ₅₀	D ₃₀	D ₁₅	D ₁₀	C _c	C _u
27	7	0.09	0.04	0.03	0.009				



MATERIAL DESCRIPTION	USCS	AASHTO
● SILTY CLAY WITH SAND	CL-ML	

Project No.: 90979.030
 Project: Sporn Plt-Bott. Ash Pond Certification LOI-002-96*
 ● Location: Boring: 96-101 Sample: ST-10
 *New Haven, WV
 Date: 12/13/95

Remarks:
 Client: American Electric Power
 Lab No. 8563

GRAIN SIZE DISTRIBUTION TEST REPORT
H. C. NUTTING COMPANY

Figure No. _____





	1	2	3	
SAMPLE NO.	1	2	3	
INITIAL	WATER CONTENT, %	18.5	16.8	15.4
	DRY DENSITY, pcf	106.5	113.5	114.3
	SATURATION, %	100.0	100.0	100.0
	VOID RATIO	0.594	0.496	0.485
	DIAMETER, in	2.84	2.85	2.85
	HEIGHT, in	4.54	4.52	4.62
AT TEST	WATER CONTENT, %	22.5	18.2	16.3
	DIAMETER, in	2.81	2.82	2.78
	HEIGHT, in	4.49	4.47	4.50
Strain rate, %/min	0.001	0.001	0.001	
BACK PRESSURE, tsf	2.88	2.88	2.88	
CELL PRESSURE, tsf	3.89	4.90	6.91	
FAILURE STRESS, tsf	4.31	5.69	9.15	
PORE PRESSURE, tsf	2.46	3.25	4.02	
ULTIMATE STRESS, tsf				
PORE PRESSURE, tsf				
$\bar{\sigma}_1$ FAILURE, tsf	5.74	7.34	12.04	
$\bar{\sigma}_3$ FAILURE, tsf	1.49	1.65	2.89	

TYPE OF TEST:
 CU with pore pressures
 SAMPLE TYPE:
 DESCRIPTION: BR & GR SILTY CLAY
 WITH SAND
 LL = 27 PL = 20 PI = 7.0
 SPECIFIC GRAVITY =
 REMARKS: Lab No. 8563

CLIENT: American Electric Power
 PROJECT: Sporn Pit-Bott. Ash Pond
 Certification LOA-002-96, New Haven, WV
 SAMPLE LOCATION: Boring: 96-101
 Sample: ST-10
 PROJ. NO.: 90979.030 DATE: 12/13/96


FIG. NO.

TRIAxIAL SHEAR TEST REPORT
H. C. NUTTING COMPANY



Client: American Electric Power
 Project: Sporn Plt-Bott. Ash Pond Certification LOA-002-96, New Haven, WV
 Location: Boring: 96-101 Sample: ST-10
 File: 8563 Project No.: 90979.030 Page 2/2 Fig. No. _____

GRAIN SIZE DISTRIBUTION TEST REPORT



● % +75 mm	% GRAVEL	% SAND	% SILT	% CLAY
0.0	16.2	45.7	26.4	11.7



LL	PI	D ₈₅	D ₆₀	D ₅₀	D ₃₀	D ₁₅	D ₁₀	C _c	C _u
NP	NP	10.35	0.20	0.14	0.045	0.0106	0.0025	3.92	80.6

MATERIAL DESCRIPTION	USCS	AASHTO
● SILTY SAND WITH GRAVEL	SM	

Project No.: 90979.030
 Project: Sporn Plt-Bott. Ash Pond Certification LOA#002-96
 ● Location: Boring: 96-104 Depth: 31.7-33.7' *
 *New Haven, WV
 Date: 12/13/95

Remarks:
 Client: American Electric Power
 * Sample: ST-9
 Lab No. 8564
 Figure No. _____

GRAIN SIZE DISTRIBUTION TEST REPORT
H. C. NUTTING COMPANY



	1	2
INITIAL		
SAMPLE NO.	1	2
WATER CONTENT, %	8.2	9.2
DRY DENSITY, pcf	119.4	113.3
SATURATION, %	100.0	100.0
VOID RATIO	0.401	0.477
DIAMETER, in	2.85	2.81
HEIGHT, in	4.91	4.40
AT TEST		
WATER CONTENT, %	13.5	14.2
DIAMETER, in	2.77	2.75
HEIGHT, in	4.78	4.31
Strain rate, %/min	0.001	0.001
BACK PRESSURE, tsf	2.88	2.88
CELL PRESSURE, tsf	3.89	4.90
FAILURE STRESS, tsf	3.67	3.22
PORE PRESSURE, tsf	2.34	3.72
ULTIMATE STRESS, tsf		
PORE PRESSURE, tsf		
$\bar{\sigma}_1$ FAILURE, tsf	5.22	4.39
$\bar{\sigma}_3$ FAILURE, tsf	1.55	1.17



TYPE OF TEST: CU with pore pressures
 SAMPLE TYPE:
 DESCRIPTION: BR SILTY SAND WITH GRAVEL
 LL= NP PL= NP PI= NP
 SPECIFIC GRAVITY=
 REMARKS: Lab No. 8564

CLIENT: American Electric Power
 PROJECT: Sporn Pit-Bott. Ash Pond
 Certification LOA-002-96, New Haven, WV
 SAMPLE LOCATION: Boring: 96-104
 Depth: 31.7-33.7' Sample: ST-9
 PROJ. NO.: 90979.030 DATE: 12/13/96




FIG. NO.

TRIAXIAL SHEAR TEST REPORT
H. C. NUTTING COMPANY

Excess Pore Pressure ---
 Deviator Stress —
 tsf



Excess Pore Pressure ---
 Deviator Stress —
 tsf



Client: American Electric Power

Project: Sporn Plt-Bott. Ash Pond Certification LOA-002-96, New Haven, WV

Location: Boring: 96-104 Depth: 31.7-33.7'



Sample: ST-9

File: 8564

Project No.: 90979.030

Page 2/2

Fig. No. _____



	1	2	3	
SAMPLE NO.				
INITIAL	WATER CONTENT, %	26.5	26.5	26.5
	DRY DENSITY, pcf	97.1	98.1	99.1
	SATURATION, %	96.4	98.7	100.0
	VOID RATIO	0.749	0.730	0.713
	DIAMETER, in	2.78	2.83	2.84
	HEIGHT, in	5.25	5.37	5.16
AT TEST	WATER CONTENT, %	26.7	24.7	25.0
	DIAMETER, in	2.73	2.77	2.77
	HEIGHT, in	5.16	5.26	5.04
Strain rate, %/min	0.001	0.001	0.001	
BACK PRESSURE, tsf	2.88	2.88	2.88	
CELL PRESSURE, tsf	4.39	5.90	8.93	
FAILURE STRESS, tsf	2.17	3.69	3.64	
PORE PRESSURE, tsf	3.72	4.67	7.38	
ULTIMATE STRESS, tsf				
PORE PRESSURE, tsf				
$\bar{\sigma}_1$ FAILURE, tsf	2.85	4.92	5.19	
$\bar{\sigma}_3$ FAILURE, tsf	0.68	1.23	1.55	



TYPE OF TEST:
 CU with pore pressures
 SAMPLE TYPE:
 DESCRIPTION: Br LEAN CLAY
 LL= 38 PL= 24 PI= 14.0
 SPECIFIC GRAVITY=
 REMARKS: Lab No. 8565

CLIENT: American Electric Power
 PROJECT: Sporn Pit-Bott. Ash Pond
 Certification LOA-002-96, New Haven, WV
 SAMPLE LOCATION: Bor Ing: 96-106
 Depth: 61.5-63.5' Sample: ST-15
 PROJ. NO.: 90979.030 DATE: 12/19/96




TRIAxIAL SHEAR TEST REPORT
H. C. NUTTING COMPANY

FIG. NO.

Excess Pore Pressure ---
Deviator Stress —



Excess Pore Pressure ---
Deviator Stress —



Client: American Electric Power

Project: Sporn Plt-Bott. Ash Pond Certification LOA-002-96, New Haven, WV

Location: Boring: 96-106 Depth: 61.5-63.5'

Sample: ST-15


File: 8565

Project No.: 90979.030

Page 2/2

Fig. No. _____

GRAIN SIZE DISTRIBUTION TEST REPORT



% +75 mm	% GRAVEL	% SAND	% SILT	% CLAY
0.0	0.0	16.1	51.5	32.4



LL	PI	D ₈₅	D ₆₀	D ₅₀	D ₃₀	D ₁₅	D ₁₀	C _c	C _u
43	17	0.08	0.03	0.01	0.004				

MATERIAL DESCRIPTION	USCS	AASHTO
● CLAY WITH SAND	CL	

Project No.: 90979.030
 Project: Sporn Plt-~~Box~~ Ash Pond Certification LOA-002-96*
 ● Location: Boring: 96-107 Depth: 66.6-68.6' *
 *New Haven, WV
 Date: 12/13/95

Remarks:
 Client: American Electric Power
 * Sample: ST-16
 Lab No. 8566
 Figure No. _____

GRAIN SIZE DISTRIBUTION TEST REPORT
H. C. NUTTING COMPANY



SAMPLE NO.		1	2	3
INITIAL	WATER CONTENT, %	26.0	27.4	28.4
	DRY DENSITY, pcf	98.3	97.2	96.5
	SATURATION, %	95.8	98.4	100.0
	VOID RATIO	0.747	0.767	0.778
	DIAMETER, in	2.83	2.85	2.84
	HEIGHT, in	5.20	5.21	5.16
AT TEST	WATER CONTENT, %	26.6	25.6	23.6
	DIAMETER, in	2.78	2.81	2.73
	HEIGHT, in	5.11	5.13	4.96
Strain rate, %/min		0.001	0.001	0.001
BACK PRESSURE, tsf		2.88	2.88	2.88
CELL PRESSURE, tsf		4.39	5.90	8.93
FAILURE STRESS, tsf		2.18	3.40	5.83
PORE PRESSURE, tsf		3.74	4.87	7.43
ULTIMATE STRESS, tsf				
PORE PRESSURE, tsf				
$\bar{\sigma}_1$	FAILURE, tsf	2.82	4.43	7.33
$\bar{\sigma}_3$	FAILURE, tsf	0.65	1.04	1.5



TYPE OF TEST:
 CU with pore pressures
 SAMPLE TYPE:
 DESCRIPTION: Br CLAY WITH SAND
 LL = 43 PL = 17 PI = 26.0
 SPECIFIC GRAVITY =
 REMARKS: Lab No. 8566

CLIENT: American Electric Power
 PROJECT: Sporn Pit-^{Fly} Ash Pond
 Certification LOA-002-96, New Haven, WV
 SAMPLE LOCATION: Borlng:96-107
 Depth: 66.6-68.6' Sample: ST-16
 PROJ. NO.: 90979.030 DATE: 12/13/96

TRIAxIAL SHEAR TEST REPORT


H. C. NUTTING COMPANY

FIG. NO.



Client: American Electric Power
 Project: Sporn Plt-Bott.Ash Pont Certification LOA-002-96, New Haven, WV
 Location: Boring:96-107 Depth:66.6-68.6' Sample:ST-16
 File: 8566 Project No.: 90979.030 Page 2/2 Fig. No. _____

GRAIN SIZE DISTRIBUTION TEST REPORT



% +75 mm	% GRAVEL	% SAND	% SILT	% CLAY
0.0	0.0	7.2	51.3	41.5

LL	PI	D ₈₅	D ₆₀	D ₅₀	D ₃₀	D ₁₅	D ₁₀	C _c	C _u
44	14	0.04	0.01	0.01	0.002				



MATERIAL DESCRIPTION	USCS	AASHTO
● SILT	ML	

Project No.: 90979.030
 Project: Sporn Plt-~~Box~~ Ash Pond Certification LOA-002-96*
 ● Location: Boring: 96-108 Depth: 41.6-43.6' *
 * New Haven, WV
 Date: 12/16/95

Remarks:
 Client: American Electric Power
 * Sample: ST-10
 Lab No. 8567

GRAIN SIZE DISTRIBUTION TEST REPORT
H. C. NUTTING COMPANY

Figure No. _____



	1	2	3
INITIAL			
WATER CONTENT, %	34.6	38.4	36.9
DRY DENSITY, pcf	88.1	85.1	84.7
SATURATION, %	100.0	100.0	100.0
VOID RATIO	0.913	0.980	0.990
DIAMETER, in	2.83	2.84	2.84
HEIGHT, in	5.56	5.56	5.56
AT TEST			
WATER CONTENT, %	34.5	33.9	32.9
DIAMETER, in	2.81	2.80	2.75
HEIGHT, in	5.52	5.49	5.38
Strain rate, %/min	0.001	0.001	0.001
BACK PRESSURE, tsf	2.88	2.88	2.88
CELL PRESSURE, tsf	3.89	4.90	6.91
FAILURE STRESS, tsf	1.77	2.25	3.82
PORE PRESSURE, tsf	3.51	4.33	5.70
ULTIMATE STRESS, tsf			
PORE PRESSURE, tsf			
$\bar{\sigma}_1$ FAILURE, tsf	2.14	2.81	5.04
$\bar{\sigma}_3$ FAILURE, tsf	0.37	0.56	1.22



TYPE OF TEST:
 CU with pore pressures
 SAMPLE TYPE:
 DESCRIPTION: ~~SILT~~ CLAY
 LL= 44 PL= 14 PI= 30.0
 SPECIFIC GRAVITY= 0
 REMARKS: Lab No. 8567

CLIENT: American Electric Power
 PROJECT: Sporn Pit-~~Butt~~^{fly}. Ash Pond
 Certification LOA-002-96
 SAMPLE LOCATION: Borlng:96-108
 Depth: 41.6-43.6' Sample: ST-10
 PROJ. NO.: 90979.030 DATE: 12/16/96

TRIAxIAL SHEAR TEST REPORT


H. C. NUTTING COMPANY

FIG. NO.



Client: American Electric Power
 Project: Sporn Plt-Bott. Ash Pond Certification LOA-002-96
 Location: Boring:96-108 Depth:41.6-43.6' Sample:ST-10
 File: 8567 Project No.: 90979.030 Page 2/2 Fig. No. _____

GRAIN SIZE DISTRIBUTION TEST REPORT



% +75 mm	% GRAVEL	% SAND	% SILT	% CLAY
0.0	0.0	19.0	50.3	30.7



LL	PI	D ₈₅	D ₆₀	D ₅₀	D ₃₀	D ₁₅	D ₁₀	C _c	C _u
39	12	0.10	0.03	0.02	0.005				

MATERIAL DESCRIPTION	USCS	AASHTO
● SILT WITH SAND	ML	

Project No.: 90979.030
 Project: Sporn Plt-~~Det.~~ Ash Pond Certification LOA-002-96*
 ● Location: Boring: 96-110 Depth: 58.6-60.6' *
 * New Haven, WV
 Date: 12/16/95

Remarks:
 Client: American Electric Power
 * Sample: ST-18
 Lab No. 8569
 Figure No. _____


GRAIN SIZE DISTRIBUTION TEST REPORT
H. C. NUTTING COMPANY



Client: American Electric Power
 Project: Sporn Plt-Bott. Ash Pond Certification LOA-002-96, New Haven, WV
 Location: Boring:96-110 Depth:58.6-60.6' Sample:St-18
 File: 8569 Project No.: 09079.030 Page 2/2 Fig. No. _____

RELATIVE DENSITY - MAX/MIN METHOD

Project : Sporn Fly Ash Pond Dike Remediation
 Location : New Haven, West Virginia
 Sample : Bucket
 Material : Bottom Ash : Dark-gray and gray fine to coarse sand,
 little fine to coarse gravel, trace silt.



JOB NO. 2010

SUMMARY OF MATERIAL PROPERTIES

SUBJECT: SPORN PLANT - FLY ASH POND DIKES
 NUMBER:

Excavation	Depth ASTM Description	ASTM Soil Type	Maximum Dry Density pcf	Optimum Moisture %	Liquid Limit %	Plastic Limit %	Gravel Sand #200 <.002			Specific Gravity	Prmbly	Natural Moisture %
							Sieve	mm	%			
-101	5.0 SILTY SAND with GRAVEL	SM		NP	NP	NP	29.9	51.2	18.9			16.5
-101	8.5 SILTY SAND with GRAVEL	SM		NP	NP	NP	17.6	44.1	38.3			10.0
-101	16.5 SILTY SAND with GRAVEL	SM		NP	NP	NP	24.7	57.3	18.0			4.2
-101	24.5 POORLY GRADED SAND with SILT and GRAVEL	SP-SM		NP	NP	NP	43.2	49.1	7.7			2.6
-101	26.5 POORLY GRADED SAND with SILT and GRAVEL	SP-SM		NP	NP	NP	35.5	52.3	12.2			6.8
-101	31.5 POORLY GRADED SAND with SILT and GRAVEL Silty Clay with sand	CL		NP	NP	NP	0.4	48.7	50.9			10.8
-101	36.5 LEAN CLAY	CL		26.6	16.3	0.0		10.7	89.3			17.0
-102	8.5 SILTY SAND with GRAVEL	SM		NP	NP	NP	31.3	49.7	19.0			6.5
-102	16.7 POORLY GRADED GRAVEL with SILT and SAND	GP-GM		NP	NP	NP	50.2	42.9	6.9			2.8
-102	26.7 SANDY SILT	ML		NP	NP	NP	1.7	37.1	61.2			11.8
-102	31.7 LEAN CLAY with SAND	CL		27.7	18.4	0.0		24.2	75.8			18.4
-102	36.7 SANDY LEAN CLAY	CL		23.8	16.2	0.0		47.3	52.7			15.6
-102	41.7 POORLY GRADED SAND with SILT and GRAVEL	SP-SM		NP	NP	NP	38.3	52.5	9.2			5.3
-103	21.6 POORLY GRADED SAND with SILT and GRAVEL	SP-SM		NP	NP	NP	40.0	51.0	9.0			4.7
-103	31.6 LEAN CLAY with SAND	CL		28.6	18.8	0.0		26.6	73.4			14.5
-103	41.6 SILTY SAND	SM		NP	NP	NP	10.0	53.7	46.3			11.4
-104	3.0 POORLY GRADED SAND with SILT and GRAVEL	SP-SM		NP	NP	NP	41.5	53.6	4.9			1.1
-104	8.5 POORLY GRADED SAND with SILT and GRAVEL	SP-SM		NP	NP	NP	30.8	57.5	11.7			1.0
-104	11.7 POORLY GRADED SAND with SILT and GRAVEL	SP-SM		NP	NP	NP	41.7	48.5	9.8			1.2
-104	16.5 SAND with GRAVEL	SM		NP	NP	NP	19.4	64.7	15.9			4.0
-104	21.5 SAND with GRAVEL	SM		NP	NP	NP	34.4	47.5	18.1			2.9
-104	26.5 LEAN CLAY with SAND	CL		27.2	19.0	0.0		22.8	77.2			18.9
-104	41.7 SANDY SILT	ML		NP	NP	NP	0.0	35.3	64.7			8.1
-105	3.0 POORLY GRADED SAND with SILT and GRAVEL	SP-SM		NP	NP	NP	40.2	53.9	5.9			1.6
-105	16.5 POORLY GRADED SAND with SILT and GRAVEL	SP-SM		NP	NP	NP	42.7	48.8	8.5			3.1
-105	21.5 SILTY SAND with GRAVEL	SM		NP	NP	NP	19.0	61.9	19.1			6.7
-105	26.5 LEAN CLAY with SAND	CL		27.4	17.7	0.0		26.6	73.4			13.3
-105	36.5 LEAN CLAY	CL		28.8	18.7	0.0		4.4	95.6			22.1
-105	41.5 SILTY SAND	SM		NP	NP	NP	0.0	51.2	48.8			11.9
-106	16.5 SAND with GRAVEL	SM		NP	NP	NP	19.1	59.8	21.1			5.5
-106	21.5 SANDY LEAN CLAY	CL		26.1	17.5	0.0		33.4	66.6			11.1
-106	31.5 SILT	ML		NP	NP	NP	0.0	11.1	88.9	2.29		42.6


P Civil Engineering Laboratory, Groveport, Ohio

SUMMARY OF MATERIAL PROPERTIES

PROJECT: SPORN PLANT - FLY ASH POND DIKES
 NUMBER:

Excav	Depth ft.	Description	ASTM Classification	Soil Type	Maximum Dry Density pcf	Optimum Moisture %	Liquid Limit %	Plastic Limit %	Gravel Sand <#200		Specific Gravity	Permeability cm/sec	Natural Moisture %
									Sieve mm	%			
-106	51.5	SILT with SAND	ML			NP	NP	NP	10.0	15.2	84.8	2.42	35.7
-106	56.5	LEAN CLAY	CL			43.6	25.6	10.0	2.6	97.4			31.9
-107	11.5	POORLY GRADED SAND with SILT and GRAVEL	SP-SM			NP	NP	34.7	54.9	10.4			3.9
-107	16.5	SANDY LEAN CLAY	CL			25.2	18.1	10.0	31.9	68.1			14.0
-107	21.5	SANDY SILTY SAND	ML			NP	NP	0.0	35.4	64.6			11.4
-107	36.5	LEAN CLAY	CL			NP	NP	0.0	21.9	78.1		2.38	37.6
-107	56.6	SILT	ML			NP	NP	0.0	11.3	88.7		2.31	36.2
-107	71.6	LEAN CLAY	CL			41.3	21.1	10.0	11.4	88.6			25.2
-108	3.0	SILTY SAND with GRAVEL	SM			NP	NP	14.8	50.6	34.6			9.1
-108	8.5	SILTY SAND	SM			NP	NP	13.7	49.9	36.4			6.2
-108	11.5	SANDY SILTY SAND with GRAVEL	SM			NP	NP	34.4	50.4	15.2			3.0
-108	16.5	SANDY SILTY SAND with GRAVEL	SM			NP	NP	16.9	55.3	27.8			1.9
-108	21.6	SANDY SILTY CLAY	CL-ML			23.3	16.5	10.0	40.5	59.5			12.2
-108	26.6	SILTY SAND	SM			NP	NP	10.4	72.7	16.9			20.6
-108	41.6	LEAN CLAY	CL			38.7	20.3	10.0	9.5	90.5			23.2
-108	56.6	LEAN CLAY with SAND	CL			34.9	20.1	10.0	25.3	74.7			25.1
-109	8.5	POORLY GRADED SAND with SILT and GRAVEL	SP-SM			NP	NP	34.7	55.9	9.4			0.4
-109	11.7	SILTY SAND	SM			NP	NP	4.9	72.1	23.0			4.3
-109	36.7	SILT	ML			22.9	17.1	10.0	40.9	59.1			9.0
-109	56.7	SILT	ML			NP	NP	0.0	8.9	91.1		2.34	38.1
-109	71.7	LEAN CLAY	CL			NP	NP	0.0	0.9	99.1		2.29	34.3
-110	5.0	SILTY SAND	SM			40.3	21.8	10.0	6.8	93.2			23.7
-110	8.5	POORLY GRADED GRAVEL with SILT and SAND	GP-GM			NP	NP	8.8	59.5	31.7			6.8
-110	16.6	LEAN CLAY with SAND	CL			25.5	17.6	10.0	38.0	8.7			0.1
-110	21.6	SANDY SILTY CLAY	CL-ML			24.0	17.0	10.0	29.1	70.9			11.5
-110	31.6	LEAN CLAY with SAND	CL			30.7	18.4	10.0	41.1	58.9			12.5
-110	46.6	LEAN CLAY	CL			36.2	21.3	10.0	18.0	82.0			14.7
-110	56.6	LEAN CLAY	CL			37.5	20.3	10.0	12.3	87.7			25.1
-110	66.6	LEAN CLAY with SAND	CL			38.7	21.7	10.0	13.1	86.9			24.4
-110									16.2	83.8			25.6

SP Civil Engineering Laboratory, Groveport, Ohio




COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.		
● 96-101 5.0		6.5	NP	NP	NP			
	SILTY SAND with GRAVEL SM							
Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-101 5.0	19.000	1.892	0.250		29.9	51.2	18.9	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio






COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.		
● 96-101 8.5	SILTY SAND with GRAVEL SM	10.0	NP	NP	NP			
Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-101 8.5	19.000	0.307			17.6	44.1	38.3	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-101 21.5		2.6	NP	NP	NP	
POORLY GRADED SAND with SILT and GRAVEL SP-SM						

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-101 21.5	19.000	5.404	0.471	0.146	43.2	49.1	7.7	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____
 DATE 05/21/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-101 26.5		6.8	NP	NP	NP	
POORLY GRADED SAND with SILT and GRAVEL SP-SM						

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-101 26.5	25.000	3.445	0.390		35.5	52.3	12.2	

PROJECT **SPORN PLANT - FLY ASH POND DIKES** JOB NO. _____
 DATE **05/21/97**

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio






COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.		
● 96-101 31.5	SANDY SILT ML	10.8	NP	NP	NP			
Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-101 31.5	9.500	0.148			0.4	48.7	50.9	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio







COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-102 8.5	SILTY SAND with GRAVEL SM	6.5	NP	NP	NP	

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-102 8.5	19.000	2.003	0.293		31.3	49.7	19.0	

PROJECT **SPORN PLANT - FLY ASH POND DIKES** JOB NO. _____
 DATE **05/21/97**

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-102 16.7		2.8	NP	NP	NP	
POORLY GRADED GRAVEL with SILT and SAND GP-GM						

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-102 16.7	25.000	8.604	0.517	0.166	50.2	42.9	6.9	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-102 26.7	SANDY SILT ML	11.8	NP	NP	NP	

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-102 26.7	9.500				1.7	37.1	61.2	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-102 36.7	SANDY LEAN CLAY CL	15.6	23.8	16.2	7.6	

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-102 36.7	2.360	0.097			0.0	47.3	52.7	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
American Electric Power Service Corp.
Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-102 41.7		5.3	NP	NP	NP	
POORLY GRADED SAND with SILT and GRAVEL SP-SM						

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-102 41.7	25.000	4.018	0.419	0.091	38.3	52.5	9.2	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-103 21.6		4.7	NP	NP	NP	
POORLY GRADED SAND with SILT and GRAVEL SP-SM						

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-103 21.6	25.000	4.750	0.445	0.096	40.0	51.0	9.0	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
American Electric Power Service Corp.
Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-103 41.6	SILTY SAND SM	11.4	NP	NP	NP	

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% <.002
● 96-103 41.6	2.360	0.105			0.0	53.7	46.3	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____
 DATE 05/22/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio






COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

Specimen Identification	Classification					MC%	LL	PL	PI	Sp.Gr.
● 96-104 3.0						1.1	NP	NP	NP	
POORLY GRADED SAND with SILT and GRAVEL SP-SM										
Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002		
● 96-104 3.0	25.000	5.044	0.578	0.202	41.5	53.6	4.9			

PROJECT **SPORN PLANT - FLY ASH POND DIKES** JOB NO. _____ DATE **05/21/97**

GRADATION CURVES
American Electric Power Service Corp.
Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification					MC%	LL	PL	PI	Sp.Gr.
● 96-104 8.5						1.0	NP	NP	NP	
POORLY GRADED SAND with SILT and GRAVEL SP-SM										

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-104 8.5	19.000	1.902	0.362		30.8	57.5	11.7	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
American Electric Power Service Corp.
Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-104 11.7		1.2	NP	NP	NP	
POORLY GRADED SAND with SILT and GRAVEL SP-SM						

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-104 11.7	25.000	5.180	0.433	0.079	41.7	48.5	9.8	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____
 DATE 05/21/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-104 16.7	SILTY SAND with GRAVEL SM	4.0	NP	NP	NP	

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% <.002
● 96-104 16.7	19.000	0.548	0.310		19.4	64.7	15.9	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-104 21.7		2.9	NP	NP	NP	
	SILTY SAND with GRAVEL SM					

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-104 21.7	25.000	2.576	0.293		34.4	47.5	18.1	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____
 DATE 05/21/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio






COBBLES	GRAVEL		SAND			SILT OR CLAY				
	coarse	fine	coarse	medium	fine					
Specimen Identification	Classification					MC%	LL	PL	PI	Sp.Gr.
● 96-104 36.7	LEAN CLAY with SAND CL					18.9	27.2	19.0	8.2	
Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002		
● 96-104 36.7	1.180				0.0	22.8	77.2			

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-104 41.7	SANDY SILT ML	8.1	NP	NP	NP	

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% <.002
● 96-104 41.7	1.180				0.0	35.3	64.7	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
American Electric Power Service Corp.
Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-105 3.0		1.6	NP	NP	NP	
POORLY GRADED SAND with SILT and GRAVEL SP-SM						

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-105 3.0	25.000	4.786	0.462	0.176	40.2	53.9	5.9	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
American Electric Power Service Corp.
Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-105 16.5		3.1	NP	NP	NP	
POORLY GRADED SAND with SILT and GRAVEL SP-SM						

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-105 16.5	25.000	5.440	0.475	0.112	42.7	48.8	8.5	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
American Electric Power Service Corp.
Groveport, Ohio






COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

Specimen Identification	Classification					MC%	LL	PL	PI	Sp.Gr.
● 96-105 21.5	SILTY SAND with GRAVEL SM					6.7	NP	NP	NP	
Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002		
● 96-105 21.5	19.000	0.511	0.210		19.0	61.9	19.1			

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-105 26.5	LEAN CLAY with SAND CL	13.3	27.4	17.7	9.8	

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-105 26.5	4.750				0.0	26.6	73.4	

PROJECT **SPORN PLANT - FLY ASH POND DIKES** JOB NO. _____ DATE **05/21/97**

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-105 36.5	LEAN CLAY CL	22.1	28.8	18.7	10.1	

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-105 36.5	1.180				0.0	4.4	95.6	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio






COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.		
● 96-105 41.5	SILTY SAND SM	11.9	NP	NP	NP			
Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-105 41.5	1.180	0.093			0.0	51.2	48.8	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-106 11.5		5.5	NP	NP	NP	
	SILTY SAND with GRAVEL SM					

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-106 11.5	19.000	0.517	0.202		19.1	59.8	21.1	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____
 DATE 05/21/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-106 21.5	SANDY LEAN CLAY CL	11.1	26.1	17.5	8.6	

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-106 21.5	4.750				0.0	33.4	66.6	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
American Electric Power Service Corp.
Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-106 31.5	SILT ML	42.6	NP	NP	NP	2.29

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-106 31.5	2.360				0.0	11.1	88.9	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____
 DATE 05/21/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-106 56.5	LEAN CLAY CL	31.9	43.6	25.6	18.0	


Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-106 56.5	4.750				0.0	2.6	97.4	

PROJECT SPORN PLANT - FLY ASH POND DIKES

JOB NO. _____
DATE 05/21/97

GRADATION CURVES
American Electric Power Service Corp.
Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-107 11.6		3.9	NP	NP	NP	
POORLY GRADED SAND with SILT and GRAVEL SP-SM						

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-107 11.6	19.000	3.266	0.395		34.7	54.9	10.4	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
American Electric Power Service Corp.
Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-107 16.6	SANDY LEAN CLAY CL	14.0	25.2	18.1	7.1	

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-107 16.6	0.600				0.0	31.9	68.1	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____
 DATE 05/21/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-107 36.6	SILT with SAND ML	37.6	NP	NP	NP	2.38


Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-107 36.6	2.360				0.0	21.9	78.1	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____
 DATE 05/21/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio







COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-108 3.0		9.1	NP	NP	NP	
	SILTY SAND with GRAVEL SM					

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-108 3.0	25.000	0.318			14.8	50.6	34.6	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-108 8.5	SILTY SAND SM	6.2	NP	NP	NP	

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-108 8.5	19.000	0.298			13.7	49.9	36.4	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-108 11.6	SILTY SAND with GRAVEL SM	3.0	NP	NP	NP	


Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-108 11.6	19.000	2.893	0.335		34.4	50.4	15.2	

PROJECT SPORN PLANT - FLY ASH POND DIKES

JOB NO. _____
DATE 05/21/97

GRADATION CURVES
American Electric Power Service Corp.
Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-108 16.6	SILTY SAND with GRAVEL SM	1.9	NP	NP	NP	

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-108 16.6	19.000	0.480	0.092		16.9	55.3	27.8	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
American Electric Power Service Corp.
Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-108 21.6	SANDY SILTY CLAY CL-ML	12.2	23.3	16.5	6.7	

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	%<.002
● 96-108 21.6	4.750	0.076			0.0	40.5	59.5	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-108 26.6	SILTY SAND SM	20.6	NP	NP	NP	

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-108 26.6	19.000	0.969	0.179		10.4	72.7	16.9	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
American Electric Power Service Corp.
Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-108 41.6	LEAN CLAY CL	23.2	38.7	20.3	18.4	

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-108 41.6	2.360				0.0	9.5	90.5	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____
 DATE 05/21/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-109 8.5		0.4	NP	NP	NP	
POORLY GRADED SAND with SILT and GRAVEL SP-SM						

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-109 8.5	19.000	3.348	0.416	0.086	34.7	55.9	9.4	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
American Electric Power Service Corp.
Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-109 11.7	SILTY SAND SM	4.3	NP	NP	NP	

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-109 11.7	19.000	0.394	0.142		4.9	72.1	23.0	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-109 16.7	SANDY SILTY CLAY CL-ML	9.0	22.9	17.1	5.7	


Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-109 16.7	4.750	0.077			0.0	40.9	59.1	

PROJECT SPORN PLANT - FLY ASH POND DIKES

JOB NO. _____
DATE 05/21/97

GRADATION CURVES
American Electric Power Service Corp.
Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-109 36.7	SILT ML	38.1	NP	NP	NP	2.34

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-109 36.7	0.600				0.0	8.9	91.1	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-109 56.7	SILT ML	34.3	NP	NP	NP	2.29

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-109 56.7	0.300				0.0	0.9	99.1	

PROJECT **SPORN PLANT - FLY ASH POND DIKES** JOB NO. _____
 DATE **05/21/97**

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-109 71.7	LEAN CLAY CL	23.7	40.3	21.8	18.5	

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-109 71.7	0.600				0.0	6.8	93.2	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-110 5.0	SILTY SAND SM	6.8	NP	NP	NP	


Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-110 5.0	19.000	0.465			8.8	59.5	31.7	

PROJECT SPORN PLANT - FLY ASH POND DIKES

JOB NO. _____
DATE 05/21/97

GRADATION CURVES
American Electric Power Service Corp.
Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-110 8.5		0.1	NP	NP	NP	
POORLY GRADED GRAVEL with SILT and SAND GP-GM						

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-110 8.5	25.000	8.931	0.554	0.106	53.3	38.0	8.7	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
American Electric Power Service Corp.
Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-110 16.6	LEAN CLAY with SAND CL	11.5	25.5	17.6	8.0	


Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-110 16.6	4.750				0.0	29.1	70.9	

PROJECT SPORN PLANT - FLY ASH POND DIKES

JOB NO. _____
DATE 05/21/97

GRADATION CURVES
American Electric Power Service Corp.
Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-110 21.6	SANDY SILTY CLAY CL-ML	12.5	24.0	17.0	7.0	

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-110 21.6	1.180	0.078			0.0	41.1	58.9	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____
 DATE 05/21/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-110 31.6	LEAN CLAY with SAND CL	14.7	30.7	18.4	12.3	

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-110 31.6	4.750				0.0	18.0	82.0	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____
 DATE 05/21/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● 96-110 56.6	LEAN CLAY CL	24.4	37.5	20.3	17.1	

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	% < .002
● 96-110 56.6	1.180				0.0	13.1	86.9	

PROJECT SPORN PLANT - FLY ASH POND DIKES JOB NO. _____ DATE 05/21/97

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, Ohio




**TABLE 3.7
COMMON PROPERTIES OF CLAY SOILS¹**

Consistency	N	Hand test	γ_{sat} , p/cm ³	Strength, U_c , kN/cm ²
Hard	> 30	Difficult to indent	> 2.0	> 4.0
Very stiff	15-30	Indented by thumb nail	2.08-2.24	2.0-4.0
Stiff	8-15	Indented by thumb	1.92-2.08	1.0-2.0
Medium (firm)	4-8	Molded by strong pressure	1.78-1.92	0.5-1.0
Soft	2-4	Molded by slight pressure	1.60-1.78	0.25-0.5
Very soft	< 2	Extrudes between fingers	1.44-1.60	0-0.25

$\gamma_{sat} = \gamma_{dry} + \gamma_w \left(\frac{e}{1+e} \right)$

Unconfined compressive strength U_c is usually taken as equal to twice the cohesion c or the undrained shear strength s_u . For the drained strength condition, most clays also have the additional strength parameter ϕ , although for most normally consolidated clays $c = 0$. (Lambe and Whitman (1969)). Typical values for s_u and drained strength parameters are given in Table 3.30, Hunt (1984).¹ From Hunt (1984).¹ Reprinted with permission of McGraw-Hill Book Company.

FIG. 3.35 Correlations of SPT N values with U_c for cohesive soils of varying plasticities. [From NAVFAC 1971]¹




**TABLE 3.5
COMMON PROPERTIES OF COHESIONLESS SOILS****

Material	Compactness	D_n , %	N^*	γ_{dry} , g/cm ³	Void ratio e	Strength [†] ϕ
GW: well-graded gravels, gravel- sand mixtures	Dense	75	90	2.21	0.22	40
	Medium dense	50	55	2.08	0.28	36
	Loose	25	> 28	1.97	0.36	32
GP: poorly graded gravels, gravel- sand mixtures	Dense	75	70	2.04	0.33	38
	Medium dense	50	50	1.92	0.39	35
	Loose	25	> 20	1.83	0.47	32
SW: well-graded sands, gravelly sands	Dense	75	65	1.89	0.43	37
	Medium dense	50	35	1.79	0.49	34
	Loose	25	> 15	1.70	0.57	30
SP: poorly graded sands, gravelly sands	Dense	75	50	1.76	0.52	36
	Medium dense	50	30	1.67	0.60	33
	Loose	25	> 10	1.59	0.65	29
SM: silty sands	Dense	75	45	1.65	0.62	35
	Medium dense	50	25	1.55	0.74	32
	Loose	25	> 8	1.49	0.80	29
ML: inorganic silts, very fine sands	Dense	75	35	1.49	0.80	33
	Medium dense	50	20	1.41	0.90	31
	Loose	25	> 4	1.35	1.0	27

* N is blows per foot of penetration in the SPT. Adjustments for gradation are after Burmister (1962).¹⁴ See Table 6.4 for general relationships of D_n vs. N .
[†]Density given is for $G_s = 2.68$ (quartz grains).
[‡]Friction angle ϕ depends on mineral type, normal stress, and grain angularity as well as D_n and gradation (see Fig. 3.29).
 **From Hunt (1984).¹ Reprinted with permission of McGraw-Hill Book Company.

"GEOTECHNICAL ENGINEERING TECHNIQUES AND PRACTICES", ROY. E. HUNT,
 MCGRAW-HILL, INC., 1986, USA


FIG. 11 APPROXIMATE RELATION BETWEEN STATIC CONE RESISTANCE AND ANGLE OF INTERNAL FRICTION OF SAND.



Meyerhof (1974)

SPORN FLY ROH FACILITY

ACTUAL
 ϕ' Vs. PI
 (BASED ON TRIAXIAL CU TESTS)



F.3.30 Approximate relationship between ϕ and PI clays of moderate to low sensitivity under drained conditions. [From Terzaghi and Peck (1967).²¹ Reprinted with permission of John Wiley & Sons, Inc.]

Roy E. Hunt, "Geotechnical Engineering Techniques and Practices", McGraw-Hill, Inc., 1986, USA.

ENGINEERING DEPT.
AMERICAN ELECTRIC POWER SERVICE CORP.
1 RIVERSIDE PLAZA
COLUMBUS, OHIO

SHEET 1 OF 1
DATE 5/5/97 BY PJ AMAGAKI
COMPANY CENTRAL OPERATING G.O.
PLANT SPORN

SUBJECT UNIT 5 FLY ASH FACILITY

STRENGTH PARAMETERS

NORTHERN DIKE:

BORING B-101 - ELEV. = 619.0

DEPTH	SOIL DESCRIPTION	N	γ_d (pcf)	STRENGTH PARAMETERS	SOURCE
3.0 to 4.5	Si. Granulley Sand (SM) M _c = 6.5%	29	1.65 g/cm ³	$\phi = 35^\circ$	TABLE 3.5 (1)
5.0 to 6.5	" "	18	1.55 g/cm ³	$\phi = 32^\circ$	TABLE 3.5 (1)
8.5 to 10.0	④ Si. Granulley Sand (SM) M _c = 10%	9	1.49 g/cm ³	$\phi = 29^\circ$	TABLE 3.5 (1)
11.5 to 13.0	② Si. Granulley Sand (SM) M _c = 4.2%	65	1.65 g/cm ³	$\phi = 35^\circ$	TABLE 3.5 (1)
16.5 to 18.0	" " "	45	1.65 g/cm ³	$\phi = 35^\circ$	TABLE 3.5 (1)
21.5 to 23.0	Si. Granulley Sand (SM) M _c = 5.5%	48	1.65 g/cm ³	$\phi = 35^\circ$	TABLE 3.5 (1)
26.5 to 28.0	Si. Granulley Sand (SP-SM) M _c = 6.8%	43	1.65 g/cm ³	$\phi = 35^\circ$	TABLE 3.5 (1)
31.5 to 33.0	③ Br/Cr Si. CL w SA (CL-MI)	12	2.08 g/cm ³	$U_c = 0.9 \text{ tsf}, \phi = 34^\circ$	Fig 3.35 & 3.30 (1)
33.5 to 35.5	① PI = 7.0, M _c = 17%	ST	1.11	$C = 1600 \text{ psf}, \phi = 26^\circ$ $C = 0 + \phi' = 38^\circ$	TRIAxIAL TESTING PERFORMED BY H.C. NUTTING
36.5 to 38.0	PI = 10.1, M _c = 17%	14	2.08 g/cm ³	$U_c = 1.0 \text{ tsf}, \phi = 34^\circ$	Fig 3.35 & 3.30 (1)
41.5 to 43.0	⑤ G. Silty Sand (SM)	11	1.55 g/cm ³	$\phi = 32^\circ$	TABLE 3.5 (1)
45 to 45.5	⑥ Gray Clay (CL)	ST	86.0	$C = 750 \text{ psf}, \phi = 15^\circ$ $C = 0 \text{ psf}, \phi' = 33^\circ$	TRIAxIAL TESTING B-108
46.5 to 48.0	⑦ G. Granulley Sand (SP)	20	1.67 g/cm ³	$\phi = 33^\circ$	TABLE 3.5 (1)

ENGINEERING DEPT.
AMERICAN ELECTRIC POWER SERVICE CORP.
1 RIVERSIDE PLAZA
COLUMBUS, OHIO

SHEET 2 OF _____
DATE 5/15/97 BY P.J. Amaya, CK
COMPANY CENTRAL OPERATING CO.
PLANT SPORN

SUBJECT UNIT 5 Fly Ash Facility

STRENGTH PARAMETERS							
Northern DIKE (CONTINUED)							
BORING B-102 - Elev. = 619.6							
DEPTH	SN	DESCRIPTION	N	ρ_d (pcf)	STRENGTH PARAMETERS	SOURCE	
3.0 to 4.5	⑤	Si. Granul. Sand (sm) $M_c = 6.5\%$	35	1.67 g/cm ³	$\phi = 33^\circ$	TABLE 3.5 (1)	
5.0 to 6.5	"	"	47	1.76 g/cm ³	$\phi = 35^\circ$	TABLE 3.5 (1)	
8.5 to 10.0	⑦	Si. Granul. Sand (sm) $M_c = 6.5\%$	35	1.67 g/cm ³	$\phi = 33^\circ$	TABLE 3.5 (1)	
11.7 to 13.2	"	"	60	1.76 g/cm ³	$\phi = 35^\circ$	TABLE 3.5 (1)	
16.7 to 18.2	③	S. SANDY SILT (ML) $M_c = 2.8\%$	47	1.76 g/cm ³	$\phi = 35^\circ$	TABLE 3.5 (1)	
21.7 to 23.2	"	"	45	1.76 g/cm ³	$\phi = 35^\circ$	TABLE 3.5 (1)	
26.7 to 28.2	②	SANDY SILT (ML) $M_c = 11.8\%$	20	1.55 g/cm ³	$\phi = 31^\circ$	TABLE 3.5 (1)	
31.7 to 33.2	④	SANDY clay (CL) $PI = 9, M_c = 18.9\%$	9	1.92 g/cm ³ *	$U_c = 0.7 \text{ tsf}; \phi = 31^\circ$	Fig. 3.35 & 3.30 (1)	
33.7 to 35.7	①	"	ST	111	$C = 1600 \text{ psf}$ $C_i = 0$ $\phi = 26^\circ$ $\phi' = 38^\circ$	TABLE 3.5 (1) - B-101 -	
36.7 to 38.2	"	SANDY clay (CL) $PI = 8, M_c = 16\%$	9	1.92 g/cm ³ *	$U_c = 1.7 \text{ tsf}; \phi = 34^\circ$	Fig. 3.35 & 3.30 (1)	
41.7 to 43.2	⑥	GRAVELLY SAND (SP) $M_c = 5\%$	13	1.59 g/cm ³	$\phi = 29^\circ$	TABLE 3.5 (1)	
46.7 to 48.2	"	"	36	1.67 g/cm ³	$\phi = 33^\circ$	TABLE 3.5 (1)	

* SATURATED

ENGINEERING DEPT.
AMERICAN ELECTRIC POWER SERVICE CORP.
1 RIVERSIDE PLAZA
COLUMBUS, OHIO

SHEET 1 OF
DATE 5/15/97 BY PJ AMAYAK CK
COMPANY CENTRAL OPERATING G.O.
PLANT SPORN.

SUBJECT UNIT 5 FLY ASH FACILITY

STRENGTH PARAMETERS

WESTERN DIKE

BOREING B-103 - ELEV. = 618.

DEPTH	SM	DESCRIPTION	N	γ_d (pcf)	STRENGTH PARAMETER	SOURCE
3.0 to 4.5	②	SCORRAUBLY SAND (SP) $M_c = 4.7\%$	43	1.76 g/cm ³	$\phi = 35^\circ$	TABLE 3.5 (1)
5.0 to 6.5	③	" " "	36	1.67 g/cm ³	$\phi = 33^\circ$	TABLE 3.5 (1)
8.5 to 10.0	"	" " "	46	1.76 g/cm ³	$\phi = 36^\circ$	TABLE 3.5 (1)
11.6 to 13.1	"	" " "	53	1.76 g/cm ³	$\phi = 36^\circ$	TABLE 3.5 (1)
16.6 to 18.1	"	" " "	44	1.76 g/cm ³	$\phi = 35^\circ$	TABLE 3.5 (1)
21.6 to 23.1	"	" " "	45	1.76 g/cm ³	$\phi = 36^\circ$	TABLE 3.5 (1)
26.6 to 28.1	"	" " "	45	1.76 g/cm ³	$\phi = 36^\circ$	TABLE 3.5 (1)
31.6 to 33.1	①	BR SILTY CLAY (CL) PI = 10 MI. 11.5/	19	2.08 g/cm ³ *	$V_c = 1.141 \text{sf}$, $\phi = 34^\circ$	FIGURES 3.35 & 3.31
36.6 to 38.6	④	SILTY SAND (SM)	57	1.59 g/cm ³	$\phi = 29^\circ$	TABLE 3.5 (1)
41.6 to 43.1	"	" $M_c = 11\%$ "	11	1.59 g/cm ³	$\phi = 29^\circ$	TABLE 3.5 (1)
46.6 to 48.1	"	SILTY SAND (SM)	11	1.59 g/cm ³	$\phi = 29^\circ$	TABLE 3.5 (1)

* SATURATED

ENGINEERING DEPT.
AMERICAN ELECTRIC POWER SERVICE CORP.
1 RIVERSIDE PLAZA
COLUMBUS, OHIO

SHEET 2 OF
DATE: 5/15/97 BY: PJAMBYB CK
COMPANY: CENTRAL OPERATING G.O.
PLANT: SPORN

SUBJECT UNIT 5 FLY ASH FACILITY

STRENGTH PARAMETERS (CONTINUED)

WESTERN DIKE (CONTINUED)

BORING B-104 - ELEV. 618.7

DEPTH	SN	DESCRIPTION	N	γ _{sat} (pcf)	STRENGTH PARAMETER	SOURCE
0.0 to 1.5	④	Br. silty clay (CL)	12	1.92 g/cm ³ *	U _c = 0.81sf ; φ = 32°	FIGURE 3.35 (1)
3.0 to 4.5	③	irregularly SAND (SP) M _c = 1%	32	1.67 g/cm ³	φ = 33°	TABLE 3.5 (1)
5.0 to 6.5	"	" " "	73	2.08 g/cm ³	φ = 36°	TABLE 3.5 (1)
8.5 to 10.0	"	" M _c = 1% "	43	1.97 g/cm ³	φ = 35°	TABLE 3.5 (1)
11.7 to 13.2	"	irregularly SAND (SP) M _c = 1%	57	1.76 g/cm ³	φ = 36°	TABLE 3.5 (1)
16.7 to 18.2	②	Gr. silty sand (SM) M _c = 4%	47	1.65 g/cm ³	φ = 35°	TABLE 3.5 (1)
21.7 to 23.2	"	" M _c = 3% " "	46	1.65 g/cm ³	φ = 35°	TABLE 3.5 (1)
26.7 to 28.2	①	Br silty clay (CL) PI = 8, M _c = 19%	14	2.08 g/cm ³ *	U _c = 1.01sf ; φ = 34°	FIGURE 3.35 (1)
31.7 to 33.7	⑤	Br. silty SAND (SM) M _c = 9% NP	ST	116	φ = 31°	TRIAxIAL TEST H.L. NORTON COMP.
36.7 to 38.2	"	" " "	8	116	φ = 29°	TABLE 3.5 (1)
41.7 to 43.2	⑥	Br. Sandy SILT (ML) M _c = 8%	11	116	φ = 27°	TABLE 3.5 (1)
47 to 48.7	"	Br. " " "	ST	116	φ = 27°	TABLE 3.5 (1)

* SATURATED

SUBJECT UNIT 5 Fly Ash Facility

STRENGTH PARAMETERS (CONTINUED)

WESTERN DIKE (CONTINUED)

BORING B-105 - ELEV. = 619.3

DEPTH	NO.	DESCRIPTION	N	ρ_d (pcf)	STRENGTH PARAMETER	SOURCE
3.0 to 4.5	④	li. G. gravelly sand (SM) $M_c = 2\%$	21	1.59 g/cm ³	$\phi = 31^\circ$	TABLE 3.5 (1)
5.0 to 6.5	③	" " "	37	1.55 g/cm ³	$\phi = 35^\circ$	TABLE 3.5 (1)
8.5 to 10.0		" " "	32	1.55 g/cm ³	$\phi = 34^\circ$	TABLE 3.5 (1)
11.5 to 13.0		" " "	35	1.55 g/cm ³	$\phi = 34^\circ$	TABLE 3.5 (1)
16.5 to 18.0		" $M_c = 3\%$ "	31	1.51 g/cm ³	$\phi = 33^\circ$	TABLE 3.5 (1)
21.5 to 23.0	②	li. silty sand (SM) $M_c = 7\%$	23	1.49 g/cm ³	$\phi = 32^\circ$	TABLE 3.5 (1)
26.5 to 28.0	①	br. silty clay (CL) $PI = 10, M_c = 13\%$	13	2.08 g/cm ³ *	$U_c = 0.95 / SF, \phi = 34^\circ$	FIGURE 3.35 (1)
31.5 to 33.5		" " "	ST	2.08 g/cm ³ *	$U_c = 0.95 / SF, \phi = 34^\circ$	FIGURE 3.35 (1)
36.5 to 38.0	⑤	" " " $PI = 10, M_c = 22\%$	8	1.92 g/cm ³ *	$U_c = 10.6 / SF, \phi = 34^\circ$	FIGURE 3.35 (1)
41.5 to 43.0	⑥	br. silty sand (SM) $M_c = 12\%$	9	1.49 g/cm ³	$\phi = 29^\circ$	TABLE 3.5 (1)
46.5 to 48.0		" " "	ST	1.49 g/cm ³	$\phi = 29^\circ$	TABLE 3.5 (1)

* SATURATED

ENGINEERING DEPT.
AMERICAN ELECTRIC POWER SERVICE CORP.
1 RIVERSIDE PLAZA
COLUMBUS, OHIO

SHEET 1 OF
DATE 5/16/97 BY PJ AMAYA CK
COMPANY CENTRAL OPERATING G.O.
PLANT SPORN PLANT

SUBJECT UNIT 5 FLY ASH FACILITY


STRENGTH PARAMETERS

SOUTHERN DIKE


BORING B-106 - ELEV.=618.9.

DEPTH	SN	DESCRIPTION	N	γ_d (pcf)	STRENGTH PARAMETERS	SOURCE
3.0 to 4.5	⑤	Gravelly sand (SM)	38	1.55 g/cm ³	$\phi = 33^\circ$	TABLE 3.5 (1)
5.0 to 6.5		" " "	54	1.65 g/cm ³	$\phi = 35^\circ$	TABLE 3.5 (1)
8.5 to 10.	④	" " "	37	1.55 g/cm ³	$\phi = 33^\circ$	TABLE 3.5 (1)
11.5 to 13.	⑥	" M.C. 6%"	25	1.55 g/cm ³	$\phi = 32^\circ$	TABLE 3.5 (1)
16.5 to 18.		" " "	32	1.55 g/cm ³	$\phi = 33^\circ$	TABLE 3.5 (1)
21.5 to 23.	③	SANDY CLAY (CL) PI = 9, Mc = 11%	18	2.08 g/cm ³ *	$U_c = 11.3$ tsf, $\phi = 24^\circ$	FIGURE 3.35 (1)
26.5 to 28.		FLY ASH (ML) Mc = 4%	12	74	$\phi = 29^\circ$	TABLE 3.5 (1)
31.5 to 33		" " "	2	74	$\phi = 27^\circ$	TABLE 3.5 (1)
36.5 to 38	②	SG = 2.69 Mc = 43%	2	74	$\phi = 27^\circ$	TABLE 3.5 (1)
41.5 to 43		" " "	2	74	$\phi = 27^\circ$	TABLE 3.5 (1)
46.5 to 48.		" " "	4	74	$\phi = 27^\circ$	TABLE 3.5 (1)
51.5 to 53.0		SG = 2.42 Mc = 36%	4	74	$\phi = 27^\circ$	TABLE 3.5 (1)
56.5 to 58		Grey silty clay (CL) PI = 18 Mc = 27%	8	1.92 g/cm ³ *	$U_c = 110$ tsf, $\phi = 32^\circ$	FIGURE 3.35 (1)
61.5 to 63.5	①	PI = 24 Mc = 2.6%	ST	98	$C = 1200$ psf, $\phi = 9^\circ$ $\alpha = 0, \beta = 22^\circ$	TRIAXIAL TEST


Sporn Fly Ash -CPT- B106



Sporn Fly Ash - CPT - B106



Sporn Fly Ash - CPT - B106



ENGINEERING DEPT.
AMERICAN ELECTRIC POWER SERVICE CORP.
1 RIVERSIDE PLAZA
COLUMBUS, OHIO

SHEET 1 OF
DATE 5/5/97 BY PJ Amador CK
COMPANY CENTRAL OPERATING G.O.
PLANT Sporn

SUBJECT UNIT 5 FLY ASH FACILITY

STRENGTH PARAMETERS

EASTERN DIKE:

BORING B-107 - ELEV. = 618.8.

DEPTH (ft)	DESCRIPTION	N	γ_d (pcf)	STRENGTH PARAMETERS	SOURCE
3.0 to 4.5	① Co. silty sand (SP)	38	1.67 g/cm ³	$\phi = 33^\circ$	TABLE 3.5 (1)
5.0 to 6.5	③ Sand and gravel	49	1.76 g/cm ³	$\phi = 36^\circ$	TABLE 3.5 (1)
8.5 to 10.	" "	42	1.76 g/cm ³	$\phi = 35^\circ$	TABLE 3.5 (1)
11.6 to 13.1	Mz. 4-1/2"	37	1.83 g/cm ³	$\phi = 33^\circ$	TABLE 3.5 (1)
16.6 to 18.1	① Silty clay (CL) PI = 7, Mc = 14%	18	2.08 g/cm ³	$U_c = 1.3 tsr; \phi = 34^\circ$	Fig. 3.12 (1)
21.6 to 23.1	⑨ Sandy silt (ML) Mc = 11%	19	1.41 g/cm ³	$\phi = 31^\circ$	TABLE 3.5 (1)
26.6 to 28.1	⑧ Gray Fly Ash (ML)	14	74.3	$\phi = 30^\circ$	TABLE 3.5 (1)
31.6 to 33.1	" "	19	74.3	$\phi = 31^\circ$	TABLE 3.5 (1)
36.6 to 38.1	" " SG = 2.28 Mc = 38%	2	74.3	$\phi = 27^\circ$	TABLE 3.5 (1)
41.6 to 43.1	" "	2	74.3	$\phi = 27^\circ$	TABLE 3.5 (1)
46.6 to 48.1	" "	2	74.3	$\phi = 27^\circ$	TABLE 3.5 (1)
51.6 to 53.1	" "	2	74.3	$\phi = 27^\circ$	TABLE 3.5 (1)
56.6 to 58.1	SG = 2.31 Mc = 38%	0	74.3	$\phi = 27^\circ$	TABLE 3.5 (1)
61.6 to 72.1	⑩ PI = 20, Mc = 25%, 17-13	07	74.3	$U_c = 1.7 tsr; \phi = 30^\circ$	Fig. 3.12 (1) PEAK STRENGTH

ENGINEERING DEPT.
AMERICAN ELECTRIC POWER SERVICE CORP.
1 RIVERSIDE PLAZA
COLUMBUS, OHIO

SHEET 2 OF
DATE 5/5/97 BY PJA Mayak CK.
COMPANY CENTRAL OPERATING G.O.
PLANT Sporn.

SUBJECT UNIT 5 FLY ASH FACILITY

STRENGTH PARAMETERS (CONTINUED)

BORING B-108 - EL. 603.4

DEPTH	NO	DESCRIPTION	N	Yd (pcf)	STRENGTH PARAMETERS	SOURCES
3.0 TO 4.5	④	BOTTOM ASH (SM) Mc = 9%	31	56.0	$\phi = 32^\circ$	TABLE 3.5 (1)
5.0 to 6.5		" "	38	60.5	$\phi = 34^\circ$	TABLE 3.5 (1)
8.5 to 10.0	⑤	Silty Sand (SM) Mc = 6.1%	45	1.65 g/cm ³	$\phi = 35^\circ$	TABLE 3.5 (1)
11.6 to 13.1		Gr. Silty Sand (SM) Mc = 3%	40	1.55 g/cm ³	$\phi = 34^\circ$	TABLE 3.5 (1)
16.6 to 18.1		Gr. Silty Sand (SM) Mc = 2.1%	45	1.65 g/cm ³	$\phi = 35^\circ$	TABLE 3.5 (1)
21.6 to 23.1	⑥	Silty Clay (CL) PI = 7 Mc = 8.1%	14	2.06 g/cm ³	U _c = 1.0 psc $\phi = 32^\circ$	Fig. 3.25 & 3.30 (1)
26.6 to 28.1	⑦	Bottom Ash (SM)	8	52.2	$\phi = 29^\circ$	TABLE 3.5 (1)
31.6 to 33.1	⑧	Gray Fly Ash (ML) Mc = 4%	3	74.3	$\phi = 27^\circ$	TABLE 3.5 (1)
36.6 to 38.1		" "	2	74.3	$\phi = 27^\circ$	TABLE 3.5 (1)
41.6 to 53.1	⑩	Gray Clay (CL) PI = 30, Mc = 37%	5 ST ²	86.0	U _c = 0.7 psc $\phi = 30^\circ$ C = 750 psc $\phi = 15^\circ$ C' = 0 psc $\phi' = 33^\circ$	Fig. 3.25 & 3.30 (1) PEAK STRENGTH H.C. NUTTING CO. TRIAXIAL TESTING
56.6 to 73.1	⑫	Gray Silty Clay (CL) PI = 15, Mc = 25%	5 ST [*]	94.2	C = 100 psc $\phi = 17^\circ$ C' = 0 psc $\phi' = 37^\circ$ U _c = 0.7 psc $\phi = 30^\circ$	TRIAXIAL TESTING - B-110 - Fig. 3.25 & 3.30 (1)

* - Saturated

SUBJECT UNIT 5 Fly Ash Facility

STRENGTH PARAMETERS (CONTINUED)

BORING B-109 - ELEV. = 619.6

DEPTH	SN	DESCRIPTION	N	γ (pcf)	STRENGTH PARAMETER	SOURCE
3.0 to 4.5	②	Coarsely Sand (SP)	43	1.76 g/cm ³	$\phi = 35^\circ$	TABLE 3.5 (1)
5.0 to 6.5	③	" "	39	1.76 g/cm ³	$\phi = 34^\circ$	TABLE 3.5 (1)
8.5 to 10.0		" Mc = 1%"	39	1.76 g/cm ³	$\phi = 34^\circ$	TABLE 3.5 (1)
11.7 to 13.2	④	SS SAND (SM)	27	1.55 g/cm ³	$\phi = 32^\circ$	TABLE 3.5 (1)
16.7 to 18.2	①	Smally Silty Clay (CL) Mc = 9%	11	1.92 g/cm ³ *	Mc = 0.81% $\phi = 34^\circ$	Fig. 3.3.1 & 3.3.6
21.7 to 23.2		" PE = 6"	14	2.08 g/cm ³	Mc = 1.01% $\phi = 34^\circ$	Fig. 3.3.1 & 3.3.6
26.7 to 28.2	①	Gray Fly Ash (MD) Mc = 4%	ST	74.3	$\phi = 31^\circ$	I.F. MURPHY Comp. Testing. TABLE 3.5
31.7 to 33.2		" "	17	74.3	$\phi = 31^\circ$	TABLE 3.5 (1)
36.7 to 38.2		SG = 2.84" Mc = 3.8%	2	74.3	$\phi = 27^\circ$	TABLE 3.5 (1)
41.7 to 43.2		" "	2	74.3	$\phi = 27^\circ$	TABLE 3.5 (1)
46.7 to 48.2		" "	4	74.3	$\phi = 27^\circ$	TABLE 3.5 (1)
51.7 to 66.7		" "	3	74.3	$\phi = 27^\circ$	TABLE 3.5 (1)
61.7 to 58.2		SG = 2.84" Mc = 3.8%	5	74.3	$\phi = 27^\circ$	TABLE 3.5 (1)
61.7 to 73.2	12	Brown Clay (CL) [= 13], Mc = 31%	ST 9-1A	97.3	C = 100 pcf $\phi = 17^\circ$ C' = 0 $\phi = 39^\circ$	INDIANA TESTING = B-107-

ENGINEERING DEPT.
AMERICAN ELECTRIC POWER SERVICE CORP.
1 RIVERSIDE PLAZA
COLUMBUS, OHIO

SHEET 4 OF _____
DATE 5/5/97 BY P.J. Amaya CK _____
COMPANY CENTRAL OPERATING G.O. _____
PLANT SPORN

SUBJECT Unit 5 Fly Ash Facility

STRENGTH PARAMETERS (CONTINUED)

BORING B-110 - ELEV: 602.3

DEPTH	SN	DESCRIPTION	N	Yd (pcf)	STRENGTH PARAMETERS	SOURCE
3.0 to 4.5	⑤	BOTTOM ASH (SM)	42	60.5	$\phi = 35^\circ$	TABLE 3.5 (15)
5.0 to 6.5		" " "	25	56.0	$\phi = 32^\circ$	TABLE 3.5 (15)
8.5 to 10.0	⑥	SAND & GRAVEL (UP) Mc = 11%	16	1.83 g/cm ³	$\phi = 32^\circ$	TABLE 3.5 (15)
11.6 to 13.1		" "	17	1.83 g/cm ³	$\phi = 32^\circ$	TABLE 3.5 (15)
16.6 to 18.1	⑨	SANDY SILTY CLAY (CL) PI = 8, Mc = 12%	20	2.08 g/cm ³ *	$U_c = 1.5 \text{ tsf}; \phi = 31^\circ$	Fig. 3.35 & 3.30
18.6 to 20.1		SANDY SILTY CLAY (CL) PI = 7, Mc = 12%	23	2.08 g/cm ³ *	$U_c = 1.7 \text{ tsf}; \phi = 31^\circ$	Fig. 3.35 & 3.30
21.6 to 23.1		" "	18	2.08 g/cm ³ *	$U_c = 1.3 \text{ tsf}; \phi = 31^\circ$	Fig. 3.35 & 3.30
26.6 to 28.1		" "	18	2.08 g/cm ³ *	$U_c = 1.3 \text{ tsf}; \phi = 31^\circ$	Fig. 3.35 & 3.30
31.6 to 33.1	⑩	REDdish BRN CLAY (CL) PI = 12, Mc = 15%	19	2.08 g/cm ³ *	$U_c = 1.4 \text{ tsf}; \phi = 33^\circ$	Fig. 3.35 & 3.30
36.6 to 50.0	⑦	GRAY CLAY (CL) PI = 5, Mc = 15% S+12	ST	86.0	$U_c = 1.2 \text{ tsf}; \phi = 31^\circ$ $C = 750 \text{ pcf}; \phi = 15^\circ$ $C = 0; \phi = 33^\circ$	Fig. 3.30 & 3.30 TRIAXIAL TESTING - 13108 -
51.6 to 73.1	⑧	GRAY SILTY CLAY (CL) PI = 12, Mc = 28% PI = 7, Mc = 24% PI = 17, Mc = 36%	ST 9 to 17	94.2	$C = 100 \text{ pcf}; \phi = 17^\circ$ $C = 0; \phi = 37^\circ$ $U_c = 1.2 \text{ tsf}; \phi = 31^\circ$	PEAK STRENGTH H.C. CURRING CO. TRIAXIAL TESTING Fig. 3.35 & 3.30
	13				*SATURATED	

SUBJECT UNIT 3 Fly Ash Facility

STRENGTH PARAMETERS

BORING SI-3 (1988)

DEPTH	SN	DESCRIPTION	N	γ_d (pcf)	STRENGTH PARAMETERS	SOURCE
3.0 to 4.5	⑤	Silty Sand (SM)	30	1.55 g/cm ³	$\phi = 32^\circ$	TABLE 3.5 (1)
8.0 to 9.5		GENUINE SAND (SP)	7	1.59 g/cm ³	$\phi = 29^\circ$	TABLE 3.5 (1)
13.0 to 14.5		Silty Sand & Gravel (GP)	9	1.97 g/cm ³	$\phi = 32^\circ$	TABLE 3.5 (1)
18.0 to 19.5	⑥	Sandy Silt (ML)	23	1.41 g/cm ³	$\phi = 31^\circ$	TABLE 3.5 (1)
23.0 to 24.5		" " "	14	1.41 g/cm ³	$\phi = 31^\circ$	TABLE 3.5 (1)
28.0 to 29.5		" " "	17	1.41 g/cm ³	$\phi = 31^\circ$	TABLE 3.5 (1)
33.0 to 34.5	⑦	Brown Clay	20	2.08 g/cm ³ *	$U_c = 1.25f; \phi = 33^\circ$	B-110 (31.6 - 33)
38.0 to 39.5	⑧	Organic Silty Clay	17	2.08 g/cm ³ *	$U_c = 1.25f; \phi = 30^\circ$	B-110 (36.6 - 50)
43.0 to 49.0	⑨	Gray Clay	9	1.92 g/cm ³	$C = 0; \phi = 33^\circ$	B-110 (36.6 - 50)
53.0 to 54.5	⑫	Silty Sand & Gravel (GM)	>50	2.08 g/cm ³	$\phi = 36^\circ$	TABLE 3.5 (1)
58.0 to 59.5		" " "	55	2.08 g/cm ³	$\phi = 36^\circ$	TABLE 3.5 (1)
63 to 64.5		SAND & GRAVEL (GP)	53	1.92 g/cm ³	$\phi = 35^\circ$	TABLE 3.5 (1)
68 to 69.5		" " "	24	1.83 g/cm ³	$\phi = 32^\circ$	TABLE 3.5 (1)
73.0 to 74.5		Silty Sand (SM)	29	1.55 g/cm ³	$\phi = 32^\circ$	TABLE 3.5 (1)
78 to 89.5		SAND (SP)	27	1.67 g/cm ³	$\phi = 32^\circ$	TABLE 3.5 (1)

* 10 feet REPLACED WITH REINFORCED BOTTOM ASH UNDER DRAIN PLACED IN THE SANDY SILT SOIL - 1995

ENGINEERING DEPT.
AMERICAN ELECTRIC POWER SERVICE CORP.
1 RIVERSIDE PLAZA
COLUMBUS, OHIO

SHEET 2 OF _____
DATE 5/6/97 BY DJ Hume CK _____
COMPANY CENTRAL OPERATING G.O.
PLANT SPORN

SUBJECT UNIT 5 Fly Ash Facility

STRENGTH PARAMETERS (CONTINUED)

Boring 9301 (1993)

DEPTH	SN	DESCRIPTION	N	γ_d (pcf.)	STRENGTH PARAMETERS	SOURCE
0.0 to 1.5	①	Silty Clay (cl)	7	1.92 g/cm ³	$U_c = 1.1 \text{ tsf}; \phi = 30^\circ$	TABLE 3.35 (1)
1.5 to 3.0		Sandy Clay (cl)	30	2.24 g/cm ³	$U_c = 4.0 \text{ tsf}; \phi = 30^\circ$	TABLE 3.35 (1)
3.0 to 4.5	④	BOTTOM ASH (SM)	25	52.2	$\phi = 32^\circ$	TABLE 3.5 (1)
4.5 to 6.0	⑪	GRAY FLY ASH (ML)	42	74.3	$\phi = 33^\circ$	TABLE 3.5 (1)
6.0 to 7.5		" " "	38	74.3	$\phi = 33^\circ$	TABLE 3.5 (1)
7.5 to 9.0		" " "	36	74.3	$\phi = 33^\circ$	TABLE 3.5 (1)
9.0 to 10.5		" " "	29	74.3	$\phi = 33^\circ$	TABLE 3.5 (1)
10.5 to 12.0		" " "	21	74.3	$\phi = 31^\circ$	TABLE 3.5 (1)
12.0 to 13.5		" " "	25	74.3	$\phi = 31^\circ$	TABLE 3.5 (1)
13.5 to 15.0		" " "	16	74.3	$\phi = 31^\circ$	TABLE 3.5 (1)
15.0 to 16.5		" " "	6	74.3	$\phi = 27^\circ$	TABLE 3.5 (1)
16.5 to 18.0		" " "	2	74.3	$\phi = 27^\circ$	TABLE 3.5 (1)
18.0 to 19.5		" " "	0	74.3	$\phi = 27^\circ$	TABLE 3.5 (1)
19.5 to 21.0		" " "	5	74.3	$\phi = 27^\circ$	TABLE 3.5 (1)
21.0 to 22.5		SMALL GRAIN SAND	15	1.82 g/cm ³	$\phi = 27^\circ$	TABLE 3.5 (1)

ENGINEERING DEPT.
AMERICAN ELECTRIC POWER SERVICE CORP.
1 RIVERSIDE PLAZA
COLUMBUS, OHIO


SHEET 3 OF _____
DATE 5/7/97 BY PJAMAYRCK
COMPANY CENTRAL OIL SERVICE CO. G.O. _____
PLANT SPORN.

SUBJECT UNIT 5 FLY ASH FACILITY

STRENGTH PARAMETERS (CONTINUED)


BORING 9301 (Continued)


DEPTH	EU	DESCRIPTION	N	γ_d (pcf)	STRENGTH PARAMETERS	SOURCE
22.5 to 24.0	(10)	Sandy silty clay (cl)	11	1.92 g/cm ³	$U_c = 0.6$; $\phi' = 34^\circ$	B-110 (216-236)
24.0 to 27.5		Brown silty clay (cl)	20	2.08 g/cm ³	$U_c = 1.4$ tsf; $\phi' = 33^\circ$	B-110
27.5 to 31.0		" " "	14	2.08 g/cm ³	$U_c = 1.0$ tsf; $\phi' = 32^\circ$	B-110
31.0 to 34.5		" " "	16	2.08 g/cm ³	$U_c = 1.7$ tsf; $\phi' = 32^\circ$	B-110
34.5 to 38.0		" " "	16	2.08 g/cm ³	$U_c = 1.2$ tsf; $\phi' = 32^\circ$	B-110
38.0 to 41.5		" " "	15	2.08 g/cm ³	$U_c = 1.1$ tsf; $\phi' = 32^\circ$	B-110
41.5 to 45.0	(9)	off dry clay (cl)	10	1.92 g/cm ³	$U_c = 0.75$ tsf; $\phi' = 33^\circ$	TABLE 3.35
45.0 to 46.5	(12)	Sand & Gravel (GP)	7	1.83 g/cm ³	$\phi = 32^\circ$	TABLE 3.5
				* SATURATED		




Sporn Fly Ash -CPT- B107


Sporn Fly Ash - CPT - B107





Sporn Fly Ash -CPT - B109





BORING B-106 - CPT - STRENGTH PARAMETERS -
FLY-ASH

AVERAGE $\gamma = 119.7 \text{ lbs/ft}^3$

@ 27' ELEVATION - 591.9 ; $\sigma_v' = 27' \times 119.7 \frac{\text{lbs}}{\text{ft}^3} = 3,231.9 \text{ lbs/ft}^2$
 $= 1.62 \text{ tsf} = 1.6 \text{ Kg/cm}^2$

USING FIG. 3.28⁽¹⁾ STATIC CONE RESISTANCE q_c VS. D_r ,

THE FLY ASH AT THIS LOCATION HAS A RELATIVE DENSITY

$D_r = 0\%$

FROM FIG. 3.29⁽¹⁾ FRICTION ANGLE AND RELATIVE DENSITY RELATION-

SHIPS FOR GRANULAR SOILS, THE FLY ASH AT THIS LOCATION

HAS A $\phi_{\text{max}}' = 28^\circ$ (1) OR $\phi = 30^\circ$ (2)

ϕ BASED ON SPT = 27° TO 29°

BORING B-107 - CPT - STRENGTH PARAMETERS

AVERAGE $\gamma = 1.69 \text{ Kg/cm}^3 = 105.7 \text{ lbs/ft}^3$

@ 26.6', ELEVATION 592.2 ; $\sigma_v' = 26.6 \times 105.7 = 2,811.6 \text{ lbs/ft}^2$
 $= 1.4 \text{ tsf} = 1.4 \text{ Kg/cm}^2$

USING FIG. 3.28⁽¹⁾ OR FIG. (5)⁽²⁾ STATIC CONE RESISTANCE q_c VS. D_r ,

THE FLY ASH AT THIS LOCATION HAS A RELATIVE DENSITY,

$D_r = 0\%$

FROM FIG. 3.29⁽¹⁾ OR FIG. 11⁽²⁾ THE FLY ASH AT THIS LOCATION HAS

A $\phi_{\text{max}}' = 28^\circ$ (1) OR $\phi = 30^\circ$ (2)

ϕ BASED ON SPT = 27° TO 31°

(1) "GEOTECHNICAL ENGINEERING, TECHNIQUES AND PRACTICE" BY E. HUNT.

(2) "INTERPRETATION OF THE CONE PENETRATION TEST" - THE WUCRIT CONE PENETROMETER CONVERSION KIT - HOGENTGLER & CO., INC.

BORING B-109 - CPT - STRENGTH PARAMETERS.

$$\text{AVERAGE } \gamma = 1.71 \text{ kg/cm}^3 = 106.6 \text{ lbs/ft}^3$$

$$\text{@ } 26.7' \text{ ELEVATION, } 592.9'; \quad \gamma_v' = 20.5' \times (106.6) + 6.2(106.6 - 62.8) =$$

$$\gamma_v' = 2459.3 \text{ lbs/ft}^2 = 1.23 \text{ tsf} = 1.2 \text{ kg/cm}^2$$

USING FIG. 3.28 (1) OR FIG 5. (2) STATIC CONE RESISTANCE q_c VS. D_r ,
THE FLY ASH AT THIS LOCATION HAS A RELATIVE DENSITY,

$$D_r = 0\%$$

FROM FIG. 3.29 (1) OR FIG. 11 (2) THE FLY ASH AT THIS LOCATION
HAS A $\phi'_{\text{MAX}} = 28^\circ$ (1) OR $\phi' = 30^\circ$ (2)

$$\boxed{\phi \text{ BASED ON SPT} = 27^\circ \pm 30^\circ}$$

LABORATORY DATA FROM:
“PHILIP SPORN POWER PLANT – STABILITY ANALYSIS”


PREPARED/COMPILED BY:
**THE GEOTECHNICAL ENGINEERING SECTION OF AMERICAN
ELECTRIC POWER SERVICE CORPORATION**

DATED: MARCH 2009

PROJECT: SPOON PLANT - FLY ASH POND DIKES - FLY ASH POND DIKES SUMMARY OF MATERIAL PROPERTIES
 NUMBER: FLY ASH POND DIKES

Sample Number	Depth ft.	ASTM Description	ASTM Class.	Max. Dry Density pcf	Optimum Moisture %	Liquid Limit %	Plastic Limit %	Gravel %	Sand %	<#200 Sieve %	mm %	Sp.G	Permbly cm/sec	Nat. Moist. %
PZ-0901	3.5	SANDY SILT	ML			NP	NP	2.2	47.6	50.2			3.61E-07	
PZ-0902	26.0	SILTY SAND with GRAVEL	SM			NP	19.3	33.0	52.9	14.0				
PZ-0903	18.5	LEAN CLAY with SAND	CL			NP	18.2	0.0	20.6	79.4	21.3			13.3
PZ-0904	31.0	SILTY SAND	SM			NP	17.4	8.9	57.5	33.5				18.1
PZ-0905	16.0	LEAN CLAY	CL			NP	17.1	0.0	0.9	99.1	32.6		1.08E-07	16.5
PZ-0906	23.5	SILTY SAND	SM			NP	19.5	19.6	61.2	19.2	22.6			28.4
PZ-0907	46.0	LEAN CLAY	CL			NP	24.7	0.0	6.5	93.5				25.3
PZ-0908	8.0	SILTY SAND with GRAVEL	SM			NP	19.1	0.0						
PZ-0909	43.5	LEAN CLAY	CL			NP	22.3							
PZ-0910	11.0	SILTY SAND with GRAVEL	SM			NP	31.2							
PZ-0911	38.0	LEAN CLAY	CL			NP								

AEP Civil Engineering Laboratory, Groveport, Ohio



COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● PZ-0901 3.5			NP	NP	NP	
	SANDY SILT ML					
	Ash Mixture - Samples 2,3,4 Combined					

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	%<.002
● PZ-0901 3.5	19.000	0.108			2.2	47.6	50.2	

PROJECT **SPORN PLANT - FLY ASH POND DIKES - FLY ASH POND DIKES** JOB NO. _____ DATE **8/14/09**

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, OH 43125



JOB NO. _____
PROJECT SPORN PLANT - FLY ASH POND DIKES
LOCATION: FLY ASH POND DIKES

DATE: Jul 17, 09

SOURCE OF MATERIAL PZ-0901 DEPTH 27.0 ft.
DESCRIPTION OF MATERIAL _____
ASTM DESCRIPTION _____

MAX. DRY DENSITY, pcf		OPTIMUM MOISTURE, %	
SPECIFIC GRAVITY	2.70		
SAMPLE HGT., mm	146.130	SAMPLE DIA., mm	72.310
CHAMBER PRESSURE, psi	70.0	BACK PRESSURE, psi	60.0
B-PARAMETER	1.00	EFFECTIVE PRESSURE, psi	10.0
INITIAL HEAD, mm	2373.2		

	<u>BEFORE</u>	<u>AFTER</u>
WATER CONTENT, %	26.7	27.0
WET DENSITY, pcf	122.4	
DRY DENSITY, pcf	96.6	
SATURATION, %	96.79	
VOID RATIO	0.7441	

PERMEABILITY COEFFICIENT K, cm/sec 3.61E-07

FLEXIBLE-MEMBRANE PERMEABILITY TEST

American Electric Power Service Corp.
Groveport, Ohio



CIVIL LABORATORY
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



**Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767**

Company: AEP

Project: SPORN ASH DISP. FACILITY


Sample No: 10906

Material Description: Boring PZ-0901, Shelby Tube - 26' - 28'; Lab # S-10906


Point Designation	Initial Conditions			Final Conditions			
	Water Content, %	Dry Density, pcf	Degree of Saturation	Water Content, %	Confining Stress, (ksf)	Deviator Stress	Induced Pore Pressure (ksf)
A	23.9%	102.1	99.2%	24.39%	0.72	2.57	0.13
B	26.7%	96.6	96.8%	27.0%	1.44	3.44	0.42
C	22.8%	104.5	100.4%	22.6%	2.88	4.84	1.35

Point Designation	Axial Strain, %	q, (ksf)	Effective Stresses, (ksf)			Total Stresses, (ksf)		
			Major, (ksf)	Minor, (ksf)	p', (ksf)	Major, (ksf)	Minor, (ksf)	p, (ksf)
A	15.0%	1.29	3.16	0.59	1.88	3.29	0.72	2.01
B	15.0%	1.72	4.46	1.02	2.74	4.88	1.44	3.16
C	11.0%	2.42	6.36	1.53	3.94	7.72	2.88	5.30

Total Stress Envelope



Effective Stress Envelope



FOSSIL AND HYDRO GENERATION
CIVIL AND MINING ENGINEERING DIVISION
CIVIL LABORATORY SECTION
AMERICAN ELECTRIC POWER SERVICE CORPORATION
4001 BIXBY ROAD
GROVEPORT, OHIO 43125
(614) 836-4200




Test Report for Consolidated-Undrained
Triaxial Compression Test - ASTM D 4767

Company: AEP

Project: SPORN ASH DISP. FACILITY

Sample No: 10906



FOSSIL AND HYDRO GENERATION
CIVIL AND MINING ENGINEERING DIVISION
CIVIL LABORATORY SECTION
AMERICAN ELECTRIC POWER SERVICE CORPORATION
4001 BIXBY ROAD
GROVEPORT, OHIO 43125
(614) 836-4200




Test Report for Consolidated-Undrained
Triaxial Compression Test - ASTM D 4767

Company: AEP

Project: SPORN ASH DISP. FACILITY

Sample No: 10906



FOSSIL AND HYDRO GENERATION
CIVIL AND MINING ENGINEERING DIVISION
CIVIL LABORATORY SECTION
AMERICAN ELECTRIC POWER SERVICE CORPORATION
4001 BIXBY ROAD
GROVEPORT, OHIO 43125
(614) 836-4200




Test Report for Consolidated-Undrained
Triaxial Compression Test - ASTM D 4767

Company: AEP

Project: SPORN ASH DISP. FACILITY

Sample No: 10906

Deviator Stress Vrs % Strain



CIVIL LABORATORY
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



**Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767**

Company: AEP
 Project: SPORN ASH DISP. FACILITY

Sample No: 10906

Point: A

Material Description:		Boring PZ-0901, Shelby Tube - 26' - 28'; Lab # S-10906	
Moisture Determination ASTM D2216		Before Testing	After Testing
Tare No.	T-100	T-100	
Mass of Container and Wet Specimen (Mcws), grams	1425.44	1429.80	
Mass of Container and Over Dry Specimen (Mcs), grams	1190.68	1190.68	
Mass of Container (Mc), grams	210.10	210.10	
Mass of Water (Mw), grams:	234.76	239.12	
Mass of Solid Particles (Ms), grams:	980.58	980.58	
Moisture Content (w), %	23.94%	24.39%	
Initial Condition of Specimen ASTM D2435		(1)	(2)
Diameter Measurements, Inches:	2.835	2.838	(3)
Height Measurements, Inches:	5.815	5.808	5.801
Initial Volume of Specimen (Vo), In.3:	36.60		
Dry Mass of Specimen After Testing, (Md), grams:	980.58		
Dry Unit Weight, (γ _d) pcf:	102.06		
Specific Gravity of the Solids, (G):	2.70		
Volume of Solids, (Vs), Cu. In.:	22.1626		
Height of Solids, (Hs), In.:	3.5167		
Void Ratio Before Consolidation (Eo):	0.6515		
Initial Degree of Saturation: (So)	99.21%		
Saturation - ASTM D4767 Section 8.2			
Dial Indicator Reading Prior to Saturation (Rb), In.	0		
Cell Pressure After Saturation, psi:	63.00		
Back Pressure After Saturation After, psi:	60.00		
Pore Pressure Parameter B:	1		
Dial Indicator Reading After Saturation, (Ra) In.:	0.016		
Change in Height during Saturation, (Delta Hs) In.	0.016		
Change in Volume of Specimen during Saturation (Delta Vsat), In.3:	0.302		

CIVIL LABORATORY
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



**Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767**

Company: AEP
 Project: SPORN ASH DISP. FACILITY
 Sample No: 10906
 Point: A

Consolidation- ASTM D2435, Section 11.5:				
Sample No:	T:	Burette 2:	Burette3:	Rc:
10906	0	23.6	23.7	0.016
10906	0.25	23.5	23.5	
10906	0.5	23.5	23.5	
10906	1	23.4	23.4	
10906	2	23.4	23.3	
10906	4	23.3	23.2	
10906	8	23.2	23	
10906	15	23.1	22.8	0.019
10906	30	23	22.6	0.02
10906	60	22.9	22.5	0.021
10906	120	22.7	22.2	0.022
10906	240	22.5	22.3	0.022
10906	450	22.3	22.2	0.022
10906	1440	22.2	22.2	0.023

Specimen Height After Consolidation, (Hc), In.: 5.79

Volume Change During Consolidation (Delta Vc), In.3: 0.18

Cross-Sectional Area of Specimen After Consolidation (Ac), In.2: 6.24

**Triaxial Compression Testing
 ASTM D 4767**

Sample Depth: 0 ft.
 Cell Pressure: 65 psi
 Back Pressure: 60 psi
 Confining Pressure: 5 psi
 Strain Rate: 0.006 in./min.

Specimen Height After Consolidation, (Hc), In.: 5.79
 Correction for Vert Displacement, In.: 0
 Load due to Friction and Uplift: 16.3 lbs.
 Correction for Filter Paper: 0
 Thickness of Membrane (tm), In.: 0.012

$\sigma_1 - \sigma_3 =$ Deviator Stress at Failure, ksf: 2.57
 $\sigma_3 f =$ Effective Consolidation Stress at Failure, ksf: 0.72
 $\sigma_1 =$ Total Major Principal Stress at Failure: 3.29
 $\sigma_3 f = \sigma_3 - \Delta v =$ Effective Minor Principal Stress at Failure, ksf: 0.59
 $\sigma_1 f =$ Effective Major Principal Stress at Failure, ksf: 3.16
 Axial Strain at Failure: 15.01%

Failure Sketch

CIVIL LABORATORY
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767

Company: AEP
 Project: SPORN ASH DISP. FACILITY
 Sample No: 10906

Point: A

Pa: Applied Force	Vertical Displacement Reading In.:	Pore Pressure psi:	Axial Strain (E):	(P) - Force Adj for U and F lbs:	Corrected Vertical Displacement In.:	Correction for Membrane ksf:	(A) Area In. 2:	($\sigma_1 - \sigma_3$) Deviator Stress ksf:	[Δu] Induced Pore Water Pressure ksf:	σ_3 Effective Consolidation Stress ksf:	σ_1 Total Major Principal Stress ksf:	σ_3 Effective Minor Principal Stress ksf:	σ_1' Effective Major Principal Stress ksf:	p'	q
16.3	0.000	62.5	0.00%	0.0	0.000	0.00002	6.244	0.00	0.3600	0.72	0.72	0.36	0.36	0.36	0.00
34.6	0.003	63.3	0.05%	18.3	0.003	0.00024	6.247	0.42	0.4752	0.72	1.14	0.24	0.67	0.46	0.21
38.7	0.006	63.7	0.10%	22.4	0.006	0.00047	6.250	0.52	0.5328	0.72	1.24	0.19	0.70	0.45	0.26
42.3	0.009	64.1	0.16%	26.0	0.009	0.00080	6.254	0.60	0.5904	0.72	1.32	0.13	0.73	0.43	0.30
44.1	0.012	64.2	0.20%	27.8	0.012	0.00100	6.257	0.64	0.6048	0.72	1.36	0.12	0.75	0.43	0.32
45.8	0.014	64.4	0.25%	29.5	0.014	0.00120	6.260	0.68	0.6336	0.72	1.40	0.09	0.76	0.43	0.34
48.0	0.018	64.5	0.31%	31.7	0.018	0.00151	6.263	0.73	0.6480	0.72	1.45	0.07	0.80	0.44	0.36
49.2	0.020	64.5	0.35%	32.9	0.020	0.00169	6.266	0.75	0.6480	0.72	1.47	0.07	0.83	0.45	0.38
50.9	0.023	64.6	0.40%	34.6	0.023	0.00197	6.269	0.79	0.6624	0.72	1.51	0.06	0.85	0.45	0.40
52.5	0.026	64.8	0.46%	36.2	0.026	0.00224	6.273	0.83	0.6912	0.72	1.55	0.03	0.86	0.44	0.41
53.7	0.029	64.8	0.50%	37.4	0.029	0.00246	6.276	0.86	0.6912	0.72	1.58	0.03	0.88	0.46	0.43
55.1	0.032	64.8	0.56%	38.8	0.032	0.00275	6.279	0.89	0.6912	0.72	1.61	0.03	0.92	0.47	0.44
56.9	0.035	65.0	0.61%	40.6	0.035	0.00300	6.283	0.93	0.7200	0.72	1.65	0.00	0.93	0.46	0.46
57.3	0.038	65.0	0.65%	41.0	0.038	0.00319	6.285	0.94	0.7200	0.72	1.66	0.00	0.94	0.47	0.47
58.4	0.041	65.0	0.70%	42.1	0.041	0.00344	6.288	0.96	0.7200	0.72	1.68	0.00	0.96	0.48	0.48
59.4	0.043	65.0	0.75%	43.1	0.043	0.00366	6.291	0.98	0.7200	0.72	1.70	0.00	0.98	0.49	0.49
60.5	0.046	65.0	0.80%	44.2	0.046	0.00392	6.294	1.01	0.7200	0.72	1.73	0.00	1.01	0.50	0.50
61.6	0.049	65.0	0.85%	45.3	0.049	0.00417	6.298	1.03	0.7200	0.72	1.75	0.00	1.03	0.52	0.52
62.8	0.053	65.1	0.91%	46.5	0.053	0.00446	6.302	1.06	0.7344	0.72	1.78	-0.01	1.04	0.51	0.53
63.8	0.056	65.1	0.96%	47.5	0.056	0.00473	6.305	1.08	0.7344	0.72	1.80	-0.01	1.07	0.53	0.54
64.5	0.058	65.1	1.00%	48.2	0.058	0.00492	6.307	1.10	0.7344	0.72	1.82	-0.01	1.08	0.53	0.55
73.0	0.087	65.2	1.50%	56.7	0.087	0.00736	6.339	1.28	0.7488	0.72	2.00	-0.03	1.25	0.61	0.64
80.9	0.116	65.1	2.00%	64.6	0.116	0.00981	6.372	1.45	0.7344	0.72	2.17	-0.01	1.44	0.71	0.73
86.9	0.145	64.9	2.50%	70.6	0.145	0.01227	6.405	1.58	0.7056	0.72	2.30	0.01	1.59	0.80	0.79
91.0	0.174	64.8	3.00%	74.7	0.174	0.01473	6.438	1.66	0.6912	0.72	2.38	0.03	1.69	0.86	0.83
94.4	0.203	64.6	3.50%	78.1	0.203	0.01717	6.471	1.72	0.6624	0.72	2.44	0.06	1.78	0.92	0.86
98.4	0.231	64.4	4.00%	82.1	0.231	0.01961	6.504	1.80	0.6336	0.72	2.52	0.09	1.88	0.99	0.90
102.2	0.261	64.2	4.50%	85.9	0.261	0.02209	6.539	1.87	0.6048	0.72	2.59	0.12	1.98	1.05	0.93
104.7	0.290	64.0	5.01%	88.4	0.290	0.02454	6.573	1.91	0.5760	0.72	2.63	0.14	2.06	1.10	0.96
107.9	0.318	63.8	5.50%	91.6	0.318	0.02698	6.608	1.97	0.5472	0.72	2.69	0.17	2.14	1.16	0.98
110.9	0.347	63.7	6.00%	94.6	0.347	0.02942	6.643	2.02	0.5328	0.72	2.74	0.19	2.21	1.20	1.01
113.7	0.376	63.5	6.51%	97.4	0.376	0.03190	6.679	2.07	0.5040	0.72	2.79	0.22	2.28	1.25	1.03
116.4	0.406	63.2	7.01%	100.1	0.406	0.03437	6.715	2.11	0.4608	0.72	2.83	0.26	2.37	1.32	1.06
119.1	0.434	63.1	7.51%	102.8	0.434	0.03680	6.751	2.16	0.4464	0.72	2.88	0.27	2.43	1.35	1.08
122.0	0.463	62.9	8.01%	105.7	0.463	0.03926	6.788	2.20	0.4176	0.72	2.92	0.30	2.51	1.40	1.10
124.3	0.492	62.8	8.50%	108.0	0.492	0.04170	6.825	2.24	0.4032	0.72	2.96	0.32	2.55	1.44	1.12
126.6	0.521	62.6	9.01%	110.3	0.521	0.04415	6.862	2.27	0.3744	0.72	2.99	0.35	2.62	1.48	1.14
128.9	0.550	62.4	9.51%	112.6	0.550	0.04661	6.900	2.30	0.3456	0.72	3.02	0.37	2.68	1.53	1.15

CIVIL LABORATORY
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



**Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767**

Company: **AEP**
 Project: **SPORN ASH DISP. FACILITY**
 Sample No: **10906**

Point: **A**

131.3	0.579	62.3	10.01%	115.0	0.579	0.04907	6.939	2.34	0.3312	0.72	3.06	0.39	2.73	1.56	1.17
135.5	0.637	61.9	11.01%	119.2	0.637	0.05399	7.017	2.39	0.2736	0.72	3.11	0.45	2.84	1.64	1.20
139.6	0.695	61.6	12.01%	123.3	0.695	0.05890	7.097	2.44	0.2304	0.72	3.16	0.49	2.93	1.71	1.22
143.7	0.753	61.4	13.01%	127.4	0.753	0.06380	7.178	2.49	0.2016	0.72	3.21	0.52	3.01	1.76	1.25
147.2	0.810	61.1	14.01%	130.9	0.810	0.06868	7.261	2.53	0.1584	0.72	3.25	0.56	3.09	1.83	1.26
151.3	0.868	60.9	15.01%	135.0	0.868	0.07360	7.347	2.57	0.1296	0.72	3.29	0.59	3.16	1.88	1.29
154.6	0.926	60.6	16.01%	138.3	0.926	0.07851	7.435	2.60	0.0864	0.72	3.32	0.63	3.23	1.93	1.30
158.0	0.984	60.4	17.02%	141.7	0.984	0.08343	7.525	2.63	0.0576	0.72	3.35	0.66	3.29	1.98	1.31
161.5	1.042	60.2	18.02%	145.2	1.042	0.08833	7.616	2.66	0.0288	0.72	3.38	0.69	3.35	2.02	1.33
165.0	1.100	59.9	19.01%	148.7	1.100	0.09322	7.710	2.68	-0.0144	0.72	3.40	0.73	3.42	2.08	1.34
168.1	1.158	59.7	20.02%	151.8	1.158	0.09814	7.807	2.70	-0.0432	0.72	3.42	0.76	3.47	2.11	1.35

CIVIL LABORATORY
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



**Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767**

Company: AEP
 Project: SPORN ASH DISP. FACILITY

Sample No: 10906

Point: B

Material Description:		Boring PZ-0901, Shelby Tube - 26' - 28'; Lab # S-10906	
Moisture Determination ASTM D2216		Before Testing	After Testing
Tare No.		4	4
Mass of Container and Wet Specimen (M _{cs}), grams		1389.93	1393.24
Mass of Container and Over Dry Specimen (M _{cs}), grams		1142.12	1142.12
Mass of Container (M _c), grams		213.10	213.10
Mass of Water (M _w), grams:		247.81	251.12
Mass of Solid Particles (M _s), grams:		929.02	929.02
Moisture Content (w), %		26.87%	27.03%
Initial Condition of Specimen ASTM D2435		(1)	(2)
Diameter Measurements, Inches:		2.854	2.852
Height Measurements, Inches:		5.75	5.75
Initial Volume of Specimen (V _o), In. 3:		36.63	
Dry Mass of Specimen After Testing, (M _d), grams:		929.02	
Dry Unit Weight, (γ _d) pcf:		96.63	
Specific Gravity of the Solids, (G):		2.70	
Volume of Solids, (V _s), Cu. In.:		20.9972	
Height of Solids, (H _s), In.:		3.2983	
Void Ratio Before Consolidation (E _o):		0.7443	
Initial Degree of Saturation: (S _o)		96.76%	
Saturation - ASTM D4767 Section 8.2			
Dial Indicator Reading Prior to Saturation (R _b), In.		0	
Cell Pressure After Saturation, psi:		65.00	
Back Pressure After Saturation After, psi:		60.00	
Pore Pressure Parameter B:		1	
Dial Indicator Reading After Saturation, (R _a) In.:		0.024	
Change in Height during Saturation, (Delta H _s) In.		0.024	
Change in Volume of Specimen during Saturation (Delta V _{sat}), In. 3:		0.458	

CIVIL LABORATORY
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767

Company: AEP
 Project: SPORN ASH DISP. FACILITY
 Sample No: 10906
 Point: B

Consolidation- ASTM D2435, Section 11.5:				
Sample No:	T:	Burette 2:	Burette3:	Rc:
10906	0	23.8	23.8	0.024
10906	0.25	23.7	23.7	
10906	0.5	23.6	23.6	
10906	1	23.6	23.6	
10906	2	23.5	23.5	
10906	4	23.4	23.3	
10906	8	23.2	23.2	
10906	15	23	23	0.028
10906	30	22.8	22.8	0.03
10906	60	22.6	22.5	0.031
10906	120	22.4	22.3	0.031
10906	240	22.3	22.2	0.032
10906	450	22.1	22.1	0.032
10906	1440	22	22	0.032

Specimen Height After Consolidation, (Hc), In.: 5.72

Volume Change During Consolidation (Delta Vc), In.3: 0.22


Cross-Sectional Area of Specimen After Consolidation (Ac), In.2: 6.28

Triaxial Compression Testing
 ASTM D 4767

Sample Depth: 0 ft.
 Cell Pressure: 70 psi
 Back Pressure: 60 psi
 Confining Pressure: 10 psi
 Strain Rate: 0.006 in/min.

Specimen Height After Consolidation, (Hc), In.: 5.72
 Correction for Vert Displacement, In.: 0
 Load due to Friction and Uplift: 19.1 lbs.
 Correction for Filter Paper: 0
 Thickness of Membrane (tm), In.: 0.012

$\sigma_1 - \sigma_3 =$ Deviator Stress at Failure, ksf: 3.44
 $\sigma_3 f =$ Effective Consolidation Stress at Failure, ksf: 1.44
 $\sigma_1 =$ Total Major Principal Stress at Failure: 4.88
 $\sigma_3 f = \sigma_3 - \Delta v =$ Effective Minor Principal Stress at Failure, ksf: 1.02
 $\sigma_1 f =$ Effective Major Principal Stress at Failure, ksf: 4.46
 Axial Strain at Failure: 15.00%



CIVIL LABORATORY
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767

Company: AEP

Project: SPORN ASH DISP. FACILITY

Sample No: 10906

Point: B

Pn: Applied Force	Vertical Displacement Reading In.:	Pore Pressure psi:	Axial Strain (EI):	(P) - Force Adj for U and F lbs:	Corrected Vertical Displacement In.:	Correction for Membrane ksf:	(A) Area In. 2:	(σ1-σ3) Deviator Stress ksf:	(Au) Induced Pore Water Pressure ksf:	σ3 Effective Consolidation Stress ksf:	σ1 Total Major Principal Stress ksf:	σ3 Effective Minor Principal Stress ksf:	σ1' Effective Major Principal Stress ksf:	p'	q
19.1	0.000	62.3	0.00%	0.0	0.000	0.00002	6.283	0.00	0.3312	1.44	1.44	1.11	1.11	1.11	0.00
38.3	0.003	63.6	0.05%	19.2	0.003	0.00026	6.286	0.44	0.5184	1.44	1.88	0.92	1.36	1.14	0.22
45.8	0.006	64.3	0.10%	26.7	0.006	0.00048	6.289	0.61	0.6192	1.44	2.05	0.82	1.43	1.13	0.31
51.7	0.009	64.9	0.16%	32.6	0.009	0.00079	6.293	0.75	0.7056	1.44	2.19	0.73	1.48	1.11	0.37
54.5	0.011	65.1	0.20%	35.4	0.011	0.00096	6.295	0.81	0.7344	1.44	2.25	0.71	1.51	1.11	0.40
58.3	0.014	65.5	0.25%	39.2	0.014	0.00123	6.299	0.89	0.7920	1.44	2.33	0.65	1.54	1.10	0.45
61.7	0.018	65.9	0.31%	42.6	0.018	0.00152	6.303	0.97	0.8496	1.44	2.41	0.59	1.56	1.08	0.49
64.0	0.020	66.0	0.35%	44.9	0.020	0.00171	6.305	1.02	0.8640	1.44	2.46	0.58	1.60	1.09	0.51
66.0	0.023	66.3	0.40%	46.9	0.023	0.00193	6.308	1.07	0.9072	1.44	2.51	0.53	1.60	1.07	0.53
69.1	0.026	66.6	0.46%	50.0	0.026	0.00224	6.312	1.14	0.9504	1.44	2.58	0.49	1.63	1.06	0.57
70.5	0.029	66.6	0.50%	51.4	0.029	0.00244	6.315	1.17	0.9504	1.44	2.61	0.49	1.66	1.07	0.58
73.7	0.032	66.9	0.56%	54.6	0.032	0.00273	6.318	1.24	0.9936	1.44	2.68	0.45	1.69	1.07	0.62
75.7	0.035	66.9	0.61%	56.6	0.035	0.00299	6.322	1.29	0.9936	1.44	2.73	0.45	1.73	1.09	0.64
77.6	0.037	67.1	0.65%	58.5	0.037	0.00316	6.324	1.33	1.0224	1.44	2.77	0.42	1.75	1.08	0.66
78.9	0.040	67.1	0.70%	59.8	0.040	0.00342	6.327	1.36	1.0224	1.44	2.80	0.42	1.78	1.10	0.68
81.0	0.043	67.3	0.75%	61.9	0.043	0.00367	6.331	1.40	1.0512	1.44	2.84	0.39	1.79	1.09	0.70
82.7	0.046	67.3	0.80%	63.6	0.046	0.00390	6.334	1.44	1.0512	1.44	2.88	0.39	1.83	1.11	0.72
85.1	0.048	67.5	0.85%	66.0	0.048	0.00413	6.337	1.50	1.0800	1.44	2.94	0.36	1.86	1.11	0.75
86.7	0.052	67.5	0.91%	67.6	0.052	0.00444	6.341	1.53	1.0800	1.44	2.97	0.36	1.89	1.13	0.77
88.9	0.055	67.6	0.96%	69.8	0.055	0.00470	6.344	1.58	1.0944	1.44	3.02	0.35	1.93	1.14	0.79
90.2	0.057	67.6	1.00%	71.1	0.057	0.00490	6.347	1.61	1.0944	1.44	3.05	0.35	1.95	1.15	0.80
105.7	0.086	67.9	1.50%	86.6	0.086	0.00733	6.379	1.95	1.1376	1.44	3.39	0.30	2.25	1.28	0.97
117.4	0.114	67.8	2.00%	98.3	0.114	0.00976	6.411	2.20	1.1232	1.44	3.64	0.32	2.51	1.42	1.10
126.9	0.143	67.7	2.50%	107.8	0.143	0.01220	6.444	2.40	1.1088	1.44	3.84	0.33	2.73	1.53	1.20
134.3	0.172	67.2	3.00%	115.2	0.172	0.01468	6.478	2.55	1.0368	1.44	3.99	0.40	2.95	1.68	1.27
140.4	0.200	66.9	3.50%	121.3	0.200	0.01709	6.511	2.67	0.9936	1.44	4.11	0.45	3.11	1.78	1.33
145.5	0.229	66.8	4.00%	126.4	0.229	0.01953	6.545	2.76	0.9792	1.44	4.20	0.46	3.22	1.84	1.38
150.1	0.257	66.4	4.50%	131.0	0.257	0.02199	6.579	2.85	0.9216	1.44	4.29	0.52	3.36	1.94	1.42
154.0	0.286	66.3	5.00%	134.9	0.286	0.02445	6.614	2.91	-0.9072	1.44	4.35	0.53	3.45	1.99	1.46
157.5	0.315	66.1	5.50%	138.4	0.315	0.02688	6.649	2.97	0.8784	1.44	4.41	0.56	3.53	2.05	1.49
160.8	0.343	65.9	6.00%	141.7	0.343	0.02930	6.684	3.02	0.8496	1.44	4.46	0.59	3.61	2.10	1.51
163.9	0.372	65.4	6.50%	144.8	0.372	0.03178	6.720	3.07	0.7776	1.44	4.51	0.66	3.73	2.20	1.54
166.8	0.400	65.2	6.99%	147.7	0.400	0.03419	6.756	3.11	0.7488	1.44	4.55	0.69	3.81	2.25	1.56
169.5	0.429	65.0	7.49%	150.4	0.429	0.03663	6.792	3.15	0.7200	1.44	4.59	0.72	3.87	2.30	1.58
172.1	0.458	64.8	8.00%	153.0	0.458	0.03909	6.829	3.19	0.6912	1.44	4.63	0.75	3.94	2.34	1.59
174.4	0.486	64.6	8.49%	155.3	0.486	0.04152	6.866	3.22	0.6624	1.44	4.66	0.78	3.99	2.39	1.61
176.8	0.515	64.6	8.99%	157.7	0.515	0.04396	6.904	3.25	0.6624	1.44	4.69	0.78	4.02	2.40	1.62
179.2	0.543	64.5	9.49%	160.1	0.543	0.04640	6.942	3.27	0.6480	1.44	4.71	0.79	4.07	2.43	1.64

CIVIL LABORATORY
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



**Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767**

Company: AEP

Project: SPORN ASH DISP. FACILITY

Sample No: 10906

Point: B

181.2	0.572	64.3	10.00%	162.1	0.572	0.04886	6.981	3.29	0.6192	1.44	4.73	0.82	4.12	2.47	1.65
185.4	0.629	64.0	11.00%	166.3	0.629	0.05375	7.059	3.34	0.5760	1.44	4.78	0.86	4.20	2.53	1.67
189.0	0.686	63.6	11.99%	169.9	0.686	0.05862	7.139	3.37	0.5184	1.44	4.81	0.92	4.29	2.61	1.68
192.6	0.744	63.5	13.00%	173.5	0.744	0.06352	7.222	3.40	0.5040	1.44	4.84	0.94	4.33	2.63	1.70
196.1	0.801	63.3	13.99%	177.0	0.801	0.06839	7.305	3.42	0.4752	1.44	4.86	0.96	4.39	2.68	1.71
199.5	0.858	62.9	15.00%	180.4	0.858	0.07331	7.392	3.44	0.4176	1.44	4.88	1.02	4.46	2.74	1.72
203.0	0.915	62.7	16.00%	183.9	0.915	0.07818	7.480	3.46	0.3888	1.44	4.90	1.05	4.51	2.78	1.73
206.0	0.972	62.5	16.99%	186.9	0.972	0.08305	7.569	3.47	0.3600	1.44	4.91	1.08	4.55	2.82	1.74
209.4	1.029	62.5	17.99%	190.3	1.029	0.08794	7.662	3.49	0.3600	1.44	4.93	1.08	4.57	2.82	1.74
212.4	1.087	62.3	19.00%	193.3	1.087	0.09284	7.756	3.50	0.3312	1.44	4.94	1.11	4.60	2.86	1.75
215.5	1.144	62.1	20.00%	196.4	1.144	0.09773	7.853	3.50	0.3024	1.44	4.94	1.14	4.64	2.89	1.75



Material Description:		Boring PZ-0901, Shelby Tube - 26" - 28"; Lab # S-10906	
Moisture Determination ASTM D2216		Before Testing	After Testing
	Tare No.	T-29	T-29
	Mass of Container and Wet Specimen (Mcws), grams	1460.95	1459.15
	Mass of Container and Over Dry Specimen (Mcs), grams	1228.10	1228.10
	Mass of Container (Mc), grams	207.93	207.93
	Mass of Water (Mw), grams:	232.85	231.05
	Mass of Solid Particles (Ms), grams:	1020.17	1020.17
	Moisture Content (w), %	22.82%	22.65%
Initial Condition of Specimen ASTM D2435		(1)	(2)
	Diameter Measurements, Inches:	2.853	2.842
	Height Measurements, Inches:	5.85	5.842
	Initial Volume of Specimen (Vo), In.3:	37.20	
	Dry Mass of Specimen After Testing, (Md), grams:	1020.17	
	Dry Unit Weight, (γ _d) pcf:	104.46	
	Specific Gravity of the Solids, (G):	2.70	
	Volume of Solids, (Vs), Cu. In.:	23.0574	
	Height of Solids, (Hs), In.:	3.6245	
	Void Ratio Before Consolidation (Eo):	0.6136	
	Initial Degree of Saturation: (So)	100.44%	
Saturation - ASTM D4767 Section 8.2			
	Dial Indicator Reading Prior to Saturation (Rb) In.	0	
	Cell Pressure After Saturation, psi:	80.00	
	Back Pressure After Saturation After, psi:	60.00	
	Pore Pressure Parameter B:	1	
	Dial Indicator Reading After Saturation, (Ra) In.:	-0.008	
	Change in Height during Saturation, (Delta Hs) In.	-0.008	
	Change in Volume of Specimen during Saturation (Delta Vsat), In.3:	-0.153	

FOSSIL AND HYDRO GENERATION
 CIVIL AND MINING ENGINEERING DIVISION
 CIVIL LABORATORY SECTION
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767

Company: AEP
 Project: SPORN ASH DISP. FACILITY
 Sample No: 10906
 Point: C

Consolidation- ASTM D2435, Section 11.5:				
Sample No:	T:	Burette 2:	Burette 3:	Rc:
10906	0	23.7	23.6	-0.008
10906	0.25	23.2	23.4	
10906	0.5	23.1	23.3	
10906	1	22.9	23.3	
10906	2	22.7	23.2	
10906	4	22.3	23.1	
10906	8	21.9	22.9	
10906	15	21.3	22.7	0.004
10906	30	20.4	22.4	0.006
10906	60	19.3	22	0.012
10906	120	18	21.5	0.018
10906	240	17	21	0.022
10906	450	16.3	20.7	0.026
10906	1440	15.8	20.5	0.029

Specimen Height After Consolidation, (Hc), In.: 5.82

Volume Change During Consolidation (Delta Vc), In.3: 0.67


Cross-Sectional Area of Specimen After Consolidation (Ac), In.2: 6.30

Triaxial Compression Testing
 ASTM D 4767

Sample Depth: 26 ft.
 Cell Pressure: 80 psi
 Back Pressure: 60 psi
 Confining Pressure: 20 psi
 Strain Rate: 0.006 In./min.

Specimen Height After Consolidation, (Hc), In.: 5.82
 Correction for Vert Displacement, In.: 0
 Load due to Friction and Uplift: 17.9 lbs.
 Correction for Filter Paper: 0
 Thickness of Membrane (tm), In.: 0.012

$\sigma_1 - \sigma_3 =$ Deviator Stress at Failure, ksf: 4.84
 $\sigma_3 f =$ Effective Consolidation Stress at Failure, ksf: 2.88
 $\sigma_1 =$ Total Major Principal Stress at Failure: 7.72
 $\sigma'_{3f} = \sigma_3 - \Delta v =$ Effective Minor Principal Stress at Failure, ksf: 1.53
 $\sigma'_{1f} =$ Effective Major Principal Stress at Failure, ksf: 6.36
 Axial Strain at Failure: 11.00%



FOSSIL AND HYDRO GENERATION
 CIVIL AND MINING ENGINEERING DIVISION
 CIVIL LABORATORY SECTION
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767

Company: AEP

Project: SPORN ASH DISP. FACILITY

Sample No: 10906

Point: C

Pa: Applied Force	Vertical Displacement Reading In.:	Pore Pressure psi:	Axial Strain (E):	(P) - Force Adj for U and F lbs:	Corrected Vertical Displacement In.:	Correction for Membrane ksf:	(A) Area In 2:	($\sigma_1 - \sigma_3$) Deviator Stress ksf:	[Δu] Induced Pore Water Pressure ksf:	σ_3 Effective Consolidation Stress ksf	σ_1 Total Major Principal Stress ksf	σ_3 Effective Minor Principal Stress ksf	σ_1' Effective Major Principal Stress ksf	p'	q
17.9	0.000	62.0	0.00%	0.0	0.000	0.00000	6.304	0.00	0.2880	2.88	2.88	2.59	2.59	2.59	0.00
64.6	0.003	65.6	0.05%	46.7	0.003	0.00025	6.307	1.07	0.8064	2.88	3.95	2.07	3.14	2.61	0.53
75.4	0.006	67.9	0.10%	57.5	0.006	0.00047	6.310	1.31	1.1376	2.88	4.19	1.74	3.05	2.40	0.66
86.6	0.009	69.0	0.16%	68.7	0.009	0.00079	6.314	1.57	1.2960	2.88	4.45	1.58	3.15	2.37	0.78
90.4	0.011	69.4	0.20%	72.5	0.011	0.00096	6.316	1.65	1.3536	2.88	4.53	1.53	3.18	2.35	0.83
94.7	0.014	71.0	0.25%	76.8	0.014	0.00121	6.320	1.75	1.5840	2.88	4.63	1.30	3.04	2.17	0.87
100.0	0.018	71.0	0.31%	82.1	0.018	0.00151	6.324	1.87	1.5840	2.88	4.75	1.30	3.16	2.23	0.93
103.4	0.020	71.0	0.35%	85.5	0.020	0.00169	6.326	1.94	1.5840	2.88	4.82	1.30	3.24	2.27	0.97
106.1	0.023	71.1	0.40%	88.2	0.023	0.00195	6.329	2.00	1.5984	2.88	4.88	1.28	3.29	2.28	1.00
109.9	0.027	73.4	0.46%	92.0	0.027	0.00223	6.333	2.09	1.9296	2.88	4.97	0.95	3.04	2.00	1.04
112.2	0.029	72.9	0.50%	94.3	0.029	0.00243	6.336	2.14	1.8576	2.88	5.02	1.02	3.16	2.09	1.07
115.9	0.033	73.0	0.56%	98.0	0.033	0.00275	6.340	2.22	1.8720	2.88	5.10	1.01	3.23	2.12	1.11
118.3	0.036	73.2	0.61%	100.4	0.036	0.00298	6.343	2.28	1.9008	2.88	5.16	0.98	3.26	2.12	1.14
120.1	0.038	73.5	0.65%	102.2	0.038	0.00317	6.345	2.32	1.9440	2.88	5.20	0.94	3.25	2.09	1.16
122.4	0.041	73.7	0.70%	104.5	0.041	0.00340	6.348	2.37	1.9728	2.88	5.25	0.91	3.27	2.09	1.18
124.8	0.044	73.9	0.75%	106.9	0.044	0.00366	6.352	2.42	2.0016	2.88	5.30	0.88	3.30	2.09	1.21
127.3	0.047	74.0	0.80%	109.4	0.047	0.00391	6.355	2.48	2.0160	2.88	5.36	0.86	3.34	2.10	1.24
129.4	0.049	74.0	0.85%	111.5	0.049	0.00414	6.358	2.52	2.0160	2.88	5.40	0.86	3.39	2.12	1.26
131.9	0.053	74.4	0.91%	114.0	0.053	0.00443	6.362	2.58	2.0736	2.88	5.46	0.81	3.38	2.09	1.29
133.9	0.056	74.7	0.96%	116.0	0.056	0.00466	6.365	2.62	2.1168	2.88	5.50	0.76	3.38	2.07	1.31
136.3	0.058	74.7	1.00%	118.4	0.058	0.00488	6.368	2.67	2.1168	2.88	5.55	0.76	3.44	2.10	1.34
152.8	0.087	75.9	1.50%	134.9	0.087	0.00733	6.400	3.03	2.2896	2.88	5.91	0.59	3.62	2.10	1.51
167.3	0.116	76.5	2.00%	149.4	0.116	0.00974	6.433	3.33	2.3760	2.88	6.21	0.50	3.84	2.17	1.67
180.1	0.146	76.5	2.50%	162.2	0.146	0.01221	6.466	3.60	2.3760	2.88	6.48	0.50	4.10	2.30	1.80
191.1	0.174	76.1	3.00%	173.2	0.174	0.01462	6.499	3.82	2.3184	2.88	6.70	0.56	4.38	2.47	1.91
200.1	0.204	76.0	3.50%	182.2	0.204	0.01707	6.533	4.00	2.3040	2.88	6.88	0.58	4.58	2.58	2.00
207.7	0.233	75.5	4.00%	189.8	0.233	0.01952	6.567	4.14	2.2320	2.88	7.02	0.65	4.79	2.72	2.07
214.5	0.262	75.0	4.50%	196.6	0.262	0.02195	6.601	4.27	2.1600	2.88	7.15	0.72	4.99	2.85	2.13
220.7	0.291	74.6	5.00%	202.8	0.291	0.02440	6.636	4.38	2.1024	2.88	7.26	0.78	5.15	2.97	2.19
226.2	0.320	74.1	5.50%	208.3	0.320	0.02683	6.671	4.47	2.0304	2.88	7.35	0.85	5.32	3.08	2.23
230.7	0.349	73.9	6.00%	212.8	0.349	0.02926	6.706	4.54	2.0016	2.88	7.42	0.88	5.42	3.15	2.27
234.8	0.378	73.3	6.50%	216.9	0.378	0.03173	6.743	4.60	1.9152	2.88	7.48	0.96	5.57	3.27	2.30
238.9	0.407	72.9	7.00%	221.0	0.407	0.03416	6.779	4.66	1.8576	2.88	7.54	1.02	5.68	3.35	2.33
242.5	0.437	72.7	7.50%	224.6	0.437	0.03661	6.815	4.71	1.8288	2.88	7.59	1.05	5.76	3.41	2.35
245.5	0.466	71.1	8.00%	227.6	0.466	0.03904	6.852	4.74	1.5984	2.88	7.62	1.28	6.03	3.65	2.37
248.5	0.495	71.0	8.50%	230.6	0.495	0.04149	6.890	4.78	1.5840	2.88	7.66	1.30	6.07	3.69	2.39
250.9	0.524	71.0	9.00%	233.0	0.524	0.04392	6.928	4.80	1.5840	2.88	7.68	1.30	6.10	3.70	2.40
253.3	0.553	71.0	9.50%	235.4	0.553	0.04637	6.966	4.82	1.5840	2.88	7.70	1.30	6.12	3.71	2.41

FOSSIL AND HYDRO GENERATION
 CIVIL AND MINING ENGINEERING DIVISION
 CIVIL LABORATORY SECTION
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767


Company: AEP

Project: SPORN ASH DISP. FACILITY

Sample No: 10906

Point: C

255.5	0.582	70.5	10.00%	237.6	0.582	0.04878	7.004	4.84	1.5120	2.88	7.72	1.37	6.20	3.79	2.42
258.4	0.640	69.4	11.00%	240.5	0.640	0.05366	7.083	4.84	1.3536	2.88	7.72	1.53	6.36	3.94	2.42
260.4	0.699	68.6	12.00%	242.5	0.699	0.05858	7.164	4.82	1.2384	2.88	7.70	1.64	6.46	4.05	2.41
261.6	0.756	67.6	13.00%	243.7	0.756	0.06342	7.246	4.78	1.0944	2.88	7.66	1.79	6.57	4.18	2.39
261.4	0.815	66.9	14.00%	243.5	0.815	0.06830	7.330	4.72	0.9936	2.88	7.60	1.89	6.60	4.24	2.36
262.5	0.873	66.1	15.00%	244.6	0.873	0.07320	7.417	4.68	0.8784	2.88	7.56	2.00	6.68	4.34	2.34
263.7	0.931	65.6	16.00%	245.8	0.931	0.07806	7.505	4.64	0.8064	2.88	7.52	2.07	6.71	4.39	2.32
267.4	0.990	65.0	17.01%	249.5	0.990	0.08298	7.596	4.65	0.7200	2.88	7.53	2.16	6.81	4.48	2.32
269.3	1.047	64.6	18.00%	251.4	1.047	0.08782	7.688	4.62	0.6624	2.88	7.50	2.22	6.84	4.53	2.31
271.6	1.106	64.2	19.00%	253.7	1.106	0.09270	7.783	4.60	0.6048	2.88	7.48	2.28	6.88	4.58	2.30
274.8	1.164	64.0	20.00%	256.9	1.164	0.09760	7.880	4.60	0.5760	2.88	7.48	2.30	6.90	4.60	2.30



COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● PZ-0902 8.5			NP	NP	NP	
	SILTY SAND with GRAVEL SM					
	Sand & Gravel Mixture - Samples 4,5,6 Combined					

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	%<.002
● PZ-0902 8.5	37.500	2.790	0.307		33.0	52.9	14.0	

PROJECT **SPORN PLANT - FLY ASH POND DIKES - FLY ASH POND DIKES** JOB NO. _____ DATE **8/14/09**

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, OH 43125





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● PZ-0902 31.0			29.5	17.4	12.2	
	LEAN CLAY with SAND CL					
	Shelby Tube Sample - 31' - 33'					

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	%<.002
● PZ-0902 31.0	0.600	0.039	0.005		0.0	20.6	79.4	21.3

PROJECT **SPORN PLANT - FLY ASH POND DIKES - FLY ASH POND DIKES** JOB NO. _____ DATE **8/14/09**

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, OH 43125



CIVIL LABORATORY
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



**Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767**

Company: AEP

Project: SPORN ASH DISP. FACILITY


Sample No: 10918

Material Description: Boring PZ-0902, Shelby Tube - 31' - 33'; Lab # S-10918


Point Designation	Initial Conditions			Final Conditions			
	Water Content, %	Dry Density, pcf	Degree of Saturation	Water Content, %	Confining Stress, (ksf)	Deviator Stress	Induced Pore Pressure (ksf)
A	16.2%	117.4	100.5%	16.62%	0.72	7.09	-1.15
B	17.2%	114.3	98.1%	17.6%	1.44	6.30	-0.42
C	17.3%	114.5	98.8%	17.4%	2.88	8.24	0.60

Point Designation	Axial Strain, %	q, (ksf)	Effective Stresses, (ksf)			Total Stresses, (ksf)		
			Major, (ksf)	Minor, (ksf)	p', (ksf)	Major, (ksf)	Minor, (ksf)	p, (ksf)
A	15.0%	3.54	8.96	1.87	5.42	7.81	0.72	4.26
B	15.0%	3.15	8.16	1.86	5.01	7.74	1.44	4.59
C	15.0%	4.12	10.52	2.28	6.40	11.12	2.88	7.00

Total Stress Envelope



Effective Stress Envelope



FOSSIL AND HYDRO GENERATION
CIVIL AND MINING ENGINEERING DIVISION
CIVIL LABORATORY SECTION
AMERICAN ELECTRIC POWER SERVICE CORPORATION
4001 BIXBY ROAD
GROVEPORT, OHIO 43125
(614) 836-4200




Test Report for Consolidated-Undrained
Triaxial Compression Test - ASTM D 4767

Company: AEP

Project: SPORN ASH DISP. FACILITY

Sample No: 10918

p'-q Diagram



FOSSIL AND HYDRO GENERATION
CIVIL AND MINING ENGINEERING DIVISION
CIVIL LABORATORY SECTION
AMERICAN ELECTRIC POWER SERVICE CORPORATION
4001 BIXBY ROAD
GROVEPORT, OHIO 43125
(614) 836-4200




Test Report for Consolidated-Undrained
Triaxial Compression Test - ASTM D 4767

Company: AEP

Project: SPORN ASH DISP. FACILITY

Sample No: 10918



FOSSIL AND HYDRO GENERATION
CIVIL AND MINING ENGINEERING DIVISION
CIVIL LABORATORY SECTION
AMERICAN ELECTRIC POWER SERVICE CORPORATION
4001 BIXBY ROAD
GROVEPORT, OHIO 43125
(614) 836-4200




Test Report for Consolidated-Undrained
Triaxial Compression Test - ASTM D 4767

Company: AEP

Project: SPORN ASH DISP. FACILITY

Sample No: 10918



CIVIL LABORATORY
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767

Company: AEP
 Project: SPORN ASH DISP. FACILITY
 Sample No: 10918
 Point: A

Material Description:		Boring PZ-0902, Shelby Tube - 31' - 33'; Lab # S-10918	
Moisture Determination ASTM D2216		Before Testing	After Testing
Tare No.	#28	#28	
Mass of Container and Wet Specimen (Mcws), grams	1493.00	1497.17	
Mass of Container and Over Dry Specimen (Mcs), grams	1313.92	1313.92	
Mass of Container (Mc), grams	211.24	211.24	
Mass of Water (Mw), grams:	179.08	183.26	
Mass of Solid Particles (Ms), grams:	1102.68	1102.68	
Moisture Content (w), %	16.24%	16.62%	
Initial Condition of Specimen ASTM D2435		(1)	(2)
Diameter Measurements, Inches:	2.813	2.803	2.824
Height Measurements, Inches:	5.763	5.763	5.757
Average	2.813		
Initial Volume of Specimen (Vo), In.3:	35.79		
Dry Mass of Specimen After Testing, (Md), grams:	1102.68		
Dry Unit Weight, (γ _d) pcf:	117.37		
Specific Gravity of the Solids, (G):	2.70		
Volume of Solids, (Vs), Cu. In.:	24.9222		
Height of Solids, (Hs), In.:	4.0092		
Void Ratio Before Consolidation (Eo):	0.4361		
Initial Degree of Saturation: (So)	100.54%		
Saturation - ASTM D4767 Section 8.2			
Dial Indicator Reading Prior to Saturation (Rb) In.	0		
Cell Pressure After Saturation, psl:	73.00		
Back Pressure After Saturation After, psl:	70.00		
Pore Pressure Parameter B:	1		
Dial Indicator Reading After Saturation, (Ra) In.:	0.003		
Change in Height during Saturation, (Delta Hs) In.	0.003		
Change in Volume of Specimen during Saturation (Delta Vsat), In.3:	0.056		

CIVIL LABORATORY
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



**Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767**

Company: AEP
 Project: SPORN ASH DISP. FACILITY
 Sample No: 10918
 Point: A

Consolidation-		ASTM		
D2435, Section 11.5:				
Sample No:	T:	Burette 2:	Burette 3:	Rc:
10918	0	23.7	24.1	0.003
10918	0.25	23.6	24	
10918	0.5	23.6	24	
10918	1	23.5	24	
10918	2	23.5	23.9	
10918	4	23.4	23.8	
10918	8	23.3	23.8	
10918	15	23.2	23.7	0.005
10918	30	23	23.6	0.005
10918	60	23	23.5	0.006
10918	180	22.9	23.4	0.007
10918	240	22.8	23.3	0.008
10918	454	22.8	23.3	0.009
10918	1440	22.9	23.1	0.01

Specimen Height After Consolidation, (Hc), In.: 5.75

Volume Change During Consolidation (Delta Vc), In. 3: 0.11

Cross-Sectional Area of Specimen After Consolidation (Ac), In. 2: 6.20


**Triaxial Compression Testing
 ASTM D 4767**

Sample Depth: 31 ft.
 Cell Pressure: 75 psi
 Back Pressure: 70 psi
 Confining Pressure: 5 psi
 Strain Rate: 0.006 in./min.

Specimen Height After Consolidation, (Hc), In.: 5.75
 Correction for Vert Displacement, In.: 0
 Load due to Friction and Uplift: 15.3 lbs.
 Correction for Filter Paper: 0
 Thickness of Membrane (tm), In.: 0.012

$\sigma_1 - \sigma_3 =$ Deviator Stress at Failure, ksf: 7.09
 $\sigma_3 f =$ Effective Consolidation Stress at Failure, ksf: 0.72
 $\sigma_1 =$ Total Major Principal Stress at Failure: 7.81
 $\sigma_3 f = \sigma_3 - \Delta \nu =$ Effective Minor Principal Stress at Failure, ksf: 1.87
 $\sigma_1 f =$ Effective Major Principal Stress at Failure, ksf: 8.96
 Axial Strain at Failure: 15.00%

Failure Sketch



CIVIL LABORATORY
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767

Company: AEP

Project: SPORN ASH DISP. FACILITY

Sample No: 10918

Point: A

Pa: Applied Force	Vertical Displacement Reading In.:	Pore Pressure psf:	Axial Strain (E1):	(P) - Force Adj for U and F lbs:	Corrected Vertical Displacement In.:	Correction for Membrane ksf:	(A) Area In. 2:	($\sigma_1 - \sigma_3$) Deviator Stress ksf:	[Δu] Induced Pore Water Pressure ksf:	σ_3 Effective Consolidation Stress ksf:	σ_1 Total Major Principal Stress ksf:	σ_3 Effective Minor Principal Stress ksf:	σ_1' Effective Major Principal Stress ksf:	p'	q
15.3	0.001	72.5	0.01%	0.0	0.001	0.00005	6.199	0.00	0.3600	0.72	0.72	0.36	0.36	0.36	0.00
36.2	0.003	73.5	0.05%	20.9	0.003	0.00024	6.201	0.49	0.5040	0.72	1.21	0.22	0.70	0.46	0.24
41.0	0.006	73.7	0.10%	25.7	0.006	0.00048	6.204	0.60	0.5328	0.72	1.32	0.19	0.78	0.49	0.30
44.2	0.009	73.9	0.16%	28.9	0.009	0.00079	6.208	0.67	0.5616	0.72	1.39	0.16	0.83	0.49	0.33
45.4	0.012	74.2	0.20%	30.1	0.012	0.00099	6.211	0.70	0.6048	0.72	1.42	0.12	0.81	0.46	0.35
47.1	0.014	74.2	0.25%	31.8	0.014	0.00123	6.214	0.74	0.6048	0.72	1.46	0.12	0.85	0.48	0.37
48.5	0.018	74.3	0.31%	33.2	0.018	0.00152	6.218	0.77	0.6192	0.72	1.49	0.10	0.87	0.48	0.38
49.3	0.020	74.4	0.35%	34.0	0.020	0.00171	6.220	0.79	0.6336	0.72	1.51	0.09	0.87	0.48	0.39
50.5	0.023	74.4	0.40%	35.2	0.023	0.00195	6.223	0.81	0.6336	0.72	1.53	0.09	0.90	0.49	0.41
51.8	0.026	74.6	0.46%	36.5	0.026	0.00224	6.227	0.84	0.6624	0.72	1.56	0.06	0.90	0.48	0.42
52.9	0.029	74.6	0.50%	37.6	0.029	0.00245	6.229	0.87	0.6624	0.72	1.59	0.06	0.92	0.49	0.43
54.1	0.032	74.6	0.56%	38.8	0.032	0.00274	6.233	0.89	0.6624	0.72	1.61	0.06	0.95	0.50	0.45
55.1	0.035	74.8	0.61%	39.8	0.035	0.00298	6.236	0.92	0.6912	0.72	1.64	0.03	0.94	0.49	0.46
55.9	0.037	74.8	0.65%	40.6	0.037	0.00320	6.239	0.93	0.6912	0.72	1.65	0.03	0.96	0.50	0.47
56.9	0.040	74.8	0.70%	41.6	0.040	0.00344	6.242	0.96	0.6912	0.72	1.68	0.03	0.99	0.51	0.48
57.8	0.043	74.8	0.75%	42.5	0.043	0.00370	6.245	0.98	0.6912	0.72	1.70	0.03	1.01	0.52	0.49
58.8	0.046	74.8	0.80%	43.5	0.046	0.00396	6.248	1.00	0.6912	0.72	1.72	0.03	1.03	0.53	0.50
59.6	0.049	74.8	0.85%	44.3	0.049	0.00418	6.251	1.02	0.6912	0.72	1.74	0.03	1.05	0.54	0.51
60.7	0.053	74.8	0.92%	45.4	0.053	0.00450	6.256	1.04	0.6912	0.72	1.76	0.03	1.07	0.55	0.52
61.5	0.055	74.8	0.96%	46.2	0.055	0.00473	6.258	1.06	0.6912	0.72	1.78	0.03	1.09	0.56	0.53
62.2	0.057	74.8	1.00%	46.9	0.057	0.00491	6.261	1.07	0.6912	0.72	1.79	0.03	1.10	0.57	0.54
70.4	0.086	74.8	1.50%	55.1	0.086	0.00740	6.293	1.25	0.6912	0.72	1.97	0.03	1.28	0.66	0.63
79.3	0.115	74.7	2.00%	64.0	0.115	0.00985	6.325	1.45	0.6768	0.72	2.17	0.04	1.49	0.77	0.72
89.3	0.144	74.6	2.50%	74.0	0.144	0.01231	6.357	1.66	0.6624	0.72	2.38	0.06	1.72	0.89	0.83
99.4	0.173	74.4	3.00%	84.1	0.173	0.01478	6.390	1.88	0.6336	0.72	2.60	0.09	1.97	1.03	0.94
109.4	0.201	74.2	3.50%	94.1	0.201	0.01721	6.423	2.09	0.6048	0.72	2.81	0.12	2.21	1.16	1.05
121.9	0.230	73.9	4.00%	106.6	0.230	0.01969	6.457	2.36	0.5616	0.72	3.08	0.16	2.52	1.34	1.18
134.4	0.259	73.6	4.50%	119.1	0.259	0.02214	6.490	2.62	0.5184	0.72	3.34	0.20	2.82	1.51	1.31
148.2	0.288	73.2	5.01%	132.9	0.288	0.02464	6.525	2.91	0.4608	0.72	3.63	0.26	3.17	1.71	1.45
162.0	0.316	72.8	5.50%	146.7	0.316	0.02705	6.559	3.19	0.4032	0.72	3.91	0.32	3.51	1.91	1.60
175.8	0.345	72.4	6.00%	160.5	0.345	0.02952	6.594	3.48	0.3456	0.72	4.20	0.37	3.85	2.11	1.74
190.0	0.374	71.9	6.50%	174.7	0.374	0.03199	6.629	3.76	0.2736	0.72	4.48	0.45	4.21	2.33	1.88
204.9	0.402	71.3	7.00%	189.6	0.402	0.03445	6.665	4.06	0.1872	0.72	4.78	0.53	4.59	2.56	2.03
218.5	0.431	70.8	7.50%	203.2	0.431	0.03690	6.701	4.33	0.1152	0.72	5.05	0.60	4.93	2.77	2.16
231.6	0.460	70.3	8.00%	216.3	0.460	0.03937	6.737	4.58	0.0432	0.72	5.30	0.68	5.26	2.97	2.29
245.2	0.489	69.7	8.50%	229.9	0.489	0.04183	6.774	4.85	-0.0432	0.72	5.57	0.76	5.61	3.19	2.42
257.8	0.517	69.1	9.00%	242.5	0.517	0.04430	6.811	5.08	-0.1296	0.72	5.80	0.85	5.93	3.39	2.54
270.3	0.546	68.5	9.50%	255.0	0.546	0.04675	6.849	5.31	-0.2160	0.72	6.03	0.94	6.25	3.59	2.66

CIVIL LABORATORY
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



**Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767**

Company: AEP

Project: SPORN ASH DISP. FACILITY

Sample No: 10918

Point: A

282.4	0.575	67.9	10.00%	267.1	0.575	0.04921	6.887	5.54	-0.3024	0.72	6.26	1.02	6.56	3.79	2.77
306.0	0.632	66.7	11.00%	290.7	0.632	0.05414	6.965	5.96	-0.4752	0.72	6.68	1.20	7.15	4.17	2.98
326.7	0.690	65.6	12.00%	311.4	0.690	0.05906	7.044	6.31	-0.6336	0.72	7.03	1.35	7.66	4.51	3.15
346.2	0.747	64.4	13.00%	330.9	0.747	0.06399	7.125	6.62	-0.8064	0.72	7.34	1.53	8.15	4.84	3.31
362.1	0.805	63.2	14.00%	346.8	0.805	0.06890	7.207	6.86	-0.9792	0.72	7.58	1.70	8.56	5.13	3.43
378.0	0.862	62.0	15.00%	362.7	0.862	0.07383	7.292	7.09	-1.1520	0.72	7.81	1.87	8.96	5.42	3.54
392.6	0.920	60.8	16.00%	377.3	0.920	0.07875	7.379	7.28	-1.3248	0.72	8.00	2.04	9.33	5.69	3.64
407.1	0.977	59.7	17.01%	391.8	0.977	0.08368	7.468	7.47	-1.4832	0.72	8.19	2.20	9.67	5.94	3.74
421.0	1.035	58.4	18.00%	405.7	1.035	0.08859	7.559	7.64	-1.6704	0.72	8.36	2.39	10.03	6.21	3.82
434.8	1.092	57.1	19.01%	419.5	1.092	0.09353	7.653	7.80	-1.8576	0.72	8.52	2.58	10.38	6.48	3.90
447.2	1.150	55.6	20.01%	431.9	1.150	0.09846	7.749	7.93	-2.0736	0.72	8.65	2.79	10.72	6.76	3.96

CIVIL LABORATORY
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



**Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767**

Company: AEP
 Project: SPORN ASH DISP. FACILITY
 Sample No: 10918
 Point: B

Material Description:		Boring PZ-0902, Shelby Tube - 31' - 33'; Lab # S-10918	
Moisture Determination ASTM D2216		Before Testing	After Testing
Tare No.	#900	#900	
Mass of Container and Wet Specimen (M _{cs}), grams	1499.01	1502.94	
Mass of Container and Over Dry Specimen (M _{cs}), grams	1310.23	1310.23	
Mass of Container (M _c), grams	215.43	215.43	
Mass of Water (M _w), grams:	188.78	192.71	
Mass of Solid Particles (M _s), grams:	1094.8	1094.8	
Moisture Content (w), %	17.24%	17.60%	
Initial Condition of Specimen ASTM D2435		(1)	(2)
Diameter Measurements, Inches:	2.849	2.839	(3)
Height Measurements, Inches:	5.756	5.766	Average
Initial Volume of Specimen (V _o), In.³:	36.49	2.834	2.841
Dry Mass of Specimen After Testing, (M _d), grams:	1094.8	5.751	5.758
Dry Unit Weight, (γ _d) pcf:	114.30		
Specific Gravity of the Solids, (G):	2.70		
Volume of Solids, (V _s), Cu. In.:	24.7441		
Height of Solids, (H _s), In.:	3.9043		
Void Ratio Before Consolidation (E _o):	0.4747		
Initial Degree of Saturation: (S _o)	98.07%		
Saturation - ASTM D4767 Section 8.2			
Dial Indicator Reading Prior to Saturation (R _b) In.	0		
Cell Pressure After Saturation, psi:	75.00		
Back Pressure After Saturation After, psi:	70.00		
Pore Pressure Parameter B:	0.99		
Dial Indicator Reading After Saturation, (R _a) In.:	0.003		
Change In Height during Saturation, (Delta H _s) In.	0.003		
Change In Volume of Specimen during Saturation (Delta V _{sat}), In.³:	0.057		

CIVIL LABORATORY
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



**Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767**

Company: AEP
 Project: SPORN ASH DISP. FACILITY
 Sample No: 10918
 Point: B

Consolidation- ASTM D2435, Section 11.5:				
Sample No:	T:	Burette 2:	Burette 3:	Re:
10918	0	24.1	23.9	0.003
10918	0.25	24	23.8	
10918	0.5	24	23.8	
10918	1	24	23.8	
10918	2	23.9	23.7	
10918	4	23.9	23.7	
10918	8	23.8	23.5	
10918	15	23.7	23.4	0.005
10918	30	23.6	23.2	0.006
10918	60	23.5	23.1	0.006
10918	180	23.4	23	0.007
10918	240	23.4	22.9	0.007
10918	452	23.3	22.9	0.008
10918	1440	23.3	22.9	0.008

Specimen Height After Consolidation, (Hc), In.: 5.75

Volume Change During Consolidation (Delta Vc), In.3: 0.11

Cross-Sectional Area of Specimen After Consolidation (Ac), In.2: 6.32

**Triaxial Compression Testing
 ASTM D 4767**

Sample Depth: 31 ft.
 Cell Pressure: 80 psi
 Back Pressure: 70 psi
 Confining Pressure: 10 psi
 Strain Rate: 0.006 In./min.

Specimen Height After Consolidation, (Hc), In.: 5.75
 Correction for Vert Displacement, In.: 0
 Load due to Friction and Uplift: 18.6 lbs.
 Correction for Filter Paper: 0
 Thickness of Membrane (tm), In.: 0.012

$\sigma_1 - \sigma_3 =$ Deviator Stress at Failure, ksf: 6.30
 $\sigma_3 f =$ Effective Consolidation Stress at Failure, ksf: 1.44
 $\sigma_1 =$ Total Major Principal Stress at Failure: 7.74
 $\sigma_3 f = \sigma_3 - \Delta v =$ Effective Minor Principal Stress at Failure, ksf: 1.86
 $\sigma_1 f =$ Effective Major Principal Stress at Failure, ksf: 8.16
 Axial Strain at Failure: 15.00%

Failure Sketch

CIVIL LABORATORY
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BXB ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767

Company: AEP

Project: SPORN ASH DISP. FACILITY

Sample No: 10918

Point: B

Pat Applied Force	Vertical Displacement Reading In.:	Pore Pressure psf:	Axial Strain (EI):	(P) - Force Adj for U and F lbs:	Corrected Vertical Displacement In.:	Correction for Membrane ksf:	(A) Area In 2:	($\sigma_1 - \sigma_3$) Deviator Stress ksf:	(Δu) Induced Pore Water Pressure ksf:	σ_3 Effective Consolidation Stress ksf	σ_1 Total Major Principal Stress ksf	σ_3 Effective Minor Principal Stress ksf	σ_1' Effective Major Principal Stress ksf	p'	q
18.6	0.000	72.6	0.00%	0.0	0.000	0.00000	6.317	0.00	0.3744	1.44	1.44	1.07	1.07	1.07	0.00
49.0	0.003	74.6	0.05%	30.4	0.003	0.00022	6.320	0.69	0.6624	1.44	2.13	0.78	1.47	1.12	0.35
61.0	0.006	75.3	0.10%	42.4	0.006	0.00047	6.324	0.97	0.7632	1.44	2.41	0.68	1.64	1.16	0.48
67.3	0.009	75.8	0.16%	48.7	0.009	0.00076	6.327	1.11	0.8352	1.44	2.55	0.60	1.71	1.16	0.55
70.9	0.011	75.9	0.20%	52.3	0.011	0.00097	6.330	1.19	0.8496	1.44	2.63	0.59	1.78	1.18	0.59
74.7	0.015	76.2	0.25%	56.1	0.015	0.00124	6.334	1.27	0.8928	1.44	2.71	0.55	1.82	1.18	0.64
77.9	0.018	76.5	0.31%	59.3	0.018	0.00149	6.337	1.35	0.9360	1.44	2.79	0.50	1.85	1.18	0.67
80.1	0.020	76.5	0.35%	61.5	0.020	0.00171	6.340	1.40	0.9360	1.44	2.84	0.50	1.90	1.20	0.70
83.0	0.023	76.8	0.40%	64.4	0.023	0.00193	6.343	1.46	0.9792	1.44	2.90	0.46	1.92	1.19	0.73
85.3	0.026	76.8	0.46%	66.7	0.026	0.00222	6.346	1.51	0.9792	1.44	2.95	0.46	1.97	1.22	0.76
87.4	0.029	77.0	0.50%	68.8	0.029	0.00244	6.349	1.56	1.0080	1.44	3.00	0.43	1.99	1.21	0.78
90.3	0.032	77.0	0.56%	71.7	0.032	0.00271	6.353	1.62	1.0080	1.44	3.06	0.43	2.05	1.24	0.81
92.4	0.035	77.2	0.61%	73.8	0.035	0.00297	6.356	1.67	1.0368	1.44	3.11	0.40	2.07	1.24	0.83
95.1	0.038	77.2	0.65%	76.5	0.038	0.00319	6.359	1.73	1.0368	1.44	3.17	0.40	2.13	1.27	0.86
96.2	0.040	77.2	0.70%	77.6	0.040	0.00339	6.362	1.75	1.0368	1.44	3.19	0.40	2.16	1.28	0.88
98.3	0.043	77.2	0.75%	79.7	0.043	0.00365	6.365	1.80	1.0368	1.44	3.24	0.40	2.20	1.30	0.90
100.9	0.046	77.2	0.80%	82.3	0.046	0.00390	6.368	1.86	1.0368	1.44	3.30	0.40	2.26	1.33	0.93
102.6	0.049	77.2	0.85%	84.0	0.049	0.00414	6.372	1.89	1.0368	1.44	3.33	0.40	2.30	1.35	0.95
104.8	0.052	77.4	0.91%	86.2	0.052	0.00443	6.375	1.94	1.0656	1.44	3.38	0.37	2.32	1.35	0.97
106.7	0.055	77.4	0.96%	88.1	0.055	0.00468	6.379	1.98	1.0656	1.44	3.42	0.37	2.36	1.37	0.99
108.3	0.058	77.4	1.00%	89.7	0.058	0.00488	6.381	2.02	1.0656	1.44	3.46	0.37	2.39	1.38	1.01
126.1	0.086	77.3	1.50%	107.5	0.086	0.00729	6.413	2.41	1.0512	1.44	3.85	0.39	2.80	1.59	1.20
141.1	0.115	77.0	2.00%	122.5	0.115	0.00975	6.446	2.73	1.0080	1.44	4.17	0.43	3.16	1.80	1.36
154.6	0.144	76.6	2.50%	136.0	0.144	0.01221	6.480	3.01	0.9504	1.44	4.45	0.49	3.50	1.99	1.51
167.2	0.172	76.4	3.00%	148.6	0.172	0.01462	6.513	3.27	0.9216	1.44	4.71	0.52	3.79	2.15	1.64
180.0	0.201	76.0	3.50%	161.4	0.201	0.01706	6.547	3.53	0.8640	1.44	4.97	0.58	4.11	2.34	1.77
191.8	0.230	75.5	4.00%	173.2	0.230	0.01950	6.581	3.77	0.7920	1.44	5.21	0.65	4.42	2.53	1.89
202.7	0.259	75.1	4.50%	184.1	0.259	0.02194	6.615	3.99	0.7344	1.44	5.43	0.71	4.69	2.70	1.99
213.2	0.287	74.6	5.00%	194.6	0.287	0.02436	6.650	4.19	0.6624	1.44	5.63	0.78	4.97	2.87	2.09
223.6	0.316	74.1	5.50%	205.0	0.316	0.02681	6.685	4.39	0.5904	1.44	5.83	0.85	5.24	3.04	2.19
233.4	0.345	73.6	6.00%	214.8	0.345	0.02923	6.720	4.57	0.5184	1.44	6.01	0.92	5.49	3.21	2.29
242.5	0.374	73.4	6.50%	223.9	0.374	0.03167	6.756	4.74	0.4896	1.44	6.18	0.95	5.69	3.32	2.37
251.2	0.402	73.0	7.00%	232.6	0.402	0.03411	6.793	4.90	0.4320	1.44	6.34	1.01	5.90	3.46	2.45
259.6	0.431	72.6	7.50%	241.0	0.431	0.03655	6.830	5.04	0.3744	1.44	6.48	1.07	6.11	3.59	2.52
267.5	0.460	72.2	8.00%	248.9	0.460	0.03900	6.867	5.18	0.3168	1.44	6.62	1.12	6.30	3.71	2.59
275.0	0.489	71.9	8.50%	256.4	0.489	0.04145	6.905	5.31	0.2736	1.44	6.75	1.17	6.47	3.82	2.65
281.4	0.518	71.3	9.01%	262.8	0.518	0.04390	6.943	5.41	0.1872	1.44	6.85	1.25	6.66	3.96	2.70
288.3	0.546	70.9	9.50%	269.7	0.546	0.04632	6.981	5.52	0.1296	1.44	6.96	1.31	6.83	4.07	2.76

CIVIL LABORATORY
AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



**Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767**

Company: AEP

Project: SPORN ASH DISP. FACILITY

Sample No: 10918

Point: B

294.5	0.575	70.6	10.00%	275.9	0.575	0.04873	7.019	5.61	0.0864	1.44	7.05	1.35	6.97	4.16	2.81
306.4	0.633	69.9	11.01%	287.8	0.633	0.05365	7.099	5.78	-0.0144	1.44	7.22	1.45	7.24	4.35	2.89
318.1	0.690	69.4	12.00%	299.5	0.690	0.05848	7.179	5.95	-0.0864	1.44	7.39	1.53	7.48	4.50	2.97
328.6	0.748	68.7	13.00%	310.0	0.748	0.06338	7.262	6.08	-0.1872	1.44	7.52	1.63	7.71	4.67	3.04
338.6	0.805	67.9	14.00%	320.0	0.805	0.06824	7.346	6.20	-0.3024	1.44	7.64	1.74	7.95	4.84	3.10
347.6	0.863	67.1	15.00%	329.0	0.863	0.07313	7.433	6.30	-0.4176	1.44	7.74	1.86	8.16	5.01	3.15
356.8	0.920	66.3	16.00%	338.2	0.920	0.07799	7.521	6.40	-0.5328	1.44	7.84	1.97	8.37	5.17	3.20
365.6	0.978	65.5	17.00%	347.0	0.978	0.08288	7.612	6.48	-0.6480	1.44	7.92	2.09	8.57	5.33	3.24
373.3	1.035	64.6	18.00%	354.7	1.035	0.08776	7.705	6.54	-0.7776	1.44	7.98	2.22	8.76	5.49	3.27
381.9	1.092	63.7	19.00%	363.3	1.092	0.09261	7.799	6.62	-0.9072	1.44	8.06	2.35	8.96	5.65	3.31
389.9	1.150	62.9	20.00%	371.3	1.150	0.09747	7.897	6.67	-1.0224	1.44	8.11	2.46	9.14	5.80	3.34

FOSSIL AND HYDRO GENERATION
 CIVIL AND MINING ENGINEERING DIVISION
 CIVIL LABORATORY SECTION
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767

Company: AEP
 Project: SPORN ASH DISP. FACILITY
 Sample No: 10918
 Point: C

Material Description:		
Boring PZ-0902, Shelby Tube - 31' - 33'; Lab # S-10918		
Moisture Determination ASTM D2216	Before Testing	After Testing
Tare No.	R-3	R-3
Mass of Container and Wet Specimen (M _{cs}), grams	1515.47	1516.93
Mass of Container and Over Dry Specimen (M _{cs}), grams	1324.08	1324.08
Mass of Container (M _c), grams	216.28	216.28
Mass of Water (M _w), grams:	191.39	192.85
Mass of Solid Particles (M _s), grams:	1107.8	1107.8
Moisture Content (w), %	17.28%	17.41%

Initial Condition of Specimen ASTM D2435	(1)	(2)	(3)	Average
Diameter Measurements, Inches:	2.843	2.848	2.837	2.843
Height Measurements, Inches:	5.801	5.809	5.811	5.807
Initial Volume of Specimen (V _o), In.3:	36.85			
Dry Mass of Specimen After Testing, (M _d), grams:	1107.8			
Dry Unit Weight, (γ _d) pcf:	114.51			
Specific Gravity of the Solids, (G):	2.70			
Volume of Solids, (V _s), Cu. In.:	25.0379			
Height of Solids, (H _s), In.:	3.9451			
Void Ratio Before Consolidation (E _o):	0.4720			
Initial Degree of Saturation: (S _o)	98.84%			

Saturation - ASTM D4767 Section 8.2	
Dial Indicator Reading Prior to Saturation (R _b) In.	0
Cell Pressure After Saturation, psi:	90.00
Back Pressure After Saturation After, psi:	70.00
Pore Pressure Parameter B:	1
Dial Indicator Reading After Saturation, (R _a) In.:	-0.004
Change in Height during Saturation, (ΔH _s) In.	-0.004
Change in Volume of Specimen during Saturation (ΔV _{sat}), In.3:	-0.076

FOSSIL AND HYDRO GENERATION
 CIVIL AND MINING ENGINEERING DIVISION
 CIVIL LABORATORY SECTION
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767

Company: AEP
 Project: SPORN ASH DISP. FACILITY
 Sample No: 10918
 Point: C

Consolidation-		ASTM			
D2435, Section 11.5:					
Sample No:	T:	Burette 2:	Burette 3:	Rc:	
10918	0	23.8	23.7	-0.004	
10918	0.25	23.5	23.5		
10918	0.5	23.5	23.5		
10918	1	23.5	23.4		
10918	2	23.4	23.3		
10918	4	23.2	23.1		
10918	8	23.1	22.8		
10918	15	22.9	22.4	0.005	
10918	30	22.5	22	0.008	
10918	60	22	21.4	0.011	
10918	180	21.2	20.6	0.015	
10918	240	21.1	20.4	0.016	
10918	450	20.8	20.1	0.018	
10918	1440	20.7	20.4	0.02	

Specimen Height After Consolidation, (Hc), In.: 5.79

Volume Change During Consolidation (Delta Vc), In.3: 0.39

Cross-Sectional Area of Specimen After Consolidation (Ac), In.2: 6.31

Triaxial Compression Testing
 ASTM D 4767

Sample Depth: 31 ft. Specimen Height After Consolidation, (Hc), in.: 5.79

Cell Pressure: 90 psi Correction for Vert Displacement, In.: 0

Back Pressure: 70 psi Load due to Friction and Uplift: 20 lbs.

Confining Pressure: 20 psi Correction for Filter Paper: 0

Strain Rate: 0.006 In./min. Thickness of Membrane (tm), In.: 0.012

$\sigma_1 - \sigma_3 =$ Deviator Stress at Failure, ksf: 8.24

$\sigma_3 =$ Effective Consolidation Stress at Failure, ksf: 2.88

$\sigma_1 =$ Total Major Principal Stress at Failure: 11.12

$\sigma_3' = \sigma_3 - \Delta u =$ Effective Minor Principal Stress at Failure, ksf: 2.28

$\sigma_1' =$ Effective Major Principal Stress at Failure, ksf: 10.52

Axial Strain at Failure: 15.01%

Failure Sketch

FOSSIL AND HYDRO GENERATION
 CIVIL AND MINING ENGINEERING DIVISION
 CIVIL LABORATORY SECTION
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767

Company: AEP

Project: SPORN ASH DISP. FACILITY

Sample No: 10918

Point: C

Pa Applied Force	Vertical Displacement Reading In. :	Pore Pressure psi:	Axial Strain (E1):	(F) - Force Adj for U and F lbs:	Corrected Vertical Displacement In. :	Correction for Membrane ksf:	(A) Area In 2:	(σ1-σ3) Deviator Stress ksf:	[Δu] Induced Pore Water Pressure ksf:	σ3 Effective Consolidation Stress ksf	σ1 Total Major Principal Stress ksf	σ3 Effective Minor Principal Stress ksf	σ1' Effective Major Principal Stress ksf	p'	q
20.0	0.000	73.5	0.00%	0.0	0.000	0.00000	6.314	0.00	0.5040	2.88	2.88	2.38	2.38	2.38	0.00
67.4	0.003	74.7	0.05%	47.4	0.003	0.00025	6.317	1.08	0.6768	2.88	3.96	2.20	3.28	2.74	0.54
81.2	0.006	77.0	0.10%	61.2	0.006	0.00049	6.321	1.39	1.0080	2.88	4.27	1.87	3.27	2.57	0.70
91.2	0.009	80.6	0.16%	71.2	0.009	0.00076	6.324	1.62	1.5264	2.88	4.50	1.35	2.97	2.16	0.81
96.0	0.011	80.3	0.20%	76.0	0.011	0.00096	6.327	1.73	1.4832	2.88	4.61	1.40	3.13	2.26	0.86
101.8	0.014	80.6	0.25%	81.8	0.014	0.00120	6.330	1.86	1.5264	2.88	4.74	1.35	3.21	2.28	0.93
107.7	0.018	81.7	0.31%	87.7	0.018	0.00150	6.334	1.99	1.6848	2.88	4.87	1.20	3.19	2.19	1.00
110.5	0.020	82.1	0.35%	90.5	0.020	0.00170	6.336	2.06	1.7424	2.88	4.94	1.14	3.19	2.17	1.03
114.8	0.023	83.1	0.40%	94.8	0.023	0.00194	6.339	2.15	1.8864	2.88	5.03	0.99	3.15	2.07	1.08
119.0	0.027	83.1	0.46%	99.0	0.027	0.00224	6.343	2.25	1.8864	2.88	5.13	0.99	3.24	2.12	1.12
122.2	0.029	83.2	0.50%	102.2	0.029	0.00244	6.346	2.32	1.9008	2.88	5.20	0.98	3.30	2.14	1.16
124.7	0.032	84.1	0.56%	104.7	0.032	0.00271	6.350	2.37	2.0304	2.88	5.25	0.85	3.22	2.04	1.19
127.8	0.035	85.0	0.61%	107.8	0.035	0.00297	6.353	2.44	2.1600	2.88	5.32	0.72	3.16	1.94	1.22
129.6	0.038	85.1	0.65%	109.6	0.038	0.00317	6.356	2.48	2.1744	2.88	5.36	0.71	3.19	1.95	1.24
132.2	0.041	85.0	0.70%	112.2	0.041	0.00342	6.359	2.54	2.1600	2.88	5.42	0.72	3.26	1.99	1.27
134.4	0.043	85.0	0.75%	114.4	0.043	0.00366	6.362	2.59	2.1600	2.88	5.47	0.72	3.31	2.01	1.29
137.1	0.046	85.0	0.80%	117.1	0.046	0.00391	6.365	2.65	2.1600	2.88	5.53	0.72	3.37	2.04	1.32
139.0	0.049	85.1	0.85%	119.0	0.049	0.00413	6.368	2.69	2.1744	2.88	5.57	0.71	3.39	2.05	1.34
142.1	0.053	86.1	0.91%	122.1	0.053	0.00445	6.372	2.75	2.3184	2.88	5.63	0.56	3.32	1.94	1.38
143.8	0.055	86.0	0.96%	123.8	0.055	0.00467	6.375	2.79	2.3040	2.88	5.67	0.58	3.37	1.97	1.40
145.6	0.058	86.1	1.00%	125.6	0.058	0.00487	6.378	2.83	2.3184	2.88	5.71	0.56	3.39	1.98	1.42
164.2	0.087	86.6	1.50%	144.2	0.087	0.00730	6.410	3.23	2.3904	2.88	6.11	0.49	3.72	2.11	1.62
181.7	0.116	86.9	2.00%	161.7	0.116	0.00976	6.443	3.60	2.4336	2.88	6.48	0.45	4.05	2.25	1.80
197.6	0.145	86.9	2.50%	177.6	0.145	0.01218	6.476	3.94	2.4336	2.88	6.82	0.45	4.38	2.41	1.97
212.0	0.174	86.4	3.00%	192.0	0.174	0.01464	6.510	4.23	2.3616	2.88	7.11	0.52	4.75	2.63	2.12
224.9	0.203	86.4	3.50%	204.9	0.203	0.01707	6.543	4.49	2.3616	2.88	7.37	0.52	5.01	2.76	2.25
238.2	0.231	86.0	4.00%	218.2	0.231	0.01950	6.577	4.76	2.3040	2.88	7.64	0.58	5.33	2.95	2.38
251.3	0.260	85.6	4.50%	231.3	0.260	0.02194	6.612	5.02	2.2464	2.88	7.90	0.63	5.65	3.14	2.51
263.4	0.290	85.0	5.01%	243.4	0.290	0.02442	6.647	5.25	2.1600	2.88	8.13	0.72	5.97	3.34	2.62
275.0	0.318	84.7	5.50%	255.0	0.318	0.02682	6.682	5.47	2.1168	2.88	8.35	0.76	6.23	3.50	2.73
286.3	0.347	84.0	6.00%	266.3	0.347	0.02927	6.717	5.68	2.0160	2.88	8.56	0.86	6.54	3.70	2.84
297.9	0.376	83.6	6.50%	277.9	0.376	0.03169	6.753	5.89	1.9584	2.88	8.77	0.92	6.82	3.87	2.95
309.3	0.406	83.0	7.01%	289.3	0.406	0.03417	6.790	6.10	1.8720	2.88	8.98	1.01	7.11	4.06	3.05
319.5	0.434	82.4	7.51%	299.5	0.434	0.03660	6.827	6.28	1.7856	2.88	9.16	1.09	7.38	4.23	3.14
329.7	0.463	81.7	8.01%	309.7	0.463	0.03904	6.864	6.46	1.6848	2.88	9.34	1.20	7.65	4.42	3.23
340.0	0.492	81.4	8.51%	320.0	0.492	0.04147	6.901	6.64	1.6416	2.88	9.52	1.24	7.87	4.56	3.32
350.1	0.521	81.0	9.00%	330.1	0.521	0.04389	6.939	6.81	1.5840	2.88	9.69	1.30	8.10	4.70	3.40
359.3	0.550	80.6	9.50%	339.3	0.550	0.04632	6.977	6.96	1.5264	2.88	9.84	1.35	8.31	4.83	3.48

FOSSIL AND HYDRO GENERATION
 CIVIL AND MINING ENGINEERING DIVISION
 CIVIL LABORATORY SECTION
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767


Company: AEP

Project: SPORN ASH DISP. FACILITY

Sample No: 10918

Point: C

368.6	0.579	80.0	10.01%	348.6	0.579	0.04878	7.016	7.11	1.4400	2.88	9.99	1.44	8.55	4.99	3.55
386.9	0.637	79.0	11.00%	366.9	0.637	0.05365	7.095	7.39	1.2960	2.88	10.27	1.58	8.98	5.28	3.70
403.5	0.695	77.7	12.00%	383.5	0.695	0.05852	7.175	7.64	1.1088	2.88	10.52	1.77	9.41	5.59	3.82
419.6	0.753	76.9	13.01%	399.6	0.753	0.06342	7.258	7.86	0.9936	2.88	10.74	1.89	9.75	5.82	3.93
434.5	0.810	75.6	14.00%	414.5	0.810	0.06828	7.342	8.06	0.8064	2.88	10.94	2.07	10.13	6.10	4.03
448.9	0.869	74.2	15.01%	428.9	0.869	0.07318	7.429	8.24	0.6048	2.88	11.12	2.28	10.52	6.40	4.12
461.8	0.926	73.1	16.01%	441.8	0.926	0.07805	7.518	8.38	0.4464	2.88	11.26	2.43	10.82	6.63	4.19
474.4	0.984	72.2	17.01%	454.4	0.984	0.08293	7.608	8.52	0.3168	2.88	11.40	2.56	11.08	6.82	4.26
486.1	1.042	71.1	18.01%	466.1	1.042	0.08779	7.701	8.63	0.1584	2.88	11.51	2.72	11.35	7.04	4.31
497.3	1.100	70.5	19.01%	477.3	1.100	0.09269	7.796	8.72	0.0720	2.88	11.60	2.81	11.53	7.17	4.36
508.3	1.158	69.3	20.01%	488.3	1.158	0.09756	7.894	8.81	-0.1008	2.88	11.69	2.98	11.79	7.39	4.41



COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● PZ-0903 46.0	LEAN CLAY CL		45.6	24.7	20.9	
	Shelby Tube Sample - 46' - 48'					

Specimen Identification	D100	D60	D30	- D10	%Gravel	%Sand	%Fines	%<.002
● PZ-0903 46.0	2.360	0.008	0.001		0.0	0.9	99.1	32.6

PROJECT SPORN PLANT - FLY ASH POND DIKES - FLY ASH POND DIKES JOB NO. _____ DATE 8/14/09

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, OH 43125



JOB NO. _____
PROJECT SPORN PLANT - FLY ASH POND DIKES
LOCATION: FLY ASH POND DIKES

DATE: Jul 31, 09

SOURCE OF MATERIAL PZ-0903 DEPTH 46.0 ft.
DESCRIPTION OF MATERIAL _____
ASTM DESCRIPTION _____

MAX DRY DENSITY, pcf		OPTIMUM MOISTURE, %	
SPECIFIC GRAVITY	2.70		
SAMPLE HGT., mm	146 740	SAMPLE DIA., mm	71.480
CHAMBER PRESSURE, psi	70.0	BACK PRESSURE, psi	60.0
B-PARAMETER	1.00	EFFECTIVE PRESSURE, psi	10 0
INITIAL HEAD, mm	2369.2		

	<u>BEFORE</u>	<u>AFTER</u>
WATER CONTENT, %	35.4	34.3
WET DENSITY, pcf	117.0	
DRY DENSITY, pcf	86.5	
SATURATION, %	100.51	
VOID RATIO	0.9497	

PERMEABILITY COEFFICIENT K, cm/sec 1.08E-07

FLEXIBLE-MEMBRANE PERMEABILITY TEST

American Electric Power Service Corp.
Groveport, Ohio



CIVIL LABORATORY
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



**Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767**

Company: AEP

Project: SPORN ASH DISP. FACILITY


Sample No: 10922

Material Description: Boring PZ-0903, Shelby Tube - 46' - 48"; Lab # S-10922


Point Designation	Initial Conditions			Final Conditions			
	Water Content, %	Dry Density, pcf	Degree of Saturation	Water Content, %	Confining Stress, (ksf)	Deviator Stress	Induced Pore Pressure (ksf)
A	29.5%	93.1	98.3%	28.43%	0.72	2.03	0.30
B	35.4%	86.4	100.5%	34.3%	1.44	2.69	0.81
C	30.3%	92.3	99.0%	27.3%	2.88	3.77	1.92

Point Designation	Axial Strain, %	q, (ksf)	Effective Stresses, (ksf)			Total Stresses, (ksf)		
			Major, (ksf)	Minor, (ksf)	p', (ksf)	Major, (ksf)	Minor, (ksf)	p, (ksf)
A	15.0%	1.01	2.45	0.42	1.43	2.75	0.72	1.73
B	13.0%	1.35	3.33	0.63	1.98	4.13	1.44	2.79
C	15.0%	1.89	4.74	0.96	2.85	6.65	2.88	4.77

Total Stress Envelope



Effective Stress Envelope



FOSSIL AND HYDRO GENERATION
CIVIL AND MINING ENGINEERING DIVISION
CIVIL LABORATORY SECTION
AMERICAN ELECTRIC POWER SERVICE CORPORATION
4001 BIXBY ROAD
GROVEPORT, OHIO 43125
(614) 836-4200




Test Report for Consolidated-Undrained
Triaxial Compression Test - ASTM D 4767

Company: AEP

Project: SPORN ASH DISP. FACILITY

Sample No: 10922

p' - q Diagram



FOSSIL AND HYDRO GENERATION
CIVIL AND MINING ENGINEERING DIVISION
CIVIL LABORATORY SECTION
AMERICAN ELECTRIC POWER SERVICE CORPORATION
4001 BIXBY ROAD
GROVEPORT, OHIO 43125
(614) 836-4200




Test Report for Consolidated-Undrained
Triaxial Compression Test - ASTM D 4767

Company: AEP

Project: SPORN ASH DISP. FACILITY

Sample No: 10922




FOSSIL AND HYDRO GENERATION
CIVIL AND MINING ENGINEERING DIVISION
CIVIL LABORATORY SECTION
AMERICAN ELECTRIC POWER SERVICE CORPORATION
4001 BIXBY ROAD
GROVEPORT, OHIO 43125
(614) 836-4200



Test Report for Consolidated-Undrained
Triaxial Compression Test - ASTM D 4767

Company: AEP
Project: SPORN ASH DISP. FACILITY
Sample No: 10922



CIVIL LABORATORY
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767

Company: AEP
 Project: SPORN ASH DISP. FACILITY
 Sample No: 10922
 Point: A

Material Description: Boring PZ-0903, Shelby Tube - 46' - 48'; Lab # S-10922

Moisture Determination ASTM D2216	Before Testing	After Testing
	Tare No.	TV
Mass of Container and Wet Specimen (M _{cs}), grams	1333.67	1324.63
Mass of Container and Over Dry Specimen (M _c), grams	1077.83	1077.83
Mass of Container (M _c), grams	209.64	209.64
Mass of Water (M _w), grams:	255.84	246.8
Mass of Solid Particles (M _s), grams:	868.19	868.19
Moisture Content (w), %	29.47%	28.43%

Initial Condition of Specimen ASTM D2435	(1)	(2)	(3)	Average
	Diameter Measurements, Inches:	2.829	2.84	2.817
Height Measurements, Inches:	5.66	5.637	5.655	5.651
Initial Volume of Specimen (V _o), In.³:	35.51			
Dry Mass of Specimen After Testing, (M _d), grams:	868.19			
Dry Unit Weight, (γ _d) pcf:	93.14			
Specific Gravity of the Solids, (G):	2.70			
Volume of Solids, (V _s), Cu. In.:	19.6224			
Height of Solids, (H _s), In.:	3.1225			
Void Ratio Before Consolidation (E _o):	0.8097			
Initial Degree of Saturation: (S _o)	98.27%			

Saturation - ASTM D4767 Section 8.2	
Dial Indicator Reading Prior to Saturation (R _b) In.	0
Cell Pressure After Saturation, psi:	63.00
Back Pressure After Saturation After, psi:	60.00
Pore Pressure Parameter B:	1
Dial Indicator Reading After Saturation, (R _a) In.:	0.021
Change in Height during Saturation, (Delta H _s) In.	0.021
Change in Volume of Specimen during Saturation (Delta V _{sat}), In.³:	0.396

CIVIL LABORATORY
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



**Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767**

Company: AEP
 Project: SPORN ASH DISP. FACILITY
 Sample No: 10922
 Point: A

Consolidation- D2435, Section 11.5:		ASTM		
Sample No:	T:	Burette 2:	Burette 3:	Re:
10922	0	24.1	24	0.021
10922	0.25	23.9	23.8	
10922	0.5	23.9	23.7	
10922	1	23.8	23.7	
10922	2	23.8	23.6	
10922	4	23.6	23.4	
10922	8	23.4	23.2	
10922	15	23.2	22.9	0.027
10922	30	23	22.5	0.028
10922	60	22.6	22.1	0.03
10922	120	22.3	21.6	0.032
10922	240	22.1	21.3	0.034
10922	360	22	21.2	0.036
10922	1440	21.8	21	0.037

Specimen Height After Consolidation, (Hc), In.:

Volume Change During Consolidation (Delta Vc), In.3:

Cross-Sectional Area of Specimen After Consolidation (Ac), In.2:

**Triaxial Compression Testing
 ASTM D 4767**

Sample Depth: ft.

Cell Pressure: psi

Back Pressure: psi

Confining Pressure: psi

Strain Rate: in./min.

Specimen Height After Consolidation, (Hc), In.:

Correction for Vert Displacement, In.:

Load due to Friction and Uplift: lbs.

Correction for Filter Paper:

Thickness of Membrane (tm), In.:

$\sigma_1 - \sigma_3 =$ Deviator Stress at Failure, ksf:

$\sigma_3 f =$ Effective Consolidation Stress at Failure, ksf:

$\sigma_1 =$ Total Major Principal Stress at Failure:

$\sigma_3' = \sigma_3 - \Delta u =$ Effective Minor Principal Stress at Failure, ksf:

$\sigma_1' =$ Effective Major Principal Stress at Failure, ksf:

Axial Strain at Failure:

Failure Sketch

CIVIL LABORATORY
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767

Company: AEP
 Project: SPORN ASH DISP. FACILITY
 Sample No: 10922

Point: A

Pa: Applied Force	Vertical Displacement Reading In. :	Pore Pressure pst:	Axial Strain (EI):	(P) - Force Adj for U and F lbs:	Corrected Vertical Displac In. :	Correction for Membrane ksf:	(A) Area In 2:	($\sigma_1 - \sigma_3$) Deviator Stress ksf:	(Δu) Induced Pore Water Pressure ksf:	σ_3 Effective Consolidation Stress ksf	σ_1 Total Major Principal Stress ksf	σ_3 Effective Minor Principal Stress ksf	σ_1' Effective Major Principal Stress ksf	p'	q
17.4	0.000	62.8	0.00%	0.0	0.000	-0.00002	6.197	0.00	0.4032	0.72	0.72	0.32	0.32	0.32	0.00
31.6	0.003	63.7	0.05%	14.2	0.003	0.00025	6.201	0.33	0.5328	0.72	1.05	0.19	0.52	0.35	0.16
34.7	0.005	64.0	0.10%	17.3	0.005	0.00047	6.203	0.40	0.5760	0.72	1.12	0.14	0.55	0.34	0.20
36.6	0.009	64.1	0.16%	19.2	0.009	0.00077	6.207	0.44	0.5904	0.72	1.16	0.13	0.57	0.35	0.22
38.1	0.011	64.3	0.20%	20.7	0.011	0.00098	6.210	0.48	0.6192	0.72	1.20	0.10	0.58	0.34	0.24
39.3	0.014	64.3	0.25%	21.9	0.014	0.00124	6.213	0.51	0.6192	0.72	1.23	0.10	0.61	0.35	0.25
40.6	0.017	64.5	0.31%	23.2	0.017	0.00153	6.217	0.54	0.6480	0.72	1.26	0.07	0.61	0.34	0.27
41.3	0.019	64.5	0.35%	23.9	0.019	0.00170	6.219	0.55	0.6480	0.72	1.27	0.07	0.62	0.35	0.28
42.4	0.022	64.5	0.40%	25.0	0.022	0.00196	6.222	0.58	0.6480	0.72	1.30	0.07	0.65	0.36	0.29
43.5	0.026	64.5	0.46%	26.1	0.026	0.00224	6.226	0.60	0.6480	0.72	1.32	0.07	0.67	0.37	0.30
44.2	0.028	64.7	0.50%	26.8	0.028	0.00244	6.228	0.62	0.6768	0.72	1.34	0.04	0.66	0.35	0.31
45.3	0.031	64.7	0.56%	27.9	0.031	0.00275	6.232	0.64	0.6768	0.72	1.36	0.04	0.69	0.36	0.32
46.2	0.034	64.7	0.61%	28.8	0.034	0.00302	6.236	0.66	0.6768	0.72	1.38	0.04	0.71	0.37	0.33
46.8	0.036	64.7	0.65%	29.4	0.036	0.00319	6.238	0.68	0.6768	0.72	1.40	0.04	0.72	0.38	0.34
47.5	0.039	64.7	0.69%	30.1	0.039	0.00342	6.241	0.69	0.6768	0.72	1.41	0.04	0.73	0.39	0.35
48.2	0.042	64.9	0.74%	30.8	0.042	0.00366	6.244	0.71	0.7056	0.72	1.43	0.01	0.72	0.37	0.35
49.0	0.045	64.9	0.80%	31.6	0.045	0.00393	6.247	0.72	0.7056	0.72	1.44	0.01	0.74	0.38	0.36
49.7	0.048	64.9	0.85%	32.3	0.048	0.00419	6.251	0.74	0.7056	0.72	1.46	0.01	0.75	0.38	0.37
50.5	0.051	64.9	0.91%	33.1	0.051	0.00447	6.254	0.76	0.7056	0.72	1.48	0.01	0.77	0.39	0.38
50.9	0.054	64.9	0.95%	33.5	0.054	0.00470	6.257	0.77	0.7056	0.72	1.49	0.01	0.78	0.40	0.38
51.6	0.056	64.9	1.00%	34.2	0.056	0.00491	6.260	0.78	0.7056	0.72	1.50	0.01	0.80	0.41	0.39
57.4	0.084	64.9	1.50%	40.0	0.084	0.00738	6.292	0.91	0.7056	0.72	1.63	0.01	0.92	0.47	0.45
62.1	0.112	64.9	2.00%	44.7	0.112	0.00982	6.324	1.01	0.7056	0.72	1.73	0.01	1.02	0.52	0.50
67.2	0.140	64.9	2.49%	49.8	0.140	0.01227	6.356	1.12	0.7056	0.72	1.84	0.01	1.13	0.57	0.56
72.0	0.168	64.8	3.00%	54.6	0.168	0.01475	6.389	1.22	0.6912	0.72	1.94	0.03	1.24	0.64	0.61
76.2	0.196	64.6	3.50%	58.8	0.196	0.01722	6.422	1.30	0.6624	0.72	2.02	0.06	1.36	0.71	0.65
80.1	0.224	64.5	4.00%	62.7	0.224	0.01967	6.456	1.38	0.6480	0.72	2.10	0.07	1.45	0.76	0.69
83.7	0.253	64.3	4.50%	66.3	0.253	0.02214	6.490	1.45	0.6192	0.72	2.17	0.10	1.55	0.83	0.72
87.0	0.280	64.2	4.99%	69.6	0.280	0.02458	6.523	1.51	0.6048	0.72	2.23	0.12	1.63	0.87	0.76
89.8	0.308	64.0	5.49%	72.4	0.308	0.02704	6.558	1.56	0.5760	0.72	2.28	0.14	1.71	0.93	0.78
92.1	0.336	63.9	5.99%	74.7	0.336	0.02949	6.593	1.60	0.5616	0.72	2.32	0.16	1.76	0.96	0.80
94.4	0.365	63.8	6.49%	77.0	0.365	0.03196	6.628	1.64	0.5472	0.72	2.36	0.17	1.81	0.99	0.82
96.9	0.393	63.7	7.00%	79.5	0.393	0.03443	6.664	1.68	0.5328	0.72	2.40	0.19	1.87	1.03	0.84
99.1	0.421	63.6	7.49%	81.7	0.421	0.03687	6.699	1.72	0.5184	0.72	2.44	0.20	1.92	1.06	0.86
101.3	0.449	63.5	7.99%	83.9	0.449	0.03933	6.736	1.75	0.5040	0.72	2.47	0.22	1.97	1.09	0.88
103.5	0.477	63.4	8.49%	86.1	0.477	0.04178	6.773	1.79	0.4896	0.72	2.51	0.23	2.02	1.12	0.89
105.9	0.505	63.3	8.99%	88.5	0.505	0.04425	6.810	1.83	0.4752	0.72	2.55	0.24	2.07	1.16	0.91
107.8	0.533	63.2	9.49%	90.4	0.533	0.04671	6.847	1.85	0.4608	0.72	2.57	0.26	2.11	1.19	0.93

CIVIL LABORATORY
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767

Company: AEP

Project: SPORN ASH DISP. FACILITY

Sample No: 10922

Point: A

109.6	0.561	63.1	9.99%	92.2	0.561	0.04918	6.886	1.88	0.4464	0.72	2.60	0.27	2.15	1.21	0.94
113.3	0.617	62.9	10.99%	95.9	0.617	0.05411	6.963	1.93	0.4176	0.72	2.65	0.30	2.23	1.27	0.96
116.1	0.673	62.7	11.99%	98.7	0.673	0.05900	7.042	1.96	0.3888	0.72	2.68	0.33	2.29	1.31	0.98
119.2	0.729	62.5	12.99%	101.8	0.729	0.06394	7.123	1.99	0.3600	0.72	2.71	0.36	2.35	1.36	1.00
121.6	0.785	62.3	13.99%	104.2	0.785	0.06885	7.206	2.01	0.3312	0.72	2.73	0.39	2.40	1.40	1.01
123.9	0.841	62.1	14.99%	106.5	0.841	0.07376	7.290	2.03	0.3024	0.72	2.75	0.42	2.45	1.43	1.01
126.0	0.897	61.8	15.99%	108.6	0.897	0.07867	7.377	2.04	0.2592	0.72	2.76	0.46	2.50	1.48	1.02
127.2	0.954	61.7	16.99%	109.8	0.954	0.08361	7.466	2.03	0.2448	0.72	2.75	0.48	2.51	1.49	1.02
129.3	1.010	61.5	17.98%	111.9	1.010	0.08851	7.557	2.04	0.2160	0.72	2.76	0.50	2.55	1.53	1.02
130.0	1.066	61.3	18.99%	112.6	1.066	0.09343	7.650	2.03	0.1872	0.72	2.75	0.53	2.56	1.55	1.01
131.6	1.122	61.1	19.98%	114.2	1.122	0.09834	7.745	2.02	0.1584	0.72	2.74	0.56	2.59	1.57	1.01

CIVIL LABORATORY
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767

Company: AEP
 Project: SPORN ASH DISP. FACILITY
 Sample No: 10922
 Point: B

Material Description:		Boring PZ-0903. Shelby Tube - 46' - 48'; Lab # S-10922	
Moisture Determination ASTM D2216		Before Testing	After Testing
Tare No.	Q	Q	
Mass of Container and Wet Specimen (Mcws), grams	1309.98	1301.68	
Mass of Container and Over Dry Specimen (Mcs), grams	1021.69	1021.69	
Mass of Container (Mc), grams	206.24	206.24	
Mass of Water (Mw), grams:	288.29	279.99	
Mass of Solid Particles (Ms), grams:	815.45	815.45	
Moisture Content (w), %	35.35%	34.34%	
Initial Condition of Speciman ASTM D2435		(1)	(2)
Diameter Measurements, Inches:	2.826	2.812	2.805
Height Measurements, Inches:	5.775	5.776	5.779
Initial Volume of Specimen (Vo), In.3:	35.94		
Dry Mass of Specimen After Testing, (Md), grams:	815.45		
Dry Unit Weight, (γ _d) pcf:	86.45		
Specific Gravity of the Solids, (G):	2.70		
Volume of Solids, (Vs), Cu. In.:	18.4304		
Height of Solids, (Hs), In.:	2.9627		
Void Ratio Before Consolidation (Eo):	0.9498		
Initial Degree of Saturation: (So)	100.60%		
Saturation - ASTM D4767 Section 8.2			
Dial Indicator Reading Prior to Saturation (Rb) In.	0		
Cell Pressure After Saturation, psi:	65.00		
Back Pressure After Saturation After, psi:	60.00		
Pore Pressure Parameter B:	1		
Dial Indicator Reading After Saturation, (Ra) In.:	0.03		
Change in Height during Saturation, (Delta Hs) In.	0.03		
Change In Volume of Specimen during Saturation (Delta Vsat), In.3:	0.560		

CIVIL LABORATORY
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



**Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767**

Company: **AEP**
 Project: **SPORN ASH DISP. FACILITY**
 Sample No: **10922**
 Point: **B**

Consolidation- ASTM D2435, Section 11.5:				
Sample No:	T:	Burette 2:	Burette 3:	Rc:
10922	0	23.9	23.7	0.03
10922	0.25	23.8	23.5	
10922	0.5	23.7	23.5	
10922	1	23.7	23.5	
10922	2	23.7	23.4	
10922	4	23.6	23.3	
10922	8	23.5	23.2	
10922	15	23.4	23.1	0.036
10922	30	23.1	22.9	0.036
10922	60	22.8	22.5	0.039
10922	120	22.5	22.2	0.042
10922	240	22.1	21.8	0.042
10922	360	21.9	21.6	0.046
10922	1440	21.6	21.3	0.048

Specimen Height After Consolidation, (Hc), In.: **5.73**

Volume Change During Consolidation (Delta Vc), In 3: **0.29**

Cross-Sectional Area of Specimen After Consolidation (Ac), In. 2: **6.13**

**Triaxial Compression Testing
 ASTM D 4767**

Sample Depth: **46** ft. Specimen Height After Consolidation, (Hc), in.: **5.73**

Cell Pressure: **70** psi Correction for Vert Displacement, In.: **0**

Back Pressure: **60** psi Load due to Friction and Uplift: **17.9** lbs.

Confining Pressure: **10** psi Correction for Filter Paper: **0**

Strain Rate: **0.006** In./min. Thickness of Membrane (tm), In.: **0.012**

$\sigma_1 - \sigma_3 =$ Deviator Stress at Failure, ksf: **2.69**

$\sigma_3 f =$ Effective Consolidation Stress at Failure, ksf: **1.44**

$\sigma_1 =$ Total Major Principal Stress at Failure: **4.13**

$\sigma_3 f = \sigma_3 - \Delta v =$ Effective Minor Principal Stress at Failure, ksf: **0.63**

$\sigma_1 f =$ Effective Major Principal Stress at Failure, ksf: **3.33**

Axial Strain at Failure: **13.02%**

Failure Sketch

CIVIL LABORATORY
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767

Company: AEP

Project: SPORN ASH DISP. FACILITY

Sample No: 10922

Point: B

Pa: Applied Force	Vertical Displacement Reading In. :	Pore Pressure psi:	Axial Strain (E1):	(F) - Force Adj for U and F lbs:	Corrected Vertical Displacement In. :	Correction for Membrane ksf:	(A) Area In 2:	($\sigma_1 - \sigma_3$) Deviator Stress ksf:	[Δu] Induced Pore Water Pressure ksf:	σ_3 Effective Consolidation Stress ksf	σ_1 Total Major Principal Stress ksf	σ_3 Effective Minor Principal Stress ksf	σ_1' Effective Major Principal Stress ksf	p'	q
17.9	0.000	63.3	0.00%	0.0	0.000	0.00000	6.125	0.00	0.4752	1.44	1.44	0.96	0.96	0.96	0.00
57.6	0.020	66.9	0.35%	39.7	0.020	0.00173	6.147	0.93	0.9936	1.44	2.37	0.45	1.37	0.91	0.46
151.0	0.686	65.7	11.97%	133.1	0.686	0.05928	6.958	2.70	0.8208	1.44	4.14	0.62	3.31	1.97	1.35
152.8	0.744	65.6	12.99%	134.9	0.744	0.06429	7.039	2.70	0.8064	1.44	4.14	0.63	3.33	1.98	1.35
152.8	0.746	65.6	13.02%	134.9	0.746	0.06446	7.042	2.69	0.8064	1.44	4.13	0.63	3.33	1.98	1.35
154.4	0.803	65.4	14.02%	136.5	0.803	0.06942	7.124	2.69	0.7776	1.44	4.13	0.66	3.35	2.01	1.34
155.5	0.861	65.0	15.03%	137.6	0.861	0.07438	7.208	2.67	0.7200	1.44	4.11	0.72	3.39	2.06	1.34
156.8	0.918	64.8	16.03%	138.9	0.918	0.07934	7.294	2.66	0.6912	1.44	4.10	0.75	3.41	2.08	1.33
157.8	0.976	64.7	17.03%	139.9	0.976	0.08432	7.383	2.64	0.6768	1.44	4.08	0.76	3.41	2.09	1.32
158.6	1.033	64.6	18.03%	140.7	1.033	0.08926	7.472	2.62	0.6624	1.44	4.06	0.78	3.40	2.09	1.31

FOSSIL AND HYDRO GENERATION
 CIVIL AND MINING ENGINEERING DIVISION
 CIVIL LABORATORY SECTION
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767

Company: AEP
 Project: SPORN ASH DISP. FACILITY
 Sample No: 10922
 Point: C

Material Description:		Boring PZ-0903, Shelby Tube - 46' - 48'; Lab # S-10922			
Moisture Determination ASTM D2216		Before Testing	After Testing		
	Tare No.	Y	Y		
	Mass of Container and Wet Specimen (M _{cw}), grams	1361.13	1334.81		
	Mass of Container and Over Dry Specimen (M _c), grams	1093.60	1093.60		
	Mass of Container (M _c), grams	210.21	210.21		
	Mass of Water (M _w), grams:	267.53	241.21		
	Mass of Solid Particles (M _s), grams:	883.39	883.39		
	Moisture Content (w), %	30.28%	27.31%		
Initial Condition of Specimen ASTM D2435		(1)	(2)	(3)	Average
	Diameter Measurements, Inches:	2.807	2.825	2.827	2.820
	Height Measurements, Inches:	5.841	5.841	5.835	5.839
	Initial Volume of Specimen (V _o), In.3:	36.46			
	Dry Mass of Specimen After Testing, (M _d), grams:	883.39			
	Dry Unit Weight, (γ _d) pcf:	92.30			
	Specific Gravity of the Solids, (G):	2.70			
	Volume of Solids, (V _s), Cu. In.:	19.9659			
	Height of Solids, (H _s), In.:	3.1974			
	Void Ratio Before Consolidation (E _o):	0.8261			
	Initial Degree of Saturation: (S _o)	98.98%			
Saturation - ASTM D4767 Section 8.2					
	Dial Indicator Reading Prior to Saturation (R _b), In.	0			
	Cell Pressure After Saturation, psi:	65.00			
	Back Pressure After Saturation, psi:	60.00			
	Pore Pressure Parameter B:	1			
	Dial Indicator Reading After Saturation, (R _a) In.:	0.031			
	Change in Height during Saturation, (ΔH _s) In.	0.031			
	Change in Volume of Specimen during Saturation (ΔV _{sat}), In.3:	0.581			

FOSSIL AND HYDRO GENERATION
 CIVIL AND MINING ENGINEERING DIVISION
 CIVIL LABORATORY SECTION
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767

Company: AEP
 Project: SPORN ASH DISP. FACILITY
 Sample No: 10922
 Point: C

Consolidation- D2435, Section 11.5:		ASTM		
Sample No:	T:	Burette 2:	Burette 3:	Re:
10922	0	23.4	23.8	0.031
10922	0.25	23.1	23.5	
10922	0.5	23	23.5	
10922	1	22.9	23.4	
10922	2	22.8	23.3	
10922	4	22.5	23.1	
10922	8	22.2	22.7	
10922	15	21.8	22.3	0.046
10922	30	21.1	21.6	0.051
10922	60	19.9	20.5	0.058
10922	120	18.2	19.1	0.068
10922	240	16.2	17.4	0.08
10922	360	15	16.4	0.086
10922	1440	13.1	14.7	0.098

Specimen Height After Consolidation, (Hc), In.: 5.74

Volume Change During Consolidation (Delta Vc), In.3: 1.18

Cross-Sectional Area of Specimen After Consolidation (Ac), In.2: 6.04

Triaxial Compression Testing
 ASTM D 4767

Sample Depth: 46 ft.
 Cell Pressure: 80 psi
 Back Pressure: 60 psi
 Confining Pressure: 20 psi
 Strain Rate: 0.006 In/min.

Specimen Height After Consolidation, (Hc), In.: 5.74
 Correction for Vert Displacement, In.: 0
 Load due to Friction and Uplift: 22.5 lbs.
 Correction for Filter Paper: 0
 Thickness of Membrane (tm), In.: 0.012

$\sigma_1 - \sigma_3 =$ Deviator Stress at Failure, ksf: 3.77
 $\sigma_3 f =$ Effective Consolidation Stress at Failure, ksf: 2.88
 $\sigma_1 =$ Total Major Principal Stress at Failure: 6.65
 $\sigma_3 f = \sigma_3 - \Delta u =$ Effective Minor Principal Stress at Failure, ksf: 0.96
 $\sigma_1 f =$ Effective Major Principal Stress at Failure, ksf: 4.74
 Axial Strain at Failure: 15.00%

Failure Sketch

FOSSIL AND HYDRO GENERATION
 CIVIL AND MINING ENGINEERING DIVISION
 CIVIL LABORATORY SECTION
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767

Company: AEP

Project: SPORN ASH DISP. FACILITY

Sample No: 10922

Point: C

Pa: Applied Force	Vertical Displacement Reading In. :	Pore Pressure psit	Axial Strain (E):	(P)- Force Adj for U and F lbs:	Corrected Vertical Displace In. :	Correction for Membrane ksf:	(A) Area In. 2:	($\sigma_1 - \sigma_3$) Deviator Stress ksf:	(Au) Induced Pore Water Pressure ksf:	σ_3 Effective Consolidation Stress ksf	σ_1 Total Major Principal Stress ksf	σ_3 Effective Minor Principal Stress ksf	σ_1' Effective Major Principal Stress ksf	p'	q
22.5	0.000	62.7	0.00%	0.0	0.000	0.00002	6.044	0.00	0.3888	2.88	2.88	2.49	2.49	2.49	0.00
51.7	0.003	65.1	0.05%	29.2	0.003	0.00024	6.046	0.70	0.7344	2.88	3.58	2.15	2.84	2.49	0.35
61.2	0.006	66.7	0.10%	38.7	0.006	0.00049	6.049	0.92	0.9648	2.88	3.80	1.92	2.84	2.38	0.46
69.8	0.009	68.2	0.16%	47.3	0.009	0.00080	6.053	1.12	1.1808	2.88	4.00	1.70	2.82	2.26	0.56
73.4	0.011	68.7	0.20%	50.9	0.011	0.00099	6.056	1.21	1.2528	2.88	4.09	1.63	2.84	2.23	0.60
77.2	0.014	69.1	0.25%	54.7	0.014	0.00123	6.059	1.30	1.3104	2.88	4.18	1.57	2.87	2.22	0.65
81.0	0.018	69.7	0.31%	58.5	0.018	0.00155	6.062	1.39	1.3968	2.88	4.27	1.48	2.87	2.18	0.69
82.8	0.020	70.9	0.35%	60.3	0.020	0.00174	6.065	1.43	1.5696	2.88	4.31	1.31	2.74	2.03	0.72
85.3	0.023	70.9	0.40%	62.8	0.023	0.00198	6.068	1.49	1.5696	2.88	4.37	1.31	2.80	2.05	0.74
88.5	0.026	71.0	0.46%	66.0	0.026	0.00229	6.071	1.56	1.5840	2.88	4.44	1.30	2.86	2.08	0.78
90.0	0.029	71.0	0.50%	67.5	0.029	0.00250	6.074	1.60	1.5840	2.88	4.48	1.30	2.89	2.09	0.80
92.1	0.032	72.3	0.56%	69.6	0.032	0.00280	6.078	1.65	1.7712	2.88	4.53	1.11	2.76	1.93	0.82
93.4	0.035	72.7	0.61%	70.9	0.035	0.00302	6.080	1.68	1.8288	2.88	4.56	1.05	2.73	1.89	0.84
94.7	0.037	72.5	0.65%	72.2	0.037	0.00325	6.083	1.71	1.8000	2.88	4.59	1.08	2.79	1.93	0.85
96.7	0.040	72.6	0.70%	74.2	0.040	0.00349	6.086	1.75	1.8144	2.88	4.63	1.07	2.82	1.94	0.88
97.2	0.043	72.6	0.75%	74.7	0.043	0.00372	6.089	1.76	1.8144	2.88	4.64	1.07	2.83	1.95	0.88
98.8	0.046	72.8	0.80%	76.3	0.046	0.00399	6.092	1.80	1.8432	2.88	4.68	1.04	2.84	1.94	0.90
99.9	0.049	73.3	0.85%	77.4	0.049	0.00422	6.095	1.82	1.9152	2.88	4.70	0.96	2.79	1.88	0.91
101.1	0.052	73.4	0.91%	78.6	0.052	0.00451	6.099	1.85	1.9296	2.88	4.73	0.95	2.80	1.88	0.93
102.3	0.055	73.6	0.96%	79.8	0.055	0.00481	6.102	1.88	1.9584	2.88	4.76	0.92	2.80	1.86	0.94
103.2	0.057	73.7	1.00%	80.7	0.057	0.00498	6.105	1.90	1.9728	2.88	4.78	0.91	2.81	1.86	0.95
112.7	0.086	74.9	1.50%	90.2	0.086	0.00748	6.136	2.11	2.1456	2.88	4.99	0.73	2.84	1.79	1.05
120.7	0.115	75.8	2.00%	98.2	0.115	0.00997	6.167	2.28	2.2752	2.88	5.16	0.60	2.89	1.75	1.14
127.6	0.143	76.9	2.50%	105.1	0.143	0.01245	6.198	2.43	2.4336	2.88	5.31	0.45	2.88	1.66	1.21
134.1	0.172	76.7	3.00%	111.6	0.172	0.01493	6.230	2.56	2.4048	2.88	5.44	0.48	3.04	1.76	1.28
140.6	0.201	76.9	3.50%	118.1	0.201	0.01743	6.263	2.70	2.4336	2.88	5.58	0.45	3.14	1.80	1.35
146.7	0.229	77.0	4.00%	124.2	0.229	0.01991	6.295	2.82	2.4480	2.88	5.70	0.43	3.25	1.84	1.41
152.0	0.258	77.2	4.50%	129.5	0.258	0.02241	6.328	2.92	2.4768	2.88	5.80	0.40	3.33	1.87	1.46
156.2	0.287	77.1	5.00%	133.7	0.287	0.02490	6.361	3.00	2.4624	2.88	5.88	0.42	3.42	1.92	1.50
161.1	0.316	77.0	5.50%	138.6	0.316	0.02741	6.395	3.09	2.4480	2.88	5.97	0.43	3.53	1.98	1.55
166.0	0.344	77.0	6.00%	143.5	0.344	0.02990	6.429	3.18	2.4480	2.88	6.06	0.43	3.62	2.02	1.59
170.7	0.373	76.8	6.50%	148.2	0.373	0.03240	6.464	3.27	2.4192	2.88	6.15	0.46	3.73	2.10	1.63
174.4	0.402	76.9	7.00%	151.9	0.402	0.03486	6.498	3.33	2.4336	2.88	6.21	0.45	3.78	2.11	1.67
178.1	0.430	76.5	7.50%	155.6	0.430	0.03736	6.533	3.39	2.3760	2.88	6.27	0.50	3.90	2.20	1.70
181.6	0.459	76.4	8.00%	159.1	0.459	0.03984	6.569	3.45	2.3616	2.88	6.33	0.52	3.97	2.24	1.72
184.9	0.488	76.2	8.50%	162.4	0.488	0.04236	6.605	3.50	2.3328	2.88	6.38	0.55	4.05	2.30	1.75
188.0	0.517	75.8	9.00%	165.5	0.517	0.04484	6.641	3.54	2.2752	2.88	6.42	0.60	4.15	2.38	1.77
190.7	0.545	75.6	9.50%	168.2	0.545	0.04733	6.678	3.58	2.2464	2.88	6.46	0.63	4.21	2.42	1.79

FOSSIL AND HYDRO GENERATION
 CIVIL AND MINING ENGINEERING DIVISION
 CIVIL LABORATORY SECTION
 AMERICAN ELECTRIC POWER SERVICE CORPORATION
 4001 BIXBY ROAD
 GROVEPORT, OHIO 43125
 (614) 836-4200



Test Report for Consolidated-Undrained
 Triaxial Compression Test - ASTM D 4767


Company: AEP

Project: SPORN ASH DISP. FACILITY

Sample No: 10922

Point: C

193.5	0.574	75.3	10.00%	171.0	0.574	0.04983	6.715	3.62	2.2032	2.88	6.50	0.68	4.29	2.49	1.81
197.7	0.632	74.7	11.00%	175.2	0.632	0.05483	6.791	3.66	2.1168	2.88	6.54	0.76	4.42	2.59	1.83
202.2	0.689	74.6	11.99%	179.7	0.689	0.05977	6.867	3.71	2.1024	2.88	6.59	0.78	4.49	2.63	1.85
206.2	0.746	74.3	13.00%	183.7	0.746	0.06477	6.946	3.74	2.0592	2.88	6.62	0.82	4.56	2.69	1.87
209.6	0.803	74.0	13.99%	187.1	0.803	0.06974	7.027	3.76	2.0160	2.88	6.64	0.86	4.63	2.75	1.88
212.5	0.861	73.3	15.00%	190.0	0.861	0.07476	7.110	3.77	1.9152	2.88	6.65	0.96	4.74	2.85	1.89
215.0	0.919	73.0	16.00%	192.5	0.919	0.07974	7.195	3.77	1.8720	2.88	6.65	1.01	4.78	2.89	1.89
217.0	0.976	72.5	16.99%	194.5	0.976	0.08469	7.281	3.76	1.8000	2.88	6.64	1.08	4.84	2.96	1.88
218.3	1.033	71.7	18.00%	195.8	1.033	0.08969	7.370	3.74	1.6848	2.88	6.62	1.20	4.93	3.06	1.87
220.1	1.090	71.0	18.99%	197.6	1.090	0.09465	7.461	3.72	1.5840	2.88	6.60	1.30	5.02	3.16	1.86
221.5	1.148	70.7	20.00%	199.0	1.148	0.09965	7.554	3.69	1.5408	2.88	6.57	1.34	5.03	3.19	1.85




COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

Specimen Identification	Classification					MC%	LL	PL	PI	Sp.Gr.
● PZ-0905 11.0	SILTY SAND with GRAVEL SM						NP	NP	NP	
	Ash Mixture - Samples 5,6,7,8 Combined									
Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	%<.002		
● PZ-0905 11.0	19.000	0.836	0.130		19.6	61.2	19.2			

PROJECT **SPORN PLANT - FLY ASH POND DIKES - FLY ASH POND DIKES** JOB NO. _____ DATE **8/14/09**

GRADATION CURVES
 American Electric Power Service Corp.
 Groveport, OH 43125





COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

Specimen Identification	Classification	MC%	LL	PL	PI	Sp.Gr.
● PZ-0905 38.0	LEAN CLAY CL Shelby Tube Sample - 38' - 40'	25.3	31.2	19.1	12.0	

Specimen Identification	D100	D60	D30	D10	%Gravel	%Sand	%Fines	%<.002
● PZ-0905 38.0	4.750	0.020	0.004		0.0	6.5	93.5	22.6

PROJECT **SPORN PLANT - FLY ASH POND DIKES - FLY ASH POND DIKES** JOB NO. _____ DATE 8/14/09

GRADATION CURVES
American Electric Power Service Corp.
Groveport, OH 43125



**LABORATORY DATA DEVELOPED BY:
GEO/ENVIRONMENTAL ASSOCIATES, INC.**

DATED: DECEMBER 2009 & JANUARY 2010

SUMMARY OF LABORATORY TEST RESULTS

Boring	Sample No.	Sample Type*	Depth (ft)	Natural Moisture (%)	Dry Density (pcf)	ATTERBERG LIMITS		USCS	Other Test **	Soil Description
						Liquid Limit (%)	Plasticity Index (%)			
GA-1A	ST-1	ST	26.5-27.2	26.8	80.6	--	--	SM	S	Ash mix, clay, sandy, dark brown & light brown
GA-1A	ST-2	ST	28.5-31.0	53.3	61.3	46	np	ML	S	Fly Ash, gray
GA-1A	ST-3	ST	32.5-35.0	58.5	61.0	--	--	ML	S	Fly Ash, dark gray, dark brown
GA-1A	ST-4	ST	36.5-39.0	33.0	--	--	--	ML	S	Fly Ash, dark gray
GA-1A	ST-5	ST	40.5-43.0	46.6	69.3	37	np	ML	S	Fly Ash, dark gray, dark brown
GA-1A	ST-6	ST	44.5-47.0	44.6	71.9	44	np	ML	S,T	Fly Ash, dark gray
GA-1A	ST-7	ST	48.5-51.0	37.2	--	--	--	ML	S	Fly Ash, dark gray
GA-1A	ST-8	ST	52.5-55.0	53.3	65.7	44	np	ML	S	Fly Ash, gray
GA-1A	ST-9	ST	56.5-59.0	51.5	66.5	45	np	ML	S	Fly Ash, dark gray

Project: Philip Sporn Plant
 Project Number: 09-387
 Date: January 2010

Geo/Environmental Associates

DATA CHECKED BY _____

*ST-SHELBY TUBE SAMPLE, SS-SPLIT SPOON SAMPLE, B-BAG SAMPLE, J-JAR SAMPLE

**TEST RESULTS REPORTED ON OTHER SHEETS:

- T-TRIAXIAL
- S-SIEVE OR GRAIN SIZE ANALYSIS
- U-UNCONFINED COMPRESSION
- P-PROCTOR TEST
- K-PERMEABILITY
- C-CONSOLIDATION

SUMMARY OF LABORATORY TEST RESULTS

Page 2 of 2

Boring	Sample No.	Sample Type*	Depth (ft)	Natural Moisture (%)	Dry Density (pcf)	ATTERBERG LIMITS		USCS	Other Test **	Soil Description
						Liquid Limit (%)	Plasticity Index (%)			
GA-1A	ST-10	ST	60.5-63.0	53.7	63.5	44	np	ML	S	Fly Ash, dark gray, dark brown
GA-1C	ST-2	ST	69.0-71.5	28.2	95.1	35	16	CL	S, I	Clay, silty, brown
GA-2	ST-2	ST	59.0-61.5	20.3	--	20	4	CL/ML	S	Clay, silty, brown
GA-2	ST-3	ST	69.0-71.5	20.8	--	23	6	CL/ML	S	Clay, silty, light brown
GA-3	ST-3	ST	79.0-81.5	24.4	--	32	12	CL	S	Clay, silty, light brown
GA-4A	ST-1	ST	28.0-30.5	73.4	51.7	--	--	ML	S	Fly Ash, dark gray
GA-4A	ST-2	ST	32.0-34.5	57.2	59.2	--	--	ML	S	Fly Ash, dark gray
GA-4A	ST-3	ST	36.0-38.0	33.8	--	32	10	CL	S	Clay, silty, light brown w/fly ash
GA-4B	ST-1	ST	29.0-31.5	56.3	61.7	--	--	ML	S	Fly Ash, dark gray

*ST-SHELBY TUBE SAMPLE, SS-SPLIT SPOON SAMPLE, B-BAG SAMPLE, J-JAR SAMPLE

**TEST RESULTS REPORTED ON OTHER SHEETS:

T-TRIAXIAL
 S-SIEVE OR GRAIN SIZE ANALYSIS
 U-UNCONFINED COMPRESSION
 P-PROCTOR TEST
 K-PERMEABILITY
 C-CONSOLIDATION

**Geo/Environmental
 Associates**

DATA CHECKED BY _____

Void Ratio Work Sheet

Project : Philip Sporn Plant

Project No. : 09-387

Samples : Boring Ga-1A

Boring Sample No. Depth	GA-1A ST-1 26.5-27.2	GA-1A ST-2 28.5-31.0	GA-1A ST-3 32.5-35.0	GA-1A ST-4 36.5-39.0	GA-1A ST-5 40.5-43.0	GA-1A ST-6 44.5-47.0	GA-1A ST-7 48.5-51.0	GA-1A ST-8 52.8-55.0	GA-1A ST-9 56.5-59.0	GA-1A ST-10 60.5-63.0
Moist(+1)	1.268	1.533	1.585	1.33	1.466	1.446	1.372	1.533	1.515	1.537
Wet Density	102.2	94.0	96.6	113.0	101.7	104.0	106.2	100.7	100.7	97.6
Dry Density	80.6	61.3	61.0	85.0	69.3	71.9	77.4	65.7	66.5	63.5
Wet wt	1.413	2.090	2.601	1.433	2.963	2.101	1.482	3.118	2.206	3.107
Dry wt	1.114	1.363	1.641	1.077	2.021	1.453	1.080	2.034	1.456	2.021
Water wt	0.299	0.727	0.960	0.356	0.942	0.648	0.402	1.084	0.750	1.086
Volume	0.0138	0.0222	0.0269	0.0127	0.0291	0.0202	0.0140	0.0310	0.0219	0.0318
Spec. Grav.	2.36	2.21	2.32	2.49	2.36	2.43	2.43	2.44	2.40	2.30
Vol. Solids	0.0076	0.0099	0.0113	0.0069	0.0137	0.0096	0.0071	0.0134	0.0097	0.0141
Vol. Water	0.0048	0.0116	0.0154	0.0057	0.0151	0.0104	0.0064	0.0174	0.0120	0.0174
Vol. Air	0.0014	0.0007	0.0002	0.0001	0.0003	0.0002	0.0004	0.0003	0.0002	0.0003
Porosity	0.4517	0.5547	0.5786	0.4540	0.5284	0.5256	0.4912	0.5691	0.5560	0.5571
Void Ratio	0.8237	1.2456	1.3731	0.8314	1.1203	1.1081	0.9653	1.3206	1.2524	1.2577

Void Ratio Work Sheet

Project : Philip Sporn Plant

Project No. : 09-387

Samples : Borings GA-1C, GA-4A & GA-4B

Boring Sample No. Depth	GA-1C ST-2 69.0-71.5	GA-4A ST-1 28.0-30.5	GA-4A ST-2 32.0-34.5	GA-4B ST-1 29.0-31.5
Moist(+1)	1.282	1.734	1.572	1.563
Wet Density	121.9	89.6	93.0	96.5
Dry Density	95.1	51.7	59.2	61.7
Wet wt	2.684	1.995	1.722	1.382
Dry wt	2.094	1.151	1.095	0.884
Water wt	0.590	0.844	0.627	0.498
Volume	0.0220	0.0223	0.0185	0.0143
Spec. Grav.	2.71	2.25	2.29	2.31
Vol. Solids	0.0124	0.0082	0.0077	0.0061
Vol. Water	0.0095	0.0135	0.0100	0.0080
Vol. Air	0.0002	0.0006	0.0008	0.0002
Porosity	0.4372	0.6325	0.5856	0.5710
Void Ratio	0.7770	1.7213	1.4133	1.3312

DENSITY CALCULATIONS

Project : Philip Sporn Plant

Date : January 07, 2010

Project No. : 09-387

Boring	Sample No.	Ht	Dia	Wt(gm)	Wt(lbs)	Moisture Data (w/tare)				Area	Volume	Wet Density	Dry Density
						wet wt	dry wt	tare wt	Moist				
GA-1A	ST-1	3.77	2.84	640.9	1.413	878.4	718.8	123.2	26.8	0.0440	0.0138	102.2	80.6
GA-1A	ST-2	5.98	2.86	947.8	2.090	833.5	584.7	117.9	53.3	0.0446	0.0222	94.0	61.3
GA-1A	ST-3	7.19	2.87	1180	2.601	606.9	426.1	117.1	58.5	0.0449	0.0269	96.6	61.0
GA-1A	ST-4	3.46	2.84	650	1.433	1035.2	844.6	266.6	33.0	0.0440	0.0127	113.0	85.0
GA-1A	ST-5	7.78	2.87	1343.8	2.963	748.1	548.7	123.1	46.9	0.0449	0.0291	101.7	69.3
GA-1A	ST-6	5.55	2.83	952.9	2.101	952.9	659.0	0.0	44.6	0.0437	0.0202	104.0	71.9
GA-1A	ST-7	3.78	2.85	672.3	1.482	954.8	768.6	267.7	37.2	0.0443	0.0140	106.2	77.4
GA-1A	ST-8	8.33	2.86	1414.2	3.118	889.8	621.5	118.2	53.3	0.0446	0.0310	100.7	65.7
GA-1A	ST-9	6.02	2.83	1000.6	2.206	895.3	632.6	122.1	51.5	0.0437	0.0219	100.7	66.5
GA-1A	ST-10	8.56	2.86	1409.3	3.107	663.1	474.3	122.4	53.7	0.0446	0.0318	97.6	63.5
GA-1C	ST-2	5.88	2.87	1217.6	2.684	1217.6	950.1	0.0	28.2	0.0449	0.0220	121.9	95.1
GA-4A	ST-1	5.99	2.86	904.9	1.995	811.4	579.5	263.7	73.4	0.0446	0.0223	89.6	51.7
GA-4A	ST-2	4.98	2.86	780.9	1.722	762.3	579.4	259.5	57.2	0.0446	0.0185	93.0	59.2
GA-4B	ST-1	3.88	2.85	626.7	1.382	587.8	418.2	117.0	56.3	0.0443	0.0143	96.5	61.7

Fly Ash Pond East Dike - Section K-K										
Sample	ST-2	ST-3	ST-4	ST-5	ST-6	ST-7	ST-8	ST-9	ST-10	
Sample Depth (ft)	28.5-31.0	32.5-35.0	36.5-39.0	40.5-43.0	44.5-47.0	48.5-51.0	52.5-55.0	56.5-59.0	60.5-63.0	
Tube Weight (g)	2672	2658	2676	2673	2675	2657	2683	2671	2508	
Tube & Sample Weight (g)	7826	8022	8234	8080	8065	7930	7975	7820	8186	
Sample Weight (g)	5154	5364	5558	5407	5390	5273	5292	5149	5678	
Sample Weight (lbs)	11.36	11.83	12.25	11.92	11.88	11.62	11.67	11.35	12.52	
Recovery Length (ft)	2.66	2.5	2.6	2.55	2.55	2.41	2.55	2.37	2.49	
Sample Volume (ft ³)	0.120	0.113	0.117	0.115	0.115	0.109	0.115	0.107	0.112	
Density (lbs/ft ³)	94.8	104.9	104.5	103.7	103.4	107.0	101.5	106.2	111.5	
Moist Sample Weight (g)	103.54	79.83	100.6	84.72	85.84	84.61	90.97	91.42	90.5	
Dry Sample Weight (g)	75.49	53.78	66.03	58.14	52.71	51.65	59.67	54.03	72.94	
Moisture Content (%)	37.2	48.4	52.4	45.7	62.9	63.8	52.5	69.2	24.1	
Sample Weight (g)	74.36	47.6	48.95	56.49	40.09	44.73	47.85	38.43	69.41	
Flask & Water (g)	673.32	680.56	673.32	680.56	673.23	680.48	673.06	680.52	673.02	
Flask, Water, and Sample (g)	719.23	708.49	702.72	710.64	695.29	705.24	701.01	702.66	716.77	
Specific Gravity of Solids	2.61	2.42	2.50	2.14	2.22	2.24	2.40	2.36	2.70	
Volume of Sample (cm ³)	3395.7	3191.4	3319.1	3255.3	3255.3	3076.6	3255.3	3025.5	3178.7	
Weight of Solids (g)	3757.7	3613.6	3648.1	3710.6	3309.7	3218.9	3471.2	3043.1	4576.3	
Volume of Solids (cm ³)	1437.7	1493.3	1457.0	1734.8	1488.5	1437.1	1443.6	1289.9	1691.8	
Void Ratio	1.36	1.14	1.28	0.88	1.19	1.14	1.25	1.35	0.88	

Fly Ash Pond East Dike - Section K-K			
GA-1C	Sample	ST-1	ST-2
DENSITY	Sample Depth (ft)	39.0-41.5	69.0-71.5
	Tube Weight (g)	2667	2667
	Tube & Sample Weight (g)	5095	8663
	Sample Weight (g)	2428	5996
	Sample Weight (lbs)	5.35	13.22
	Recovery Length (ft)	0.98	2.58
	Sample Volume (ft ³)	0.044	0.116
	Density (lbs/ft ³)	121.2	113.7
	Moist Sample Weight (g)	75.15	84.75
	Dry Sample Weight (g)	46.08	65.06
MOISTURE	Moisture Content (%)	63.1	30.3
	Sample Weight (g)	43.65	57.43
SPECIFIC GRAVITY	Flask & Water (g)	673.41	680.85
	Flask, Water, and Sample (g)	696.56	717.27
	Specific Gravity of Solids	2.13	2.73
	Volume of Sample (cm ³)	1251.0	3293.6
VOID RATIO	Weight of Solids (g)	1488.8	4602.9
	Volume of Solids (cm ³)	699.2	1683.9
	Void Ratio	0.79	0.96

Fly Ash Pond East Dike - Section K-K				
Sample	ST-1	ST-2	ST-3	
Sample Depth (ft)	29.0-31.5	39.0-41.5	59.0-61.5	
Tube Weight (g)	2668	2665	2673	
Tube & Sample Weight (g)	5014	7952	7533	
Sample Weight (g)	2346	5287	4860	
Sample Weight (lbs)	5.17	11.66	10.71	
Recovery Length (ft)	1.17	2.48	2.36	
Sample Volume (ft ³)	0.053	0.112	0.106	
Density (lbs/ft ³)	98.1	104.3	100.7	
Moist Sample Weight (g)	80.9	84.89	84.19	
Dry Sample Weight (g)	52.33	57.14	59.66	
Moisture Content (%)	54.6	48.6	41.1	
Sample Weight (g)	47.49	44.37	46.25	
Flask & Water (g)	673.36	680.53	673.19	
Flask, Water, and Sample (g)	698.44	705.66	700.87	
Specific Gravity of Solids	2.12	2.31	2.49	
Volume of Sample (cm ³)	1493.6	3165.9	3012.7	
Weight of Solids (g)	1517.5	3558.7	3444.0	
Volume of Solids (cm ³)	716.1	1543.2	1382.8	
Void Ratio	1.09	1.05	1.18	

Fly Ash Pond East Dike - Section M-M				
Sample	ST-1	ST-2	ST-3	
Sample Depth (ft)	39.0-41.5	59.0-61.5	69.0-70.5	
Tube Weight (g)	2669	2657	2659	
Tube & Sample Weight (g)	4859	8808	6679	
Sample Weight (g)	2190	6151	4020	
Sample Weight (lbs)	4.83	13.56	8.86	
Recovery Length (ft)	1.10	2.50	1.70	
Sample Volume (ft ³)	0.050	0.113	0.077	
Density (lbs/ft ³)	97.4	120.3	115.6	
Moist Sample Weight (g)	62.21	73.94	96.65	
Dry Sample Weight (g)	34.09	59.79	79.79	
Moisture Content (%)	82.5	23.7	21.1	
Sample Weight (g)	32.52	51.63	55.71	
Flask & Water (g)	686.86	673.69	681.01	
Flask, Water, and Sample (g)	704.09	706.28	714.17	
Specific Gravity of Solids	2.13	2.71	2.47	
Volume of Sample (cm ³)	1404.2	3191.4	2170.2	
Weight of Solids (g)	1200.1	4973.9	3318.7	
Volume of Solids (cm ³)	564.2	1834.3	1343.3	
Void Ratio	1.49	0.74	0.62	

Fly Ash Pond East Dike - Section L-L				
Sample	ST-1	ST-2	ST-3	
Sample Depth (ft)	29.0-31.5	49.0-51.5	79.0-81.5	
Tube Weight (g)	2655	2653	2659	
Tube & Sample Weight (g)	5565	7463	8276	
Sample Weight (g)	2910	4810	5617	
Sample Weight (lbs)	6.42	10.60	12.38	
Recovery Length (ft)	1.51	2.34	2.27	
Sample Volume (ft ³)	0.068	0.105	0.102	
Density (lbs/ft ³)	94.2	100.5	121.0	
Moist Sample Weight (g)	54.9	84.35	93.18	
Dry Sample Weight (g)	40.85	53.78	66.03	
Moisture Content (%)	34.4	56.8	41.1	
Sample Weight (g)	37.96	43.22	65.77	
Flask & Water (g)	680.82	673.27	680.82	
Flask, Water, and Sample (g)	700.62	697.43	721.95	
Specific Gravity of Solids	2.09	2.27	2.67	
Volume of Sample (cm ³)	1927.6	2987.2	2897.8	
Weight of Solids (g)	2165.3	3066.8	3980.4	
Volume of Solids (cm ³)	1035.9	1352.4	1491.2	
Void Ratio	0.86	1.21	0.94	
GA-3				
DENSITY				
MOISTURE				
SPECIFIC GRAVITY				
VOID RATIO				

GA-4A	Bottom Ash Pond West Dike - Section A-A			
	Sample	ST-1	ST-2	ST-3
DENSITY	Sample Depth (ft)	28.0-30.5	32.0-34.5	36.0-38.0
	Tube Weight (g)	2666	2667	2678
	Tube & Sample Weight (g)	7502	7165	6105
	Sample Weight (g)	4836	4498	3427
	Sample Weight (lbs)	10.66	9.92	7.56
	Recovery Length (ft)	2.55	2.24	1.52
	Sample Volume (ft ³)	0.115	0.101	0.069
	Density (lbs/ft ³)	92.7	98.2	110.3
	Moist Sample Weight (g)	77.78	72.51	72.92
	Dry Sample Weight (g)	41.3	51.55	52.06
MOISTURE	Moisture Content (%)	88.3	40.7	40.1
	Sample Weight (g)	30.22	35.05	51.82
	Flask & Water (g)	680.47	673.21	673.21
SPECIFIC GRAVITY	Flask, Water, and Sample (g)	696.81	692.85	705.99
	Specific Gravity of Solids	2.18	2.27	2.72
	Volume of Sample (cm ³)	3255.3	2859.5	1940.4
	Weight of Solids (g)	2567.8	3197.8	2446.6
VOID RATIO	Volume of Solids (cm ³)	1179.4	1405.9	899.0
	Void Ratio	1.76	1.03	1.16


Bottom Ash Pond West Dike - Section A-A		ST-1
GA-4B	Sample	29.0-31.5
	Sample Depth (ft)	2684
DENSITY	Tube Weight (g)	7601
	Tube & Sample Weight (g)	4917
	Sample Weight (g)	10.84
	Sample Weight (lbs)	2.38
	Recovery Length (ft)	0.107
MOISTURE	Sample Volume (ft ³)	101.0
	Density (lbs/ft ³)	80.67
	Moist Sample Weight (g)	48.5
	Dry Sample Weight (g)	66.3
	Moisture Content (%)	47.83
SPECIFIC GRAVITY	Sample Weight (g)	680.66
	Flask & Water (g)	707.42
	Flask, Water, and Sample (g)	2.27
	Specific Gravity of Solids	3038.3
VOID RATIO	Volume of Sample (cm ³)	2956.2
	Weight of Solids (g)	1302.2
	Volume of Solids (cm ³)	1.33

Particle Size Distribution Report

U.S. SIEVE OPENING IN INCHES
 6 in. 3 in. 2 in. 1 1/2 in. 1 in. 3/4 in. 3/8 in.

U.S. STANDARD SIEVE NUMBERS

HYDROMETER



		GRAIN SIZE - mm.				% Fines	
		% Gravel		% Sand		Silt	Clay
		Coarse	Fine	Coarse	Medium		
0	% +3"	0.0	0.0	0.1	0.2	87.4	10.4
	Coarse	0.0	0.0	0.1	0.2		
	Fine						
	Coarse						
	Fine						


Source	Sample #	Depth/Elev.	Date Sampled	USCS	Material Description	NM %	LL	PL
	GA-1A ST2	28.5'-31.0'		ML	Fly Ash, gray	53.3	46	np

Client American Electric Power
 Project Philip Sporn Plant

**Geo/Environmental
 Associates, Inc.
 Knoxville, Tennessee**

Project No. 09-387 Figure

Particle Size Distribution Report




		GRAIN SIZE - mm.						
		% Gravel		% Sand				% Fines
		Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0		0.0	0.0	0.1	0.2	2.6	83.1	14.0

Source	Sample #	Depth/Elev.	Date Sampled	USCS	Material Description	NM %	LL	PL
	GA-1A ST3	32.5'-35.0'		ML	Fly Ash, dark gray, dark brown	58.5	nv	np

Client American Electric Power
 Project Philip Sporn Plant
 Project No. 09-387 Figure

**Geo/Environmental
 Associates, Inc.
 Knoxville, Tennessee**

Particle Size Distribution Report




	% Gravel			% Sand			% Fines		
	Coarse	Fine		Coarse	Medium	Fine	Silt	Clay	
0	0.0	0.0		0.1	0.7	4.0	82.0	13.2	

Source	Sample #	Depth/Elev.	Date Sampled	USCS	Material Description	NM %	LL	PL
	GA-1A ST4	36.5'-39.0'		ML	Fly Ash, dark gray	33.0	nv	np

Client American Electric Power
 Project Philip Sporn Plant
 Project No. 09-387 Figure

Geo/Environmental Associates, Inc.
 Knoxville, Tennessee

Particle Size Distribution Report



U.S. SIEVE OPENING IN INCHES		U.S. STANDARD SIEVE NUMBERS		HYDROMETER					
1 1/2 in.	3/8 in.	#4	#10	#20	#40	#60	#100	#140	#200
100	47.5	20	10	4.75	2.0	0.85	0.425	0.25	0.15
6 in.	3 in.	2 in.	1 in.	1/2 in.	3/8 in.				

GRAIN SIZE - mm.				% Sand		% Fines	
% +3"		% Gravel		% Sand		% Fines	
Coarse	Fine	Coarse	Fine	Medium	Fine	Silt	Clay
0.0	0.0	0.1	0.0	0.6	4.5	83.0	11.8

Source	Sample #	Depth/Elev.	Date Sampled	USCS	Material Description	NM %	LL	PL
	GA-1A ST5	40.5'-43.0'		ML	Fly Ash, dark gray, dark brown	46.6	37	np

Client American Electric Power
 Project Philip Sporn Plant
 Project No. 09-387 Figure

Geo/Environmental Associates, Inc.
 Knoxville, Tennessee

**CONSTANT HEAD PERMEABILITY TESTING
ASTM D5084-90/EPA 9100 Method 2.8**

PROJECT NAME : Philip Sporn Plant

PROJECT NUMBER : 09-387

CLIENT : AEP

DATE : December 18, 2009

SAMPLE LOCATION AND CONDITIONS

Sample Id.: GA-1A ST-6 - 20 psi Depth of Tested Sample : 44.5' - 47.0'
 Remolded: No Sample Type : Shelby Tube
 Sample Description : Fly Ash, dark gray - 20 psi triaxial specimen

INITIAL SPECIMEN PROPERTIES

Length (in.):	<u>5.55</u>	Volume (ft ³):	<u>0.0202</u>	Wet Density (PCF):	<u>104.0</u>
Diameter (in.):	<u>2.83</u>	Weight (lbs):	<u>2.10</u>	Dry Density (PCF):	<u>71.9</u>
Area (ft ²):	<u>0.0437</u>	Moisture (%):	<u>44.6</u>		
Chamber Pressure (psi):	<u>10</u>	Change in Pore Pressure (psi):	<u>2.0</u>		
Influent Pressure (psi):	<u>8</u>	Change in Chamber Pressure (psi):	<u>2.0</u>		
Back Pressure (psi):	<u>5</u>	"B" Factor:	<u>1.0</u>		

PERMEABILITY CALCULATIONS

k = Hydraulic Conductivity, (cm/sec)

$$k = \frac{QL}{Ath} \text{ cm/sec}$$

L = Length of Sample, along path of flow, (cm)

$$k = \frac{(600.0)(14.10)}{(40.58)(14,506)(211.01)}$$

Q = Quantity of flow, taken as the average of inflow and outflow, (cm³)

A = Cross-sectional area of specimen, (cm²)

$$k = \frac{8,460.00}{124,211,770.81}$$

t = Interval of time, over which the flow Q occurs, (sec)

h = Difference in hydraulic head across specimen, (cm)

$$k = \underline{6.81 \times 10^{-5} \text{ cm/sec}}$$

**CONSTANT HEAD PERMEABILITY TESTING
ASTM D5084-90/EPA 9100 Method 2.8**

PROJECT NAME : Philip Sporn Plant

PROJECT NUMBER : 09-387

CLIENT : AEP

DATE : December 18, 2009

SAMPLE LOCATION AND CONDITIONS

Sample Id.: GA-1A ST-6 - 40 psi **Depth of Tested Sample :** 44.5' - 47.0'
Remolded: No **Sample Type :** Shelby Tube
Sample Description : Fly Ash, dark gray - 40 psi triaxial specimen

INITIAL SPECIMEN PROPERTIES

Length (in.): <u>5.58</u>	Volume (ft³): <u>0.0206</u>	Wet Density (PCF): <u>103.8</u>
Diameter (in.): <u>2.85</u>	Weight (lbs): <u>2.14</u>	Dry Density (PCF): <u>71.5</u>
Area (ft²): <u>0.0443</u>	Moisture (%): <u>45.2</u>	
Chamber Pressure (psi): <u>10</u>	Change in Pore Pressure (psi): <u>2.0</u>	
Influent Pressure (psi): <u>8</u>	Change in Chamber Pressure (psi): <u>2.0</u>	
Back Pressure (psi): <u>5</u>	"B" Factor: <u>1.0</u>	

PERMEABILITY CALCULATIONS

k = Hydraulic Conductivity, (cm/sec)

$$k = \frac{QL}{Ath} \text{ cm/sec}$$

L = Length of Sample, along path of flow, (cm)

$$k = \frac{(600.0)(14.17)}{(41.16)(8,599)(211.01)}$$

Q = Quantity of flow, taken as the average of inflow and outflow, (cm³)

A = Cross-sectional area of specimen, (cm²)

$$k = \frac{8,502.00}{74,683,790.59}$$

t = Interval of time, over which the flow Q occurs, (sec)

h = Difference in hydraulic head across specimen, (cm)

$$k = \underline{1.14 \times 10^{-4} \text{ cm/sec}}$$

CONSTANT HEAD PERMEABILITY TESTING
ASTM D5084-90/EPA 9100 Method 2.8

PROJECT NAME : Philip Sporn Plant

PROJECT NUMBER : 09-387

CLIENT : AEP

DATE : December 18, 2009

SAMPLE LOCATION AND CONDITIONS

Sample Id.: GA-1A ST-6 - 60 psi **Depth of Tested Sample :** 44.5' - 47.0'
Remolded: No **Sample Type :** Shelby Tube
Sample Description : Fly Ash, dark gray - 60 psi triaxial specimen

INITIAL SPECIMEN PROPERTIES

Length (in.): <u>5.44</u>	Volume (ft³): <u>0.0202</u>	Wet Density (PCF): <u>104.0</u>
Diameter (in.): <u>2.86</u>	Weight (lbs): <u>2.10</u>	Dry Density (PCF): <u>73.5</u>
Area (ft²): <u>0.0446</u>	Moisture (%): <u>41.6</u>	
Chamber Pressure (psi): <u>10</u>	Change in Pore Pressure (psi): <u>2.0</u>	
Influent Pressure (psi): <u>8</u>	Change in Chamber Pressure (psi): <u>2.0</u>	
Back Pressure (psi): <u>5</u>	"B" Factor: <u>1.0</u>	

PERMEABILITY CALCULATIONS

k = Hydraulic Conductivity, (cm/sec)

$$k = \frac{QL}{Ath} \text{ cm/sec}$$

L = Length of Sample, along path of flow, (cm)

$$k = \frac{(600.0)(13.82)}{(41.45)(9,531)(211.01)}$$

Q = Quantity of flow, taken as the average of inflow and outflow, (cm³)



A = Cross-sectional area of specimen, (cm²)

$$k = \frac{8,292.00}{83,361,600.05}$$

t = Interval of time, over which the flow Q occurs, (sec)

h = Difference in hydraulic head across specimen, (cm)

$$k = \underline{9.95 \times 10^{-5} \text{ cm/sec}}$$



Sample No.		1	2	3
Initial	Water Content, %	44.6	45.2	41.6
	Dry Density, pcf	71.9	71.5	73.5
	Saturation, %	97.7	98.0	94.8
	Void Ratio	1.1095	1.1210	1.0651
	Diameter, in.	2.83	2.85	2.86
At Test	Height, in.	5.55	5.58	5.44
	Water Content, %	40.1	44.4	40.7
	Dry Density, pcf	76.8	73.0	76.3
	Saturation, %	100.0	100.0	100.0
	Void Ratio	0.9746	1.0779	0.9883
Strain rate, in./min.	Diameter, in.	2.77	2.83	2.82
	Height, in.	5.43	5.54	5.37
	Strain rate, in./min.	0.00	0.00	0.00
Back Pressure, psi	30.00	30.00	30.00	
Cell Pressure, psi	50.00	70.00	90.00	
Fail. Stress, ksf	Total Pore Pr., ksf	14.3	19.4	21.8
	Ult. Stress, ksf	4.5	4.8	4.5
$\bar{\sigma}_1$ Failure, ksf	Total Pore Pr., ksf	17.0	24.7	30.3
	$\bar{\sigma}_3$ Failure, ksf	2.7	5.3	8.5

Type of Test:
CU with Pore Pressures

Sample Type: Shelby Tube

Description: Fly Ash, dark gray

LL= 44

Specific Gravity= 2.43

Remarks:

Client: American Electric Power

Project: Philip Sporn Plant






Sample Number: GA-1A ST6 **Depth:** 44.5'-47.0'

Proj. No.: 09-387 **Date Sampled:** 12/18/09

TRIAXIAL SHEAR TEST REPORT

Geo/Environmental Associates, Inc.

Figure 1



Client: American Electric Power

Project: Philip Sporn Plant

Depth: 44.5'-47.0'


Sample Number: GA-1A ST6

Project No.: 09-387

Figure 2

Geo/Environmental Associates, Inc.

Particle Size Distribution Report




% +3"		% Gravel		% Sand		% Fines	
Coarse	Fine	Coarse	Fine	Coarse	Medium	Silt	Clay
0.0	0.0	0.2	4.4	1.7	78.6	15.1	

Source	Sample #	Depth/Elev.	Date Sampled	USCS	Material Description	NM %	LL	PL
	GA-1A ST7	48.5'-51.0'		ML	Fly Ash, dark gray	37.2	nv	np

Client American Electric Power
 Project Philip Sporn Plant
 Project No: 09-387 Figure

Geo/Environmental Associates, Inc.
 Knoxville, Tennessee

Particle Size Distribution Report



%	% Gravel			% Sand			% Fines		
	Coarse	Fine		Coarse	Medium	Fine	Silt	Clay	
0.0	0.0	0.0		0.0	0.3	5.2	77.1	17.4	


Source	Sample #	Depth/Elev.	Date Sampled	USCS	Material Description	NM %	LL	PL
	GA-1A ST8	52.5'-55.0'		ML	Fly Ash, gray	53.3	44	np

Client American Electric Power
 Project Philip Sporn Plant

Geo/Environmental Associates, Inc.
 Knoxville, Tennessee

Project No. 09-387 Figure

Particle Size Distribution Report




% +3"		% Gravel		% Sand			% Fines	
Coarse	Fine	Coarse	Medium	Fine	Silt	Clay		
0.0	0.0	0.2	0.6	2.1	81.3	15.8		

Source	Sample #	Depth/Elev.	Date Sampled	USCS	Material Description	NM %	LL	PL
	GA-1A ST9	56.5'-59.0'		ML	Fly Ash, dark gray	51.5	45	np

Client American Electric Power
 Project Philip Sporn Plant
 Project No. 09-387 Figure

**Geo/Environmental
 Associates, Inc.
 Knoxville, Tennessee**

Particle Size Distribution Report




% +3"		% Gravel		% Sand		% Fines	
Coarse	Fine	Coarse	Fine	Medium	Fine	Silt	Clay
0.0	0.0	0.1	1.7	0.4	1.7	84.2	13.6

Source	Sample #	Depth/Elev.	Date Sampled	USCS	Material Description	NM %	LL	PL
	GA1A ST10	60.5'-63.0'		ML	Fly Ash, dark gray, dark brown	53.7	44	np

Client: American Electric Power
 Project: Philip Sporn Plant
 Project No. 09-387 Figure

Geo/Environmental Associates, Inc.
Knoxville, Tennessee

Particle Size Distribution Report




GRAIN SIZE - mm.	% Sand			% Fines	
	Coarse	Medium	Fine	Silt	Clay
	0.1	1.5	2.3	65.0	31.1

Source	Sample #	Depth/Elev.	Date Sampled	USCS	Material Description	NM %	LL	PL
	GA-1C ST2	69.0'-71.5'		CL	Clay, silty, brown	27.2	35	19

Client American Electric Power
 Project Philip Sporn Plant
 Project No. 09-387 Figure

Geo/Environmental Associates, Inc.
 Knoxville, Tennessee

Particle Size Distribution Report



% +3"		% Gravel		% Sand			% Fines	
Coarse	Fine	Coarse	Medium	Fine	Silt	Clay	Silt	Clay
0.0	11.3	0.4	1.1	11.5	58.9	16.8		

Source	Sample #	Depth/Elev.	Date Sampled	USCS	Material Description	NM %	LL	PL
	GA-2 ST2	59.0'-61.5'		CL-ML	Clay, silty, brown	20.3	20	16

Client American Electric Power
 Project Philip Sporn Plant
 Project No. 09-387 Figure

Geo/Environmental Associates, Inc.
 Knoxville, Tennessee

**CONSTANT HEAD PERMEABILITY TESTING
ASTM D5084-90/EPA 9100 Method 2.8**

PROJECT NAME : Philip Sporn Plant

PROJECT NUMBER : 09-387

CLIENT : AEP

DATE : December 29, 2009

SAMPLE LOCATION AND CONDITIONS

Sample Id.: GA-1C ST-2 - 20 psi Depth of Tested Sample : 69.0' - 71.5'
 Remolded: No Sample Type : Shelby Tube
 Sample Description : Clay, silty brown - 20 psi triaxial specimen

INITIAL SPECIMEN PROPERTIES

Length (in.):	<u>5.15</u>	Volume (ft ³):	<u>0.0190</u>	Wet Density (PCF):	<u>122.7</u>
Diameter (in.):	<u>2.85</u>	Weight (lbs):	<u>2.33</u>	Dry Density (PCF):	<u>96.3</u>
Area (ft ²):	<u>0.0443</u>	Moisture (%):	<u>27.4</u>		
Chamber Pressure (psi):	<u>10</u>	Change in Pore Pressure (psi):	<u>2.0</u>		
Influent Pressure (psi):	<u>8</u>	Change in Chamber Pressure (psi):	<u>2.0</u>		
Back Pressure (psi):	<u>5</u>	"B" Factor:	<u>1.0</u>		

PERMEABILITY CALCULATIONS

k = Hydraulic Conductivity, (cm/sec) $k = \frac{QL}{Ath}$ cm/sec

L = Length of Sample, along path of flow, (cm)

$$k = \frac{(16.8)(13.08)}{(41.16)(63,300)(211.01)}$$

Q = Quantity of flow, taken as the average of
inflow and outflow, (cm³)

A = Cross-sectional area of specimen, (cm²)

$$k = \frac{219.74}{549,771,362.28}$$

t = Interval of time, over which the flow Q occurs, (sec)

h = Difference in hydraulic head across
specimen, (cm)

$$k = \underline{4.00 \times 10^{-7} \text{ cm/sec}}$$

CONSTANT HEAD PERMEABILITY TESTING
ASTM D5084-90/EPA 9100 Method 2.8

PROJECT NAME : Philip Sporn Plant

PROJECT NUMBER : 09-387

CLIENT : AEP

DATE : December 29, 2009

SAMPLE LOCATION AND CONDITIONS

Sample Id.: GA-1C ST-2 - 40 psi **Depth of Tested Sample :** 69.0' - 71.5'
Remolded: No **Sample Type :** Shelby Tube
Sample Description : Clay, silty brown - 40 psi triaxial specimen

INITIAL SPECIMEN PROPERTIES

Length (in.): <u>5.97</u>	Volume (ft³): <u>0.0224</u>	Wet Density (PCF): <u>121.7</u>
Diameter (in.): <u>2.87</u>	Weight (lbs): <u>2.72</u>	Dry Density (PCF): <u>94.9</u>
Area (ft²): <u>0.0449</u>	Moisture (%): <u>28.2</u>	
Chamber Pressure (psi): <u>10</u>	Change in Pore Pressure (psi): <u>2.0</u>	
Influent Pressure (psi): <u>8</u>	Change in Chamber Pressure (psi): <u>2.0</u>	
Back Pressure (psi): <u>5</u>	"B" Factor: <u>1.0</u>	

PERMEABILITY CALCULATIONS

k = Hydraulic Conductivity, (cm/sec)

$$k = \frac{QL}{Ath} \text{ cm/sec}$$

L = Length of Sample, along path of flow, (cm)

$$k = \frac{(16.8)(15.16)}{(41.74)(63,300)(211.01)}$$

Q = Quantity of flow, taken as the average of inflow and outflow, (cm³)

A = Cross-sectional area of specimen, (cm²)

$$k = \frac{254.69}{557,518,383.42}$$

t = Interval of time, over which the flow Q occurs, (sec)

h = Difference in hydraulic head across specimen, (cm)

$$k = \underline{4.57 \times 10^{-7} \text{ cm/sec}}$$

CONSTANT HEAD PERMEABILITY TESTING
ASTM D5084-90/EPA 9100 Method 2.8

PROJECT NAME : Philip Sporn Plant

PROJECT NUMBER : 09-387

CLIENT : AEP

DATE : December 29, 2009

SAMPLE LOCATION AND CONDITIONS

Sample Id.: GA-1C ST-2 - 60 psi **Depth of Tested Sample :** 69.0' - 71.5'
Remolded: No **Sample Type :** Shelby Tube
Sample Description : Clay, silty brown - 60 psi triaxial specimen

INITIAL SPECIMEN PROPERTIES

Length (in.): <u>5.88</u>	Volume (ft³): <u>0.0220</u>	Wet Density (PCF): <u>121.9</u>
Diameter (in.): <u>2.87</u>	Weight (lbs): <u>2.68</u>	Dry Density (PCF): <u>95.1</u>
Area (ft²): <u>0.0449</u>	Moisture (%): <u>28.2</u>	
Chamber Pressure (psi): <u>10</u>	Change in Pore Pressure (psi): <u>2.0</u>	
Influent Pressure (psi): <u>8</u>	Change in Chamber Pressure (psi): <u>2.0</u>	
Back Pressure (psi): <u>5</u>	"B" Factor: <u>1.0</u>	

PERMEABILITY CALCULATIONS

k = Hydraulic Conductivity, (cm/sec)

$$k = \frac{QL}{Ath} \text{ cm/sec}$$

L = Length of Sample, along path of flow, (cm)

$$k = \frac{(23.0)(14.94)}{(41.74)(69,600)(211.01)}$$

Q = Quantity of flow, taken as the average of inflow and outflow, (cm³)



A = Cross-sectional area of specimen, (cm²)

$$k = \frac{343.62}{613,005,995.04}$$

t = Interval of time, over which the flow Q occurs, (sec)

h = Difference in hydraulic head across specimen, (cm)

$$k = \underline{5.61 \times 10^{-7} \text{ cm/sec}}$$



Sample No.	1	2	3	
Initial	Water Content, %	27.4	28.2	28.2
	Dry Density, pcf	96.3	94.9	95.1
	Saturation, %	98.1	97.8	98.1
	Void Ratio	0.7572	0.7825	0.7782
	Diameter, in.	2.85	2.87	2.87
At Test	Height, in.	5.15	5.97	5.88
	Water Content, %	25.1	24.1	25.2
	Dry Density, pcf	100.6	102.3	100.6
	Saturation, %	100.0	100.0	100.0
	Void Ratio	0.6812	0.6539	0.6823
Strain rate, in./min.	Diameter, in.	2.81	2.80	2.82
	Height, in.	5.08	5.82	5.77
	Back Pressure, psi	0.00	0.00	0.00
Cell Pressure, psi	30.00	30.00	30.00	
Fail. Stress, ksf	50.00	70.00	90.00	
	Total Pore Pr., ksf	4.4	5.5	8.0
Ult. Stress, ksf	Total Pore Pr., ksf	5.4	7.8	9.5
	$\bar{\sigma}_1$ Failure, ksf	6.2	7.8	11.4
$\bar{\sigma}_3$ Failure, ksf	1.8	2.3	3.4	

Type of Test:

CU with Pore Pressures

Sample Type: Shelby Tube

Description: Clay, silty, brown

LL= 35

PL= 19

PI= 16

Specific Gravity= 2.71

Remarks:

Client: American Electric Power

Project: Philip Sporn Plant

Sample Number: GA-1C ST2

Depth: 69.0'-71.5'






Proj. No.: 09-387

Date Sampled:

TRIAxIAL SHEAR TEST REPORT

Geo/Environmental Associates, Inc.

Figure 1



Client: American Electric Power

Project: Philip Sporn Plant

Depth: 69.0'-71.5'


Sample Number: GA-1C ST2

Project No.: 09-387

Figure 2

Geo/Environmental Associates, Inc.

Particle Size Distribution Report



		GRAIN SIZE - mm.						
		% Gravel		% Sand				% Fines
		Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
%		0.0	0.2	0.6	3.9	13.3	60.7	21.3


Source	Sample #	Depth/Elev.	Date Sampled	USCS	Material Description	NM %	LL	PL
	GA-2 ST3	69.0'-71.5'		CL-ML	Clay, silty, light brown	20.8	23	17

Client American Electric Power
 Project Philip Sporn Plant
 Project No. 09-387

Geo/Environmental Associates, Inc.
 Knoxville, Tennessee

Figure

Particle Size Distribution Report




	% Gravel		% Sand		% Fines	
	Coarse	Fine	Coarse	Fine	Silt	Clay
○	0.0	0.0	0.1	4.5	67.8	24.8

Source	Sample #	Depth/Elev.	Date Sampled	USCS	Material Description	NM %	LL	PL
○	GA-4A ST2	32.0'-34.5'		ML	Fly Ash, dark gray	57.2	nv	np

Client American Electric Power
 Project Philip Sporn Plant
 Project No. 09-387 Figure

Geo/Environmental Associates, Inc.
 Knoxville, Tennessee

Particle Size Distribution Report



	% Gravel		% Sand			% Fines	
	Coarse	Fine	Coarse	Medium	Fine	Silt	Clay
0	0.0	0.0	0.1	1.0	2.8	68.5	27.6


Source	Sample #	Depth/Elev.	Date Sampled	USCS	Material Description	NM %	LL	PL
0	GA-4A ST3	36.0'-38.0'		CL	Clay, silty, light brown w/ fly ash	33.8	32	22

Client American Electric Power
 Project Philip Sporn Plant

Geo/Environmental Associates, Inc.
 Knoxville, Tennessee

Project No. 09-387 Figure

Particle Size Distribution Report



	% Gravel		% Sand		% Fines	
	Coarse	Fine	Medium	Fine	Silt	Clay
0	0.0	0.0	3.3	6.3	65.2	24.9

Source	Sample #	Depth/Elev.	Date Sampled	USCS	Material Description	NM %	LL	PL
0	GA-4B ST1	29.0'-31.5'		ML	Fly Ash, dark gray	56.3	nv	np

Client American Electric Power		<h2>Geo/Environmental Associates, Inc.</h2> <h3>Knoxville, Tennessee</h3>
Project Philip Sporn Plant		
Project No. 09-387	Figure	



Geo/Environmental
Associates, Inc.

Job Name: AEP Philip Sporn

Job Number: 09-387

Title: G_{max} Calc for Section H-H

Computed By: SWF

Checked by:

Date: 4/26/10

Sheet: 1 Of: 2

$$\text{Small Strain Shear Modulus } [G_{max} (\text{lbs/ft}^2)] = \frac{\gamma \cdot V_v^2}{g}$$

Where: γ = unit weight (lbs/ft³)

V_v = shear wave velocity (ft/s)

g = gravitational acceleration (32.2 ft/s²)

$$\text{Silty Sand (1)} \quad \frac{130 (694)^2}{32.2} = 194493 \text{ lbs/ft}^2$$

$$\text{Silty Sand (2)} \quad \frac{107 (978.7)^2}{32.2} = 3182930 \text{ lbs/ft}^2$$

$$\text{Gravelly Sand (3)} \quad \frac{105 (978.7)^2}{32.2} = 3123436 \text{ lbs/ft}^2$$

$$\text{Silty Clay (4)} \quad \frac{115 (978.7)^2}{32.2} = 3420906 \text{ lbs/ft}^2$$

$$\text{Silty Sand (5)} \quad \frac{131 (694)^2}{32.2} = 1959450 \text{ lbs/ft}^2$$

$$\text{Sandy Silt (6)} \quad \frac{130 (694)^2}{32.2} = 1933302 \text{ lbs/ft}^2$$

$$\text{Fly Ash (7)} \quad \frac{110 (476.25)^2}{32.2} = 774831 \text{ lbs/ft}^2$$

$$\text{Silty Sand (8)} \quad \frac{112 (978.7)^2}{32.2} = 3331665 \text{ lbs/ft}^2$$



Geo/Environmental
Associates, Inc.

Job Name: AEP Philip Sporn
Job Number: 09-387
Title: G_{max} Calcs for Section A-A
Computed By: SWF Checked by:
Date: 4/26/10 Sheet: 2 Of: 2

$$\text{Clayey Sand (9)} \quad \frac{115 (1377.2)^2}{32.2} = 6816193 \text{ lbs/ft}^2$$

$$\text{Sand (10)} \quad \frac{123 (1377.2)}{32.2} = 7245081 \text{ lbs/ft}^2$$

$$\text{Sand and Gravel (11)} \quad \frac{123 (1377.2)^2}{32.2} = 7245081 \text{ lbs/ft}^2$$

$$\text{Riprap (12)} \quad \frac{115 (1178.9)^2}{32.2} = 4963590 \text{ lbs/ft}^2$$



Geo/Environmental
Associates, Inc.

Job Name: AEP Philip Sporn
Job Number: 09-387
Title: G_{max} Calcs for Section A-A
Computed By: SWF Checked by:
Date: 4/26/10 Sheet: 1 Of: 1

$$\text{Small Strain Shear Modulus } [G_{max} (\text{lbs}/\text{ft}^2)] = \frac{\gamma \cdot V_v}{g}$$

Where: γ = unit weight (lbs/ft^3)

V_v = shear wave velocity (ft/s)

g = gravitational acceleration ($32.2 \text{ ft}/\text{s}^2$)

$$\text{Silty Clay (1)} \quad \frac{123 (1377.2)^2}{32.2} = 7245081 \text{ lbs}/\text{ft}^2$$

$$\text{Fly Ash (2)} \quad \frac{97 (434.33)^2}{32.2} = 568271 \text{ lbs}/\text{ft}^2$$

$$\text{Bottom Ash (3)} \quad \frac{80 (1377.2)^2}{32.2} = 4712248 \text{ lbs}/\text{ft}^2$$

$$\text{Clayey Sand (4)} \quad \frac{104 (1178.9)^2}{32.2} = 4488812 \text{ lbs}/\text{ft}^2$$

$$\text{Bottom Ash (5)} \quad \frac{62 (1178.9)^2}{32.2} = 2676022 \text{ lbs}/\text{ft}^2$$

$$\text{Gravelly Sand (6)} \quad \frac{111 (1178.9)^2}{32.2} = 4790943 \text{ lbs}/\text{ft}^2$$

$$\text{Clayey Sand (7)} \quad \frac{110 (1178.9)^2}{32.2} = 4747781 \text{ lbs}/\text{ft}^2$$


$$\text{Road Material (8)} \quad \frac{145 (1178.9)^2}{32.2} = 6258440 \text{ lbs}/\text{ft}^2$$

MISCELLANEOUS REFERENCES

**CSR GRAPH DEVELOPED BY OSU FOR SPORN FLY ASH
DAMPING RATIO OF DIFFERENT TYPES OF SOILS (KOKUSHO)
SEED-IDRISS DAMPING VALUES FROM SHAKE91**

Sporn Fly Ash Triaxial Cyclic Strength

- ◆ 62 pcf initial density, 20 psi effective pressure
- ▲ 62 pcf initial density, 40 psi effective pressure
- ◇ No liquefaction after 500 cycles






Fig. 10.20 Damping ratio of different types of soils
 (Kokusho, 1987)




Fig. B-2 Modulus Reduction and Damping Values Used for Sample Problem

FROM SHAKE91 USERS MANUAL (SEED IDRIS)

APPENDIX IV

LEM SLOPE STABILITY ANALYSES



LIMIT EQUILIBRIUM METHOD SLOPE STABILITY ANALYSIS SUMMARY
RAILWAY-INDUCED VIBRATION ASSESSMENT
BOTTOM ASH AND FLY ASH DISPOSAL FACILITIES
PHILIP SPORN PLANT
NEW HAVEN, MASON COUNTY, WEST VIRGINIA
GA FILE NO. 09-387

GENERAL

Geo/Environmental Associates, Inc. (GA) has prepared pseudo-static slope stability analyses for the western dikes of the Bottom Ash Disposal and Fly Ash Disposal Facilities at the Philip Sporn Plant. Specifically, GA has evaluated Section A-A for the Bottom Ash Disposal Facility Western Dike and Section H-H for the Fly Ash Disposal Facility Western Dike. The slope stability analyses were conducted using the computer program *SLOPE/W*. *SLOPE/W* is developed by GEO-SLOPE International, Ltd. of Calgary, Alberta, Canada.

The slope stability analyses provided herein are based on the Morgenstern-Price Limit Equilibrium Method (LEM) provided in the *SLOPE/W* program. The Morgenstern-Price LEM is a robust method that satisfies both moment and force equilibrium conditions. Furthermore, the Morgenstern-Price LEM is capable of utilizing user defined functions to develop both shear and normal interslice forces. More specifically, the half-sine function was applied to the slope stability analyses provided herein to determine interslice forces.

The slope stability analyses were performed in both the upstream and downstream directions for both of the critical sections. At the request of the USEPA, both shallow-seated and deep-seated (global) slip surfaces were modeled in the slope stability analyses. The phreatic levels used in the analyses were adapted from previous seepage and stability analyses prepared for the critical sections by AEP. We understand that the phreatic levels developed by AEP were based on *SEEP/W* seepage analyses and from site specific piezometer readings and subsurface exploration data.

Ground acceleration loadings developed from railway vibration monitoring were applied in the LEM pseudo-static analyses. GA conservatively applied the accelerations from the dike exterior toe vibration monitoring locations (i.e., Location A for Section A-A and Location C for Section H-H) to the downstream direction LEM slope stability analyses and we applied the accelerations from the dike crest monitoring locations (i.e., Location B for Section A-A and Location D for Section H-H) to the upstream direction LEM slope stability analyses. The acceleration values used in the analyses are provided in Table IV-1.



TABLE IV-1 SUMMARY OF ACCELERATIONS USED IN LIMIT EQUILIBRIUM METHOD PSEUDO-STATIC SLOPE STABILITY ANALYSES			
Critical Section	Vibration Monitoring Location	Maximum Acceleration (g's)	
		Horizontal	Vertical
Bottom Ash Disposal Facility Section A-A	Location A (Exterior Toe - Adjacent to Track) Downstream Direction Analyses	0.033	0.008
	Location B (Crest) Upstream Direction Analyses	0.013	0.002
Fly Ash Disposal Facility Section H-H	Location C (Exterior Toe - Adjacent to Track) Downstream Direction Analyses	0.046	0.008
	Location D (Crest) Upstream Direction Analyses	0.010	0.003

MATERIAL PARAMETERS

Strength parameters for the various embankment and foundation materials used in the slope stability analyses for critical Sections A-A and H-H are provided in Tables IV-2 and IV-3, respectively. In general, the strength parameters were selected based on previous parameters developed by AEP and based on laboratory testing conducted by GA in December 2009 and January 2010. Effective stress conditions were assumed; therefore, material parameters used in the slope stability analyses and presented herein are effective strength parameters. Additionally, the Mohr-Coulomb material model was used in the analyses.



TABLE IV.2. LEM MATERIAL PARAMETERS FOR SECTION A-A ANALYSES

	Silty Clay (1)	Fly Ash (2)	Bottom Ash (3)	Clayey Sand (4)	Bottom Ash (5)	Gravelly Sand (6)	Clayey Sand (7)	Road Material (8)	Clayey Sand (9)	Sand (10)	Sand & Gravel (11)	Riprap (12)
Moist Unit Weight γ (pcf)	123	139	80	105	62	111	104	145	115	123	123	115
Saturated Unit Weight γ (pcf)	123	134	80	105	80	115	110	145	115	123	123	115
Source	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)
Cohesion	0	0	0	0	0	0	0	0	0	0	0	0
Source	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)
Phi Angle ϕ (degrees)	36	33	36	31	38	34	34	36	29	29	32	38
Source	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)

Note:

- (1) AEP Philip Sporn Electric Generating Plant Bottom Ash Facility - Engineering Report, 1996
- (2) AEP Philip Sporn Power Plant Bottom Ash Disposal Facility - Stability Analysis, 2009



TABLE IV.2. LEM MATERIAL PARAMETERS FOR SECTION H-H ANALYSES

	Silty Sand (1)	Silty Sand (2)	Gravelly Sand (3)	Silty Clay (4)	Silty Sand (5)	Sandy Silt (6)	Fly Ash (7)	Rock Fill (9)
Moist Unit Weight γ (pcf)	125	107	105	115	126	125	90	115
Saturated Unit Weight γ (pcf)	130	112	110	120	131	130	102	115
Source	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)
Cohesion (psf)	0	0	0	0	0	0	0	0
Source	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)
Phi Angle ϕ (degrees)	34	35	33	32	31	27	27	38
Source	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)

Note:

(1) AEP Philip Sporn Electric Generating Plant Bottom Ash Facility - Engineering Report, 1996

(2) AEP Philip Sporn Power Plant Bottom Ash Disposal Facility - Stability Analysis, 2009



SLOPE STABILITY ANALYSIS RESULTS

Graphical output from the LEM slope stability analyses are provided in this appendix. Specifically, the results show the critical slip surface and corresponding safety factor for each of the modeled conditions. The slope stability analysis results are tabulated in Table IV-4.

Critical Section	Analysis Method	Pseudo-Static Loading Condition	Slope and Slip Surface Condition	Safety Factor
Bottom Ash Disposal Facility Section A-A	LEM	Location A (Exterior Toe) ($a_h = 0.033g$, $a_v = 0.008g$)	Downstream (Shallow)	2.96
			Downstream (Deep)	3.08
		Location B (Crest) ($a_h = 0.013g$, $a_v = 0.002g$)	Upstream (Shallow)	1.70
			Upstream (Deep)	2.02
Fly Ash Disposal Facility Section H-H	LEM	Location C (Exterior Toe) ($a_h = 0.046g$, $a_v = 0.008g$)	Downstream (Shallow)	1.84
			Downstream (Deep)	2.15
		Location D (Crest) ($a_h = 0.010g$, $a_v = 0.003g$)	Upstream (Shallow)	1.40
			Upstream (Deep)	1.65

SUMMARY OF RESULTS


GA used *SLOPE/W* to calculate slope stability safety factors for Section A-A of the Bottom Ash Disposal Facility Western Dike and Section H-H of the Fly Ash Disposal Facility Western Dike (See Table IV-4 and graphical output provided in this appendix). The safety factors were calculated by applying LEM pseudo-static train loading conditions developed from railway-induced vibrations. Specifically, the LEM pseudo-static analyses were evaluated by conservatively applying accelerations from the dike exterior toe vibration monitoring locations (i.e., Location A for Section A-A and Location C for Section H-H) to the downstream direction LEM slope stability analyses and by applying the accelerations from the dike crest monitoring locations (i.e., Location B for Section A-A and Location D for Section H-H) to the upstream direction LEM slope stability analyses.

As shown in Table IV-4, the LEM safety factors equal or exceed 1.70 for the Bottom Ash Disposal Facility Section A-A and 1.40 for the Fly Ash Disposal Facility Section H-H for the shallow-seated slip surface conditions. Moreover, the LEM safety factors equal or exceed 2.02 for the Bottom Ash Disposal Facility Section A-A and 1.65 for the Fly Ash Disposal Facility Section H-H for the deep-seated (global) slip surface conditions. The LEM slope stability analyses indicate that adequate safety factors/stability factors are available for each of the conservatively modeled dike/train loading conditions.



**BOTTOM ASH DISPOSAL FACILITY
SECTION A-A
LEM SLOPE STABILITY ANALYSIS RESULTS**

Title: Sporn Bottom Ash Disposal Facility
 Comments: LEM - Location A (Exterior Toe)
 Railway Induced Pseudo Static Analysis
 Down Stream Shallow Failure Surface
 File Name: BAP_A-A_Slope-DS_Shallow.gsz
 Date: 5/3/2010
 Horz Seismic Load: 0.033
 Vert Seismic Load: 0.008



SLOPE/W Analysis

Report generated using GeoStudio 2007, version 7.15. Copyright © 1991-2009 GEO-SLOPE International Ltd.

File Information

Title: Sporn Bottom Ash Disposal Facility
Comments: LEM - Location A (Exterior Toe) Railway Induced Pseudo Static Analysis Down Stream Shallow Failure Surface
Created By: Seth W. Frank, E.I.
Revision Number: 170
Last Edited By: Seth Frank
Date: 5/3/2010
Time: 4:15:55 PM
File Name: BAP_A-A_Slope-DS_Shallow.gsz
Directory: E:\Final Analysis Files\LEM BAP_A-A GA\Shallow\
Last Solved Date: 5/3/2010
Last Solved Time: 4:16:10 PM

Project Settings

Length(L) Units: feet
Time(t) Units: Seconds
Force(F) Units: lbf
Pressure(p) Units: psf
Strength Units: psf
Unit Weight of Water: 62.4 pcf
View: 2D

Analysis Settings

SLOPE/W Analysis

Description: Bottom Ash Pond Section A-A Downstream Seismic Stability with Existing Piezo Levels

Kind: SLOPE/W

Method: Morgenstern-Price

Settings

Apply Phreatic Correction: Yes

Side Function

Interslice force function option: Half-Sine

PWP Conditions Source: Piezometric Line with B-bar

SlipSurface

Direction of movement: Right to Left

Use Passive Mode: No

Slip Surface Option: Entry and Exit

Critical slip surfaces saved: 1

Optimize Critical Slip Surface Location: No

Tension Crack

Tension Crack Option: (none)

FOS Distribution

FOS Calculation Option: Constant

Advanced

Number of Slices: 30

Optimization Tolerance: 0.05

Minimum Slip Surface Depth: 1 ft

Optimization Maximum Iterations: 2000

Optimization Convergence Tolerance: 1e-007

Starting Optimization Points: 8

Ending Optimization Points: 16

Complete Passes per Insertion: 1

Driving Side Maximum Convex Angle: 5 °

Resisting Side Maximum Convex Angle: 1 °

Materials

Fly Ash (2)

Model: Mohr-Coulomb

Unit Weight: 139 pcf

Unit Wt. Above Water Table: 134 pcf

Cohesion: 0.1 psf

Phi: 33 °

Phi-B: 18 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Bottom Ash (3)

Model: Mohr-Coulomb

Unit Weight: 80 pcf

Unit Wt. Above Water Table: 80 pcf

Cohesion: 0.1 psf

Phi: 36 °

Phi-B: 20 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Clayey Sand (4)

Model: Mohr-Coulomb

Unit Weight: 105 pcf

Unit Wt. Above Water Table: 105 pcf

Cohesion: 0.1 psf

Phi: 31 °

Phi-B: 20 °

Pore Water Pressure

SLOPE/W Analysis

Piezometric Line: 1

B-bar: 0

Add Weight: Yes

Bottom Ash (5)

Model: Mohr-Coulomb

Unit Weight: 80 pcf

Unit Wt. Above Water Table: 62 pcf

Cohesion: 0.1 psf

Phi: 38 °

Phi-B: 20 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Gravelly Sand (6)

Model: Mohr-Coulomb

Unit Weight: 115 pcf

Unit Wt. Above Water Table: 111 pcf

Cohesion: 0.1 psf

Phi: 34 °

Phi-B: 19 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Clayey Sand (7)

Model: Mohr-Coulomb

Unit Weight: 110 pcf

Unit Wt. Above Water Table: 104 pcf

Cohesion: 0.1 psf

Phi: 34 °

Phi-B: 19 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Road Material (8)

Model: Mohr-Coulomb

Unit Weight: 145 pcf

Cohesion: 0.1 psf

Phi: 36 °

Phi-B: 20 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Silty Clay (1)

Model: Mohr-Coulomb

SLOPE/W Analysis

Unit Weight: 123 pcf
Cohesion: 0.1 psf
Phi: 36 °
Phi-B: 20 °
Pore Water Pressure
Piezometric Line: 1
B-bar: 0
Add Weight: Yes

Clayey Sand (9)

Model: Mohr-Coulomb
Unit Weight: 115 pcf
Cohesion: 0.1 psf
Phi: 29 °
Phi-B: 15 °
Pore Water Pressure
Piezometric Line: 1
Add Weight: Yes

Sand (10)

Model: Mohr-Coulomb
Unit Weight: 123 pcf
Cohesion: 0.1 psf
Phi: 29 °
Phi-B: 15 °
Pore Water Pressure
Piezometric Line: 1
Add Weight: Yes

Sand and Gravel (11)

Model: Mohr-Coulomb
Unit Weight: 123 pcf
Cohesion: 0.1 psf
Phi: 32 °
Phi-B: 18 °
Pore Water Pressure
Piezometric Line: 1
Add Weight: Yes

Riprap (12)

Model: Mohr-Coulomb
Unit Weight: 115 pcf
Cohesion: 0 psf
Phi: 38 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1
Add Weight: No

Slip Surface Entry and Exit

Left Projection: Range
 Left-Zone Left Coordinate: (35, 584.55556) ft
 Left-Zone Right Coordinate: (61, 584.11765) ft
 Left-Zone Increment: 20
 Right Projection: Range
 Right-Zone Left Coordinate: (98.5, 592.81818) ft
 Right-Zone Right Coordinate: (134.204, 592.328) ft
 Right-Zone Increment: 20
 Radius Increments: 20

Slip Surface Limits

Left Coordinate: (0, 589) ft
 Right Coordinate: (335, 545) ft

Piezometric Lines

Piezometric Line 1

Coordinates

	X (ft)	Y (ft)
	1	570.5
	107	570.5
	168	583
	334	583

Maximum Suction: 120 psf

Seismic Loads

Horz Seismic Load: 0.033
 Vert Seismic Load: 0.008
 Ignore seismic load in strength: No

Regions

	Material	Points	Area (ft ²)
Region 1	Sand (10)	3,4,5,6	8375
Region 2	Sand and Gravel (11)	6,5,2,1	4020
Region 3	Clayey Sand (9)	7,8,4,3	2680
Region 4	Silty Clay (1)	9,36,10,45,11,12,13,14,15,16,17,8,7	5834.125
Region 5	Fly Ash (2)	13,18,15,14	688.5
Region 6	Bottom Ash (5)	12,19,20,18,13	680
Region 7	Clayey Sand (4)	19,21,22,20	301.25

SLOPE/W Analysis

Region 8	Bottom Ash (5)	21,23,24,22	273
Region 9	Bottom Ash (5)	11,12,19,21,23,39,38,37	243.875
Region 10	Gravelly Sand (6)	23,25,26,24	81
Region 11	Bottom Ash (3)	26,27,28,29,34,30,35,31,16,15,18,20,22,24	2927.75
Region 12	Riprap (12)	25,40,41,42,43,44,45,11,37,38,39,23	59.875
Region 13	Road Material (8)	32,46,47,33	80.5
Region 14	Clayey Sand (7)	46,40,25,26,27,47	85.5

Points

	X (ft)	Y (ft)
Point 1	0	500
Point 2	335	500
Point 3	0	537
Point 4	335	537
Point 5	335	512
Point 6	0	512
Point 7	0	545
Point 8	335	545
Point 9	0	589
Point 10	27	586
Point 11	39	583
Point 12	51	575
Point 13	67	566.5
Point 14	83.5	557.5
Point 15	158.5	557.5
Point 16	300	557.5
Point 17	334.5	557.5
Point 18	145	566.5
Point 19	65.5	575
Point 20	133	575
Point 21	73	580
Point 22	126	580
Point 23	86	586.5
Point 24	117	586.5
Point 25	90.5	589.5
Point 26	113.5	589.5
Point 27	153	589.5
Point 28	161	587
Point 29	166	584
Point 30	230	575
Point 31	280	570
Point 32	99	593
Point 33	129.5	593
Point 34	184	575
Point 35	240	570
Point 36	8	586
Point 37	52	583

SLOPE/W Analysis

Point 38	59	583
Point 39	77.5	585
Point 40	89	589.5
Point 41	85	588
Point 42	77	586
Point 43	60	584
Point 44	39	584
Point 45	30	585.25
Point 46	93.5	591
Point 47	143.5	591

Critical Slip Surfaces

	Slip Surface	FOS	Center (ft)	Radius (ft)	Entry (ft)	Exit (ft)
1	8886	2.96	(63.183, 681.319)	97.226	(103.836, 593)	(61, 584.118)


Slices of Slip Surface: 8886

	Slip Surface	X (ft)	Y (ft)	PWP (psf)	Base Normal Stress (psf)	Frictional Strength (psf)	Cohesive Strength (psf)
1	8886	61.727275	584.10675	120.00338	11.266171	8.8020973	0
2	8886	63.18182	584.09585	120.00316	32.540073	25.423091	0
3	8886	64.636365	584.1067	119.99659	51.281082	40.065172	0
4	8886	66.09091	584.13935	119.99758	67.443836	52.692899	0
5	8886	67.545455	584.19375	119.99901	80.988344	63.275029	0
6	8886	69	584.27	120.00088	91.884465	71.788012	0
7	8886	70.454545	584.36815	120.00293	100.12128	78.223315	0
8	8886	71.90909	584.48825	119.99808	105.68048	82.56664	0
9	8886	73.363635	584.6304	119.99978	108.56797	84.822598	0
10	8886	74.81818	584.79465	120.00068	108.81354	85.014456	0
11	8886	76.272725	584.9811	120.00054	106.44386	83.163054	0
12	8886	77.666665	585.18035	120.00335	111.73416	87.296296	0
13	8886	79	585.3907	119.99976	124.78022	97.48899	0
14	8886	80.333335	585.6201	120.00074	135.51114	105.8729	0
15	8886	81.666665	585.8687	119.99826	143.95815	112.47244	0
16	8886	83	586.1366	119.99927	150.15511	117.31403	0

SLOPE/W Analysis

17	8886	84.333335	586.424	- 120.00302	154.13064	120.42005	0
18	8886	85.866135	586.7804	- 119.99856	167.60056	130.94391	0
19	8886	87.299205	587.13335	-119.9974	184.59693	124.5122	0.1
20	8886	88.43307	587.43095	-120.0015	195.54538	131.89702	0.1
21	8886	89.75	587.79645	- 119.99887	200.18623	135.02732	0.1
22	8886	91.25	588.23565	- 119.99706	199.91	134.841	0.1
23	8886	92.75	588.70125	- 120.00025	198.89113	134.15376	0.1
24	8886	94.326995	589.22035	- 120.00027	208.75191	140.80494	0.1
25	8886	95.79499	589.72825	- 119.99888	228.61514	154.20286	0.1
26	8886	97.076995	590.1949	- 120.00161	245.39868	165.5235	0.1
27	8886	98.359	590.6821	- 120.00006	260.32494	175.59139	0.1
28	8886	99.087	590.96545	- 120.00239	264.01274	178.07884	0.1
29	8886	99.9509	591.3174	- 119.99943	216.71032	157.44926	0.1
30	8886	101.50475	591.968	- 120.00149	130.39937	94.740689	0.1
31	8886	103.0586	592.6506	- 120.00042	40.059422	29.104874	0.1

Title: Sporn Bottom Ash Disposal Facility
 Comments: LEM - Location A (Exterior Toe)
 Railway Induced Pseudo Static Analysis
 Down Stream Deep Failure Surface
 File Name: BAP_A-A_Slope-DS_Deep.gsz
 Date: 5/3/2010
 Horz Seismic Load: 0.033
 Vert Seismic Load: 0.008



SLOPE/W Analysis

port generated using GeoStudio 2007, version 7.15. Copyright © 1991-2009 GEO-SLOPE International Ltd.

File Information

Title: Sporn Bottom Ash Disposal Facility
Comments: LEM - Location A (Exterior Toe) Railway Induced Pseudo Static Analysis Down Stream Deep Failure Surface
Created By: Seth W. Frank, E.I.
Revision Number: 169
Last Edited By: Seth Frank
Date: 5/3/2010
Time: 4:12:57 PM
File Name: BAP_A-A_Slope-DS_Deep.gsz
Directory: E:\Final Analysis Files\LEM BAP_A-A GA\Deep\
Last Solved Date: 5/3/2010
Last Solved Time: 4:13:12 PM

Project Settings

Length(L) Units: feet
Time(t) Units: Seconds
Force(F) Units: lbf
Pressure(p) Units: psf
Strength Units: psf
Unit Weight of Water: 62.4 pcf
View: 2D

Analysis Settings

SLOPE/W Analysis

Description: Bottom Ash Pond Section A-A Downstream Seismic Stability with Existing Piezo Levels
Kind: SLOPE/W
Method: Morgenstern-Price
Settings
 Apply Phreatic Correction: Yes
 Side Function
 Interslice force function option: Half-Sine
 PWP Conditions Source: Piezometric Line with B-bar
SlipSurface

Direction of movement: Right to Left
Use Passive Mode: No
Slip Surface Option: Entry and Exit
Critical slip surfaces saved: 1
Optimize Critical Slip Surface Location: No
Tension Crack
Tension Crack Option: (none)

FOS Distribution

FOS Calculation Option: Constant

Advanced

Number of Slices: 30
Optimization Tolerance: 0.05
Minimum Slip Surface Depth: 5 ft
Optimization Maximum Iterations: 2000
Optimization Convergence Tolerance: 1e-007
Starting Optimization Points: 8
Ending Optimization Points: 16
Complete Passes per Insertion: 1
Driving Side Maximum Convex Angle: 5 °
Resisting Side Maximum Convex Angle: 1 °

Materials

Fly Ash (2)

Model: Mohr-Coulomb
Unit Weight: 139 pcf
Unit Wt. Above Water Table: 134 pcf
Cohesion: 0.1 psf
Phi: 33 °
Phi-B: 18 °
Pore Water Pressure
Piezometric Line: 1
Add Weight: Yes

Bottom Ash (3)

Model: Mohr-Coulomb
Unit Weight: 80 pcf
Unit Wt. Above Water Table: 80 pcf
Cohesion: 0.1 psf
Phi: 36 °
Phi-B: 20 °
Pore Water Pressure
Piezometric Line: 1

Add Weight: Yes

Clayey Sand (4)

Model: Mohr-Coulomb

Unit Weight: 105 pcf

Unit Wt. Above Water Table: 105 pcf

Cohesion: 0.1 psf

Phi: 31 °

Phi-B: 20 °

Pore Water Pressure

Piezometric Line: 1

B-bar: 0

Add Weight: Yes

Bottom Ash (5)

Model: Mohr-Coulomb

Unit Weight: 80 pcf

Unit Wt. Above Water Table: 62 pcf

Cohesion: 0.1 psf

Phi: 38 °

Phi-B: 20 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Gravelly Sand (6)

Model: Mohr-Coulomb

Unit Weight: 115 pcf

Unit Wt. Above Water Table: 111 pcf

Cohesion: 0.1 psf

Phi: 34 °

Phi-B: 19 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Clayey Sand (7)

Model: Mohr-Coulomb

Unit Weight: 110 pcf

Unit Wt. Above Water Table: 104 pcf

Cohesion: 0.1 psf

Phi: 34 °

Phi-B: 19 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

road Material (8)

Model: Mohr-Coulomb

Unit Weight: 145 pcf

Cohesion: 0.1 psf

Phi: 36 °

Phi-B: 20 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Silty Clay (1)

Model: Mohr-Coulomb

Unit Weight: 123 pcf

Cohesion: 0.1 psf

Phi: 36 °

Phi-B: 20 °

Pore Water Pressure

Piezometric Line: 1

B-bar: 0

Add Weight: Yes

Clayey Sand (9)

Model: Mohr-Coulomb

Unit Weight: 115 pcf

Cohesion: 0.1 psf

Phi: 29 °

Phi-B: 15 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Sand (10)

Model: Mohr-Coulomb

Unit Weight: 123 pcf

Cohesion: 0.1 psf

Phi: 29 °

Phi-B: 15 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Sand and Gravel (11)

Model: Mohr-Coulomb
Unit Weight: 123 pcf
Cohesion: 0.1 psf
Phi: 32 °
Phi-B: 18 °
Pore Water Pressure
Piezometric Line: 1
Add Weight: Yes

Riprap (12)

Model: Mohr-Coulomb
Unit Weight: 115 pcf
Cohesion: 0 psf
Phi: 38 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1
Add Weight: No

Slip Surface Entry and Exit

Left Projection: Range
Left-Zone Left Coordinate: (35, 584.55556) ft
Left-Zone Right Coordinate: (61, 584.11765) ft
Left-Zone Increment: 20
Right Projection: Range
Right-Zone Left Coordinate: (98.5, 592.81818) ft
Right-Zone Right Coordinate: (134.204, 592.328) ft
Right-Zone Increment: 20
Radius Increments: 20

Slip Surface Limits

Left Coordinate: (0, 589) ft
Right Coordinate: (335, 545) ft

Piezometric Lines

Piezometric Line 1

Coordinates

X (ft)	Y (ft)
1	570.5
107	570.5
168	583
334	583

Maximum Suction: 120 psf

Seismic Loads

Horz Seismic Load: 0.033

Vert Seismic Load: 0.008

Ignore seismic load in strength: No

Regions

	Material	Points	Area (ft ²)
Region 1	Sand (10)	3,4,5,6	8375
Region 2	Sand and Gravel (11)	6,5,2,1	4020
Region 3	Clayey Sand (9)	7,8,4,3	2680
Region 4	Silty Clay (1)	9,36,10,45,11,12,13,14,15,16,17,8,7	5834.125
Region 5	Fly Ash (2)	13,18,15,14	688.5
Region 6	Bottom Ash (5)	12,19,20,18,13	680
Region 7	Clayey Sand (4)	19,21,22,20	301.25
Region 8	Bottom Ash (5)	21,23,24,22	273
Region 9	Bottom Ash (5)	11,12,19,21,23,39,38,37	243.875
Region 10	Gravelly Sand (6)	23,25,26,24	81
Region 11	Bottom Ash (3)	26,27,28,29,34,30,35,31,16,15,18,20,22,24	2927.75
Region 12	Riprap (12)	25,40,41,42,43,44,45,11,37,38,39,23	59.875
Region 13	Road Material (8)	32,46,47,33	80.5
Region 14	Clayey Sand (7)	46,40,25,26,27,47	85.5

Points

X (ft)	Y (ft)
--------	--------

SLOPE/W Analysis

Point 1	0	500
Point 2	335	500
Point 3	0	537
Point 4	335	537
Point 5	335	512
Point 6	0	512
Point 7	0	545
Point 8	335	545
Point 9	0	589
Point 10	27	586
Point 11	39	583
Point 12	51	575
Point 13	67	566.5
Point 14	83.5	557.5
Point 15	158.5	557.5
Point 16	300	557.5
Point 17	334.5	557.5
Point 18	145	566.5
Point 19	65.5	575
Point 20	133	575
Point 21	73	580
Point 22	126	580
Point 23	86	586.5
Point 24	117	586.5
Point 25	90.5	589.5
Point 26	113.5	589.5
Point 27	153	589.5
Point 28	161	587
Point 29	166	584
Point 30	230	575
Point 31	280	570
Point 32	99	593

SLOPE/W Analysis

Point 33	129.5	593
Point 34	184	575
Point 35	240	570
Point 36	8	586
Point 37	52	583
Point 38	59	583
Point 39	77.5	585
Point 40	89	589.5
Point 41	85	588
Point 42	77	586
Point 43	60	584
Point 44	39	584
Point 45	30	585.25
Point 46	93.5	591
Point 47	143.5	591

Critical Slip Surfaces

	Slip Surface	FOS	Center (ft)	Radius (ft)	Entry (ft)	Exit (ft)
1	8935	3.08	(79.139, 615.039)	35.849	(107.414, 593)	(61, 584.118)


Slices of Slip Surface: 8935

	Slip Surface	X (ft)	Y (ft)	PWP (psf)	Base Normal Stress (psf)	Frictional Strength (psf)	Cohesive Strength (psf)
1	8935	61.676715	583.74005	-120.00057	63.268393	49.430686	0
2	8935	63.09019	582.99355	-120.00073	173.03503	135.18978	0.1
3	8935	64.56371	582.2966	-119.99908	244.0901	190.70409	0.1
4	8935	66.03723	581.67925	-119.99912	309.54554	241.84348	0.1
5	8935	67.51075	581.1372	-120.00295	368.52089	287.92007	0.1
6	8935	68.984275	580.6668	-120.00109	420.24464	328.33109	0.1
7	8935	70.4578	580.26515	-120.00008	464.13199	362.61965	0.1
8	8935	71.93132	579.92995	-119.99952	499.8019	390.48804	0.1
9	8935	72.83404	579.74905	-119.99954	511.66111	307.43701	0.1

SLOPE/W Analysis

10	8935	73.666665	579.6164	-120.0013	536.26278	322.21918	0.1
11	8935	75	579.4359	-120.00164	561.07546	337.12815	0.1
12	8935	76.333335	579.30605	-119.99809	577.22302	346.83058	0.1
13	8935	77.25	579.2405	-120.00098	588.32117	353.49903	0.1
14	8935	78.25	579.2087	-120.00304	603.41415	362.5678	0.1
15	8935	79.75	579.20285	-120.00256	617.63024	371.10969	0.1
16	8935	81.25	579.25985	-119.99803	622.66406	374.13431	0.1
17	8935	82.75	579.38005	-119.99973	619.4061	372.17673	0.1
18	8935	84.25	579.56405	-120.00111	608.75521	365.77703	0.1
19	8935	85.5	579.76225	-120.00492	602.2389	361.86164	0.1
20	8935	86.35891	579.9262	-120.00023	604.44967	363.19	0.1
21	8935	87.85891	580.2863	-119.99973	619.10255	483.69592	0.1
22	8935	89.75	580.80505	-120.0015	627.88581	490.55816	0.1
23	8935	91.25	581.3068	-120.00053	625.42706	488.63717	0.1
24	8935	92.75	581.88395	-120.00207	621.96572	485.93288	0.1
25	8935	94.1875	582.50985	-120.00008	627.10272	489.94634	0.1
6	8935	95.5625	583.18235	-120.00279	640.59021	500.48393	0.1
27	8935	96.9375	583.9301	-120.00278	651.65106	509.12561	0.1
28	8935	98.3125	584.75875	-120.00302	660.35458	515.92554	0.1
29	8935	99.9174	585.84705	-119.99922	627.9034	490.5719	0.1
30	8935	101.70045	587.20155	-120.00011	540.22934	364.38929	0.1
31	8935	103.43175	588.70155	-119.99827	407.58142	274.91714	0.1
32	8935	105.0159	590.25	-120.00127	276.84491	186.73425	0.1
33	8935	106.3672	591.7395	-120.00238	128.48372	93.348884	0.1
34	8935	107.20695	592.7395	-120.00041	15.557807	11.303409	0.1

Title: Sporn Bottom Ash Disposal Facility
 Comments: LEM - Location B (Crest)
 Railway Induced Pseudo Static Analysis
 Up Stream Shallow Failure Surface
 File Name: BAP_A-A_Slope-US_Shallow.gsz
 Date: 5/3/2010
 Horiz Seismic Load: 0.013
 Vert Seismic Load: 0.002



SLOPE/W Analysis

Report generated using GeoStudio 2007, version 7.15. Copyright © 1991-2009 GEO-SLOPE International Ltd.

File Information

Title: Sporn Bottom Ash Disposal Facility
Comments: LEM - Location B (Crest) Railway Induced Pseudo Static Analysis Up Stream Shallow Failure Surface
Created By: Seth W. Frank, E.I.
Revision Number: 171
Last Edited By: Seth Frank
Date: 5/3/2010
Time: 4:20:21 PM
File Name: BAP_A-A_Slope-US_Shallow.gsz
Directory: E:\Final Analysis Files\LEM BAP_A-A GA\Shallow\
Last Solved Date: 5/3/2010
Last Solved Time: 4:20:44 PM

Project Settings

Length(L) Units: feet
Time(t) Units: Seconds
Force(F) Units: lbf
Pressure(p) Units: psf
Strength Units: psf
Unit Weight of Water: 62.4 pcf
View: 2D

Analysis Settings

SLOPE/W Analysis

Description: Bottom Ash Pond Section A-A Downstream Seismic Stability with Existing Piezo Levels

Kind: SLOPE/W

Method: Morgenstern-Price

Settings

Apply Phreatic Correction: Yes

Side Function

Interslice force function option: Half-Sine

PWP Conditions Source: Piezometric Line with B-bar

SlipSurface

Direction of movement: Left to Right

Use Passive Mode: No

Slip Surface Option: Entry and Exit

Critical slip surfaces saved: 1

Optimize Critical Slip Surface Location: No

Tension Crack

Tension Crack Option: (none)

FOS Distribution

FOS Calculation Option: Constant

Advanced

Number of Slices: 30

Optimization Tolerance: 0.05

Minimum Slip Surface Depth: 5 ft

Optimization Maximum Iterations: 2000

Optimization Convergence Tolerance: 1e-007

Starting Optimization Points: 8

Ending Optimization Points: 16

Complete Passes per Insertion: 1

Driving Side Maximum Convex Angle: 5 °

Resisting Side Maximum Convex Angle: 1 °

Materials

Fly Ash (2)

Model: Mohr-Coulomb

Unit Weight: 139 pcf

Unit Wt. Above Water Table: 134 pcf

Cohesion: 0.1 psf

Phi: 33 °

Phi-B: 18 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Bottom Ash (3)

Model: Mohr-Coulomb

Unit Weight: 80 pcf

Unit Wt. Above Water Table: 80 pcf

Cohesion: 0.1 psf

Phi: 36 °

Phi-B: 20 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Clayey Sand (4)

Model: Mohr-Coulomb

Unit Weight: 105 pcf

Unit Wt. Above Water Table: 105 pcf

Cohesion: 0.1 psf

Phi: 31 °

Phi-B: 20 °

Pore Water Pressure

SLOPE/W Analysis

Piezometric Line: 1

B-bar: 0

Add Weight: Yes

Bottom Ash (5)

Model: Mohr-Coulomb

Unit Weight: 80 pcf

Unit Wt. Above Water Table: 62 pcf

Cohesion: 0.1 psf

Phi: 38 °

Phi-B: 20 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Gravelly Sand (6)

Model: Mohr-Coulomb

Unit Weight: 115 pcf

Unit Wt. Above Water Table: 111 pcf

Cohesion: 0.1 psf

Phi: 34 °

Phi-B: 19 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Clayey Sand (7)

Model: Mohr-Coulomb

Unit Weight: 110 pcf

Unit Wt. Above Water Table: 104 pcf

Cohesion: 0.1 psf

Phi: 34 °

Phi-B: 19 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Road Material (8)

Model: Mohr-Coulomb

Unit Weight: 145 pcf

Cohesion: 0.1 psf

Phi: 36 °

Phi-B: 20 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Silty Clay (1)

Model: Mohr-Coulomb

SLOPE/W Analysis

Unit Weight: 123 pcf
Cohesion: 0.1 psf
Phi: 36 °
Phi-B: 20 °
Pore Water Pressure
Piezometric Line: 1
B-bar: 0
Add Weight: Yes

Clayey Sand (9)

Model: Mohr-Coulomb
Unit Weight: 115 pcf
Cohesion: 0.1 psf
Phi: 29 °
Phi-B: 15 °
Pore Water Pressure
Piezometric Line: 1
Add Weight: Yes

Sand (10)

Model: Mohr-Coulomb
Unit Weight: 123 pcf
Cohesion: 0.1 psf
Phi: 29 °
Phi-B: 15 °
Pore Water Pressure
Piezometric Line: 1
Add Weight: Yes

Sand and Gravel (11)

Model: Mohr-Coulomb
Unit Weight: 123 pcf
Cohesion: 0.1 psf
Phi: 32 °
Phi-B: 18 °
Pore Water Pressure
Piezometric Line: 1
Add Weight: Yes

Riprap (12)

Model: Mohr-Coulomb
Unit Weight: 115 pcf
Cohesion: 0 psf
Phi: 38 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1
Add Weight: No

Slip Surface Entry and Exit

Left Projection: Range
 Left-Zone Left Coordinate: (111, 593) ft
 Left-Zone Right Coordinate: (145, 590.76316) ft
 Left-Zone Increment: 15
 Right Projection: Range
 Right-Zone Left Coordinate: (184.69356, 575) ft
 Right-Zone Right Coordinate: (242, 570) ft
 Right-Zone Increment: 30
 Radius Increments: 30

Slip Surface Limits

Left Coordinate: (0, 589) ft
 Right Coordinate: (335, 545) ft

Piezometric Lines

Piezometric Line 1

Coordinates

	X (ft)	Y (ft)
	1	570
	107	570
	168	583
	334	583

Maximum Suction: 120 psf

Seismic Loads

Horz Seismic Load: 0.013
 Vert Seismic Load: 0.002
 Ignore seismic load in strength: No

Regions

	Material	Points	Area (ft ²)
Region 1	Sand (10)	3,4,5,6	8375
Region 2	Sand and Gravel (11)	6,5,2,1	4020
Region 3	Clayey Sand (9)	7,8,4,3	2680
Region 4	Silty Clay (1)	9,36,10,45,11,12,13,14,15,16,17,8,7	5834.125
Region 5	Fly Ash (2)	13,18,15,14	688.5
Region 6	Bottom Ash (5)	12,19,20,18,13	680
Region 7	Clayey Sand (4)	19,21,22,20	301.25

SLOPE/W Analysis

Region 8	Bottom Ash (5)	21,23,24,22	273
Region 9	Bottom Ash (5)	11,12,19,21,23,39,38,37	243.875
Region 10	Gravelly Sand (6)	23,25,26,24	81
Region 11	Bottom Ash (3)	26,27,28,29,34,30,35,31,16,15,18,20,22,24	2927.75
Region 12	Riprap (17)	25,40,41,42,43,44,45,11,37,38,39,23	59.875
Region 13	Road Material (8)	32,46,47,33	80.5
Region 14	Clayey Sand (7)	46,40,25,26,27,47	85.5

Points

	X (ft)	Y (ft)
Point 1	0	500
Point 2	335	500
Point 3	0	537
Point 4	335	537
Point 5	335	512
Point 6	0	512
Point 7	0	545
Point 8	335	545
Point 9	0	589
Point 10	27	586
Point 11	39	583
Point 12	51	575
Point 13	67	566.5
Point 14	83.5	557.5
Point 15	158.5	557.5
Point 16	300	557.5
Point 17	334.5	557.5
Point 18	145	566.5
Point 19	65.5	575
Point 20	133	575
Point 21	73	580
Point 22	126	580
Point 23	86	586.5
Point 24	117	586.5
Point 25	90.5	589.5
Point 26	113.5	589.5
Point 27	153	589.5
Point 28	161	587
Point 29	166	584
Point 30	230	575
Point 31	280	570
Point 32	99	593
Point 33	129.5	593
Point 34	184	575
Point 35	240	570
Point 36	8	586
Point 37	52	583

SLOPE/W Analysis

Point 38	59	583
Point 39	77.5	585
Point 40	89	589.5
Point 41	85	588
Point 42	77	586
Point 43	60	584
Point 44	39	584
Point 45	30	585.25
Point 46	93.5	591
Point 47	143.5	591

Critical Slip Surfaces

	Slip Surface	FOS	Center (ft)	Radius (ft)	Entry (ft)	Exit (ft)
1	14521	1.70	(180.119, 618.555)	44.785	(145, 590.763)	(190.542, 575)


Slices of Slip Surface: 14521

	Slip Surface	X (ft)	Y (ft)	PWP (psf)	Base Normal Stress (psf)	Frictional Strength (psf)	Cohesive Strength (psf)
1	14521	145.51885	590.1316	- 120.00117	18.684997	12.60319	0.1
2	14521	146.7339	588.7209	- 119.99814	91.506002	66.483002	0.1
3	14521	148.12635	587.23075	- 119.99966	160.54552	116.64314	0.1
4	14521	149.51885	585.86795	- 120.00143	224.63109	163.20404	0.1
5	14521	150.9113	584.617	- 119.99767	284.48892	206.6933	0.1
6	14521	152.30375	583.4659	- 120.00261	340.73808	247.56071	0.1
7	14521	153.86155	582.2902	- 120.00041	394.2038	286.40583	0.1
8	14521	155.58465	581.10205	- 44.645913	450.71182	327.4613	0.1
9	14521	157.20515	580.08565	36.637589	501.83044	337.98239	0.1
10	14521	158.7231	579.22075	107.57206	545.99128	318.53021	0.1
11	14521	160.24105	578.4319	173.96704	584.09716	297.97697	0.1
12	14521	161.83335	577.6831	238.91299	602.01999	263.81268	0.1
13	14521	163.5	576.9772	302.25081	598.37303	215.14539	0.1
14	14521	165.16665	576.3489	360.95191	587.16472	164.35323	0.1
15	14521	167	575.74725	420.18735	573.18918	111.16234	0.1
16	14521	168.72725	575.2495	483.62893	582.27091	71.667592	0.1
17	14521	170.1818	574.8927	505.89347	611.80356	76.948185	0.1
18	14521	171.63635	574.5869	524.97528	637.85765	82.013846	0.1
19	14521	173.0909	574.331	540.94389	659.79946	86.353622	0.1
20	14521	174.54545	574.1242	553.84827	676.93628	89.428671	0.1
21	14521	176	573.9658	563.73598	688.55653	90.68744	0.1
22	14521	177.45455	573.8553	570.63013	693.96881	89.610798	0.1

SLOPE/W Analysis

23	14521	178.9091	573.79235	574.56105	692.47242	85.667623	0.1
24	14521	180.36365	573.77665	575.53897	683.59862	78.509931	0.1
25	14521	181.8182	573.80825	573.56653	666.88926	67.802929	0.1
26	14521	183.27275	573.88725	568.63857	642.11438	53.3833	0.1
27	14521	184.8178	574.0249	560.04928	593.52163	24.319086	0.1
28	14521	186.45335	574.22805	547.36871	575.00498	20.078921	0.1
29	14521	188.0889	574.49285	530.84588	549.48493	13.542062	0.1
30	14521	189.72445	574.8204	510.407	517.1551	4.90278	0.1

Title: Sporn Bottom Ash Disposal Facility
 Comments: LEM - Location B (Crest)
 Railway Induced Pseudo Static Analysis
 Up Stream Deep Failure Surface
 File Name: BAP_A-A_Slope-US_Deep.gsz
 Date: 5/3/2010
 Horz Seismic Load: 0.013
 Vert Seismic Load: 0.002



SLOPE/W Analysis

Report generated using GeoStudio 2007, version 7.15. Copyright © 1991-2009 GEO-SLOPE International Ltd.

File Information

Title: Sporn Bottom Ash Disposal Facility
Comments: LEM - Location B (Crest) Railway Induced Pseudo Static Analysis Up Stream Deep Failure Surface
Created By: Seth W. Frank, E.I.
Revision Number: 170
Last Edited By: Seth Frank
Date: 5/3/2010
Time: 4:24:31 PM
File Name: BAP_A-A_Slope-US_Deep.gsz
Directory: E:\Final Analysis Files\LEM BAP_A-A GA\Deep\
Last Solved Date: 5/3/2010
Last Solved Time: 4:24:58 PM

Project Settings

Length(L) Units: feet
Time(t) Units: Seconds
Force(F) Units: lbf
Pressure(p) Units: psf
Strength Units: psf
Unit Weight of Water: 62.4 pcf
View: 2D

Analysis Settings

SLOPE/W Analysis

Description: Bottom Ash Pond Section A-A Downstream Seismic Stability with Existing Piezo Levels
Kind: SLOPE/W
Method: Morgenstern-Price
Settings
 Apply Phreatic Correction: Yes
 Side Function
 Interslice force function option: Half-Sine
 PWP Conditions Source: Piezometric Line with B-bar
SlipSurface

Direction of movement: Left to Right
Use Passive Mode: No
Slip Surface Option: Entry and Exit
Critical slip surfaces saved: 1
Optimize Critical Slip Surface Location: No
Tension Crack
Tension Crack Option: (none)

FOS Distribution

FOS Calculation Option: Constant

Advanced

Number of Slices: 30
Optimization Tolerance: 0.05
Minimum Slip Surface Depth: 10 ft
Optimization Maximum Iterations: 2000
Optimization Convergence Tolerance: 1e-007
Starting Optimization Points: 8
Ending Optimization Points: 16
Complete Passes per Insertion: 1
Driving Side Maximum Convex Angle: 5 °
Resisting Side Maximum Convex Angle: 1 °

Materials

Fly Ash (2)

Model: Mohr-Coulomb
Unit Weight: 139 pcf
Unit Wt. Above Water Table: 134 pcf
Cohesion: 0.1 psf
Phi: 33 °
Phi-B: 18 °
Pore Water Pressure
Piezometric Line: 1
Add Weight: Yes

Bottom Ash (3)

Model: Mohr-Coulomb
Unit Weight: 80 pcf
Unit Wt. Above Water Table: 80 pcf
Cohesion: 0.1 psf
Phi: 36 °
Phi-B: 20 °
Pore Water Pressure
Piezometric Line: 1

Add Weight: Yes

Clayey Sand (4)

Model: Mohr-Coulomb

Unit Weight: 105 pcf

Unit Wt. Above Water Table: 105 pcf

Cohesion: 0.1 psf

Phi: 31 °

Phi-B: 20 °

Pore Water Pressure

Piezometric Line: 1

B-bar: 0

Add Weight: Yes

Bottom Ash (5)

Model: Mohr-Coulomb

Unit Weight: 80 pcf

Unit Wt. Above Water Table: 62 pcf

Cohesion: 0.1 psf

Phi: 38 °

Phi-B: 20 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Gravelly Sand (6)

Model: Mohr-Coulomb

Unit Weight: 115 pcf

Unit Wt. Above Water Table: 111 pcf

Cohesion: 0.1 psf

Phi: 34 °

Phi-B: 19 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Clayey Sand (7)

Model: Mohr-Coulomb

Unit Weight: 110 pcf

Unit Wt. Above Water Table: 104 pcf

Cohesion: 0.1 psf

Phi: 34 °

Phi-B: 19 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Load Material (8)

Model: Mohr-Coulomb

Unit Weight: 145 pcf

Cohesion: 0.1 psf

Phi: 36 °

Phi-B: 20 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Silty Clay (1)

Model: Mohr-Coulomb

Unit Weight: 123 pcf

Cohesion: 0.1 psf

Phi: 36 °

Phi-B: 20 °

Pore Water Pressure

Piezometric Line: 1

B-bar: 0

Add Weight: Yes

Clayey Sand (9)

Model: Mohr-Coulomb

Unit Weight: 115 pcf

Cohesion: 0.1 psf

Phi: 29 °

Phi-B: 15 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Sand (10)

Model: Mohr-Coulomb

Unit Weight: 123 pcf

Cohesion: 0.1 psf

Phi: 29 °

Phi-B: 15 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Sand and Gravel (11)

Model: Mohr-Coulomb
Unit Weight: 123 pcf
Cohesion: 0.1 psf
Phi: 32 °
Phi-B: 18 °
Pore Water Pressure
Piezometric Line: 1
Add Weight: Yes

Riprap (12)

Model: Mohr-Coulomb
Unit Weight: 115 pcf
Cohesion: 0 psf
Phi: 38 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1
Add Weight: No

Slip Surface Entry and Exit

Left Projection: Range
Left-Zone Left Coordinate: (99.45937, 593) ft
Left-Zone Right Coordinate: (129.5, 593) ft
Left-Zone Increment: 15
Right Projection: Range
Right-Zone Left Coordinate: (184.69356, 575) ft
Right-Zone Right Coordinate: (277, 570) ft
Right-Zone Increment: 30
Radius Increments: 30

Slip Surface Limits

Left Coordinate: (0, 589) ft
Right Coordinate: (335, 545) ft

Piezometric Lines

Piezometric Line 1

Coordinates

X (ft)	Y (ft)
1	570
107	570
168	583
334	583

Maximum Suction: 120 psf

Seismic Loads

Horz Seismic Load: 0.013

Vert Seismic Load: 0.002

Ignore seismic load in strength: No

Regions

	Material	Points	Area (ft ²)
Region 1	Sand (10)	3,4,5,6	8375
Region 2	Sand and Gravel (11)	6,5,2,1	4020
Region 3	Clayey Sand (9)	7,8,4,3	2680
Region 4	Silty Clay (1)	9,36,10,45,11,12,13,14,15,16,17,8,7	5834.125
Region 5	Fly Ash (2)	13,18,15,14	688.5
Region 6	Bottom Ash (5)	12,19,20,18,13	680
Region 7	Clayey Sand (4)	19,21,22,20	301.25
Region 8	Bottom Ash (5)	21,23,24,22	273
Region 9	Bottom Ash (5)	11,12,19,21,23,39,38,37	243.875
Region 10	Gravelly Sand (6)	23,25,26,24	81
Region 11	Bottom Ash (3)	26,27,28,29,34,30,35,31,16,15,18,20,22,24	2927.75
Region 12	Riprap (12)	25,40,41,42,43,44,45,11,37,38,39,23	59.875
Region 13	Road Material (8)	32,46,47,33	80.5
Region 14	Clayey Sand (7)	46,40,25,26,27,47	85.5

Points

X (ft)	Y (ft)
--------	--------

SLOPE/W Analysis

Point 1	0	500
Point 2	335	500
Point 3	0	537
Point 4	335	537
Point 5	335	512
Point 6	0	512
Point 7	0	545
Point 8	335	545
Point 9	0	589
Point 10	27	586
Point 11	39	583
Point 12	51	575
Point 13	67	566.5
Point 14	83.5	557.5
Point 15	158.5	557.5
Point 16	300	557.5
Point 17	334.5	557.5
Point 18	145	566.5
Point 19	65.5	575
Point 20	133	575
Point 21	73	580
Point 22	126	580
Point 23	86	586.5
Point 24	117	586.5
Point 25	90.5	589.5
Point 26	113.5	589.5
Point 27	153	589.5
Point 28	161	587
Point 29	166	584
Point 30	230	575
Point 31	280	570
Point 32	99	593

SLOPE/W Analysis

Point 33	129.5	593
Point 34	184	575
Point 35	240	570
Point 36	8	586
Point 37	52	583
Point 38	59	583
Point 39	77.5	585
Point 40	89	589.5
Point 41	85	588
Point 42	77	586
Point 43	60	584
Point 44	39	584
Point 45	30	585.25
Point 46	93.5	591
Point 47	143.5	591

Critical Slip Surfaces

	Slip Surface	FOS	Center (ft)	Radius (ft)	Entry (ft)	Exit (ft)
1	14583	2.02	(177.569, 633.864)	63.092	(129.5, 593)	(200.275, 575)

Slices of Slip Surface: 14583


	Slip Surface	X (ft)	Y (ft)	PWP (psf)	Base Normal Stress (psf)	Frictional Strength (psf)	Cohesive Strength (psf)
1	14583	130.3873	592	-120.00172	72.537349	52.701469	0.1
2	14583	131.9923	590.25	-120.00096	216.3283	145.91528	0.1
3	14583	133.789	588.4596	-119.99908	305.76698	222.15272	0.1
4	14583	135.947	586.4716	-119.99968	396.64481	288.17933	0.1
5	14583	138.105	584.6586	-120.00062	479.73498	348.54787	0.1
6	14583	140.263	583.0018	-120	555.9645	403.93186	0.1
7	14583	142.421	581.4863	-119.99918	626.08437	454.87692	0.1
8	14583	144.42355	580.19185	-120.00133	689.59767	501.02204	0.1
9	14583	146.2707	579.09375	-43.250596	752.63389	546.82053	0.1

SLOPE/W Analysis

10	14583	148.6457	577.817	63.172602	830.15827	557.24771	0.1
11	14583	151.54855	576.41065	184.04323	916.46617	532.13642	0.1
12	14583	154.33335	575.22495	290.23947	976.9592	498.93109	0.1
13	14583	157	574.23665	383.14394	1012.8074	457.47728	0.1
14	14583	159.66665	573.38205	468.09944	1037.672	413.81867	0.1
15	14583	162.25	572.67445	543.19547	1024.6562	349.80173	0.1
16	14583	164.75	572.10205	609.13733	972.63014	264.09298	0.1
17	14583	167	571.67265	663.38834	923.50873	188.98853	0.1
18	14583	169.14285	571.34865	727.02551	914.41841	136.14892	0.1
19	14583	171.42855	571.0828	743.61388	933.15313	137.70832	0.1
20	14583	173.71425	570.90105	754.98014	944.10728	137.40891	0.1
21	14583	176	570.80265	761.10184	946.41322	134.63659	0.1
22	14583	178.28575	570.7872	762.07575	939.20805	128.69415	0.1
23	14583	180.57145	570.85465	757.85286	921.59837	118.96808	0.1
24	14583	182.85715	571.00525	748.45627	892.88984	104.93713	0.1
25	14583	185.1625	571.24235	733.69385	835.01816	73.616416	0.1
26	14583	187.48745	571.56835	713.35184	809.56131	69.900275	0.1
27	14583	189.8124	571.9834	687.41949	774.50725	63.272963	0.1
28	14583	192.13735	572.48935	655.85488	729.75992	53.695152	0.1
29	14583	194.4623	573.0884	618.4998	675.31475	41.278482	0.1
30	14583	196.78725	573.78335	575.13338	611.34806	26.311506	0.1
31	14583	199.1122	574.5776	525.57154	538.14386	9.134326	0.1

**FLY ASH DISPOSAL FACILITY
SECTION H-H
LEM SLOPE STABILITY ANALYSIS RESULTS**

Title: Sporn Fly Ash Disposal Facility
 Comments: LEM - Location C (Exterior Toe)
 Railway Induced Pseudo Static Analysis
 Down Stream Shallow Failure Surface
 File Name: FAP_H-H_Slope-DS_Shallow.gsz
 Date: 5/3/2010
 Horz Seismic Load: 0.046
 Vert Seismic Load: 0.008



SLOPE/W Analysis

Report generated using GeoStudio 2007, version 7.15. Copyright © 1991-2009 GEO-SLOPE International Ltd.

File Information

Title: Sporn Fly Ash Disposal Facility
Comments: LEM - Location C (Exterior Toe) Railway Induced Pseudo Static Analysis Down Stream Shallow Failure Surface
Created By: Seth W. Frank, E.I.
Revision Number: 172
Last Edited By: Seth Frank
Date: 5/3/2010
Time: 3:17:51 PM
File Name: FAP_H-H_Slope-DS_Shallow.gsz
Directory: E:\Final Analysis Files\LEM FAP_H-H GA\Shallow\
Last Solved Date: 5/3/2010
Last Solved Time: 3:18:12 PM

Project Settings

Length(L) Units: feet
Time(t) Units: Seconds
Force(F) Units: lbf
Pressure(p) Units: psf
Strength Units: psf
Unit Weight of Water: 62.4 pcf
View: 2D

Analysis Settings

SLOPE/W Analysis

Description: Fly Ash Pond Section H-H Downstream Seismic Stability
Kind: SLOPE/W
Method: Morgenstern-Price

Settings

Apply Phreatic Correction: Yes
Side Function
Interslice force function option: Half-Sine
PWP Conditions Source: Piezometric Line with B-bar

SlipSurface

Direction of movement: Right to Left
Use Passive Mode: No
Slip Surface Option: Entry and Exit
Critical slip surfaces saved: 1
Optimize Critical Slip Surface Location: No
Tension Crack

Tension Crack Option: (none)

FOS Distribution

FOS Calculation Option: Constant

Advanced

Number of Slices: 50

Optimization Tolerance: 0.05

Minimum Slip Surface Depth: 1 ft

Optimization Maximum Iterations: 2000

Optimization Convergence Tolerance: 1e-007

Starting Optimization Points: 8

Ending Optimization Points: 16

Complete Passes per Insertion: 1

Driving Side Maximum Convex Angle: 5 °

Resisting Side Maximum Convex Angle: 1 °

Materials

Silty Sand (1)

Model: Mohr-Coulomb

Unit Weight: 130 pcf

Unit Wt. Above Water Table: 125 pcf

Cohesion: 0.1 psf

Phi: 34 °

Phi-B: 18 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Silty Sand (2)

Model: Mohr-Coulomb

Unit Weight: 112 pcf

Unit Wt. Above Water Table: 107 pcf

Cohesion: 0.1 psf

Phi: 35 °

Phi-B: 18 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Gravelly Sand (3)

Model: Mohr-Coulomb

Unit Weight: 110 pcf

Unit Wt. Above Water Table: 105 pcf

Cohesion: 0.1 psf

Phi: 33 °

Phi-B: 17 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Silty Clay (4)

Model: Mohr-Coulomb

Unit Weight: 120 pcf

Unit Wt. Above Water Table: 115 pcf

Cohesion: 0.1 psf

Phi: 32 °

Phi-B: 17 °

Pore Water Pressure

Piezometric Line: 1

B-bar: 0

Add Weight: Yes

Silty Sand (5)

Model: Mohr-Coulomb

Unit Weight: 131 pcf

Unit Wt. Above Water Table: 126 pcf

Cohesion: 0.1 psf

Phi: 31 °

Phi-B: 16 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Sandy Silt (6)

Model: Mohr-Coulomb

Unit Weight: 130 pcf

Unit Wt. Above Water Table: 125 pcf

Cohesion: 0.1 psf

Phi: 27 °

Phi-B: 14 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Fly Ash (7)

Model: Mohr-Coulomb

Unit Weight: 90 pcf

Unit Wt. Above Water Table: 102 pcf

Cohesion: 0.1 psf

Phi: 27 °

Phi-B: 15 °

Pore Water Pressure

Piezometric Line: 1

B-bar: 0

Add Weight: Yes

Rock Fill (9)

Model: Mohr-Coulomb

Unit Weight: 115 pcf

Cohesion: 0 psf

Phi: 38 °

Phi-B: 0 "

Pore Water Pressure

Piezometric Line: 1

Add Weight: No

Slip Surface Entry and Exit

Left Projection: Range

Left-Zone Left Coordinate: (33, 590.06452) ft

Left-Zone Right Coordinate: (78, 592.34198) ft

Left-Zone Increment: 20

Right Projection: Range

Right-Zone Left Coordinate: (126, 610.18182) ft

Right-Zone Right Coordinate: (146.73585, 611) ft

Right-Zone Increment: 20

Radius Increments: 30

Slip Surface Limits

Left Coordinate: (0, 593) ft

Right Coordinate: (310, 588) ft

Piezometric Lines

Piezometric Line 1

Coordinates

	X (ft)	Y (ft)
	0	589
	135	589
	146	605
	309	605

Seismic Loads

Horz Seismic Load: 0.046

Vert Seismic Load: 0.008

Ignore seismic load in strength: No

Regions

	Material	Points	Area (ft ²)
Region 1	Sandy Silt (6)	1,3,4,5,6,2	5355
Region 2	Silty Sand (5)	7,8,4,3	2085
Region 3	Silty Sand (1)	7,9,36,35,34,33,32,42,10,12,13,14,29,8	973.49995
Region 4	Silty Sand (2)	11,37,38,39,16,12,10	420
Region 5	Silty Clay (4)	16,17,18,19,20,13,12	134
Region 6	Gravelly Sand (3)	41,17,16,39	148
Region 7	Silty Sand (2)	19,20,23,24,22	51.5
Region 8	Silty Sand (1)	40,26,21,18,17,41	19
Region 9	Silty Sand (2)	13,20,23,24,14	324
Region 10	Gravelly Sand (3)	21,27,28,22,19,18	121
Region 11	Fly Ash (7)	30,31,6,5,4,8,29	2399
Region 12	Rock Fill (9)	11,10,42,15,25,40,41,39,38,37	120.4339

Points

	X (ft)	Y (ft)
Point 1	0	555
Point 2	310	555
Point 3	0	576
Point 4	218	576
Point 5	248	561
Point 6	310	561
Point 7	0	586
Point 8	199	586
Point 9	0	590
Point 10	76	591
Point 11	82	592
Point 12	137	591
Point 13	139	591
Point 14	189	591
Point 15	106	602
Point 16	137	602
Point 17	137	610
Point 18	145	610
Point 19	145	602
Point 20	145	597
Point 21	149	610
Point 22	167	602
Point 23	148	600
Point 24	170	600
Point 25	128	611
Point 26	147	611
Point 27	154	608
Point 28	159	608
Point 29	193	589

SLOPE/W Analysis

Point 30	201	588
Point 31	310	588
Point 32	49.5	590.5
Point 33	46.5	590.5
Point 34	31	590
Point 35	15.5	592
Point 36	0	593
Point 37	91	592
Point 38	107	600
Point 39	109	602
Point 40	130	611
Point 41	128	610
Point 42	74	590.96226

Critical Slip Surfaces

	Slip Surface	FOS	Center (ft)	Radius (ft)	Entry (ft)	Exit (ft)
1	13115	1.84	(20.316, 828.893)	243.483	(128.974, 611)	(78, 592.342)

Slices of Slip Surface: 13115

	Slip Surface	X (ft)	Y (ft)	PWP (psf)	Base Normal Stress (psf)	Frictional Strength (psf)	Cohesive Strength (psf)
1	13115	78.51852	592.46965	-216.50769	5.3842747	4.2066564	0
2	13115	79.555555	592.72735	-232.58337	15.904935	12.426297	0
3	13115	80.59259	592.9899	-248.9737	25.926002	20.255613	0
4	13115	81.62963	593.2573	-265.65718	35.439622	27.688467	0
5	13115	82.66667	593.52955	-282.6505	44.435682	34.71696	0
6	13115	83.703705	593.80675	-299.94209	52.906969	41.335455	0
7	13115	84.74074	594.08885	-317.53899	60.844514	47.536944	0
8	13115	85.77778	594.37585	-335.45715	68.243118	53.317367	0
9	13115	86.814815	594.6678	-353.66625	75.094015	58.669874	0
10	13115	87.85185	594.9647	-372.20097	81.392268	63.590609	0
11	13115	88.88889	595.2666	-391.03985	87.132038	68.075009	0
12	13115	89.925925	595.5735	-410.18955	92.310436	72.120817	0
13	13115	90.96296	595.8854	-429.64781	96.921991	75.723758	0
14	13115	92	596.20235	-449.42961	100.97398	78.889522	0
15	13115	93.03704	596.52435	-469.52288	104.4509	81.605984	0


SLOPE/W Analysis

16	13115	94.074075	596.85145	-489.93399	107.36404	83.881977	0
17	13115	95.11111	597.18365	-510.66001	109.70638	85.712015	0
18	13115	96.14815	597.52095	-531.70667	111.48925	87.104947	0
19	13115	97.185185	597.86345	-553.08056	112.71505	88.06265	0
20	13115	98.22222	598.2111	-574.7684	113.37682	88.57968	0
21	13115	99.25926	598.5639	-596.78524	113.49528	88.672234	0
22	13115	100.29629	598.92195	-619.12777	113.05471	88.328019	0
23	13115	101.33335	599.28525	-641.80173	112.07592	87.563304	0
24	13115	102.3704	599.6538	-664.79402	110.56144	86.380065	0
25	13115	103.4074	600.02765	-688.12836	108.51398	84.780412	0
26	13115	104.44445	600.4068	-711.78238	105.94526	82.773508	0
27	13115	105.4815	600.7913	-735.77955	102.84906	80.354491	0
28	13115	106.5	601.17415	-759.66379	102.51369	80.092476	0
29	13115	107.5	601.55515	-783.44447	104.93794	81.986502	0
30	13115	108.5	601.9412	-807.53256	106.84764	83.478529	0
31	13115	109.5	602.3323	-831.93448	108.26398	84.585091	0
32	13115	110.5	602.7285	-856.65507	109.17069	85.293492	0
33	13115	111.5	603.1298	-881.70061	109.59829	85.627567	0
34	13115	112.5	603.53625	-907.06478	109.53046	85.574578	0
35	13115	113.5	603.94795	-932.73602	108.9701	85.136774	0
36	13115	114.5	604.3648	-958.7649	107.93828	84.330628	0
37	13115	115.5	604.7869	-985.12691	106.40991	83.13653	0
38	13115	116.5	605.2143	-1011.7268	104.41557	81.578382	0
39	13115	117.5	605.64695	-1038.7441	101.9306	79.636915	0
40	13115	118.5	606.08495	-1066.0805	98.967046	77.32153	0
41	13115	119.5	606.5283	-1093.7316	95.509728	74.620377	0
42	13115	120.5	606.977	-1121.7839	91.580149	71.550254	0

SLOPE/W Analysis

43	13115	121.5	607.43115	- 1150.1404	87.156902	68.094435	0
44	13115	122.5	607.8908	- 1178.7953	82.240646	64.253435	0
45	13115	123.5	608.35595	- 1207.8356	76.825951	60.023011	0
46	13115	124.5	608.8266	- 1237.1622	70.907255	55.398819	0
47	13115	125.5	609.3028	- 1266.8628	64.478599	50.376203	0
48	13115	126.5	609.7846	- 1296.9296	57.533026	44.949726	0
49	13115	127.5	610.27205	- 1327.3558	50.061147	39.112054	0
50	13115	128.4868	610.7586	- 1357.7005	23.09149	18.041049	0

Title: Sporn Fly Ash Disposal Facility
 Comments: LEM - Location C (Exterior Toe)
 Railway Induced Pseudo Static Analysis
 Down Stream Deep Failure Surface
 File Name: FAP_H-H_Slope-DS_Deep.gsz
 Date: 5/4/2010
 Horz Seismic Load: 0.046
 Vert Seismic Load: 0.008



SLOPE/W Analysis

Report generated using GeoStudio 2007, version 7.16. Copyright © 1991-2010 GEO-SLOPE International Ltd.

File Information

Title: Sporn Fly Ash Disposal Facility
Comments: LEM - Location C (Exterior Toe) Railway Induced Pseudo Static Analysis Down Stream
Deep Failure Surface
Created By: Seth W. Frank, E.I.
Revision Number: 174
Last Edited By: Roger Cecil
Date: 5/4/2010
Time: 8:59:09 PM
File Name: FAP_H-H_Slope-DS_Deep.gsz
Directory: P:\Frank\Philip Sporn\Final Analysis Files\LEM FAP_H-H GA\Deep\
Last Solved Date: 5/4/2010
Last Solved Time: 8:59:49 PM

Project Settings

Length(L) Units: feet
Time(t) Units: Seconds
Force(F) Units: lbf
Pressure(p) Units: psf
Strength Units: psf
Unit Weight of Water: 62.4 pcf
View: 2D

Analysis Settings

SLOPE/W Analysis

Description: Fly Ash Pond Section H-H Downstream Seismic Stability

Kind: SLOPE/W

Method: Morgenstern-Price

Settings

Apply Phreatic Correction: Yes

Side Function

Interslice force function option: Half-Sine

PWP Conditions Source: Piezometric Line with B-bar

Slip Surface

Direction of movement: Right to Left

Use Passive Mode: No

Slip Surface Option: Entry and Exit

Critical slip surfaces saved: 1

Optimize Critical Slip Surface Location: No
Tension Crack

Tension Crack Option: (none)

FOS Distribution

FOS Calculation Option: Constant

Advanced

Number of Slices: 50

Optimization Tolerance: 0.05

Minimum Slip Surface Depth: 5 ft

Optimization Maximum Iterations: 2000

Optimization Convergence Tolerance: 1e-007

Starting Optimization Points: 8

Ending Optimization Points: 16

Complete Passes per Insertion: 1

Driving Side Maximum Convex Angle: 5 °

Resisting Side Maximum Convex Angle: 1 °

Materials

Silty Sand (1)

Model: Mohr-Coulomb

Unit Weight: 130 pcf

Unit Wt. Above Water Table: 125 pcf

Cohesion: 0.1 psf

Phi: 34 °

Phi-B: 18 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Silty Sand (2)

Model: Mohr-Coulomb

Unit Weight: 112 pcf

Unit Wt. Above Water Table: 107 pcf

Cohesion: 0.1 psf

Phi: 35 °

Phi-B: 18 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Gravelly Sand (3)

Model: Mohr-Coulomb

Unit Weight: 110 pcf

Unit Wt. Above Water Table: 105 pcf

Cohesion: 0.1 psf

Phi: 33 °
Phi-B: 17 °
Pore Water Pressure
Piezometric Line: 1
Add Weight: Yes

Silty Clay (4)

Model: Mohr-Coulomb
Unit Weight: 120 pcf
Unit Wt. Above Water Table: 115 pcf
Cohesion: 0.1 psf
Phi: 32 °
Phi-B: 17 °
Pore Water Pressure
Piezometric Line: 1
B-bar: 0
Add Weight: Yes

Silty Sand (5)

Model: Mohr-Coulomb
Unit Weight: 131 pcf
Unit Wt. Above Water Table: 126 pcf
Cohesion: 0.1 psf
Phi: 31 °
Phi-B: 16 °
Pore Water Pressure
Piezometric Line: 1
Add Weight: Yes

Sandy Silt (6)

Model: Mohr-Coulomb
Unit Weight: 130 pcf
Unit Wt. Above Water Table: 125 pcf
Cohesion: 0.1 psf
Phi: 27 °
Phi-B: 14 °
Pore Water Pressure
Piezometric Line: 1
Add Weight: Yes

Fly Ash (7)

Model: Mohr-Coulomb
Unit Weight: 90 pcf
Unit Wt. Above Water Table: 102 pcf
Cohesion: 0.1 psf
Phi: 27 °
Phi-B: 15 °
Pore Water Pressure

Piezometric Line: 1
B-bar: 0
Add Weight: Yes

Rock Fill (9)

Model: Mohr-Coulomb
Unit Weight: 115 pcf
Cohesion: 0 psf
Phi: 38 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1
Add Weight: No

Slip Surface Entry and Exit

Left Projection: Range
Left-Zone Left Coordinate: (31, 590) ft
Left-Zone Right Coordinate: (74, 590.96226) ft
Left-Zone Increment: 20
Right Projection: Range
Right-Zone Left Coordinate: (128, 611) ft
Right-Zone Right Coordinate: (159, 608) ft
Right-Zone Increment: 20
Radius Increments: 30

Slip Surface Limits

Left Coordinate: (0, 593) ft
Right Coordinate: (310, 588) ft

Piezometric Lines

Piezometric Line 1

Coordinates

	X (ft)	Y (ft)
	0	589
	135	589
	146	605
	309	605

Seismic Loads

Horz Seismic Load: 0.046

Vert Seismic Load: 0.008

Ignore seismic load in strength: No

Regions

	Material	Points	Area (ft ²)
Region 1	Sandy Silt (6)	1,3,4,5,6,2	5355
Region 2	Silty Sand (5)	7,8,4,3	2085
Region 3	Silty Sand (1)	7,9,36,35,34,33,32,42,10,12,13,14,29,8	973.49995
Region 4	Silty Sand (2)	11,37,38,39,16,12,10	420
Region 5	Silty Clay (4)	16,17,18,19,20,13,12	134
Region 6	Gravelly Sand (3)	41,17,16,39	148
Region 7	Silty Sand (2)	19,20,23,24,22	51.5
Region 8	Silty Sand (1)	40,26,21,18,17,41	19
Region 9	Silty Sand (2)	13,20,23,24,14	324
Region 10	Gravelly Sand (3)	21,27,28,22,19,18	121
Region 11	Fly Ash (7)	30,31,6,5,4,8,29	2399
Region 12	Rock Fill (9)	11,10,42,15,25,40,41,39,38,37	120.4339

Points

	X (ft)	Y (ft)
Point 1	0	555
Point 2	310	555
Point 3	0	576
Point 4	218	576
Point 5	248	561
Point 6	310	561
Point 7	0	586
Point 8	199	586
Point 9	0	590
Point 10	76	591
Point 11	82	592
Point 12	137	591
Point 13	139	591

Point 14	189	591
Point 15	106	602
Point 16	137	602
Point 17	137	610
Point 18	145	610
Point 19	145	602
Point 20	145	597
Point 21	149	610
Point 22	167	602
Point 23	148	600
Point 24	170	600
Point 25	128	611
Point 26	147	611
Point 27	154	608
Point 28	159	608
Point 29	193	589
Point 30	201	588
Point 31	310	588
Point 32	49.5	590.5
Point 33	46.5	590.5
Point 34	31	590
Point 35	15.5	592
Point 36	0	593
Point 37	91	592
Point 38	107	600
Point 39	109	602
Point 40	130	611
Point 41	128	610
Point 42	74	590.96226

Critical Slip Surfaces


	Slip Surface	FOS	Center (ft)	Radius (ft)	Entry (ft)	Exit (ft)
1	3707	2.15	(87.752, 644.982)	71.424	(149.834, 609.666)	(41.7475, 590.347)

Slices of Slip Surface: 3707

	Slip Surface	X (ft)	Y (ft)	PWP (psf)	Base Normal Stress (psf)	Frictional Strength (psf)	Cohesive Strength (psf)
1	3707	42.57181	589.67335	-42.016937	128.22302	86.487516	0.1
2	3707	44.94805	587.8375	72.540509	438.92526	247.12963	0.1
3	3707	46.98552	586.3375	166.14085	692.50159	355.0348	0.1
4	3707	48.48552	585.3322	228.87329	841.29336	367.9791	0.1
5	3707	50.59632	583.99645	312.22469	1067.9864	454.10746	0.1
6	3707	52.788965	582.7129	392.31539	1291.0025	539.98568	0.1
7	3707	54.98161	581.5311	466.03999	1496.9524	619.43465	0.1
8	3707	57.174255	580.44545	533.8145	1685.0684	691.74313	0.1
9	3707	59.3669	579.4511	595.85538	1854.7767	756.43623	0.1
10	3707	61.55954	578.544	652.46999	2005.6515	813.07349	0.1
11	3707	63.752185	577.7206	703.85237	2137.5016	861.42338	0.1
12	3707	65.94483	576.97785	750.18761	2250.3891	901.41201	0.1
13	3707	68.13747	576.31315	791.68019	2344.4311	932.98687	0.1
14	3707	70.425345	575.702	829.79748	2385.9527	792.90069	0.1
15	3707	72.80845	575.149	864.32154	2447.215	806.5245	0.1
16	3707	75	574.71255	891.5385	2530.2731	834.97696	0.1
17	3707	77	574.3788	912.38071	2636.0081	878.23204	0.1
18	3707	79	574.103	929.58977	2725.7976	915.21359	0.1
19	3707	81	573.88455	943.20604	2801.9924	947.09897	0.1
20	3707	83.125	573.71655	953.68065	2870.1339	976.48171	0.1
21	3707	85.375	573.60605	960.57874	2929.0877	1003.0054	0.1
22	3707	87.625	573.5666	963.06495	2973.4614	1024.3481	0.1
23	3707	89.875	573.59805	961.0861	3004.4047	1041.1228	0.1
24	3707	92.07143	573.6964	954.962	3018.3246	1051.3358	0.1
25	3707	94.214285	573.85865	944.84134	3016.9858	1055.8103	0.1
26	3707	96.35714	574.08605	930.61007	3006.4616	1057.6992	0.1
27	3707	98.5	574.3792	912.32289	2987.4365	1057.3232	0.1
28	3707	100.64287	574.73895	889.91216	2960.6975	1055.1179	0.1
29	3707	102.7857	575.1663	863.23977	2926.8126	1051.4429	0.1
30	3707	104.92855	575.6625	832.23791	2886.3114	1046.6027	0.1
31	3707	106.1352	575.964	813.43608	2862.6603	1044.1319	0.1

32	3707	106.6352	576.1	804.96132	2852.9756	1230.5711	0.1
33	3707	108	576.49565	780.26331	2823.0064	1227.4039	0.1
34	3707	110.05555	577.1383	740.19075	2775.9066	1223.1815	0.1
35	3707	112.16665	577.8693	694.5582	2725.2162	1220.1424	0.1
36	3707	114.27775	578.6756	644.25928	2668.559	1216.322	0.1
37	3707	116.38885	579.55995	589.06462	2605.857	1211.8111	0.1
38	3707	118.5	580.5255	528.81257	2536.9664	1206.6206	0.1
39	3707	120.61115	581.57605	463.25152	2461.5625	1200.7064	0.1
40	3707	122.72225	582.7159	392.12844	2379.203	1193.9549	0.1
41	3707	124.83335	583.95005	315.11755	2289.1474	1186.1168	0.1
42	3707	126.94445	585.2844	231.85487	2190.6886	1176.986	0.1
43	3707	129	586.68495	144.46122	2027.551	1270.1601	0.1
44	3707	131.05405	588.19625	50.156728	1846.0709	1211.3594	0.1
45	3707	133.31485	590	-62.400122	1639.1079	1105.5922	0.1
46	3707	134.7608	591.20915	-137.84979	1500.7346	1050.8256	0.1
47	3707	136	592.3347	-37.654405	1411.3675	988.25014	0.1
48	3707	138.51345	594.7815	-13.438985	1339.6938	837.1336	0.1
49	3707	141.2702	597.71975	8.0222125	1087.6773	674.64338	0.1
50	3707	143.75675	600.7	20.770424	841.01883	512.54809	0.1
51	3707	145.5	602.9595	26.301049	601.80565	373.73706	0.1
52	3707	146.4686	604.3233	42.226639	503.96304	299.85512	0.1
53	3707	146.9686	605.0466	-2.9065669	436.09629	283.20424	0.1
54	3707	148	606.66555	-103.92901	260.873	169.4129	0.1
55	3707	149.41725	608.95205	-246.60938	21.756806	14.129035	0.1

Title: Sporn Fly Ash Disposal Facility
 Comments: LEM - Location D (Crest)
 Railway Induced Pseudo Static Analysis
 Up Stream Shallow Failure Surface
 File Name: FAP_H-H_Slope-US_Shallow.gsz
 Date: 5/3/2010
 Horz Seismic Load: 0.01
 Vert Seismic Load: 0.003



SLOPE/W Analysis

Report generated using GeoStudio 2007, version 7.15. Copyright © 1991-2009 GEO-SLOPE International Ltd.

File Information

Title: Sporn Fly Ash Disposal Facility
Comments: LEM - Location D (Crest) Railway Induced Pseudo Static Analysis Up Stream Shallow Failure Surface
Created By: Seth W. Frank, E.I.
Revision Number: 177
Last Edited By: Seth Frank
Date: 5/3/2010
Time: 3:19:19 PM
File Name: FAP_H-H_Slope-US_Shallow.gsz
Directory: E:\Final Analysis Files\LEM FAP_H-H GA\Shallow\
Last Solved Date: 5/3/2010
Last Solved Time: 3:19:42 PM

Project Settings

Length(L) Units: feet
Time(t) Units: Seconds
Force(F) Units: lbf
Pressure(p) Units: psf
Strength Units: psf
Unit Weight of Water: 62.4 pcf
View: 2D

Analysis Settings

SLOPE/W Analysis

Description: Fly Ash Pond Section H-H Downstream Seismic Stability

Kind: SLOPE/W

Method: Morgenstern-Price

Settings

Apply Phreatic Correction: No

Side Function

Interslice force function option: Half-Sine

PWP Conditions Source: Piezometric Line with B-bar

SlipSurface

Direction of movement: Left to Right

Use Passive Mode: No

Slip Surface Option: Entry and Exit

Critical slip surfaces saved: 1

Optimize Critical Slip Surface Location: No

Tension Crack

Tension Crack Option: (none)

FOS Distribution

FOS Calculation Option: Constant

Advanced

Number of Slices: 50

Optimization Tolerance: 0.05

Minimum Slip Surface Depth: 2 ft

Optimization Maximum Iterations: 2000

Optimization Convergence Tolerance: 1e-007

Starting Optimization Points: 8

Ending Optimization Points: 16

Complete Passes per Insertion: 1

Driving Side Maximum Convex Angle: 5 °

Resisting Side Maximum Convex Angle: 1 °

Materials

Silty Sand (1)

Model: Mohr-Coulomb

Unit Weight: 130 pcf

Unit Wt. Above Water Table: 125 pcf

Cohesion: 0.1 psf

Phi: 34 °

Phi-B: 18 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Silty Sand (2)

Model: Mohr-Coulomb

Unit Weight: 112 pcf

Unit Wt. Above Water Table: 107 pcf

Cohesion: 0.1 psf

Phi: 35 °

Phi-B: 18 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Gravelly Sand (3)

Model: Mohr-Coulomb

Unit Weight: 110 pcf

Unit Wt. Above Water Table: 105 pcf

Cohesion: 0.1 psf

Phi: 33 °

Phi-B: 17 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Silty Clay (4)

Model: Mohr-Coulomb

Unit Weight: 120 pcf

Unit Wt. Above Water Table: 115 pcf

Cohesion: 0.1 psf

Phi: 32 °

Phi-B: 17 °

Pore Water Pressure

Piezometric Line: 1

B-bar: 0

Add Weight: Yes

Silty Sand (5)

Model: Mohr-Coulomb

Unit Weight: 131 pcf

Unit Wt. Above Water Table: 126 pcf

Cohesion: 0.1 psf

Phi: 31 °

Phi-B: 16 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Sandy Silt (6)

Model: Mohr-Coulomb

Unit Weight: 130 pcf

Unit Wt. Above Water Table: 125 pcf

Cohesion: 0.1 psf

Phi: 27 °

Phi-B: 14 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Fly Ash (7)

Model: Mohr-Coulomb

Unit Weight: 90 pcf

Unit Wt. Above Water Table: 102 pcf

Cohesion: 0.1 psf

Phi: 27 °

Phi-B: 15 °

Pore Water Pressure

Piezometric Line: 1

B-bar: 0

Add Weight: Yes

Rock Fill (9)

Model: Mohr-Coulomb

Unit Weight: 115 pcf

Cohesion: 0 psf

Phi: 38 °

Phi-B: 0 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: No

Slip Surface Entry and Exit

Left Projection: Range

Left-Zone Left Coordinate: (128.79943, 611) ft

Left-Zone Right Coordinate: (147, 611) ft

Left-Zone Increment: 20

Right Projection: Range

Right-Zone Left Coordinate: (196.12179, 588.60978) ft

Right-Zone Right Coordinate: (255, 588) ft

Right-Zone Increment: 20

Radius Increments: 30

Slip Surface Limits

Left Coordinate: (0, 593) ft

Right Coordinate: (310, 588) ft

Piezometric Lines

Piezometric Line 1

Coordinates

	X (ft)	Y (ft)
	0	589
	135	589
	146	605
	309	605

Seismic Loads

Horz Seismic Load: 0.01

Vert Seismic Load: 0.003

Ignore seismic load in strength: No

Regions

	Material	Points	Area (ft ²)
Region 1	Sandy Silt (6)	1,3,4,5,6,2	5355
Region 2	Silty Sand (5)	7,8,4,3	2085
Region 3	Silty Sand (1)	7,9,36,35,34,33,32,42,10,12,13,14,29,8	973.49995
Region 4	Silty Sand (2)	11,37,38,39,16,12,10	420
Region 5	Silty Clay (4)	16,17,18,19,20,13,12	134
Region 6	Gravelly Sand (3)	41,17,16,39	148
Region 7	Silty Sand (2)	19,20,23,24,22	51.5
Region 8	Silty Sand (1)	40,26,21,18,17,41	19
Region 9	Silty Sand (2)	13,20,23,24,14	324
Region 10	Gravelly Sand (3)	21,27,28,22,19,18	121
Region 11	Fly Ash (7)	30,31,6,5,4,8,29	2399
Region 12	Rock Fill (9)	11,10,42,15,25,40,41,39,38,37	120.4339

Points

	X (ft)	Y (ft)
Point 1	0	555
Point 2	310	555
Point 3	0	576
Point 4	218	576
Point 5	248	561
Point 6	310	561
Point 7	0	586
Point 8	199	586
Point 9	0	590
Point 10	76	591
Point 11	82	592
Point 12	137	591
Point 13	139	591
Point 14	189	591
Point 15	106	602
Point 16	137	602
Point 17	137	610
Point 18	145	610
Point 19	145	602
Point 20	145	597
Point 21	149	610
Point 22	167	602
Point 23	148	600
Point 24	170	600
Point 25	128	611
Point 26	147	611
Point 27	154	608
Point 28	159	608
Point 29	193	589

SLOPE/W Analysis

Point 30	201	588
Point 31	310	588
Point 32	49.5	590.5
Point 33	46.5	590.5
Point 34	31	590
Point 35	15.5	592
Point 36	0	593
Point 37	91	592
Point 38	107	600
Point 39	109	602
Point 40	130	611
Point 41	128	610
Point 42	74	590.96226

Critical Slip Surfaces

	Slip Surface	FOS	Center (ft)	Radius (ft)	Entry (ft)	Exit (ft)
1	13028	1.40	(204.098, 671.188)	82.963	(147, 611)	(196.122, 588.61)


Slices of Slip Surface: 13028

	Slip Surface	X (ft)	Y (ft)	PWP (psf)	Base Normal Stress (psf)	Frictional Strength (psf)	Cohesive Strength (psf)
1	13028	147.5365	610.5	343.19715	-30.175059	-20.353334	0.1
2	13028	148.5365	609.58195	285.91432	14.03658	9.1154618	0.1
3	13028	149.5	608.72685	232.55814	51.277534	33.30002	0.1
4	13028	150.5	607.8666	178.87401	94.005221	61.047704	0.1
5	13028	151.5	607.03345	126.88622	133.96983	87.001023	0.1
6	13028	152.5	606.22635	76.524084	171.36208	111.28384	0.1
7	13028	153.5	605.4444	27.730185	206.35975	134.01159	0.1
8	13028	154.03935	605.0298	1.8588825	225.75979	146.61012	0.1
9	13028	154.60865	604.6061	24.578507	265.20888	156.26719	0.1
10	13028	155.6685	603.8312	72.931996	337.71708	171.95344	0.1
11	13028	156.72835	603.08165	119.70686	407.60287	186.96185	0.1
12	13028	157.7882	602.35655	164.9538	475.17277	201.45856	0.1
13	13028	158.65905	601.7768	201.12602	525.40369	227.06167	0.1
14	13028	159.41575	601.28785	231.64015	547.73509	221.33205	0.1
15	13028	160.2473	600.7632	264.38225	548.97753	199.27576	0.1
16	13028	161.07885	600.25215	296.26437	548.61144	176.69532	0.1
17	13028	161.87095	599.77745	325.89129	546.85741	154.72214	0.1
18	13028	162.62365	599.33765	353.32741	543.91963	133.45411	0.1
19	13028	163.5	598.83985	384.39468	558.50512	121.91344	0.1

SLOPE/W Analysis

20	13028	164.5	598.2877	418.84849	591.13305	120.63495	0.1
21	13028	165.5	597.7533	452.19169	623.0836	119.6598	0.1
22	13028	166.5	597.2363	484.45297	654.31058	118.93558	0.1
23	13028	167.5	596.7363	515.65617	682.01337	116.48457	0.1
24	13028	168.5	596.253	545.8124	712.06628	116.41222	0.1
25	13028	169.5	595.78605	574.95324	741.11608	116.34847	0.1
26	13028	170.49315	595.3381	602.90384	758.95063	109.26514	0.1
27	13028	171.47945	594.90875	629.69665	790.25307	112.42282	0.1
28	13028	172.46575	594.4945	655.5461	820.50816	115.50768	0.1
29	13028	173.45205	594.09505	680.46939	849.63515	118.45114	0.1
30	13028	174.4384	593.7102	704.47954	877.53867	121.17731	0.1
31	13028	175.42475	593.33975	727.59845	904.1203	123.60193	0.1
32	13028	176.41105	592.9835	749.82319	929.25547	125.63984	0.1
33	13028	177.39735	592.6413	771.17943	952.81749	127.18434	0.1
34	13028	178.38365	592.3129	791.67807	974.6444	128.1144	0.1
35	13028	179.36995	591.9981	811.31851	994.69554	128.40198	0.1
36	13028	180.35625	591.6968	830.11371	1012.7603	127.89051	0.1
37	13028	181.34255	591.40885	848.08741	1028.7145	126.47645	0.1
38	13028	182.3289	591.1341	865.23325	1042.432	124.07591	0.1
39	13028	183.3369	590.86695	881.90188	1056.4205	117.71428	0.1
40	13028	184.36655	590.6078	898.07627	1069.9223	115.9116	0.1
41	13028	185.3962	590.3626	913.37461	1080.3691	112.63923	0.1
42	13028	186.42585	590.13125	927.81285	1087.7322	107.86693	0.1
43	13028	187.4555	589.91355	941.39799	1091.9848	101.57205	0.1
44	13028	188.48515	589.70945	954.12967	1092.9139	93.611146	0.1
45	13028	189.5	589.52145	965.86015	1087.9548	82.3539	0.1
46	13028	190.5	589.349	976.62053	1072.2988	64.535795	0.1
47	13028	191.5	589.1891	986.60417	1053.44	45.081327	0.1
48	13028	192.5	589.0417	995.82342	1031.5689	24.110628	0.1
49	13028	193.0395	588.9658	1000.5375	1001.8541	0.88805506	0.1
50	13028	193.58615	588.8957	1004.8988	1006.0724	0.59798134	0.1
51	13028	194.6004	588.77245	1012.5734	1013.9447	0.69868901	0.1
52	13028	195.61465	588.6619	1019.5225	1020.1109	0.29983991	0.1

Title: Sporn Fly Ash Disposal Facility
 Comments: LEM - Location D (Crest)
 Railway Induced Pseudo Static Analysis
 Up Stream Deep Failure Surface
 File Name: FAP_H-H_Slope-US_Deep.gsz
 Date: 5/4/2010
 Horiz Seismic Load: 0.01
 Vert Seismic Load: 0.003



SLOPE/W Analysis

Report generated using GeoStudio 2007, version 7.16. Copyright © 1991-2010 GEO-SLOPE International Ltd.

File Information

Title: Sporn Fly Ash Disposal Facility
Comments: LEM - Location D (Crest) Railway Induced Pseudo Static Analysis Up Stream Deep Failure Surface
Created By: Seth W. Frank, E.I.
Revision Number: 179
Last Edited By: Jeff Gateley
Date: 5/4/2010
Time: 2:51:09 PM
File Name: FAP_H-H_Slope-US_Deep.gsz
Directory: P:\Frank\Philip Sporn\Final Analysis Files\LEM FAP_H-H GA\Deep\
Last Solved Date: 5/4/2010
Last Solved Time: 2:54:56 PM

Project Settings

Length(L) Units: feet
Time(t) Units: Seconds
Force(F) Units: lbf
Pressure(p) Units: psf
Strength Units: psf
Unit Weight of Water: 62.4 pcf
View: 2D

Analysis Settings

SLOPE/W Analysis

Description: Fly Ash Pond Section H-H Downstream Seismic Stability

Kind: SLOPE/W

Method: Morgenstern-Price

Settings

Apply Phreatic Correction: No

Side Function

Interslice force function option: Half-Sine

PWP Conditions Source: Piezometric Line with B-bar

Slip Surface

Direction of movement: Left to Right

Use Passive Mode: No

Slip Surface Option: Entry and Exit

Critical slip surfaces saved: 1

Optimize Critical Slip Surface Location: No
Tension Crack

Tension Crack Option: (none)

FOS Distribution

FOS Calculation Option: Constant

Advanced

Number of Slices: 50

Optimization Tolerance: 0.05

Minimum Slip Surface Depth: 1.5 ft

Optimization Maximum Iterations: 2000

Optimization Convergence Tolerance: 1e-007

Starting Optimization Points: 8

Ending Optimization Points: 16

Complete Passes per Insertion: 1

Driving Side Maximum Convex Angle: 5 °

Resisting Side Maximum Convex Angle: 1 °

Materials

Silty Sand (1)

Model: Mohr-Coulomb

Unit Weight: 130 pcf

Unit Wt. Above Water Table: 125 pcf

Cohesion: 0.1 psf

Phi: 34 °

Phi-B: 18 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Silty Sand (2)

Model: Mohr-Coulomb

Unit Weight: 112 pcf

Unit Wt. Above Water Table: 107 pcf

Cohesion: 0.1 psf

Phi: 35 °

Phi-B: 18 °

Pore Water Pressure

Piezometric Line: 1

Add Weight: Yes

Gravelly Sand (3)

Model: Mohr-Coulomb

Unit Weight: 110 pcf

Unit Wt. Above Water Table: 105 pcf

Cohesion: 0.1 psf

Phi: 33 °
Phi-B: 17 °
Pore Water Pressure
Piezometric Line: 1
Add Weight: Yes

Silty Clay (4)

Model: Mohr-Coulomb
Unit Weight: 120 pcf
Unit Wt. Above Water Table: 115 pcf
Cohesion: 0.1 psf
Phi: 32 °
Phi-B: 17 °
Pore Water Pressure
Piezometric Line: 1
B-bar: 0
Add Weight: Yes

Silty Sand (5)

Model: Mohr-Coulomb
Unit Weight: 131 pcf
Unit Wt. Above Water Table: 126 pcf
Cohesion: 0.1 psf
Phi: 31 °
Phi-B: 16 °
Pore Water Pressure
Piezometric Line: 1
Add Weight: Yes

Sandy Silt (6)

Model: Mohr-Coulomb
Unit Weight: 130 pcf
Unit Wt. Above Water Table: 125 pcf
Cohesion: 0.1 psf
Phi: 27 °
Phi-B: 14 °
Pore Water Pressure
Piezometric Line: 1
Add Weight: Yes

Fly Ash (7)

Model: Mohr-Coulomb
Unit Weight: 90 pcf
Unit Wt. Above Water Table: 102 pcf
Cohesion: 0.1 psf
Phi: 27 °
Phi-B: 15 °
Pore Water Pressure

Piezometric Line: 1
B-bar: 0
Add Weight: Yes

Rock Fill (9)

Model: Mohr-Coulomb
Unit Weight: 115 pcf
Cohesion: 0 psf
Phi: 38 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1
Add Weight: No

Slip Surface Entry and Exit

Left Projection: Range
Left-Zone Left Coordinate: (128.79943, 611) ft
Left-Zone Right Coordinate: (147, 611) ft
Left-Zone Increment: 20
Right Projection: Range
Right-Zone Left Coordinate: (203, 588) ft
Right-Zone Right Coordinate: (264, 588) ft
Right-Zone Increment: 20
Radius Increments: 30

Slip Surface Limits

Left Coordinate: (0, 593) ft
Right Coordinate: (310, 588) ft

Piezometric Lines

Piezometric Line 1

Coordinates

	X (ft)	Y (ft)
	0	589
	135	589
	146	605
	309	605

Seismic Loads

Horz Seismic Load: 0.01

Vert Seismic Load: 0.003

Ignore seismic load in strength: No

Regions

	Material	Points	Area (ft ²)
Region 1	Sandy Silt (6)	1,3,4,5,6,2	5355
Region 2	Silty Sand (5)	7,8,4,3	2085
Region 3	Silty Sand (1)	7,9,36,35,34,33,32,42,10,12,13,14,29,8	973.49995
Region 4	Silty Sand (2)	11,37,38,39,16,12,10	420
Region 5	Silty Clay (4)	16,17,18,19,20,13,12	134
Region 6	Gravelly Sand (3)	41,17,16,39	148
Region 7	Silty Sand (2)	19,20,23,24,22	51.5
Region 8	Silty Sand (1)	40,26,21,18,17,41	19
Region 9	Silty Sand (2)	13,20,23,24,14	324
Region 10	Gravelly Sand (3)	21,27,28,22,19,18	121
Region 11	Fly Ash (7)	30,31,6,5,4,8,29	2399
Region 12	Rock Fill (9)	11,10,42,15,25,40,41,39,38,37	120.4339

Points

	X (ft)	Y (ft)
Point 1	0	555
Point 2	310	555
Point 3	0	576
Point 4	218	576
Point 5	248	561
Point 6	310	561
Point 7	0	586
Point 8	199	586
Point 9	0	590
Point 10	76	591
Point 11	82	592
Point 12	137	591
Point 13	139	591

Point 14	189	591
Point 15	106	602
Point 16	137	602
Point 17	137	610
Point 18	145	610
Point 19	145	602
Point 20	145	597
Point 21	149	610
Point 22	167	602
Point 23	148	600
Point 24	170	600
Point 25	128	611
Point 26	147	611
Point 27	154	608
Point 28	159	608
Point 29	193	589
Point 30	201	588
Point 31	310	588
Point 32	49.5	590.5
Point 33	46.5	590.5
Point 34	31	590
Point 35	15.5	592
Point 36	0	593
Point 37	91	592
Point 38	107	600
Point 39	109	602
Point 40	130	611
Point 41	128	610
Point 42	74	590.96226

Critical Slip Surfaces



	Slip Surface	FOS	Center (ft)	Radius (ft)	Entry (ft)	Exit (ft)
1	8510	1.65	(187.536, 639.88)	55.084	(140.63, 611)	(206.05, 588)

Slices of Slip Surface: 8510

	Slip Surface	X (ft)	Y (ft)	PWP (psf)	Base Normal Stress (psf)	Frictional Strength (psf)	Cohesive Strength (psf)
1	8510	140.9451	610.5	-802.00234	-113.56639	-76.601495	0.1
2	8510	141.88365	609.07625	-627.95384	39.013006	24.378032	0.1
3	8510	143.1302	607.30295	-404.17672	219.3324	137.05409	0.1
4	8510	144.37675	605.6671	-188.96038	387.13008	241.90572	0.1
5	8510	145.25175	604.5793	-41.663951	457.33477	296.99667	0.1
6	8510	145.75175	603.98875	40.570403	522.49304	312.96422	0.1
7	8510	146.5	603.1412	115.98706	613.18593	322.88472	0.1
8	8510	147.272	602.29135	169.01833	684.56624	334.80073	0.1
9	8510	148.272	601.25985	233.38425	732.56457	349.52982	0.1
10	8510	149.269	600.25985	295.78462	792.31508	347.67437	0.1
11	8510	150.2817	599.317	354.62166	856.026	351.0871	0.1
12	8510	151.76905	597.9989	436.87104	942.98866	354.38737	0.1
13	8510	153.25635	596.7724	513.4041	1021.009	355.42881	0.1
14	8510	154.625	595.71525	579.3671	1105.5175	368.41445	0.1
15	8510	155.875	594.81045	635.82691	1199.188	394.46969	0.1
16	8510	157.125	593.9575	689.07879	1289.1796	420.19514	0.1
17	8510	158.375	593.15355	739.21397	1375.88	445.79834	0.1
18	8510	159.7847	592.30575	792.13196	1420.906	440.2723	0.1
19	8510	161.35405	591.424	847.11604	1421.3902	402.11109	0.1
20	8510	162.56935	590.781	887.26565	1423.0777	361.40978	0.1
21	8510	163.66665	590.24145	920.92981	1448.6141	355.92758	0.1
22	8510	165	589.62195	959.59071	1497.1449	362.58489	0.1
23	8510	166.33335	589.04495	995.59413	1542.1568	368.66119	0.1
24	8510	167.75	588.4782	1030.9868	1585.1477	373.78623	0.1
25	8510	169.25	587.9255	1065.4635	1629.0404	380.13742	0.1
26	8510	170.60805	587.46515	1094.2077	1661.7746	382.82872	0.1
27	8510	171.8241	587.0878	1117.6896	1698.4847	391.75122	0.1
28	8510	173.04015	586.74095	1139.3909	1731.9345	399.67569	0.1
29	8510	174.2562	586.42405	1159.114	1761.9746	406.63461	0.1
30	8510	175.47225	586.1365	1177.0624	1788.5412	412.44761	0.1
31	8510	176.7263	585.8707	1193.6909	1813.7605	372.57541	0.1

32	8510	178.01825	585.62805	1208.8111	1833.3432	375.25674	0.1
33	8510	179.3102	585.41715	1222.0051	1848.1995	376.25555	0.1
34	8510	180.6022	585.23765	1233.1734	1858.2066	375.55778	0.1
35	8510	181.8942	585.08915	1242.4536	1863.103	372.92375	0.1
36	8510	183.18615	584.97145	1249.7512	1862.5513	368.20747	0.1
37	8510	184.4781	584.88435	1255.2117	1856.3872	361.22266	0.1
38	8510	185.7701	584.8277	1258.7476	1844.3736	351.87956	0.1
39	8510	187.06205	584.8014	1260.3549	1826.2144	340.00265	0.1
40	8510	188.354	584.8054	1260.1075	1801.7788	325.46896	0.1
41	8510	189.66665	584.8408	1257.9328	1765.3028	304.85864	0.1
42	8510	191	584.9086	1253.6883	1711.4803	275.06917	0.1
43	8510	192.33335	585.0089	1247.4419	1650.0812	241.93006	0.1
44	8510	193.59925	585.13355	1239.6965	1561.2314	193.19764	0.1
45	8510	194.7977	585.2796	1230.517	1510.9958	168.52867	0.1
46	8510	195.99615	585.45245	1219.7787	1455.4233	141.58961	0.1
47	8510	197.1946	585.65235	1207.3312	1394.5468	112.49049	0.1
48	8510	198.39305	585.87955	1193.1114	1328.3335	81.249589	0.1
49	8510	199.49555	586.11195	1178.6463	1277.5618	50.399973	0.1
50	8510	200.4994	586.3451	1164.0753	1247.5633	42.539267	0.1
51	8510	201.63125	586.6334	1146.1081	1209.2788	32.187085	0.1
52	8510	202.89375	586.9838	1124.1912	1171.5808	24.146215	0.1
53	8510	204.15625	587.36685	1100.3434	1130.0212	15.121585	0.1
54	8510	205.41875	587.7833	1074.3126	1084.5763	5.229594	0.1


**FLY ASH DISPOSAL FACILITY
SECTION H-H
LEM SLOPE STABILITY ANALYSES
FOR SHALLOW SLOUGHING ASSESSMENT**



LOCATION MAP

SLOPE GRADING NOTES:
 1) REGRADE SOIL TO ELIMINATE DEPRESSIONS AND SURFACE DISCONTINUITIES.
 2) INSTRUMENTATION NOT TO BE DISTURBED - PROVIDE PROTECTION AS REQUIRED.
 3) ROADWAY CULVERTS AND RIPRAP OUTLET CHANNELS TO REMAIN IN TACT.
 4) UTILIZE SOIL FROM WEST DMIC EXCAVATION TO THE EXTENT POSSIBLE FOR FILLING DEPRESSIONS.

STABILIZATION NOTES:
 1) ALL WORK TO BE PERFORMED FROM THE POND SIDE OF THE EXISTING EMBANKMENT.
 2) NO MORE THAN 100' OF WIDTH MAY BE OPEN CUT AT ONE TIME.
 3) ALL SOIL AREAS DISTURBED BY THE WORK SHALL BE GRADED, SEED, FERTILIZED AND MULCHED.
 4) SOILS EXCAVATED SHALL BE DISPOSED OF / UTILIZED IN THE EAST DAM GRADING.
 5) DMIC CREST AND HAULAGE ROUTES TO BE RESTORED TO ORIGINAL GRADE.
 6) APPROXIMATE LIMITS OF STABILIZATION WORK. ROADWAY TO BE RESURFACED AS REQUIRED.



TYPICAL SECTION

DATE	DESCRIPTION	BY	APP'D
0	ISSUED FOR PERMIT	AW	
REVISIONS			

THIS DRAWING IS THE PROPERTY OF THE AMERICAN ELECTRIC POWER SERVICE CORP. AND IS LOANED TO YOU FOR YOUR INFORMATION ONLY. IT IS NOT TO BE REPRODUCED OR COPIED IN ANY MANNER WITHOUT THE WRITTEN CONSENT OF THE AMERICAN ELECTRIC POWER SERVICE CORP. THE WRITING ENGINEER'S OFFICE IS NOT RESPONSIBLE FOR THE ACCURACY OF THIS DRAWING.

APPALACHIAN POWER COMPANY
 PHILIP SPORN PLANT
 GRAHAM STATION M. VA.
 UNIT 5 FLY ASH POND MODIFICATIONS
 JOB NO. 5-30075-0
 SCALE: 1"=50'




NOTE: THIS MAP COMPLES WITH NATIONAL MAP ACCURACY STANDARDS

HEWLETT AERIAL SURVEYS INC.
 3899 GROVE CITY RD. GROVE CITY, OHIO 43123
 JOB NO. 42148 NAME: SPORN PLANT
 SCALE: 1"=50' AERIAL PHOTOGRAPHY EXPOSED: 85-22-27
 CONTOUR INTERVAL: 20' SHEET: 1 OF 1

NOTE: CONTOURS INSIDE TREE LINES SHOULD BE CONSIDERED AS GROUND OBTAINED FROM AERIAL PHOTOGRAPHY. DRAWING IS IN US SURVEY FEET.

Title: Sporn Fly Ash Disposal Facility Western Dike Section H-H
 Comments: Shallow Sloughing Assessment
 Moist Topsoil Material (Condition 1)
 File Name: Sporn FADF-Shallow Sloughing Assessment for Section H-H Condition 1.gsz
 Date: 5/4/2010
 Horz Seismic Load: 0
 Vert Seismic Load: 0



SLOPE/W Analysis

Report generated using GeoStudio 2007, version 7.16. Copyright © 1991-2010 GEO-SLOPE International Ltd.

File Information

Title: Sporn Fly Ash Disposal Facility Western Dike Section H-H
Comments: Shallow Sloughing Assessment Moist Topsoil Material (Condition 1)
Created By: Roger W. Cecil, P.E.
Revision Number: 183
Last Edited By: Roger Cecil
Date: 5/4/2010
Time: 9:02:42 AM
File Name: Sporn FADF-Shallow Sloughing Assessment for Section H-H Condition 1.gsz
Directory: C:\Working Folder\Sporn\VIBRATION ASSESSMENT\
Last Solved Date: 5/4/2010
Last Solved Time: 9:02:50 AM

Project Settings

Length(L) Units: feet
Time(t) Units: Seconds
Force(F) Units: lbf
Pressure(p) Units: psf
Strength Units: psf
Unit Weight of Water: 62.4 pcf
View: 2D

Analysis Settings

SLOPE/W Analysis

Description: Shallow Sloughing Assessment
Kind: SLOPE/W
Method: Morgenstern-Price
Settings

Apply Phreatic Correction: No
Side Function
Interslice force function option: Half-Sine
PWP Conditions Source: Piezometric Line
Use Staged Rapid Drawdown: No

Slip Surface

Direction of movement: Right to Left
Use Passive Mode: No
Slip Surface Option: Entry and Exit
Critical slip surfaces saved: 1

Optimize Critical Slip Surface Location: No
Tension Crack
Tension Crack Option: (none)
FOS Distribution
FOS Calculation Option: Constant
Advanced
Number of Slices: 50
Optimization Tolerance: 0.05
Minimum Slip Surface Depth: 0.5 ft
Optimization Maximum Iterations: 2000
Optimization Convergence Tolerance: 1e-007
Starting Optimization Points: 8
Ending Optimization Points: 16
Complete Passes per Insertion: 1
Driving Side Maximum Convex Angle: 5 °
Resisting Side Maximum Convex Angle: 1 °

Materials

Silty Sand (1)

Model: Mohr-Coulomb
Unit Weight: 130 pcf
Unit Wt. Above Water Table: 125 pcf
Cohesion: 0.1 psf
Phi: 34 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1

Silty Sand (2)

Model: Mohr-Coulomb
Unit Weight: 112 pcf
Unit Wt. Above Water Table: 107 pcf
Cohesion: 0.1 psf
Phi: 35 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1

Gravelly Sand (3)

Model: Mohr-Coulomb
Unit Weight: 110 pcf
Unit Wt. Above Water Table: 105 pcf
Cohesion: 0.1 psf
Phi: 33 °
Phi-B: 0 °

Pore Water Pressure
Piezometric Line: 1

Silty Clay (4)

Model: Mohr-Coulomb
Unit Weight: 120 pcf
Unit Wt. Above Water Table: 115 pcf
Cohesion: 0.1 psf
Phi: 32 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1

Silty Sand (5)

Model: Mohr-Coulomb
Unit Weight: 131 pcf
Unit Wt. Above Water Table: 126 pcf
Cohesion: 0.1 psf
Phi: 31 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1

Sandy Silt (6)

Model: Mohr-Coulomb
Unit Weight: 130 pcf
Unit Wt. Above Water Table: 125 pcf
Cohesion: 0.1 psf
Phi: 27 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1

Fly Ash (7)

Model: Mohr-Coulomb
Unit Weight: 90 pcf
Unit Wt. Above Water Table: 102 pcf
Cohesion: 0.1 psf
Phi: 27 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1

Topsoil

Model: Mohr-Coulomb
Unit Weight: 130 pcf
Unit Wt. Above Water Table: 125 pcf
Cohesion: 0 psf

Phi: 27 °
Phi-B: 0 °

Slip Surface Entry and Exit

Left Projection: Range
Left-Zone Left Coordinate: (74, 591) ft
Left-Zone Right Coordinate: (96.98653, 598.24439) ft
Left-Zone Increment: 10
Right Projection: Range
Right-Zone Left Coordinate: (105.97741, 601.99059) ft
Right-Zone Right Coordinate: (128, 611) ft
Right-Zone Increment: 10
Radius Increments: 10

Slip Surface Limits

Left Coordinate: (0, 593) ft
Right Coordinate: (310, 588) ft

Piezometric Lines

Piezometric Line 1

Coordinates

	X (ft)	Y (ft)
	0	589
	135	589
	146	605
	309	605

Seismic Loads

Horz Seismic Load: 0
Vert Seismic Load: 0

Regions

	Material	Points	Area (ft ²)
Region 1	Sandy Silt (6)	1,3,4,5,6,2	5355
Region 2	Silty Sand (5)	7,8,4,3	2085

Region 3	Silty Sand (1)	7,9,36,35,34,33,32,10,41,12,13,14,42,8	974
Region 4	Silty Sand (2)	40,39,16,12,41	467
Region 5	Silty Clay (4)	16,17,18,19,20,13,12	134
Region 6	Gravelly Sand (3)	38,17,16,39	152
Region 7	Silty Sand (2)	19,20,24,25,23	51.5
Region 8	Silty Sand (1)	37,27,22,18,17,38	19
Region 9	Silty Sand (2)	13,20,24,25,14	324
Region 10	Gravelly Sand (3)	22,28,29,23,19,18	121
Region 11	Fly Ash (7)	30,31,6,5,4,8,42	2405.5
Region 12	Topsoil	38,21,26,37	2
Region 13	Topsoil	21,38,39,15	16
Region 14	Topsoil	39,40,41,10,11,15	22

Points

	X (ft)	Y (ft)
Point 1	0	555
Point 2	310	555
Point 3	0	576
Point 4	218	576
Point 5	248	561
Point 6	310	561
Point 7	0	586
Point 8	199	586
Point 9	0	590
Point 10	74	591
Point 11	82	592
Point 12	137	591
Point 13	139	591
Point 14	189	591
Point 15	106	602
Point 16	137	602
Point 17	137	610
Point 18	145	610
Point 19	145	602
Point 20	145	597

Point 21	126	610
Point 22	149	610
Point 23	167	602
Point 24	148	600
Point 25	170	600
Point 26	128	611
Point 27	147	611
Point 28	154	608
Point 29	159	608
Point 30	214	588
Point 31	310	588
Point 32	49.5	590.5
Point 33	46.5	590.5
Point 34	31	590
Point 35	15.5	592
Point 36	0	593
Point 37	130	611
Point 38	128	610
Point 39	108	602
Point 40	84	592
Point 41	76	591
Point 42	193	589

Critical Slip Surfaces

	Slip Surface	FOS	Center (ft)	Radius (ft)	Entry (ft)	Exit (ft)
1	496	1.23	(19.266, 782.232)	200.189	(108.187, 602.875)	(83.5294, 592.637)


Slices of Slip Surface: 496

	Slip Surface	X (ft)	Y (ft)	PWP (psf)	Base Normal Stress (psf)	Frictional Strength (psf)	Cohesive Strength (psf)
1	496	83.773605	592.72035	0	2.1243523	1.0824116	0
2	496	84.2621	592.88735	0	6.2940586	3.206983	0

3	496	84.750595	593.05575	0	10.305439	5.2508836	0
4	496	85.239085	593.22555	0	14.156294	7.2129921	0
5	496	85.727575	593.39675	0	17.844633	9.0922945	0
6	496	86.216065	593.5694	0	21.368284	10.887685	0
7	496	86.70456	593.7435	0	24.725481	12.598262	0
8	496	87.193055	593.919	0	27.914473	14.223135	0
9	496	87.681545	594.0959	0	30.931794	15.760536	0
10	496	88.170035	594.27425	0	33.779751	17.211643	0
11	496	88.65853	594.45405	0	36.452999	18.573731	0
12	496	89.147025	594.6353	0	38.951941	19.847005	0
13	496	89.635515	594.818	0	41.277023	21.031694	0
14	496	90.124005	595.00215	0	43.426758	22.127039	0
15	496	90.612495	595.18775	0	45.397773	23.131321	0
16	496	91.10099	595.3748	0	47.194363	24.046729	0
17	496	91.589485	595.5633	0	48.813171	24.871553	0
18	496	92.077975	595.7533	0	50.254696	25.606047	0
19	496	92.566465	595.9448	0	51.521323	26.251425	0
20	496	93.054955	596.13775	0	52.613551	26.807943	0
21	496	93.54345	596.3322	0	53.529977	27.274885	0
22	496	94.031945	596.5281	0	54.273033	27.653491	0
23	496	94.520435	596.7255	0	54.841337	27.943057	0
24	496	95.008925	596.92445	0	55.239217	28.145787	0
25	496	95.49742	597.12485	0	55.467189	28.261945	0
26	496	95.985915	597.32675	0	55.525796	28.291806	0
27	496	96.474405	597.5302	0	55.4156	28.235658	0
28	496	96.962895	597.73515	0	55.139027	28.094737	0
29	496	97.451385	597.94165	0	54.698533	27.870295	0
30	496	97.93988	598.1497	0	54.092781	27.561648	0
31	496	98.428375	598.35925	0	53.322348	27.169093	0
32	496	98.916865	598.5703	0	52.391567	26.694837	0
33	496	99.405355	598.7829	0	51.29728	26.13727	0
34	496	99.89385	598.9971	0	50.043817	25.498599	0
35	496	100.38235	599.21285	0	48.629916	24.77818	0
36	496	100.87085	599.4301	0	47.056163	23.976312	0
37	496	101.35935	599.64895	0	45.32133	23.092371	0
38	496	101.84785	599.8694	0	43.427903	22.127622	0

39	496	102.33635	600.0914	0	41.374658	21.081441	0
40	496	102.8248	600.31495	0	39.158529	19.952267	0
41	496	103.31325	600.5401	0	36.782035	18.741383	0
42	496	103.80175	600.7669	0	34.244002	17.44819	0
43	496	104.29025	600.99525	0	31.541409	16.071151	0
44	496	104.77875	601.2252	0	28.673131	14.60969	0
45	496	105.26725	601.4568	0	25.638039	13.063234	0
46	496	105.75575	601.69	0	22.435036	11.431222	0
47	496	106.20015	601.9035	0	19.020712	9.691537	0
48	496	106.62365	602.10835	0	15.204579	7.7471198	0
49	496	107.07035	602.3257	0	11.040893	5.6256161	0
50	496	107.51705	602.5444	0	6.7294443	3.4288231	0
51	496	107.9638	602.7645	0	2.2680943	1.1556518	0

Title: Sporn Fly Ash Disposal Facility Western Dike Section H-H
 Comments: Shallow Sloughing Assessment
 Saturated Topsoil Material (Condition 2)
 File Name: Sporn FADF- Shallow Sloughing Assessment for Section H-H Condition 2.gsz
 Date: 5/4/2010
 Horz Seismic Load: 0
 Vert Seismic Load: 0



SLOPE/W Analysis

Report generated using GeoStudio 2007, version 7.16. Copyright © 1991-2010 GEO-SLOPE International Ltd.

File Information

Title: Sporn Fly Ash Disposal Facility Western Dike Section H-H
Comments: Shallow Sloughing Assessment Saturated Topsoil Material (Condition 2)
Created By: Roger W. Cecil, P.E.
Revision Number: 184
Last Edited By: Roger Cecil
Date: 5/4/2010
Time: 9:05:43 AM
File Name: Sporn FADF-Shallow Sloughing Assessment for Section H-H Condition 2.gsz
Directory: C:\Working Folder\Sporn\VIBRATION ASSESSMENT\
Last Solved Date: 5/4/2010
Last Solved Time: 9:05:48 AM

Project Settings

Length(L) Units: feet
Time(t) Units: Seconds
Force(F) Units: lbf
Pressure(p) Units: psf
Strength Units: psf
Unit Weight of Water: 62.4 pcf
View: 2D

Analysis Settings

SLOPE/W Analysis

Description: Shallow Sloughing Assessment
Kind: SLOPE/W
Method: Morgenstern-Price
Settings
 Apply Phreatic Correction: No
 Side Function
 Interslice force function option: Half-Sine
 PWP Conditions Source: Piezometric Line
 Use Staged Rapid Drawdown: No
Slip Surface
 Direction of movement: Right to Left
 Use Passive Mode: No
 Slip Surface Option: Entry and Exit
 Critical slip surfaces saved: 1

Optimize Critical Slip Surface Location: No
Tension Crack
Tension Crack Option: (none)
FOS Distribution
FOS Calculation Option: Constant
Advanced
Number of Slices: 50
Optimization Tolerance: 0.05
Minimum Slip Surface Depth: 0.5 ft
Optimization Maximum Iterations: 2000
Optimization Convergence Tolerance: 1e-007
Starting Optimization Points: 8
Ending Optimization Points: 16
Complete Passes per Insertion: 1
Driving Side Maximum Convex Angle: 5 °
Resisting Side Maximum Convex Angle: 1 °

Materials

Silty Sand (1)

Model: Mohr-Coulomb
Unit Weight: 130 pcf
Unit Wt. Above Water Table: 125 pcf
Cohesion: 0.1 psf
Phi: 34 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1

Silty Sand (2)

Model: Mohr-Coulomb
Unit Weight: 112 pcf
Unit Wt. Above Water Table: 107 pcf
Cohesion: 0.1 psf
Phi: 35 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1

Gravelly Sand (3)

Model: Mohr-Coulomb
Unit Weight: 110 pcf
Unit Wt. Above Water Table: 105 pcf
Cohesion: 0.1 psf
Phi: 33 °
Phi-B: 0 °

Pore Water Pressure
Piezometric Line: 1

Silty Clay (4)

Model: Mohr-Coulomb
Unit Weight: 120 pcf
Unit Wt. Above Water Table: 115 pcf
Cohesion: 0.1 psf
Phi: 32 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1

Silty Sand (5)

Model: Mohr-Coulomb
Unit Weight: 131 pcf
Unit Wt. Above Water Table: 126 pcf
Cohesion: 0.1 psf
Phi: 31 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1

Sandy Silt (6)

Model: Mohr-Coulomb
Unit Weight: 130 pcf
Unit Wt. Above Water Table: 125 pcf
Cohesion: 0.1 psf
Phi: 27 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1

Fly Ash (7)

Model: Mohr-Coulomb
Unit Weight: 90 pcf
Unit Wt. Above Water Table: 102 pcf
Cohesion: 0.1 psf
Phi: 27 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1

Topsoil

Model: Mohr-Coulomb
Unit Weight: 130 pcf
Unit Wt. Above Water Table: 125 pcf
Cohesion: 0 psf

Phi: 27 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 2

Slip Surface Entry and Exit

Left Projection: Range
Left-Zone Left Coordinate: (74, 591) ft
Left-Zone Right Coordinate: (96.98653, 598.24439) ft
Left-Zone Increment: 10
Right Projection: Range
Right-Zone Left Coordinate: (105.97741, 601.99059) ft
Right-Zone Right Coordinate: (128, 611) ft
Right-Zone Increment: 10
Radius Increments: 10

Slip Surface Limits

Left Coordinate: (0, 593) ft
Right Coordinate: (310, 588) ft

Piezometric Lines

Piezometric Line 1

Coordinates

	X (ft)	Y (ft)
	0	589
	135	589
	146	605
	309	605

Piezometric Line 2

Coordinates

	X (ft)	Y (ft)
	74	591
	82	592
	106	602
	126	610

	128	611
	130	611

Seismic Loads

Horz Seismic Load: 0

Vert Seismic Load: 0

Regions

	Material	Points	Area (ft ²)
Region 1	Sandy Silt (6)	1,3,4,5,6,2	5355
Region 2	Silty Sand (5)	7,8,4,3	2085
Region 3	Silty Sand (1)	7,9,36,35,34,33,32,10,41,12,13,14,42,8	974
Region 4	Silty Sand (2)	40,39,16,12,41	467
Region 5	Silty Clay (4)	16,17,18,19,20,13,12	134
Region 6	Gravelly Sand (3)	38,17,16,39	152
Region 7	Silty Sand (2)	19,20,24,25,23	51.5
Region 8	Silty Sand (1)	37,27,22,18,17,38	19
Region 9	Silty Sand (2)	13,20,24,25,14	324
Region 10	Gravelly Sand (3)	22,28,29,23,19,18	121
Region 11	Fly Ash (7)	30,31,6,5,4,8,42	2405.5
Region 12	Topsoil	38,21,26,37	2
Region 13	Topsoil	21,38,39,15	16
Region 14	Topsoil	39,40,41,10,11,15	22

Points

	X (ft)	Y (ft)
Point 1	0	555
Point 2	310	555
Point 3	0	576
Point 4	218	576
Point 5	248	561
Point 6	310	561
Point 7	0	586
Point 8	199	586

Point 9	0	590
Point 10	74	591
Point 11	82	592
Point 12	137	591
Point 13	139	591
Point 14	189	591
Point 15	106	602
Point 16	137	602
Point 17	137	610
Point 18	145	610
Point 19	145	602
Point 20	145	597
Point 21	126	610
Point 22	149	610
Point 23	167	602
Point 24	148	600
Point 25	170	600
Point 26	128	611
Point 27	147	611
Point 28	154	608
Point 29	159	608
Point 30	214	588
Point 31	310	588
Point 32	49.5	590.5
Point 33	46.5	590.5
Point 34	31	590
Point 35	15.5	592
Point 36	0	593
Point 37	130	611
Point 38	128	610
Point 39	108	602
Point 40	84	592
Point 41	76	591
Point 42	193	589

Critical Slip Surfaces


	Slip Surface	FOS	Center (ft)	Radius (ft)	Entry (ft)	Exit (ft)
1	496	0.54	(19.266, 782.232)	200.189	(108.187, 602.875)	(83.5294, 592.637)

Slices of Slip Surface: 496

	Slip Surface	X (ft)	Y (ft)	PWP (psf)	Base Normal Stress (psf)	Frictional Strength (psf)	Cohesive Strength (psf)
1	496	83.773605	592.72035	1.1625606	2.117182	0.48640389	0
2	496	84.2621	592.88735	3.4437545	6.273922	1.4420424	0
3	496	84.750595	593.05575	5.6371171	10.2741	2.362661	0
4	496	85.239085	593.22555	7.7422427	14.115899	3.2475403	0
5	496	85.727575	593.39675	9.7589253	17.79713	4.0956698	0
6	496	86.216065	593.5694	11.687155	21.316194	4.9062407	0
7	496	86.70456	593.7435	13.526542	24.669585	5.6776639	0
8	496	87.193055	593.919	15.276704	27.858629	6.410811	0
9	496	87.681545	594.0959	16.937456	30.877926	7.1030241	0
10	496	88.170035	594.27425	18.508613	33.727856	7.7545919	0
11	496	88.65853	594.45405	19.989239	36.404994	8.3642448	0
12	496	89.147025	594.6353	21.381843	38.909737	8.9309079	0
13	496	89.635515	594.818	22.681473	41.238694	9.4553762	0
14	496	90.124005	595.00215	23.892184	43.392296	9.9358032	0
15	496	90.612495	595.18775	25.012289	45.370996	10.373279	0
16	496	91.10099	595.3748	26.040114	47.173344	10.767919	0
17	496	91.589485	595.5633	26.975901	48.7979	11.118864	0
18	496	92.077975	595.7533	27.821811	50.245162	11.425268	0
19	496	92.566465	595.9448	28.574275	51.517513	11.690164	0
20	496	93.054955	596.13775	29.233556	52.611648	11.911733	0
21	496	93.54345	596.3322	29.80182	53.531878	12.091068	0
22	496	94.031945	596.5281	30.27744	54.276831	12.2283	0
23	496	94.520435	596.7255	30.658792	54.848925	12.325488	0
24	496	95.008925	596.92445	30.94806	55.250587	12.382756	0
25	496	95.49742	597.12485	31.141733	55.48044	12.40119	0

26	496	95.985915	597.32675	31.242005	55.540923	12.380917	0
27	496	96.474405	597.5302	31.249185	55.434487	12.323027	0
28	496	96.962895	597.73515	31.159795	55.161666	12.229564	0
29	496	97.451385	597.94165	30.976048	54.723032	12.099693	0
30	496	97.93988	598.1497	30.698255	54.121017	11.934493	0
31	496	98.428375	598.35925	30.322984	53.358073	11.736964	0
32	496	98.916865	598.5703	29.852451	52.432886	11.505306	0
33	496	99.405355	598.7829	29.285128	51.346054	11.240603	0
34	496	99.89385	598.9971	28.621361	50.10003	10.943928	0
35	496	100.38235	599.21285	27.861513	48.693548	10.614452	0
36	496	100.87085	599.4301	27.004065	47.127196	10.253248	0
37	496	101.35935	599.64895	26.047535	45.401614	9.8613956	0
38	496	101.84785	599.8694	24.994168	43.515549	9.4371152	0
39	496	102.33635	600.0914	23.842486	41.469648	8.9814873	0
40	496	102.8248	600.31495	22.59103	39.260843	8.4936943	0
41	496	103.31325	600.5401	21.242057	36.889797	7.9729216	0
42	496	103.80175	600.7669	19.792268	34.353484	7.4193101	0
43	496	104.29025	600.99525	18.242829	31.650754	6.8316791	0
44	496	104.77875	601.2252	16.593249	28.782337	6.2106507	0
45	496	105.26725	601.4568	14.843037	25.743409	5.5540171	0
46	496	105.75575	601.69	12.991902	22.532885	4.8613735	0
47	496	106.20015	601.9035	11.0159	19.108705	4.1234899	0
48	496	106.62365	602.10835	8.8062445	15.278095	3.2975725	0
49	496	107.07035	602.3257	6.3944361	11.096618	2.3958813	0
50	496	107.51705	602.5444	3.8969775	6.7646065	1.4611299	0
51	496	107.9638	602.7645	1.3133153	2.2805365	0.49282382	0

Title: Sporn Fly Ash Disposal Facility Western Dike Section H-H
 Comments: Shallow Sloughing Assessment
 Moist Topsoil Material with Maximum Pseudo-Static Train Loads
 (Condition 3)
 File Name: Sporn FADF-Shallow Sloughing Assessment for Section H-H Condition 3.gsz
 Date: 5/4/2010
 Horz Seismic Load: 0.046
 Vert Seismic Load: 0.008



SLOPE/W Analysis

Report generated using GeoStudio 2007, version 7.16. Copyright © 1991-2010 GEO-SLOPE International Ltd.

File Information

Title: Sporn Fly Ash Disposal Facility Western Dike Section H-H
Comments: Shallow Sloughing Assessment Moist Topsoil Material with Maximum Pseudo-Static Train Loads (Condition 3)
Created By: Roger W. Cecil, P.E.
Revision Number: 187
Last Edited By: Roger Cecil
Date: 5/4/2010
Time: 9:09:43 AM
File Name: Sporn FADF-Shallow Sloughing Assessment for Section H-H Condition 3.gsz
Directory: C:\Working Folder\Sporn\VIBRATION ASSESSMENT\
Last Solved Date: 5/4/2010
Last Solved Time: 9:09:54 AM

Project Settings

Length(L) Units: feet
Time(t) Units: Seconds
Force(F) Units: lbf
Pressure(p) Units: psf
Strength Units: psf
Unit Weight of Water: 62.4 pcf
View: 2D

Analysis Settings

SLOPE/W Analysis

Description: Shallow Sloughing Assessment
Kind: SLOPE/W
Method: Morgenstern-Price

Settings

Apply Phreatic Correction: No
Side Function
Interslice force function option: Half-Sine
PWP Conditions Source: Piezometric Line
Use Staged Rapid Drawdown: No

Slip Surface

Direction of movement: Right to Left
Use Passive Mode: No
Slip Surface Option: Entry and Exit

Critical slip surfaces saved: 1
Optimize Critical Slip Surface Location: No
Tension Crack
Tension Crack Option: (none)

FOS Distribution
FOS Calculation Option: Constant

Advanced
Number of Slices: 50
Optimization Tolerance: 0.05
Minimum Slip Surface Depth: 0.5 ft
Optimization Maximum Iterations: 2000
Optimization Convergence Tolerance: 1e-007
Starting Optimization Points: 8
Ending Optimization Points: 16
Complete Passes per Insertion: 1
Driving Side Maximum Convex Angle: 5 °
Resisting Side Maximum Convex Angle: 1 °

Materials

Silty Sand (1)

Model: Mohr-Coulomb
Unit Weight: 130 pcf
Unit Wt. Above Water Table: 125 pcf
Cohesion: 0.1 psf
Phi: 34 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1

Silty Sand (2)

Model: Mohr-Coulomb
Unit Weight: 112 pcf
Unit Wt. Above Water Table: 107 pcf
Cohesion: 0.1 psf
Phi: 35 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1

Gravelly Sand (3)

Model: Mohr-Coulomb
Unit Weight: 110 pcf
Unit Wt. Above Water Table: 105 pcf
Cohesion: 0.1 psf
Phi: 33 °

Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1

Silty Clay (4)

Model: Mohr-Coulomb
Unit Weight: 120 pcf
Unit Wt. Above Water Table: 115 pcf
Cohesion: 0.1 psf
Phi: 32 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1

Silty Sand (5)

Model: Mohr-Coulomb
Unit Weight: 131 pcf
Unit Wt. Above Water Table: 126 pcf
Cohesion: 0.1 psf
Phi: 31 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1

Sandy Silt (6)

Model: Mohr-Coulomb
Unit Weight: 130 pcf
Unit Wt. Above Water Table: 125 pcf
Cohesion: 0.1 psf
Phi: 27 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1

Fly Ash (7)

Model: Mohr-Coulomb
Unit Weight: 90 pcf
Unit Wt. Above Water Table: 102 pcf
Cohesion: 0.1 psf
Phi: 27 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1

Topsoil

Model: Mohr-Coulomb
Unit Weight: 130 pcf
Unit Wt. Above Water Table: 125 pcf

Cohesion: 0 psf

Phi: 27 °

Phi-B: 0 °

Slip Surface Entry and Exit

Left Projection: Range

Left-Zone Left Coordinate: (74, 591) ft

Left-Zone Right Coordinate: (96.98653, 598.24439) ft

Left-Zone Increment: 10

Right Projection: Range

Right-Zone Left Coordinate: (105.97741, 601.99059) ft

Right-Zone Right Coordinate: (128, 611) ft

Right-Zone Increment: 10

Radius Increments: 10

Slip Surface Limits

Left Coordinate: (0, 593) ft

Right Coordinate: (310, 588) ft

Piezometric Lines

Piezometric Line 1

Coordinates

	X (ft)	Y (ft)
	0	589
	135	589
	146	605
	309	605

Seismic Loads

Horz Seismic Load: 0.046

Vert Seismic Load: 0.008

Ignore seismic load in strength: No

Regions

	Material	Points	Area (ft ²)
Region 1	Sandy Silt (6)	1,3,4,5,6,2	5355

Region 2	Silty Sand (5)	7,8,4,3	2085
Region 3	Silty Sand (1)	7,9,36,35,34,33,32,10,41,12,13,14,42,8	974
Region 4	Silty Sand (2)	40,39,16,12,41	467
Region 5	Silty Clay (4)	16,17,18,19,20,13,12	134
Region 6	Gravelly Sand (3)	38,17,16,39	152
Region 7	Silty Sand (2)	19,20,24,25,23	51.5
Region 8	Silty Sand (1)	37,27,22,18,17,38	19
Region 9	Silty Sand (2)	13,20,24,25,14	324
Region 10	Gravelly Sand (3)	22,28,29,23,19,18	121
Region 11	Fly Ash (7)	30,31,6,5,4,8,42	2405.5
Region 12	Topsoil	38,21,26,37	2
Region 13	Topsoil	21,38,39,15	16
Region 14	Topsoil	39,40,41,10,11,15	22

Points

	X (ft)	Y (ft)
Point 1	0	555
Point 2	310	555
Point 3	0	576
Point 4	218	576
Point 5	248	561
Point 6	310	561
Point 7	0	586
Point 8	199	586
Point 9	0	590
Point 10	74	591
Point 11	82	592
Point 12	137	591
Point 13	139	591
Point 14	189	591
Point 15	106	602
Point 16	137	602
Point 17	137	610
Point 18	145	610
Point 19	145	602

Point 20	145	597
Point 21	126	610
Point 22	149	610
Point 23	167	602
Point 24	148	600
Point 25	170	600
Point 26	128	611
Point 27	147	611
Point 28	154	608
Point 29	159	608
Point 30	214	588
Point 31	310	588
Point 32	49.5	590.5
Point 33	46.5	590.5
Point 34	31	590
Point 35	15.5	592
Point 36	0	593
Point 37	130	611
Point 38	128	610
Point 39	108	602
Point 40	84	592
Point 41	76	591
Point 42	193	589

Critical Slip Surfaces

	Slip Surface	FOS	Center (ft)	Radius (ft)	Entry (ft)	Exit (ft)
1	496	1.08	(19.266, 782.232)	200.189	(108.187, 602.875)	(83.5294, 592.637)

Slices of Slip Surface: 496

	Slip Surface	X (ft)	Y (ft)	PWP (psf)	Base Normal Stress (psf)	Frictional Strength (psf)	Cohesive Strength (psf)
1	496	83.773605	592.72035	0	2.1071048	1.0736235	0

2	496	84.2621	592.88735	0	6.2425552	3.1807408	0
3	496	84.750595	593.05575	0	10.220128	5.2074153	0
4	496	85.239085	593.22555	0	14.037623	7.152526	0
5	496	85.727575	593.39675	0	17.693049	9.0150585	0
6	496	86.216065	593.5694	0	21.185006	10.7943	0
7	496	86.70456	593.7435	0	24.509606	12.488268	0
8	496	87.193055	593.919	0	27.667988	14.097544	0
9	496	87.681545	594.0959	0	30.656682	15.62036	0
10	496	88.170035	594.27425	0	33.474148	17.05593	0
11	496	88.65853	594.45405	0	36.120805	18.404469	0
12	496	89.147025	594.6353	0	38.593211	19.664223	0
13	496	89.635515	594.818	0	40.891812	20.835419	0
14	496	90.124005	595.00215	0	43.015121	21.917299	0
15	496	90.612495	595.18775	0	44.963592	22.910094	0
16	496	91.10099	595.3748	0	46.735776	23.813067	0
17	496	91.589485	595.5633	0	48.334049	24.627428	0
18	496	92.077975	595.7533	0	49.755086	25.351483	0
19	496	92.566465	595.9448	0	51.003176	25.987416	0
20	496	93.054955	596.13775	0	52.076911	26.534511	0
21	496	93.54345	596.3322	0	52.976789	26.993022	0
22	496	94.031945	596.5281	0	53.703337	27.363217	0
23	496	94.520435	596.7255	0	54.258968	27.646325	0
24	496	95.008925	596.92445	0	54.646103	27.84358	0
25	496	95.49742	597.12485	0	54.863359	27.954278	0
26	496	95.985915	597.32675	0	54.913171	27.979658	0
27	496	96.474405	597.5302	0	54.797982	27.920967	0
28	496	96.962895	597.73515	0	54.516435	27.777511	0
29	496	97.451385	597.94165	0	54.072869	27.551503	0
30	496	97.93988	598.1497	0	53.46594	27.242257	0
31	496	98.428375	598.35925	0	52.698101	26.851023	0
32	496	98.916865	598.5703	0	51.769915	26.378089	0
33	496	99.405355	598.7829	0	50.683851	25.824712	0
34	496	99.89385	598.9971	0	49.4386	25.190225	0
35	496	100.38235	599.21285	0	48.03664	24.475891	0
36	496	100.87085	599.4301	0	46.474807	23.680097	0
37	496	101.35935	599.64895	0	44.757474	22.805072	0

38	496	101.84785	599.8694	0	42.881511	21.849221	0
39	496	102.33635	600.0914	0	40.849419	20.813819	0
40	496	102.8248	600.31495	0	38.658118	19.697295	0
41	496	103.31325	600.5401	0	36.308256	18.49998	0
42	496	103.80175	600.7669	0	33.798648	17.221271	0
43	496	104.29025	600.99525	0	31.126269	15.859626	0
44	496	104.77875	601.2252	0	28.293685	14.416353	0
45	496	105.26725	601.4568	0	25.296051	12.888982	0
46	496	105.75575	601.69	0	22.134105	11.27789	0
47	496	106.20015	601.9035	0	18.763037	9.5602449	0
48	496	106.62365	602.10835	0	14.997122	7.6414152	0
49	496	107.07035	602.3257	0	10.889009	5.5482271	0
50	496	107.51705	602.5444	0	6.6360133	3.3812176	0
51	496	107.9638	602.7645	0	2.2363867	1.1394959	0

SLOPE/W Analysis

Report generated using GeoStudio 2007, version 7.16. Copyright © 1991-2010 GEO-SLOPE International Ltd.

File Information

Title: Sporn Fly Ash Disposal Facility Western Dike Section H-H
Comments: Shallow Sloughing Assessment Saturated Topsoil Material with Maximum Pseudo-Static Train Loads (Condition 4)
Created By: Roger W. Cecil, P.E.
Revision Number: 186
Last Edited By: Roger Cecil
Date: 5/4/2010
Time: 9:12:48 AM
File Name: Sporn FADF-Shallow Sloughing Assessment for Section H-H Condition 4.gsz
Directory: C:\Working Folder\Sporn\VIBRATION ASSESSMENT\
Last Solved Date: 5/4/2010
Last Solved Time: 9:12:54 AM

Project Settings

Length(L) Units: feet
Time(t) Units: Seconds
Force(F) Units: lbf
Pressure(p) Units: psf
Strength Units: psf
Unit Weight of Water: 62.4 pcf
View: 2D

Analysis Settings

SLOPE/W Analysis

Description: Shallow Sloughing Assessment

Kind: SLOPE/W

Method: Morgenstern-Price

Settings

Apply Phreatic Correction: No

Side Function

Interslice force function option: Half-Sine

PWP Conditions Source: Piezometric Line

Use Staged Rapid Drawdown: No

Slip Surface

Direction of movement: Right to Left

Use Passive Mode: No

Slip Surface Option: Entry and Exit

Critical slip surfaces saved: 1
Optimize Critical Slip Surface Location: No
Tension Crack:

Tension Crack Option: (none)

FOS Distribution

FOS Calculation Option: Constant

Advanced

Number of Slices: 50

Optimization Tolerance: 0.05

Minimum Slip Surface Depth: 0.5 ft

Optimization Maximum Iterations: 2000

Optimization Convergence Tolerance: 1e-007

Starting Optimization Points: 8

Ending Optimization Points: 16

Complete Passes per Insertion: 1

Driving Side Maximum Convex Angle: 5 °

Resisting Side Maximum Convex Angle: 1 °

Materials

Silty Sand (1)

Model: Mohr-Coulomb

Unit Weight: 130 pcf

Unit Wt. Above Water Table: 125 pcf

Cohesion: 0.1 psf

Phi: 34 °

Phi-B: 0 °

Pore Water Pressure

Piezometric Line: 1

Silty Sand (2)

Model: Mohr-Coulomb

Unit Weight: 112 pcf

Unit Wt. Above Water Table: 107 pcf

Cohesion: 0.1 psf

Phi: 35 °

Phi-B: 0 °

Pore Water Pressure

Piezometric Line: 1

Gravelly Sand (3)

Model: Mohr-Coulomb

Unit Weight: 110 pcf

Unit Wt. Above Water Table: 105 pcf

Cohesion: 0.1 psf

Phi: 33 °

Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1

Silty Clay (4)

Model: Mohr-Coulomb
Unit Weight: 120 pcf
Unit Wt. Above Water Table: 115 pcf
Cohesion: 0.1 psf
Phi: 32 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1

Silty Sand (5)

Model: Mohr-Coulomb
Unit Weight: 131 pcf
Unit Wt. Above Water Table: 126 pcf
Cohesion: 0.1 psf
Phi: 31 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1

Sandy Silt (6)

Model: Mohr-Coulomb
Unit Weight: 130 pcf
Unit Wt. Above Water Table: 125 pcf
Cohesion: 0.1 psf
Phi: 27 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1

Fly Ash (7)

Model: Mohr-Coulomb
Unit Weight: 90 pcf
Unit Wt. Above Water Table: 102 pcf
Cohesion: 0.1 psf
Phi: 27 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1

Topsoil

Model: Mohr-Coulomb
Unit Weight: 130 pcf
Unit Wt. Above Water Table: 125 pcf

Cohesion: 0 psf
Phi: 27 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 2

Slip Surface Entry and Exit

Left Projection: Range
Left-Zone Left Coordinate: (74, 591) ft
Left-Zone Right Coordinate: (96.98653, 598.24439) ft
Left-Zone Increment: 10
Right Projection: Range
Right-Zone Left Coordinate: (105.97741, 601.99059) ft
Right-Zone Right Coordinate: (128, 611) ft
Right-Zone Increment: 10
Radius Increments: 10

Slip Surface Limits

Left Coordinate: (0, 593) ft
Right Coordinate: (310, 588) ft

Piezometric Lines

Piezometric Line 1

Coordinates

	X (ft)	Y (ft)
	0	589
	135	589
	146	605
	309	605

Piezometric Line 2

Coordinates

	X (ft)	Y (ft)
	74	591
	82	592
	106	602

	126	610
	128	611
	130	611

Seismic Loads

Horz Seismic Load: 0.046

Vert Seismic Load: 0.008

Ignore seismic load in strength: No

Regions

	Material	Points	Area (ft ²)
Region 1	Sandy Silt (6)	1,3,4,5,6,2	5355
Region 2	Silty Sand (5)	7,8,4,3	2085
Region 3	Silty Sand (1)	7,9,36,35,34,33,32,10,41,12,13,14,42,8	974
Region 4	Silty Sand (2)	40,39,16,12,41	467
Region 5	Silty Clay (4)	16,17,18,19,20,13,12	134
Region 6	Gravelly Sand (3)	38,17,16,39	152
Region 7	Silty Sand (2)	19,20,24,25,23	51.5
Region 8	Silty Sand (1)	37,27,22,18,17,38	19
Region 9	Silty Sand (2)	13,20,24,25,14	324
Region 10	Gravelly Sand (3)	22,28,29,23,19,18	121
Region 11	Fly Ash (7)	30,31,6,5,4,8,42	2405.5
Region 12	Topsoil	38,21,26,37	2
Region 13	Topsoil	21,38,39,15	16
Region 14	Topsoil	39,40,41,10,11,15	22

Points

	X (ft)	Y (ft)
Point 1	0	555
Point 2	310	555
Point 3	0	576
Point 4	218	576
Point 5	248	561
Point 6	310	561
Point 7	0	586

Point 8	199	586
Point 9	0	590
Point 10	74	591
Point 11	82	592
Point 12	137	591
Point 13	139	591
Point 14	189	591
Point 15	106	602
Point 16	137	602
Point 17	137	610
Point 18	145	610
Point 19	145	602
Point 20	145	597
Point 21	126	610
Point 22	149	610
Point 23	167	602
Point 24	148	600
Point 25	170	600
Point 26	128	611
Point 27	147	611
Point 28	154	608
Point 29	159	608
Point 30	214	588
Point 31	310	588
Point 32	49.5	590.5
Point 33	46.5	590.5
Point 34	31	590
Point 35	15.5	592
Point 36	0	593
Point 37	130	611
Point 38	128	610
Point 39	108	602
Point 40	84	592
Point 41	76	591
Point 42	193	589

Critical Slip Surfaces


	Slip Surface	FOS	Center (ft)	Radius (ft)	Entry (ft)	Exit (ft)
1	496	0.47	(19.266, 782.232)	200.189	(108.187, 602.875)	(83.5294, 592.637)

Slices of Slip Surface: 496

	Slip Surface	X (ft)	Y (ft)	PWP (psf)	Base Normal Stress (psf)	Frictional Strength (psf)	Cohesive Strength (psf)
1	496	83.773605	592.72035	1.1625606	2.0985779	0.47692464	0
2	496	84.2621	592.88735	3.4437545	6.2181589	1.4136297	0
3	496	84.750595	593.05575	5.6371171	10.182405	2.3159401	0
4	496	85.239085	593.22555	7.7422427	13.98911	3.1829381	0
5	496	85.727575	593.39675	9.7589253	17.63647	4.0138095	0
6	496	86.216065	593.5694	11.687155	21.12327	4.8079409	0
7	496	86.70456	593.7435	13.526542	24.444072	5.5627592	0
8	496	87.193055	593.919	15.276704	27.602515	6.2803146	0
9	496	87.681545	594.0959	16.937456	30.591271	6.9569661	0
10	496	88.170035	594.27425	18.508613	33.412643	7.5939826	0
11	496	88.65853	594.45405	19.989239	36.063199	8.1900916	0
12	496	89.147025	594.6353	21.381843	38.541415	8.7432386	0
13	496	89.635515	594.818	22.681473	40.847733	9.2561717	0
14	496	90.124005	595.00215	23.892184	42.976829	9.7241125	0
15	496	90.612495	595.18775	25.012289	44.932989	10.150103	0
16	496	91.10099	595.3748	26.040114	46.712846	10.533283	0
17	496	91.589485	595.5633	26.975901	48.316869	10.873767	0
18	496	92.077975	595.7533	27.821811	49.745552	11.170703	0
19	496	92.566465	595.9448	28.574275	50.997461	11.425184	0
20	496	93.054955	596.13775	29.233556	52.076911	11.63927	0
21	496	93.54345	596.3322	29.80182	52.980591	11.810174	0
22	496	94.031945	596.5281	30.27744	53.712832	11.940929	0
23	496	94.520435	596.7255	30.658792	54.272246	12.031656	0
24	496	95.008925	596.92445	30.94806	54.661263	12.08248	0
25	496	95.49742	597.12485	31.141733	54.882288	12.096417	0

26	496	95.985915	597.32675	31.242005	54.93397	12.071659	0
27	496	96.474405	597.5302	31.249185	54.822536	12.011222	0
28	496	96.962895	597.73515	31.159795	54.544734	11.915222	0
29	496	97.451385	597.94165	30.976048	54.10679	11.785702	0
30	496	97.93988	598.1497	30.698255	53.50547	11.620856	0
31	496	98.428375	598.35925	30.322984	52.745107	11.424642	0
32	496	98.916865	598.5703	29.852451	51.82438	11.195257	0
33	496	99.405355	598.7829	29.285128	50.745757	10.934736	0
34	496	99.89385	598.9971	28.621361	49.509802	10.643192	0
35	496	100.38235	599.21285	27.861513	48.117116	10.320745	0
36	496	100.87085	599.4301	27.004065	46.566403	9.9675092	0
37	496	101.35935	599.64895	26.047535	44.858296	9.5845611	0
38	496	101.84785	599.8694	24.994168	42.991535	9.1701166	0
39	496	102.33635	600.0914	23.842486	40.96676	8.725253	0
40	496	102.8248	600.31495	22.59103	38.782756	8.2500965	0
41	496	103.31325	600.5401	21.242057	36.438313	7.7428789	0
42	496	103.80175	600.7669	19.792268	33.932254	7.2046825	0
43	496	104.29025	600.99525	18.242829	31.26156	6.6333748	0
44	496	104.77875	601.2252	16.593249	28.426954	6.0295739	0
45	496	105.26725	601.4568	14.843037	25.425452	5.39201	0
46	496	105.75575	601.69	12.991902	22.254108	4.7193299	0
47	496	106.20015	601.9035	11.0159	18.870158	4.0019443	0
48	496	106.62365	602.10835	8.8062445	15.086751	3.200078	0
49	496	107.07035	602.3257	6.3944361	10.957005	2.3247449	0
50	496	107.51705	602.5444	3.8969775	6.6792125	1.4176195	0
51	496	107.9638	602.7645	1.3133153	2.2514378	0.47799728	0

Title: Sporn Fly Ash Disposal Facility Western Dike Section H-H
 Comments: Shallow Sloughing Assessment
 with Ongoing Repairs
 File Name: Sporn FADF-Shallow Sloughing Assessment for Section H-H_REPAIR.gsz
 Date: 5/4/2010
 Horz Seismic Load: 0.046
 Vert Seismic Load: 0.008



SLOPE/W Analysis

Report generated using GeoStudio 2007, version 7.16. Copyright © 1991-2010 GEO-SLOPE International Ltd.

File Information

Title: Sporn Fly Ash Disposal Facility Western Dike Section H-H
Comments: Shallow Sloughing Assessment with Ongoing Repairs
Created By: Roger W. Cecil, P.E.
Revision Number: 191
Last Edited By: Roger Cecil
Date: 5/4/2010
Time: 8:58:30 AM
File Name: Sporn FADF-Shallow Sloughing Assessment for Section H-H_REPAIR.gsz
Directory: C:\Working Folder\Sporn\VIBRATION ASSESSMENT\
Last Solved Date: 5/4/2010
Last Solved Time: 8:58:41 AM

Project Settings

Length(L) Units: feet
Time(t) Units: Seconds
Force(F) Units: lbf
Pressure(p) Units: psf
Strength Units: psf
Unit Weight of Water: 62.4 pcf
View: 2D

Analysis Settings

SLOPE/W Analysis

Description: Shallow Sloughing Assessment

Kind: SLOPE/W

Method: Morgenstern-Price

Settings

Apply Phreatic Correction: No

Side Function

Interslice force function option: Half-Sine

PWP Conditions Source: Piezometric Line

Use Staged Rapid Drawdown: No

Slip Surface

Direction of movement: Right to Left

Use Passive Mode: No

Slip Surface Option: Entry and Exit

Critical slip surfaces saved: 1

Optimize Critical Slip Surface Location: No
Tension Crack

Tension Crack Option: (none)

FOS Distribution

FOS Calculation Option: Constant

Advanced

Number of Slices: 50

Optimization Tolerance: 0.05

Minimum Slip Surface Depth: 0.5 ft

Optimization Maximum Iterations: 2000

Optimization Convergence Tolerance: 1e-007

Starting Optimization Points: 8

Ending Optimization Points: 16

Complete Passes per Insertion: 1

Driving Side Maximum Convex Angle: 5 °

Resisting Side Maximum Convex Angle: 1 °

Materials

Silty Sand (1)

Model: Mohr-Coulomb

Unit Weight: 130 pcf

Unit Wt. Above Water Table: 125 pcf

Cohesion: 0.1 psf

Phi: 34 °

Phi-B: 0 °

Pore Water Pressure

Piezometric Line: 1

Silty Sand (2)

Model: Mohr-Coulomb

Unit Weight: 112 pcf

Unit Wt. Above Water Table: 107 pcf

Cohesion: 0.1 psf

Phi: 35 °

Phi-B: 0 °

Pore Water Pressure

Piezometric Line: 1

Gravelly Sand (3)

Model: Mohr-Coulomb

Unit Weight: 110 pcf

Unit Wt. Above Water Table: 105 pcf

Cohesion: 0.1 psf

Phi: 33 °

Phi-B: 0 °

Pore Water Pressure
Piezometric Line: 1

Silty Clay (4)

Model: Mohr-Coulomb
Unit Weight: 120 pcf
Unit Wt. Above Water Table: 115 pcf
Cohesion: 0.1 psf
Phi: 32 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1

Silty Sand (5)

Model: Mohr-Coulomb
Unit Weight: 131 pcf
Unit Wt. Above Water Table: 126 pcf
Cohesion: 0.1 psf
Phi: 31 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1

Sandy Silt (6)

Model: Mohr-Coulomb
Unit Weight: 130 pcf
Unit Wt. Above Water Table: 125 pcf
Cohesion: 0.1 psf
Phi: 27 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1

Fly Ash (7)

Model: Mohr-Coulomb
Unit Weight: 90 pcf
Unit Wt. Above Water Table: 102 pcf
Cohesion: 0.1 psf
Phi: 27 °
Phi-B: 0 °
Pore Water Pressure
Piezometric Line: 1

Rockfill

Model: Mohr-Coulomb
Unit Weight: 115 pcf
Unit Wt. Above Water Table: 125 pcf
Cohesion: 0 psf

Phi: 38 °
Phi-B: 0 °

Slip Surface Entry and Exit

Left Projection: Range
Left-Zone Left Coordinate: (74, 591) ft
Left-Zone Right Coordinate: (96.98653, 598.24439) ft
Left-Zone Increment: 10
Right Projection: Range
Right-Zone Left Coordinate: (105.97741, 601.99059) ft
Right-Zone Right Coordinate: (128, 611) ft
Right-Zone Increment: 10
Radius Increments: 10

Slip Surface Limits

Left Coordinate: (0, 593) ft
Right Coordinate: (310, 588) ft

Piezometric Lines

Piezometric Line 1

Coordinates

	X (ft)	Y (ft)
	0	589
	135	589
	146	605
	309	605

Seismic Loads

Horz Seismic Load: 0.046
Vert Seismic Load: 0.008
Ignore seismic load in strength: No

Regions

	Material	Points	Area (ft ²)
Region 1	Sandy Silt (6)	1,3,4,5,6,2	5355

Region 2	Silty Sand (5)	7,8,4,3	2085
Region 3	Silty Sand (1)	7,9,36,35,34,33,32,10,41,12,13,14,45,8	974
Region 4	Silty Sand (2)	40,42,43,39,16,12,41	420.34
Region 5	Silty Clay (4)	16,17,18,19,20,13,12	134
Region 6	Gravelly Sand (3)	38,17,16,39,44	151.832
Region 7	Silty Sand (2)	19,20,24,25,23	51.5
Region 8	Silty Sand (1)	37,27,22,18,17,38	19
Region 9	Silty Sand (2)	13,20,24,25,14	324
Region 10	Gravelly Sand (3)	22,28,29,23,19,18	121
Region 11	Fly Ash (7)	30,31,6,5,4,8,45	2405.5
Region 12	Rockfill	38,21,26,37	2
Region 13	Rockfill	21,38,44,39,15	16.168
Region 14	Rockfill	39,43,42,40,41,10,11,15	68.66

Points

	X (ft)	Y (ft)
Point 1	0	555
Point 2	310	555
Point 3	0	576
Point 4	218	576
Point 5	248	561
Point 6	310	561
Point 7	0	586
Point 8	199	586
Point 9	0	590
Point 10	74	591
Point 11	82	592
Point 12	137	591
Point 13	139	591
Point 14	189	591
Point 15	106	602
Point 16	137	602
Point 17	137	610
Point 18	145	610
Point 19	145	602

Point 20	145	597
Point 21	126	610
Point 22	149	610
Point 23	167	602
Point 24	148	600
Point 25	170	600
Point 26	128	611
Point 27	147	611
Point 28	154	608
Point 29	159	608
Point 30	214	588
Point 31	310	588
Point 32	49.5	590.5
Point 33	46.5	590.5
Point 34	31	590
Point 35	15.5	592
Point 36	0	593
Point 37	130	611
Point 38	128	610
Point 39	108.7	602
Point 40	84	592
Point 41	76	591
Point 42	91.3	592
Point 43	106.9	600.2
Point 44	109.2	602.48
Point 45	193	589

Critical Slip Surfaces

	Slip Surface	FOS	Center (ft)	Radius (ft)	Entry (ft)	Exit (ft)
1	1322	1.56	(78.795, 686.555)	90.165	(128, 611)	(96.9865, 598.244)

Slices of Slip Surface: 1322

	Slip Surface	X (ft)	Y (ft)	PWP (psf)	Base Normal Stress (psf)	Frictional Strength	Cohesive
--	--------------	--------	--------	-----------	--------------------------	---------------------	----------

	e					(psf)	Strengt h (psf)
1	1322	97.28698	598.30735	0	6.5487514	5.1164453	0
2	1322	97.88788	598.4354	0	19.442419	15.190082	0
3	1322	98.488775	598.56775	0	31.914716	24.934509	0
4	1322	99.08967	598.7044	0	43.951596	34.338751	0
5	1322	99.69057	598.8454	0	55.535302	43.388933	0
6	1322	100.29146	598.99075	0	66.649912	52.072618	0
7	1322	100.89235	599.14045	0	77.276528	60.375041	0
8	1322	101.49325	599.29455	0	87.399683	68.284116	0
9	1322	102.09415	599.45305	0	97.005794	75.789233	0
10	1322	102.69505	599.616	0	106.0767	82.876198	0
11	1322	103.29595	599.78345	0	114.60088	89.536022	0
12	1322	103.89685	599.9554	0	122.56712	95.759931	0
13	1322	104.49775	600.13185	0	129.96443	101.53934	0
14	1322	105.09865	600.31285	0	136.78685	106.8696	0
15	1322	105.69955	600.4984	0	143.02544	111.74372	0
16	1322	106.32095	600.6952	0	148.30533	115.86882	0
17	1322	106.96285	600.90365	0	152.58197	119.2101	0
18	1322	107.6047	601.1174	0	156.20179	122.03821	0
19	1322	108.3128	601.35975	771.2495 1	170.01534	119.04602	0.1
20	1322	108.95	601.58265	785.1636 7	165.72369	116.04097	0.1
21	1322	109.65115	601.8357	800.9441 8	164.21907	114.98743	0.1
22	1322	110.41375	602.11665	818.4777 5	165.45459	107.44746	0.1
23	1322	111.03665	602.35255	833.1929	165.5921	107.53677	0.1
24	1322	111.65955	602.5937	848.2377 9	165.23744	107.30645	0.1

25	1322	112.28245	602.8402	- 863.6194 1	164.4095	106.76878	0.1
26	1322	112.9053	603.09205	- 879.3445 4	163.11238	105.92642	0.1
27	1322	113.52815	603.3493	- 895.4044	161.36509	104.79172	0.1
28	1322	114.15105	603.6121	-911.79	159.15712	103.35785	0.1
29	1322	114.77395	603.8804	- 928.5366 3	156.52256	101.64694	0.1
30	1322	115.39685	604.15425	- 945.6342 1	153.45117	99.652355	0.1
31	1322	116.01975	604.4338	- 963.0726 4	149.94777	97.377221	0.1
32	1322	116.64265	604.71905	- 980.8705 8	146.03192	94.834239	0.1
33	1322	117.26555	605.01	- 999.0314 2	141.70574	92.024783	0.1
34	1322	117.88845	605.30675	- 1017.543 5	136.96288	88.944733	0.1
35	1322	118.51135	605.60945	- 1036.423 9	131.80604	85.595844	0.1
36	1322	119.13425	605.9181	- 1055.688 9	126.23528	81.978148	0.1
37	1322	119.75715	606.23275	- 1075.324 8	120.24662	78.08907	0.1
38	1322	120.38005	606.55345	- 1095.332 3	113.83365	73.924437	0.1

39	1322	121.00295	606.8803	1115.725 4	106.99036	69.480355	0.1
40	1322	121.62585	607.21345	1136.517 6	99.706992	64.750478	0.1
41	1322	122.24875	607.5529	1157.706 6	91.972843	59.727863	0.1
42	1322	122.87165	607.8987	1179.276 4	83.773662	54.403252	0.1
43	1322	123.4648	608.2339	0	66.674695	52.091981	0
44	1322	124.0282	608.55795	0	57.764842	45.13084	0
45	1322	124.59155	608.8874	0	48.437083	37.843196	0
46	1322	125.1549	609.22235	0	38.679681	30.219879	0
47	1322	125.7183	609.5629	0	28.481487	22.252176	0
48	1322	126.21465	609.8673	0	21.036726	16.435692	0
49	1322	126.69105	610.16415	0	15.878217	12.405423	0
50	1322	127.2146	610.49495	0	9.8267589	7.6775055	0
51	1322	127.7382	610.8308	0	3.3458689	2.6140793	0

APPENDIX V

FESM SLOPE STABILITY AND LIQUEFACTION ANALYSES



FINITE ELEMENT STRESS METHOD STABILITY ANALYSIS SUMMARY
RAILWAY-INDUCED VIBRATION ASSESSMENT
BOTTOM ASH AND FLY ASH DISPOSAL FACILITIES
PHILIP SPORN PLANT
NEW HAVEN, MASON COUNTY, WEST VIRGINIA
GA FILE NO. 09-387

GENERAL

Geo/Environmental Associates, Inc. (GA) has prepared finite element stress method (FESM) slope stability analyses for the western dikes of the Bottom Ash Disposal and Fly Ash Disposal Facilities at the Philip Sporn Plant. Specifically, GA has evaluated Section A-A for the Bottom Ash Disposal Facility Western Dike and Section H-H for the Fly Ash Disposal Facility Western Dike. The FESM analyses were conducted using the finite element computer program *QUAKE/W* and the slope stability analyses were conducted using *SLOPE/W*. Both *QUAKE/W* and *SLOPE/W* are developed by GEO-SLOPE International, Ltd. of Calgary, Alberta Canada.

The *QUAKE/W* program was used to conduct finite element analyses in order to model initial stresses in the western dikes under static conditions. Thereafter, the *QUAKE/W* program was used to approximate the stress conditions at specified time steps generated during the field measured railway-induced vibration events. The results of the railway-induced vibration events that are modeled in the *QUAKE/W* finite element analyses are then evaluated for liquefaction. The stresses developed in the railway-induced vibration analyses are then applied in *SLOPE/W* to conduct slope stability analyses based on the Newmark Deformation Analysis Method. Specifically, *SLOPE/W* uses the stress conditions generated by *QUAKE/W* to perform a static analysis for each time step with the stress conditions approximated at that time step. The result is a dynamic analysis for the specific train vibration event. The *SLOPE/W* slope stability analyses were performed in both the upstream and downstream directions for both Section A-A and H-H. At the request of the USEPA, both shallow-seated and deep-seated (global) slip surfaces were modeled in the FESM slope stability analyses. GA conservatively applied the vibration events from the dike exterior toe monitoring locations (i.e., Location A for Section A-A and Location C for Section H-H) to the downstream direction FESM slope stability analyses. We applied the accelerations from the dike crest monitoring locations (i.e., Location B for Section A-A and Location D for Section H-H) to the upstream direction FESM slope stability analyses. Table V-1 summarizes the vibration event applied in each analysis.



TABLE V-1 SUMMARY OF VIBRATION EVENTS USED IN FINITE ELEMENT STRESS METHOD SLOPE STABILITY ANALYSES		
Critical Section	Vibration Monitoring Location	Maximum Railway Induced Vibration Data Used
Bottom Ash Disposal Facility Section A-A	Location A (Exterior Toe - Adjacent to Track) Downstream Direction Analyses	November 11, 2009 12:12 pm Train 10 sec. to 20 sec.
	Location B (Crest) Upstream Direction Analyses	November 11, 2009 12:12 pm Train 16 sec. to 26 sec.
Fly Ash Disposal Facility Section H-H	Location C (Exterior Toe - Adjacent to Track) Downstream Direction Analyses	November 11, 2009 12:12 pm Train 36 sec. to 46 sec.
	Location D (Crest) Upstream Direction Analyses	November 11, 2009 12:12 pm Train 0 sec. to 5.5 sec.

MATERIAL PARAMETERS

Strength parameters for the various embankment and foundation materials used in the finite element stability analyses for critical Sections A-A and H-H are provided in Tables V-2 and V-3, respectively. In general, the parameters are based on site specific data and by applying accepted reference data to the site specific soils/conditions. Material parameters required for the finite element stress analysis include the unit weight, damping ratio, small strain shear modulus, Poisson's ratio, and effective friction angle, ϕ' . The damping ratio for the fly ash and foundation materials was measured by free-free resonant column testing performed by Dr. Kalinski at the University of Kentucky. The damping ratio for all other materials was developed by relating published data to site specific soils. Small strain shear modulus and Poisson's ratio values were calculated from shear wave velocity data that was obtained by Dr. Kalinski using crosshole seismic testing performed at site. Unit weight and ϕ' were determined from in-situ and laboratory testing performed by AEP and GA.



TABLE V.2. FESM AND QUAKE/W MATERIAL PARAMETERS FOR SECTION A-A ANALYSIS

	Silty Clay (1)	Fly Ash (2)	Bottom Ash (3)	Clayey Sand (4)	Bottom Ash (5)	Gravelly Sand (6)	Clayey Sand (7)	Road Material (8)	Clayey Sand (9)	Sand (10)	Sand & Gravel (11)	Riprap (12)
Unit Weight γ (pcf)	123	97	80	105	62	111	110	145	115	123	123	145
Source	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)
Damping Ratio λ (%)	7	4.5	10	10	10	10	10	10	7	7	7	10
Source ⁽⁶⁾	Kalinski Report	Kalinski Report	Seed-Idriss, Kokusho	Seed-Idriss, Kokusho	Seed-Idriss, Kokusho	Seed-Idriss, Kokusho	Seed-Idriss, Kokusho	Seed-Idriss, Kokusho	Kalinski Report	Kalinski Report	Kalinski Report	Seed-Idriss, Kokusho
Small Strain Shear Modulus G_{max} (psf)	1,839,790	568,271	4,712,248	4,488,812	2,676,022	4,790,943	4,747,781	6,258,440	6,816,193	7,245,081	7,245,081	6,258,440
Source ⁽³⁾	Kalinski Report	Kalinski Report	Kalinski Report	Kalinski Report	Kalinski Report	Kalinski Report	Kalinski Report	Kalinski Report	Kalinski Report	Kalinski Report	Kalinski Report	Kalinski Report
Poisson's Ratio ν	.468	0.495	0.468	0.352	0.352	0.352	0.468	0.352	0.468	0.468	0.468	0.352
Source	Kalinski Report	Kalinski Report	Kalinski Report	Kalinski Report	Kalinski Report	Kalinski Report	Kalinski Report	Kalinski Report	Kalinski Report	Kalinski Report	Kalinski Report	Kalinski Report
Cyclic Number Function ^(4,5)	QUAKE	OSU	QUAKE	QUAKE	QUAKE	QUAKE	QUAKE	QUAKE	QUAKE	QUAKE	QUAKE	QUAKE
Phi Angle ϕ (degrees)	36	33	36	31	38	34	34	36	29	29	32	38
Source	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)

Notes:

- (1) AEP Philip Sporn Electric Generating Plant Bottom Ash Facility - Engineering Report, 1996
- (2) AEP Philip Sporn Power Plant Bottom Ash Disposal Facility - Stability Analysis, 2009
- (3) G_{max} derived from shear wave velocities from cross hole measurements
- (4) Cyclic Number Function for fly ash based on data prepared by Ohio State University (OSU)
- (5) Cyclic Number Function for other materials based on functions built into QUAKE/W computer program (QUAKE)
- (6) Damping Ratios From:
 - Kalinski Report
 - Seed Idriss (SHAKE91 Users Manual)
 - Kokusho (Geotechnical Earthquake Engineering by Kuo Towhata)



TABLE V.3. FESM AND QUAKE/W MATERIAL PARAMETERS FOR SECTION H-H ANALYSIS

	Silty Sand (1)	Silty Sand (2)	Gravelly Sand (3)	Silty Clay (4)	Silty Sand (5)	Sandy Silt (6)	Fly Ash (7)	Silty Sand (8)
Unit Weight γ (pcf)	130	107	105	115	131	130	90	112
Source	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	GA	AEP ^(1,2)
Damping Ratio λ (%)	10	10	10	10	7	7	4.5	10
Source ⁽⁶⁾	Seed-Idriss, Kokusho	Seed-Idriss, Kokusho	Seed-Idriss, Kokusho	Seed-Idriss, Kokusho	Kalinski Report	Kalinski Report	Kalinski Report	Seed-Idriss, Kokusho
Small Strain Shear Modulus G_{max} (psf)	1,944,493	3,182,930	3,123,436	3,420,906	1,959,450	1,933,302	774,831	3,331,665
Source ⁽⁵⁾	Kalinski Report	Kalinski Report	Kalinski Report	Kalinski Report	Kalinski Report	Kalinski Report	Kalinski Report	Kalinski Report
Poisson's Ratio ν	0.352	0.352	0.352	0.352	0.45	0.45	0.495	0.45
Source	Kalinski Report	Kalinski Report	Kalinski Report	Kalinski Report	Kalinski Report	Kalinski Report	Kalinski Report	Kalinski Report
Cyclic Number Function ^(4,5)	QUAKE	QUAKE	QUAKE	QUAKE	QUAKE	QUAKE	OSU	QUAKE
Phi Angle ϕ (degrees)	34	35	33	32	31	27	27	38
Source	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)	AEP ^(1,2)

Notes:

- (1) AEP Philip Sporn Electric Generating Plant Fly Ash Facility - Engineering Report, 1998
- (2) AEP Philip Sporn Power Plant Fly Ash Disposal Facility - Stability Analysis, 2009
- (3) G_{max} derived from shear wave velocities from cross hole measurements
- (4) Cyclic Number Function for fly ash based on data prepared by Ohio State University (OSU)
- (5) Cyclic Number Function for other materials based on functions built into QUAKE/W computer program (QUAKE)
- (6) Damping Ratios From:
 - Kalinski Report
 - Seed Idriss (SHAKE91 Users Manual)
 - Kokusho (Geotechnical Earthquake Engineering by Kuo Towhata)



SLOPE STABILITY ANALYSIS RESULTS

Graphical output from the FESM slope stability analyses are provided in this appendix. Specifically, the results show the critical slip surface and corresponding safety factor for each of the modeled conditions. The slope stability analysis results are tabulated in Table V-4.

Critical Section	Analysis Method	Rail Induced Vibration Loading Condition	Slope and Slip Surface Condition	Stability Factor
Bottom Ash Disposal Facility Section A-A	FESM	Location A (Exterior Toe) (11-11-09 12:12 pm Train)	Downstream (Shallow)	4.06
			Downstream (Deep)	4.25
		Location B (Crest) (11-11-09 12:12 pm Train)	Upstream (Shallow)	2.68
			Upstream (Deep)	2.72
Fly Ash Disposal Facility Section H-H	FESM	Location C (Exterior Toe) (11-11-09 12:12 pm Train)	Downstream (Shallow)	2.66
			Downstream (Deep)	2.75
		Location D (Crest) (11-11-09 12:12 pm Train)	Upstream (Shallow)	1.78
			Upstream (Deep)	2.12

SUMMARY OF RESULTS

GA used *QUAKE/W* to perform finite element stress analyses for Sections A-A of the Bottom Ash Disposal Facility Western Dike and Section H-H of the Fly Ash Disposal Facility Western Dike. Given the material parameters and railway induced loadings, *QUAKE/W* analyses were performed to delineate potential liquefaction zones. As shown in the liquefaction analysis results provided in this appendix; for the measured railway-induced vibrations, no liquefaction zones are predicted for Section A-A of the Bottom Ash Disposal Facility Western Dike or for Section H-H of the Fly Ash Disposal Facility Western Dike. It should be noted that vibration monitoring conducted at the crest and at the downstream bench of the Fly Ash Disposal Facility Eastern Dike (i.e., along Section K-K) yielded non-detectable vibration levels due to rail traffic during three monitoring events (i.e., on November 11, 2009; January 6, 2010; and January 7, 2010). Correspondingly, we believe that liquefaction of the fly ash material under the raised Eastern Dike of the Fly Ash Disposal Facility, due to railway induced ground vibration, is improbable.

GA used *SLOPE/W* to perform FESM stability analyses for Sections A-A of the Bottom Ash Disposal Facility Western Dike and Section H-H of the Fly Ash Disposal Facility Western Dike. The *SLOPE/W* program uses the Newmark Deformation Analysis Method to analyze the stability at specified time steps during a vibration event. The stresses within the western dikes for each time step were calculated by the associated *QUAKE/W* analysis. As shown in Table V-4, the FESM stability factors equal or exceed 2.68 for the Bottom Ash Disposal Facility Section A-A and 1.78 for the Fly Ash Disposal Facility Section H-H for the shallow-seated slip surface




conditions. Moreover, the FESM stability factors exceed 2.72 for the Bottom Ash Disposal Facility Section A-A and 2.12 for the Fly Ash Disposal Facility Section H-H for the deep-seated (global) slip surface conditions. Based on the results obtained in our FESM stability assessment, we believe that railway induced vibrations will not have a significant/consequential impact on the slope stability of the dikes for the Bottom Ash and Fly Ash Disposal Facilities.



**BOTTOM ASH DISPOSAL FACILITY
SECTION A-A
FESM SLOPE STABILITY ANALYSIS RESULTS**

Title: Sporn Bottom Ash Disposal Facility
 Comments: FESM - Location A (Exterior Toe)
 Railway Induced Vibration Loadings
 Down Stream Shallow Failure Surface
 File Name: BAP_A-A_Slope-DS_Shallow.gsz
 Date: 5/3/2010



Newmark Deformation

Report generated using GeoStudio 2007, version 7.15. Copyright © 1991-2009 GEO-SLOPE International Ltd.

File Information

Title: Sporn Bottom Ash Disposal Facility
Comments: FESM - Location A (Exterior Toe) Railway Induced Vibration Loadings Down Stream Shallow Failure Surface
Created By: Seth W. Frank, E.I.
Revision Number: 165
Last Edited By: Seth Frank
Date: 5/3/2010
Time: 7:31:40 PM
File Name: BAP_A-A_Slope-DS_Shallow.gsz
Directory: E:\Final Analysis Files\BAP_A-A GA\Shallow\
Last Solved Date: 5/3/2010
Last Solved Time: 8:03:36 PM

Project Settings

Length(L) Units: feet
Time(t) Units: Seconds
Force(F) Units: lbf
Pressure(p) Units: psf
Strength Units: psf
Unit Weight of Water: 62.4 pcf
View: 2D

Analysis Settings

Newmark Deformation

Kind: SLOPE/W
Parent: Bottom Ash Pond A-A
Method: QUAKE/W Newmark Deformation
Settings
Initial Stress: Parent Analysis
PWP Conditions Source: Parent Analysis
SlipSurface
Direction of movement: Right to Left
Use Passive Mode: No
Slip Surface Option: Entry and Exit
Critical slip surfaces saved: 1
Optimize Critical Slip Surface Location: No
Tension Crack
Tension Crack Option: (none)
FOS Distribution

Newmark Deformation

FOS Calculation Option: Constant

Time

Starting Time: 0 sec

Duration: 10 sec

of Steps: 10240

Advanced

Number of Slices: 30

Optimization Tolerance: 0.01

Minimum Slip Surface Depth: 1 ft

Optimization Maximum Iterations: 2000

Optimization Convergence Tolerance: 1e-007

Starting Optimization Points: 8

Ending Optimization Points: 16

Complete Passes per Insertion: 1

Driving Side Maximum Convex Angle: 5 °

Resisting Side Maximum Convex Angle: 1 °

Materials

Fly Ash (2)

Model: Mohr-Coulomb

Unit Weight: 139 pcf

Unit Wt. Above Water Table: 134 pcf

Cohesion: 0.1 psf

Phi: 33 °

Phi-B: 18 °

Bottom Ash (3)

Model: Mohr-Coulomb

Unit Weight: 80 pcf

Unit Wt. Above Water Table: 80 pcf

Cohesion: 0.1 psf

Phi: 36 °

Phi-B: 20 °

Clayey Sand (4)

Model: Mohr-Coulomb

Unit Weight: 105 pcf

Unit Wt. Above Water Table: 105 pcf

Cohesion: 0.1 psf

Phi: 31 °

Phi-B: 20 °

Bottom Ash (5)

Model: Mohr-Coulomb

Unit Weight: 80 pcf

Unit Wt. Above Water Table: 62 pcf

Newmark Deformation

Cohesion: 0.1 psf

Phi: 38 °

Phi-B: 20 °

Gravelly Sand (6)

Model: Mohr-Coulomb

Unit Weight: 115 pcf

Unit Wt. Above Water Table: 111 pcf

Cohesion: 0.1 psf

Phi: 34 °

Phi-B: 19 °

Clayey Sand (7)

Model: Mohr-Coulomb

Unit Weight: 110 pcf

Unit Wt. Above Water Table: 104 pcf

Cohesion: 0.1 psf

Phi: 34 °

Phi-B: 19 °

Road Material (8)

Model: Mohr-Coulomb

Unit Weight: 145 pcf

Cohesion: 0.1 psf

Phi: 36 °

Phi-B: 20 °

Silty Clay (1)

Model: Mohr-Coulomb

Unit Weight: 123 pcf

Cohesion: 0.1 psf

Phi: 36 °

Phi-B: 20 °

Clayey Sand (9)

Model: Mohr-Coulomb

Unit Weight: 115 pcf

Cohesion: 0.1 psf

Phi: 29 °

Phi-B: 15 °

Sand (10)

Model: Mohr-Coulomb

Unit Weight: 123 pcf

Cohesion: 0.1 psf

Phi: 29 °

Phi-B: 15 °

Sand and Gravel (11)

Newmark Deformation

Model: Mohr-Coulomb

Unit Weight: 123 pcf

Cohesion: 0.1 psf

Phi: 32 °

Phi-B: 18 °

Riprap (12)

Model: Mohr-Coulomb

Unit Weight: 145 pcf

Cohesion: 0.1 psf

Phi: 36 °

Phi-B: 20 °

Slip Surface Entry and Exit

Left Projection: Range

Left-Zone Left Coordinate: (42, 584) ft

Left-Zone Right Coordinate: (61, 584.11765) ft

Left-Zone Increment: 6

Right Projection: Range

Right-Zone Left Coordinate: (96.63839, 592.14123) ft

Right-Zone Right Coordinate: (119, 593) ft

Right-Zone Increment: 6

Radius Increments: 10

Slip Surface Limits

Left Coordinate: (0, 589) ft

Right Coordinate: (335, 545) ft

Regions

	Material	Points	Area (ft ²)
Region 1	Sand (10)	3,4,5,6	8375
Region 2	Sand and Gravel (11)	6,5,2,1	4020
Region 3	Clayey Sand (9)	7,8,4,3	2680
Region 4	Silty Clay (1)	9,36,10,45,11,12,13,14,15,16,17,8,7	5834.125
Region 5	Fly Ash (2)	13,18,15,14	688.5
Region 6	Bottom Ash (5)	12,19,20,18,13	680
Region 7	Clayey Sand (4)	19,21,22,20	301.25
Region 8	Bottom Ash (5)	21,23,24,22	273
Region 9	Bottom Ash (5)	11,12,19,21,23,39,38,37	243.875
Region 10	Clayey Sand (7)	23,25,26,24	81
Region 11	Bottom Ash (3)	26,27,28,29,34,30,35,31,16,15,18,20,22,24	2927.75
Region 12	Riprap (12)	25,40,41,42,43,44,45,11,37,38,39,23	59.875
Region 13	Road Material (8)	32,46,47,33	80.5
Region 14	Gravelly Sand (6)	46,40,25,26,27,47	85.5

Points

	X (ft)	Y (ft)
Point 1	0	500
Point 2	335	500
Point 3	0	537
Point 4	335	537
Point 5	335	512
Point 6	0	512
Point 7	0	545
Point 8	335	545
Point 9	0	589
Point 10	27	586
Point 11	39	583
Point 12	51	575
Point 13	67	566.5
Point 14	83.5	557.5
Point 15	158.5	557.5
Point 16	300	557.5
Point 17	334.5	557.5
Point 18	145	566.5
Point 19	65.5	575
Point 20	133	575
Point 21	73	580
Point 22	126	580
Point 23	86	586.5
Point 24	117	586.5
Point 25	90.5	589.5
Point 26	113.5	589.5
Point 27	153	589.5
Point 28	161	587
Point 29	166	584
Point 30	230	575
Point 31	280	570
Point 32	99	593
Point 33	129.5	593
Point 34	184	575
Point 35	240	570
Point 36	8	586
Point 37	52	583
Point 38	59	583
Point 39	77.5	585
Point 40	89	589.5
Point 41	85	588
Point 42	77	586
Point 43	60	584
Point 44	39	584
Point 45	30	585.25

Newmark Deformation

Point 46	93.5	591
Point 47	143.5	591


Critical Slip Surfaces

	Slip Surface	FOS	Center (ft)	Radius (ft)	Entry (ft)	Exit (ft)
1	486	4.06	(63.275, 681.586)	97.495	(103.991, 593)	(61, 584.118)

Slices of Slip Surface: 486

	Slip Surface	X (ft)	Y (ft)	PWP (psf)	Base Normal Stress (psf)	Frictional Strength (psf)	Cohesive Strength (psf)
1	486	61.727275	584.10605	0	132.712	96.420914	0.1
2	486	63.18182	584.0938	0	126.4312	91.857646	0.1
3	486	64.636365	584.1033	0	122.17749	88.767139	0.1
4	486	66.09091	584.1345	0	118.46185	86.067573	0.1
5	486	67.545455	584.18735	0	114.04979	82.862026	0.1
6	486	69	584.262	0	120.11868	87.271328	0.1
7	486	70.454545	584.3585	0	133.8631	97.257235	0.1
8	486	71.90909	584.47685	0	141.86291	103.06944	0.1
9	486	73.363635	584.61715	0	145.45992	105.68282	0.1
10	486	74.81818	584.77955	0	145.91275	106.01182	0.1
11	486	76.272725	584.9641	0	144.40131	104.91369	0.1
12	486	77.666665	585.1614	0	146.39111	106.35937	0.1
13	486	79	585.36985	0	167.88772	121.97757	0.1
14	486	80.333335	585.5973	0	188.06356	136.63618	0.1
15	486	81.666665	585.84385	0	206.55368	150.07003	0.1
16	486	83	586.1096	0	223.10133	162.0926	0.1
17	486	84.333335	586.3948	0	237.52021	172.56853	0.1
18	486	85.82648	586.7388	0	250.8599	182.26039	0.1
19	486	87.23972	587.0841	0	255.17381	172.11691	0.1
20	486	88.41324	587.3895	0	257.80716	173.89313	0.1
21	486	89.75	587.7577	0	258.46195	174.33478	0.1
22	486	91.25	588.19395	0	256.60872	173.08477	0.1
23	486	92.75	588.6565	0	251.96996	169.95588	0.1
24	486	94.398915	589.1972	0	243.63425	164.33338	0.1
25	486	95.91486	589.7192	0	238.41867	160.81542	0.1
26	486	97.148915	590.16705	0	234.80978	158.3812	0.1
27	486	98.38297	590.63385	0	225.41613	152.0451	0.1
28	486	99.161615	590.936	0	216.47537	146.01448	0.1
29	486	100.10127	591.3174	0	231.2146	167.98724	0.1
30	486	101.6573	591.968	0	258.67814	187.94067	0.1
31	486	103.21335	592.6506	0	218.16197	158.50395	0.1

Title: Sporn Bottom Ash Disposal Facility
 Comments: FESM - Location A (Exterior Toe)
 Railway Induced Vibration Loadings
 Down Stream Deep Failure Surface
 File Name: BAP_A-A_Slope-DS_Deep.gsz
 Date: 5/3/2010



Newmark Deformation

Report generated using GeoStudio 2007, version 7.15. Copyright © 1991-2009 GEO-SLOPE International Ltd.

File Information

Title: Sporn Bottom Ash Disposal Facility
Comments: FESM - Location A (Exterior Toe) Railway Induced Vibration Loadings Down Stream Deep Failure Surface
Created By: Seth W. Frank, E.I.
Revision Number: 167
Last Edited By: Seth Frank
Date: 5/3/2010
Time: 8:17:20 PM
File Name: BAP_A-A_Slope-DS_Deep.gsz
Directory: E:\Final Analysis Files\BAP_A-A GA\Deep\
Last Solved Date: 5/3/2010
Last Solved Time: 8:32:36 PM

Project Settings

Length(L) Units: feet
Time(t) Units: Seconds
Force(F) Units: lbf
Pressure(p) Units: psf
Strength Units: psf
Unit Weight of Water: 62.4 pcf
View: 2D

Analysis Settings

Newmark Deformation

Kind: SLOPE/W
Parent: Bottom Ash Pond A-A
Method: QUAKE/W Newmark Deformation
Settings
Initial Stress: Parent Analysis
PWP Conditions Source: Parent Analysis
SlipSurface
Direction of movement: Right to Left
Use Passive Mode: No
Slip Surface Option: Entry and Exit
Critical slip surfaces saved: 1
Optimize Critical Slip Surface Location: No
Tension Crack
Tension Crack Option: (none)
FOS Distribution

Newmark Deformation

FOS Calculation Option: Constant

Time

Starting Time: 0 sec

Duration: 10 sec

of Steps: 10240

Advanced

Number of Slices: 30

Optimization Tolerance: 0.01

Minimum Slip Surface Depth: 1 ft

Optimization Maximum Iterations: 2000

Optimization Convergence Tolerance: 1e-007

Starting Optimization Points: 8

Ending Optimization Points: 16

Complete Passes per Insertion: 1

Driving Side Maximum Convex Angle: 5 °

Resisting Side Maximum Convex Angle: 1 °

Materials

Fly Ash (2)

Model: Mohr-Coulomb

Unit Weight: 139 pcf

Unit Wt. Above Water Table: 134 pcf

Cohesion: 0.1 psf

Phi: 33 °

Phi-B: 18 °

Bottom Ash (3)

Model: Mohr-Coulomb

Unit Weight: 80 pcf

Unit Wt. Above Water Table: 80 pcf

Cohesion: 0.1 psf

Phi: 36 °

Phi-B: 20 °

Clayey Sand (4)

Model: Mohr-Coulomb

Unit Weight: 105 pcf

Unit Wt. Above Water Table: 105 pcf

Cohesion: 0.1 psf

Phi: 31 °

Phi-B: 20 °

Bottom Ash (5)

Model: Mohr-Coulomb

Unit Weight: 80 pcf

Unit Wt. Above Water Table: 62 pcf

Newmark Deformation

Cohesion: 0.1 psf

Phi: 38 °

Phi-B: 20 °

Gravelly Sand (6)

Model: Mohr-Coulomb

Unit Weight: 115 pcf

Unit Wt. Above Water Table: 111 pcf

Cohesion: 0.1 psf

Phi: 34 °

Phi-B: 19 °

Clayey Sand (7)

Model: Mohr-Coulomb

Unit Weight: 110 pcf

Unit Wt. Above Water Table: 104 pcf

Cohesion: 0.1 psf

Phi: 34 °

Phi-B: 19 °

Road Material (8)

Model: Mohr-Coulomb

Unit Weight: 145 pcf

Cohesion: 0.1 psf

Phi: 36 °

Phi-B: 20 °

Silty Clay (1)

Model: Mohr-Coulomb

Unit Weight: 123 pcf

Cohesion: 0.1 psf

Phi: 36 °

Phi-B: 20 °

Clayey Sand (9)

Model: Mohr-Coulomb

Unit Weight: 115 pcf

Cohesion: 0.1 psf

Phi: 29 °

Phi-B: 15 °

Sand (10)

Model: Mohr-Coulomb

Unit Weight: 123 pcf

Cohesion: 0.1 psf

Phi: 29 °

Phi-B: 15 °

Sand and Gravel (11)

Newmark Deformation

Model: Mohr-Coulomb

Unit Weight: 123 pcf

Cohesion: 0.1 psf

Phi: 32 °

Phi-B: 18 °

Riprap (12)

Model: Mohr-Coulomb

Unit Weight: 145 pcf

Cohesion: 0.1 psf

Phi: 36 °

Phi-B: 20 °

Slip Surface Entry and Exit

Left Projection: Range

Left-Zone Left Coordinate: (29, 585.5) ft

Left-Zone Right Coordinate: (60, 584) ft

Left-Zone Increment: 6

Right Projection: Range

Right-Zone Left Coordinate: (108, 593) ft

Right-Zone Right Coordinate: (129.5, 593) ft

Right-Zone Increment: 6

Radius Increments: 10

Slip Surface Limits

Left Coordinate: (0, 589) ft

Right Coordinate: (335, 545) ft

Regions

	Material	Points	Area (ft ²)
Region 1	Sand (10)	3,4,5,6	8375
Region 2	Sand and Gravel (11)	6,5,2,1	4020
Region 3	Clayey Sand (9)	7,8,4,3	2680
Region 4	Silty Clay (1)	9,36,10,45,11,12,13,14,15,16,17,8,7	5834.125
Region 5	Fly Ash (2)	13,18,15,14	688.5
Region 6	Bottom Ash (5)	12,19,20,18,13	680
Region 7	Clayey Sand (4)	19,21,22,20	301.25
Region 8	Bottom Ash (5)	21,23,24,22	273
Region 9	Bottom Ash (5)	11,12,19,21,23,39,38,37	243.875
Region 10	Clayey Sand (7)	23,25,26,24	81
Region 11	Bottom Ash (3)	26,27,28,29,34,30,35,31,16,15,18,20,22,24	2927.75
Region 12	Riprap (12)	25,40,41,42,43,44,45,11,37,38,39,23	59.875
Region 13	Road Material (8)	32,46,47,33	80.5
Region 14	Gravelly Sand (6)	46,40,25,26,27,47	85.5

Points

	X (ft)	Y (ft)
Point 1	0	500
Point 2	335	500
Point 3	0	537
Point 4	335	537
Point 5	335	512
Point 6	0	512
Point 7	0	545
Point 8	335	545
Point 9	0	589
Point 10	27	586
Point 11	39	583
Point 12	51	575
Point 13	67	566.5
Point 14	83.5	557.5
Point 15	158.5	557.5
Point 16	300	557.5
Point 17	334.5	557.5
Point 18	145	566.5
Point 19	65.5	575
Point 20	133	575
Point 21	73	580
Point 22	126	580
Point 23	86	586.5
Point 24	117	586.5
Point 25	90.5	589.5
Point 26	113.5	589.5
Point 27	153	589.5
Point 28	161	587
Point 29	166	584
Point 30	230	575
Point 31	280	570
Point 32	99	593
Point 33	129.5	593
Point 34	184	575
Point 35	240	570
Point 36	8	586
Point 37	52	583
Point 38	59	583
Point 39	77.5	585
Point 40	89	589.5
Point 41	85	588
Point 42	77	586
Point 43	60	584
Point 44	39	584
Point 45	30	585.25

Newmark Deformation

Point 46	93.5	591
Point 47	143.5	591


Critical Slip Surfaces

	Slip Surface	FOS	Center (ft)	Radius (ft)	Entry (ft)	Exit (ft)
1	467	4.25	(78.153, 619.683)	40.035	(108, 593)	(60, 584)

Slices of Slip Surface: 467

	Slip Surface	X (ft)	Y (ft)	PWP (psf)	Base Normal Stress (psf)	Frictional Strength (psf)	Cohesive Strength (psf)
1	467	60.754865	583.63565	0	94.071581	68.347005	0.1
2	467	62.328745	582.9188	0	199.09944	155.55353	0.1
3	467	63.96678	582.25585	0	259.4939	202.73886	0.1
4	467	65.604815	581.675	0	313.9366	245.27415	0.1
5	467	67.24285	581.17255	0	362.96559	283.5798	0.1
6	467	68.880885	580.74545	0	407.1413	318.09365	0.1
7	467	70.518915	580.3913	0	447.00977	349.24231	0.1
8	467	72.15695	580.1081	0	483.13273	377.46466	0.1
9	467	73.65465	579.90725	0	523.89385	314.78718	0.1
10	467	75	579.7778	0	566.62148	340.46053	0.1
11	467	76.333335	579.69475	0	603.12592	362.39461	0.1
12	467	77.25	579.65875	0	625.34079	375.74265	0.1
13	467	78.243985	579.6548	0	645.34275	387.76104	0.1
14	467	79.73195	579.68585	0	670.26655	402.73677	0.1
15	467	81.219915	579.7724	0	688.24291	413.53806	0.1
16	467	82.70788	579.9148	0	699.27595	420.16738	0.1
17	467	84.22593	580.1188	0	701.28394	547.90306	0.1
18	467	85.5	580.33095	0	696.26985	543.98563	0.1
19	467	86.75	580.58925	0	688.93895	538.2581	0.1
20	467	88.25	580.9497	0	678.46098	530.07181	0.1
21	467	89.75	581.3722	0	666.27702	520.55266	0.1
22	467	91.25	581.8589	0	652.83881	510.05358	0.1
23	467	92.75	582.41235	0	638.51038	498.85898	0.1
24	467	94.416665	583.11375	0	621.79068	485.79612	0.1
25	467	96.25	583.98615	0	596.79897	466.27046	0.1
26	467	98.083335	584.9773	0	561.74514	438.8834	0.1
27	467	99.77595	586.00185	0	526.1106	411.04265	0.1
28	467	101.52775	587.20225	0	468.82362	316.22553	0.1
29	467	103.47945	588.70225	0	388.23216	261.8659	0.1
30	467	105.2694	590.25	0	272.29712	183.66673	0.1
31	467	107.04175	592	0	183.5753	133.37526	0.1

Title: Sporn Bottom Ash Disposal Facility
 Comments: FESM - Location B (Crest)
 Railway Induced Vibration Loadings
 Up Stream Shallow Failure Surface
 File Name: BAP_A-A_Slope-US_Shallow.gsz
 Date: 5/3/2010



Newmark Deformation

Report generated using GeoStudio 2007, version 7.15. Copyright © 1991-2009 GEO-SLOPE International Ltd.

File Information

Title: Sporn Bottom Ash Disposal Facility
Comments: FESM - Location B (Crest) Railway Induced Vibration Loadings Up Stream Shallow Failure Surface
Created By: Seth W. Frank, E.I.
Revision Number: 166
Last Edited By: Seth Frank
Date: 5/3/2010
Time: 7:20:16 PM
File Name: BAP_A-A_Slope-US_Shallow.gsz
Directory: E:\Final Analysis Files\BAP_A-A GA\Shallow\
Last Solved Date: 5/3/2010
Last Solved Time: 7:37:36 PM

Project Settings

Length(L) Units: feet
Time(t) Units: Seconds
Force(F) Units: lbf
Pressure(p) Units: psf
Strength Units: psf
Unit Weight of Water: 62.4 pcf
View: 2D

Analysis Settings

Newmark Deformation

Kind: SLOPE/W
Parent: Bottom Ash Pond A-A
Method: QUAKE/W Newmark Deformation
Settings
Initial Stress: Parent Analysis
PWP Conditions Source: Parent Analysis
SlipSurface
Direction of movement: Left to Right
Use Passive Mode: No
Slip Surface Option: Entry and Exit
Critical slip surfaces saved: 1
Optimize Critical Slip Surface Location: No
Tension Crack
Tension Crack Option: (none)
FOS Distribution

Newmark Deformation

FOS Calculation Option: Constant

Time

Starting Time: 0 sec

Duration: 10 sec

of Steps: 10240

Advanced

Number of Slices: 30

Optimization Tolerance: 0.01

Minimum Slip Surface Depth: 1 ft

Optimization Maximum Iterations: 2000

Optimization Convergence Tolerance: 1e-007

Starting Optimization Points: 8

Ending Optimization Points: 16

Complete Passes per Insertion: 1

Driving Side Maximum Convex Angle: 5 °

Resisting Side Maximum Convex Angle: 1 °

Materials

Fly Ash (2)

Model: Mohr-Coulomb

Unit Weight: 139 pcf

Unit Wt. Above Water Table: 134 pcf

Cohesion: 0.1 psf

Phi: 33 °

Phi-B: 18 °

Bottom Ash (3)

Model: Mohr-Coulomb

Unit Weight: 80 pcf

Unit Wt. Above Water Table: 80 pcf

Cohesion: 0.1 psf

Phi: 36 °

Phi-B: 20 °

Clayey Sand (4)

Model: Mohr-Coulomb

Unit Weight: 105 pcf

Unit Wt. Above Water Table: 105 pcf

Cohesion: 0.1 psf

Phi: 31 °

Phi-B: 20 °

Bottom Ash (5)

Model: Mohr-Coulomb

Unit Weight: 80 pcf

Unit Wt. Above Water Table: 62 pcf

Newmark Deformation

Cohesion: 0.1 psf

Phi: 38 °

Phi-B: 20 °

Gravelly Sand (6)

Model: Mohr-Coulomb

Unit Weight: 115 pcf

Unit Wt. Above Water Table: 111 pcf

Cohesion: 0.1 psf

Phi: 34 °

Phi-B: 19 °

Clayey Sand (7)

Model: Mohr-Coulomb

Unit Weight: 110 pcf

Unit Wt. Above Water Table: 104 pcf

Cohesion: 0.1 psf

Phi: 34 °

Phi-B: 19 °

Road Material (8)

Model: Mohr-Coulomb

Unit Weight: 145 pcf

Cohesion: 0.1 psf

Phi: 36 °

Phi-B: 20 °

Silty Clay (1)

Model: Mohr-Coulomb

Unit Weight: 123 pcf

Cohesion: 0.1 psf

Phi: 36 °

Phi-B: 20 °

Clayey Sand (9)

Model: Mohr-Coulomb

Unit Weight: 115 pcf

Cohesion: 0.1 psf

Phi: 29 °

Phi-B: 15 °

Sand (10)

Model: Mohr-Coulomb

Unit Weight: 123 pcf

Cohesion: 0.1 psf

Phi: 29 °

Phi-B: 15 °

Sand and Gravel (11)

Newmark Deformation

Model: Mohr-Coulomb

Unit Weight: 123 pcf

Cohesion: 0.1 psf

Phi: 32 °

Phi-B: 18 °

Riprap (12)

Model: Mohr-Coulomb

Unit Weight: 145 pcf

Cohesion: 0.1 psf

Phi: 36 °

Phi-B: 20 °

Slip Surface Entry and Exit

Left Projection: Range

Left-Zone Left Coordinate: (119.5, 593) ft

Left-Zone Right Coordinate: (140, 591.5) ft

Left-Zone Increment: 6

Right Projection: Range

Right-Zone Left Coordinate: (175, 579.5) ft

Right-Zone Right Coordinate: (193, 575) ft

Right-Zone Increment: 6

Radius Increments: 10

Slip Surface Limits

Left Coordinate: (0, 589) ft

Right Coordinate: (335, 545) ft

Regions

	Material	Points	Area (ft ²)
Region 1	Sand (10)	3,4,5,6	8375
Region 2	Sand and Gravel (11)	6,5,2,1	4020
Region 3	Clayey Sand (9)	7,8,4,3	2680
Region 4	Silty Clay (1)	9,36,10,45,11,12,13,14,15,16,17,8,7	5834.125
Region 5	Fly Ash (2)	13,18,15,14	688.5
Region 6	Bottom Ash (5)	12,19,20,18,13	680
Region 7	Clayey Sand (4)	19,21,22,20	301.25
Region 8	Bottom Ash (5)	21,23,24,22	273
Region 9	Bottom Ash (5)	11,12,19,21,23,39,38,37	243.875
Region 10	Clayey Sand (7)	23,25,26,24	81
Region 11	Bottom Ash (3)	26,27,28,29,34,30,35,31,16,15,18,20,22,24	2927.75
Region 12	Riprap (12)	25,40,41,42,43,44,45,11,37,38,39,23	59.875
Region 13	Road Material (8)	32,46,47,33	80.5
Region 14	Gravelly Sand (6)	46,40,25,26,27,47	85.5

Points

	X (ft)	Y (ft)
Point 1	0	500
Point 2	335	500
Point 3	0	537
Point 4	335	537
Point 5	335	512
Point 6	0	512
Point 7	0	545
Point 8	335	545
Point 9	0	589
Point 10	27	586
Point 11	39	583
Point 12	51	575
Point 13	67	566.5
Point 14	83.5	557.5
Point 15	158.5	557.5
Point 16	300	557.5
Point 17	334.5	557.5
Point 18	145	566.5
Point 19	65.5	575
Point 20	133	575
Point 21	73	580
Point 22	126	580
Point 23	86	586.5
Point 24	117	586.5
Point 25	90.5	589.5
Point 26	113.5	589.5
Point 27	153	589.5
Point 28	161	587
Point 29	166	584
Point 30	230	575
Point 31	280	570
Point 32	99	593
Point 33	129.5	593
Point 34	184	575
Point 35	240	570
Point 36	8	586
Point 37	52	583
Point 38	59	583
Point 39	77.5	585
Point 40	89	589.5
Point 41	85	588
Point 42	77	586
Point 43	60	584
Point 44	39	584
Point 45	30	585.25

Newmark Deformation

Point 46	93.5	591
Point 47	143.5	591


Critical Slip Surfaces

	Slip Surface	FOS	Center (ft)	Radius (ft)	Entry (ft)	Exit (ft)
1	466	2.68	(169.939, 621.781)	42.583	(140, 591.5)	(175, 579.5)

Slices of Slip Surface: 466

	Slip Surface	X (ft)	Y (ft)	PWP (psf)	Base Normal Stress (psf)	Frictional Strength (psf)	Cohesive Strength (psf)
1	466	140.25715	591.25	0	-26.485719	-19.243002	0.1
2	466	141.34125	590.25	0	120.38016	81.197441	0.1
3	466	142.8341	588.9502	0	273.97966	199.05788	0.1
4	466	144.09375	587.94685	0	321.02098	233.2354	0.1
5	466	145.28125	587.0715	0	365.44787	265.51342	0.1
6	466	146.46875	586.2574	0	407.784	296.27242	0.1
7	466	147.65625	585.50045	0	448.16593	325.6116	0.1
8	466	148.84375	584.7971	0	485.77458	352.93589	0.1
9	466	150.03125	584.14435	0	513.93785	373.39771	0.1
10	466	151.21875	583.53965	0	533.44769	387.57243	0.1
11	466	152.40625	582.9807	0	543.66052	394.99249	0.1
12	466	153.57145	582.47445	0	544.06196	395.28415	0.1
13	466	154.7143	582.0177	0	534.55437	388.37648	0.1
14	466	155.85715	581.59865	0	514.68736	373.94226	0.1
15	466	157	581.2161	0	483.9991	351.64593	0.1
16	466	158.14285	580.86905	0	487.29797	354.0427	0.1
17	466	159.2857	580.55665	0	526.35413	382.41866	0.1
18	466	160.42855	580.27805	0	560.99891	407.58957	0.1
19	466	161.625	580.02265	0	592.53721	430.50348	0.1
20	466	162.875	579.79305	0	620.45587	450.78757	0.1
21	466	164.125	579.60175	0	642.84129	467.05154	0.1
22	466	165.375	579.4482	0	658.08176	478.12438	0.1
23	466	166.5625	579.33605	0	669.96292	486.75655	0.1
24	466	167.6875	579.2615	0	678.86232	493.22235	0.1
25	466	168.8125	579.21685	0	685.591	498.11102	0.1
26	466	169.9375	579.20195	0	690.20444	501.46288	0.1
27	466	171.0625	579.21675	0	692.75417	503.31537	0.1
28	466	172.1875	579.26135	0	693.29851	503.71085	0.1
29	466	173.3125	579.3358	0	691.87194	502.67439	0.1
30	466	174.4375	579.44025	0	688.51645	500.23648	0.1

Title: Sporn Bottom Ash Disposal Facility
 Comments: FESM - Location B (Crest)
 Railway Induced Vibration Loadings
 Up Stream Deep Failure Surface
 File Name: BAP_A-A_Slope-US_Deep.gsz
 Date: 5/3/2010



Newmark Deformation

Report generated using GeoStudio 2007, version 7.15. Copyright © 1991-2009 GEO-SLOPE International Ltd.

File Information

Title: Sporn Bottom Ash Disposal Facility
Comments: FESM - Location B (Crest) Railway Induced Vibration Loadings Up Stream Deep Failure Surface
Created By: Seth W. Frank, E.I.
Revision Number: 167
Last Edited By: Seth Frank
Date: 5/3/2010
Time: 8:03:02 PM
File Name: BAP_A-A_Slope-US_Deep.gsz
Directory: E:\Final Analysis Files\BAP_A-A GA\Deep\
Last Solved Date: 5/3/2010
Last Solved Time: 8:20:38 PM

Project Settings

Length(L) Units: feet
Time(t) Units: Seconds
Force(F) Units: lbf
Pressure(p) Units: psf
Strength Units: psf
Unit Weight of Water: 62.4 pcf
View: 2D

Analysis Settings

Newmark Deformation

Kind: SLOPE/W
Parent: Bottom Ash Pond A-A
Method: QUAKE/W Newmark Deformation

Settings

Initial Stress: Parent Analysis
PWP Conditions Source: Parent Analysis

SlipSurface

Direction of movement: Left to Right
Use Passive Mode: No
Slip Surface Option: Entry and Exit
Critical slip surfaces saved: 1
Optimize Critical Slip Surface Location: No
Tension Crack
Tension Crack Option: (none)

FOS Distribution

Newmark Deformation

FOS Calculation Option: Constant

.Time

Starting Time: 0 sec

Duration: 10 sec

of Steps: 10240

Advanced

Number of Slices: 30

Optimization Tolerance: 0.01

Minimum Slip Surface Depth: 5 ft

Optimization Maximum Iterations: 2000

Optimization Convergence Tolerance: 1e-007

Starting Optimization Points: 8

Ending Optimization Points: 16

Complete Passes per Insertion: 1

Driving Side Maximum Convex Angle: 5 °

Resisting Side Maximum Convex Angle: 1 °

Materials

Fly Ash (2)

Model: Mohr-Coulomb

Unit Weight: 139 pcf

Unit Wt. Above Water Table: 134 pcf

Cohesion: 0.1 psf

Phi: 33 °

Phi-B: 18 °

Bottom Ash (3)

Model: Mohr-Coulomb

Unit Weight: 80 pcf

Unit Wt. Above Water Table: 80 pcf

Cohesion: 0.1 psf

Phi: 36 °

Phi-B: 20 °

Clayey Sand (4)

Model: Mohr-Coulomb

Unit Weight: 105 pcf

Unit Wt. Above Water Table: 105 pcf

Cohesion: 0.1 psf

Phi: 31 °

Phi-B: 20 °

Bottom Ash (5)

Model: Mohr-Coulomb

Unit Weight: 80 pcf

Unit Wt. Above Water Table: 62 pcf

Newmark Deformation

Cohesion: 0.1 psf

Phi: 38 °

Phi-B: 20 °

Gravelly Sand (6)

Model: Mohr-Coulomb

Unit Weight: 115 pcf

Unit Wt. Above Water Table: 111 pcf

Cohesion: 0.1 psf

Phi: 34 °

Phi-B: 19 °

Clayey Sand (7)

Model: Mohr-Coulomb

Unit Weight: 110 pcf

Unit Wt. Above Water Table: 104 pcf

Cohesion: 0.1 psf

Phi: 34 °

Phi-B: 19 °

Road Material (8)

Model: Mohr-Coulomb

Unit Weight: 145 pcf

Cohesion: 0.1 psf

Phi: 36 °

Phi-B: 20 °

Silty Clay (1)

Model: Mohr-Coulomb

Unit Weight: 123 pcf

Cohesion: 0.1 psf

Phi: 36 °

Phi-B: 20 °

Clayey Sand (9)

Model: Mohr-Coulomb

Unit Weight: 115 pcf

Cohesion: 0.1 psf

Phi: 29 °

Phi-B: 15 °

Sand (10)

Model: Mohr-Coulomb

Unit Weight: 123 pcf

Cohesion: 0.1 psf

Phi: 29 °

Phi-B: 15 °

Sand and Gravel (11)

Newmark Deformation

Model: Mohr-Coulomb

Unit Weight: 123 pcf

Cohesion: 0.1 psf

Phi: 32 °

Phi-B: 18 °

Riprap (12)

Model: Mohr-Coulomb

Unit Weight: 145 pcf

Cohesion: 0.1 psf

Phi: 36 °

Phi-B: 20 °

Slip Surface Entry and Exit

Left Projection: Range

Left-Zone Left Coordinate: (99, 593) ft

Left-Zone Right Coordinate: (129.5, 593) ft

Left-Zone Increment: 6

Right Projection: Range

Right-Zone Left Coordinate: (208.5, 575) ft

Right-Zone Right Coordinate: (245.5, 570) ft

Right-Zone Increment: 6

Radius Increments: 10

Slip Surface Limits

Left Coordinate: (0, 589) ft

Right Coordinate: (335, 545) ft

Regions

	Material	Points	Area (ft ²)
Region 1	Sand (10)	3,4,5,6	8375
Region 2	Sand and Gravel (11)	6,5,2,1	4020
Region 3	Clayey Sand (9)	7,8,4,3	2680
Region 4	Silty Clay (1)	9,36,10,45,11,12,13,14,15,16,17,8,7	5834.125
Region 5	Fly Ash (2)	13,18,15,14	688.5
Region 6	Bottom Ash (5)	12,19,20,18,13	680
Region 7	Clayey Sand (4)	19,21,22,20	301.25
Region 8	Bottom Ash (5)	21,23,24,22	273
Region 9	Bottom Ash (5)	11,12,19,21,23,39,38,37	243.875
Region 10	Clayey Sand (7)	23,25,26,24	81
Region 11	Bottom Ash (3)	26,27,28,29,34,30,35,31,16,15,18,20,22,24	2927.75
Region 12	Riprap (12)	25,40,41,42,43,44,45,11,37,38,39,23	59.875
Region 13	Road Material (8)	32,46,47,33	80.5
Region 14	Gravelly Sand (6)	46,40,25,26,27,47	85.5

Points

	X (ft)	Y (ft)
Point 1	0	500
Point 2	335	500
Point 3	0	537
Point 4	335	537
Point 5	335	512
Point 6	0	512
Point 7	0	545
Point 8	335	545
Point 9	0	589
Point 10	27	586
Point 11	39	583
Point 12	51	575
Point 13	67	566.5
Point 14	83.5	557.5
Point 15	158.5	557.5
Point 16	300	557.5
Point 17	334.5	557.5
Point 18	145	566.5
Point 19	65.5	575
Point 20	133	575
Point 21	73	580
Point 22	126	580
Point 23	86	586.5
Point 24	117	586.5
Point 25	90.5	589.5
Point 26	113.5	589.5
Point 27	153	589.5
Point 28	161	587
Point 29	166	584
Point 30	230	575
Point 31	280	570
Point 32	99	593
Point 33	129.5	593
Point 34	184	575
Point 35	240	570
Point 36	8	586
Point 37	52	583
Point 38	59	583
Point 39	77.5	585
Point 40	89	589.5
Point 41	85	588
Point 42	77	586
Point 43	60	584
Point 44	39	584
Point 45	30	585.25

Newmark Deformation

Point 46	93.5	591
Point 47	143.5	591

Critical Slip Surfaces


	Slip Surface	FOS	Center (ft)	Radius (ft)	Entry (ft)	Exit (ft)
1	468	2.72	(178.486, 625.634)	58.861	(129.5, 593)	(208.5, 575)

Slices of Slip Surface: 468

	Slip Surface	X (ft)	Y (ft)	PWP (psf)	Base Normal Stress (psf)	Frictional Strength (psf)	Cohesive Strength (psf)
1	468	130.1965	592	0	-59.253752	-43.050371	0.1
2	468	131.4573	590.25	0	127.20839	85.803145	0.1
3	468	133.4564	587.79265	0	336.0944	244.18687	0.1
4	468	136.326	584.61075	0	478.14785	347.39475	0.1
5	468	139.1956	581.8487	0	598.95429	435.16576	0.1
6	468	142.0652	579.4302	0	697.38458	506.67955	0.1
7	468	144.6875	577.46595	0	857.8771	623.28419	0.1
8	468	147.0625	575.88265	0	981.42837	713.04945	0.1
9	468	149.4375	574.45855	0	1083.5821	787.26851	0.1
10	468	151.8125	573.1806	0	1171.2392	850.95507	0.1
11	468	154.33335	571.97655	0	1252.7138	910.14987	0.1
12	468	157	570.85345	0	1321.999	960.48849	0.1
13	468	159.66665	569.8804	0	1353.1058	983.0889	0.1
14	468	162.25	569.0715	0	1363.1516	990.38759	0.1
15	468	164.75	568.41265	0	1365.7593	992.28223	0.1
16	468	167.2857	567.8633	0	1361.6935	989.3282	0.1
17	468	169.85715	567.4234	0	1379.7884	1002.475	0.1
18	468	172.4286	567.09975	0	1367.5352	993.57247	0.1
19	468	175	566.8904	0	1340.3971	973.85552	0.1
20	468	177.5714	566.7941	0	1299.0432	943.81011	0.1
21	468	180.14285	566.81035	0	1242.4741	902.71027	0.1
22	468	182.7143	566.9392	0	1209.3056	878.61198	0.1
23	468	185.3611	567.1919	0	1197.4862	870.02463	0.1
24	468	188.0833	567.577	0	1182.2059	858.92287	0.1
25	468	190.80555	568.0934	0	1164.2246	845.85868	0.1
26	468	193.5278	568.7447	0	1141.1109	829.06556	0.1
27	468	196.25	569.5356	0	1112.2987	808.13232	0.1
28	468	198.9722	570.47205	0	1078.1415	783.31565	0.1
29	468	201.69445	571.5617	0	1038.2906	754.36231	0.1
30	468	204.4167	572.8141	0	996.51714	724.01208	0.1
31	468	207.1389	574.24115	0	949.04593	689.52223	0.1

**FLY ASH DISPOSAL FACILITY
SECTION H-H
FESM SLOPE STABILITY ANALYSIS RESULTS**

Title: Sporn Fly Ash Disposal Facility
 Comments: FESM - Location C (Exterior Toe)
 Railway Induced Vibration Loadings
 Down Stream Shallow Failure Surface
 File Name: FAP_H-H_Slope-DS_Toe Accel.gsz
 Date: 5/3/2010



Newmark Deformation

Report generated using GeoStudio 2007, version 7.15. Copyright © 1991-2009 GEO-SLOPE International Ltd.

File Information

Title: Sporn Fly Ash Disposal Facility
Comments: FESM - Location C (Exterior Toe) Railway Induced Vibration Loadings Down Stream Shallow Failure Surface
Created By: Seth W. Frank, E.I.
Revision Number: 169
Last Edited By: Seth Frank
Date: 5/3/2010
Time: 8:41:34 PM
File Name: FAP_H-H_Slope-DS_Toe Accel.gsz
Directory: E:\Final Analysis Files\FAP_H-H GA\Shallow\
Last Solved Date: 5/3/2010
Last Solved Time: 9:04:20 PM

Project Settings

Length(L) Units: feet
Time(t) Units: Seconds
Force(F) Units: lbf
Pressure(p) Units: psf
Strength Units: psf
Unit Weight of Water: 62.4 pcf
View: 2D

Analysis Settings

Newmark Deformation

Kind: SLOPE/W
Parent: Dynamic QUAKE/W
Method: QUAKE/W Newmark Deformation
Settings
Initial Stress: Parent Analysis
PWP Conditions Source: Parent Analysis
SlipSurface
Direction of movement: Right to Left
Use Passive Mode: No
Slip Surface Option: Entry and Exit
Critical slip surfaces saved: 1
Optimize Critical Slip Surface Location: Yes
Tension Crack
Tension Crack Option: (none)
FOS Distribution

Newmark Deformation

FOS Calculation Option: Constant

Time

Starting Time: 0 sec

Duration: 10 sec

of Steps: 10240

Advanced

Number of Slices: 30

Optimization Tolerance: 0.01

Minimum Slip Surface Depth: 5 ft

Optimization Maximum Iterations: 2000

Optimization Convergence Tolerance: 1e-007

Starting Optimization Points: 8

Ending Optimization Points: 16

Complete Passes per Insertion: 1

Driving Side Maximum Convex Angle: 5 °

Resisting Side Maximum Convex Angle: 1 °

Materials

Silty Sand (1)

Model: Mohr-Coulomb

Unit Weight: 130 pcf

Unit Wt. Above Water Table: 125 pcf

Cohesion: 0.1 psf

Phi: 34 °

Phi-B: 18 °

Silty Sand (2)

Model: Mohr-Coulomb

Unit Weight: 112 pcf

Unit Wt. Above Water Table: 107 pcf

Cohesion: 0.1 psf

Phi: 35 °

Phi-B: 18 °

Gravelly Sand (3)

Model: Mohr-Coulomb

Unit Weight: 110 pcf

Unit Wt. Above Water Table: 105 pcf

Cohesion: 0.1 psf

Phi: 33 °

Phi-B: 17 °

Silty Clay (4)

Model: Mohr-Coulomb

Unit Weight: 120 pcf

Unit Wt. Above Water Table: 115 pcf

Newmark Deformation

Cohesion: 0.1 psf

Phi: 32 °

Phi-B: 17 °

Silty Sand (5)

Model: Mohr-Coulomb

Unit Weight: 131 pcf

Unit Wt. Above Water Table: 126 pcf

Cohesion: 0.1 psf

Phi: 31 °

Phi-B: 16 °

Sandy Silt (6)

Model: Mohr-Coulomb

Unit Weight: 130 pcf

Unit Wt. Above Water Table: 125 pcf

Cohesion: 0.1 psf

Phi: 27 °

Phi-B: 14 °

Fly Ash (7)

Model: Mohr-Coulomb

Unit Weight: 90 pcf

Unit Wt. Above Water Table: 102 pcf

Cohesion: 0.1 psf

Phi: 27 °

Phi-B: 15 °

Rock Fill (9)

Model: Mohr-Coulomb

Unit Weight: 115 pcf

Cohesion: 0 psf

Phi: 38 °

Phi-B: 0 °

Slip Surface Entry and Exit

Left Projection: Range

Left-Zone Left Coordinate: (47.90981, 590.5) ft

Left-Zone Right Coordinate: (75, 591.30719) ft

Left-Zone Increment: 5

Right Projection: Range

Right-Zone Left Coordinate: (128.0816, 611) ft

Right-Zone Right Coordinate: (143, 611) ft

Right-Zone Increment: 5

Radius Increments: 10

Slip Surface Limits

Left Coordinate: (0, 593) ft

Right Coordinate: (310, 588) ft

Regions

	Material	Points	Area (ft ²)
Region 1	Sandy Silt (6)	1,3,4,5,6,2	5355
Region 2	Silty Sand (5)	7,8,4,3	2085
Region 3	Silty Sand (1)	7,9,36,35,34,33,32,42,10,12,13,14,29,8	973.49995
Region 4	Silty Sand (2)	11,37,38,39,16,12,10	420
Region 5	Silty Clay (4)	16,17,18,19,20,13,12	134
Region 6	Gravelly Sand (3)	41,17,16,39	148
Region 7	Silty Sand (2)	19,20,23,24,22	51.5
Region 8	Silty Sand (1)	40,26,21,18,17,41	19
Region 9	Silty Sand (2)	13,20,23,24,14	324
Region 10	Gravelly Sand (3)	21,27,28,22,19,18	121
Region 11	Fly Ash (7)	30,31,6,5,4,8,29	2399
Region 12	Rock Fill (9)	11,10,42,15,25,40,41,39,38,37	120.4339

Points

	X (ft)	Y (ft)
Point 1	0	555
Point 2	310	555
Point 3	0	576
Point 4	218	576
Point 5	248	561
Point 6	310	561
Point 7	0	586
Point 8	199	586
Point 9	0	590
Point 10	76	591
Point 11	82	592
Point 12	137	591
Point 13	139	591
Point 14	189	591
Point 15	106	602
Point 16	137	602
Point 17	137	610
Point 18	145	610
Point 19	145	602
Point 20	145	597
Point 21	149	610
Point 22	167	602
Point 23	148	600
Point 24	170	600

Newmark Deformation

Point 25	128	611
Point 26	147	611
Point 27	154	608
Point 28	159	608
Point 29	193	589
Point 30	201	588
Point 31	310	588
Point 32	49.5	590.5
Point 33	46.5	590.5
Point 34	31	590
Point 35	15.5	592
Point 36	0	593
Point 37	91	592
Point 38	107	600
Point 39	109	602
Point 40	130	611
Point 41	128	610
Point 42	74	590.96226

Critical Slip Surfaces

	Slip Surface	FOS	Center (ft)	Radius (ft)	Entry (ft)	Exit (ft)
1	355	2.66	(75.638, 687.771)	96.466	(134.049, 611)	(75, 591.307)


Slices of Slip Surface: 355

	Slip Surface	X (ft)	Y (ft)	PWP (psf)	Base Normal Stress (psf)	Frictional Strength (psf)	Cohesive Strength (psf)
1	355	75.751195	591.3081	0	284.64646	222.39019	0
2	355	77.253585	591.32155	0	322.85372	252.24097	0
3	355	79.003585	591.369	0	347.63371	243.41575	0.1
4	355	81.001195	591.4595	0	388.79775	272.23912	0.1
5	355	82.86595	591.5802	0	418.97026	293.36613	0.1
6	355	84.59785	591.72605	0	416.63337	291.72983	0.1
7	355	86.32975	591.9034	0	391.51011	274.13833	0.1
8	355	88.10062	592.1179	0	381.81666	298.30787	0
9	355	89.910465	592.3712	0	390.71273	305.25824	0
10	355	91.72031	592.6596	0	419.10351	327.43955	0
11	355	93.58057	592.99345	0	474.21604	332.04965	0.1
12	355	95.491255	593.37525	0	549.60758	384.83937	0.1
13	355	97.40194	593.79745	0	618.73647	433.24394	0.1
14	355	99.31264	594.2606	0	657.84934	460.63107	0.1
15	355	101.2233	594.7653	0	683.61809	478.67454	0.1
16	355	103.13395	595.3122	0	704.68144	493.42326	0.1
17	355	105.04465	595.9021	0	721.3706	505.10913	0.1
18	355	106.5	596.37675	0	731.61234	512.28048	0.1
19	355	108	596.90175	0	706.38873	494.61871	0.1
20	355	110.0785	597.67015	0	655.8395	459.22377	0.1
21	355	112.23555	598.5247	0	613.37536	429.49005	0.1

Newmark Deformation

22	355	114.3926	599.4402	0	588.48952	412.06479	0.1
23	355	116.54965	600.4185	0	572.14853	400.62271	0.1
24	355	118.7067	601.4618	0	553.6596	387.67663	0.1
25	355	120.81205	602.5443	0	506.71926	329.06733	0.1
26	355	122.86575	603.6652	0	461.2928	299.56705	0.1
27	355	124.91945	604.8521	0	426.48823	276.96469	0.1
28	355	126.97315	606.1079	0	399.09242	259.17364	0.1
29	355	129	607.4175	0	353.58683	229.62197	0.1
30	355	131.3554	609.0408	0	273.07778	177.33878	0.1
31	355	133.3799	610.5	0	185.32641	125.00424	0.1

Title: Sporn Fly Ash Disposal Facility
 Comments: FEM - Location C (Exterior Toe)
 Railway Induced Vibration Loadings
 Down Stream Deep Failure Surface
 File Name: FAP_H-H_Slope-DS_Toe Accel.gsz
 Date: 5/3/2010



Newmark Deformation

Report generated using GeoStudio 2007, version 7.15. Copyright © 1991-2009 GEO-SLOPE International Ltd.

File Information

Title: Sporn Fly Ash Disposal Facility
Comments: FESM - Location C (Exterior Toe) Railway Induced Vibration Loadings Down Stream Deep Failure Surface
Created By: Seth W. Frank, E.I.
Revision Number: 167
Last Edited By: Seth Frank
Date: 5/3/2010
Time: 11:30:08 AM
File Name: FAP_H-H_Slope-DS_Toe Accel.gsz
Directory: E:\Final Analysis Files\FAP_H-H GA\Deep\
Last Solved Date: 5/3/2010
Last Solved Time: 11:45:02 AM

Project Settings

Length(L) Units: feet
Time(t) Units: Seconds
Force(F) Units: lbf
Pressure(p) Units: psf
Strength Units: psf
Unit Weight of Water: 62.4 pcf
View: 2D

Analysis Settings

Newmark Deformation

Kind: SLOPE/W
Parent: Dynamic QUAKE/W
Method: QUAKE/W Newmark Deformation
Settings
Initial Stress: Parent Analysis
PWP Conditions Source: Parent Analysis
SlipSurface
Direction of movement: Right to Left
Use Passive Mode: No
Slip Surface Option: Entry and Exit
Critical slip surfaces saved: 1
Optimize Critical Slip Surface Location: Yes
Tension Crack
Tension Crack Option: (none)
FOS Distribution

Newmark Deformation

FOS Calculation Option: Constant

Time

Starting Time: 0 sec

Duration: 10 sec

of Steps: 10240

Advanced

Number of Slices: 30

Optimization Tolerance: 0.01

Minimum Slip Surface Depth: 10 ft

Optimization Maximum Iterations: 2000

Optimization Convergence Tolerance: 1e-007

Starting Optimization Points: 8

Ending Optimization Points: 16

Complete Passes per Insertion: 1

Driving Side Maximum Convex Angle: 5 °

Resisting Side Maximum Convex Angle: 1 °

Materials

Silty Sand (1)

Model: Mohr-Coulomb

Unit Weight: 130 pcf

Unit Wt. Above Water Table: 125 pcf

Cohesion: 0.1 psf

Phi: 34 °

Phi-B: 18 °

Silty Sand (2)

Model: Mohr-Coulomb

Unit Weight: 112 pcf

Unit Wt. Above Water Table: 107 pcf

Cohesion: 0.1 psf

Phi: 35 °

Phi-B: 18 °

Gravelly Sand (3)

Model: Mohr-Coulomb

Unit Weight: 110 pcf

Unit Wt. Above Water Table: 105 pcf

Cohesion: 0.1 psf

Phi: 33 °

Phi-B: 17 °

Silty Clay (4)

Model: Mohr-Coulomb

Unit Weight: 120 pcf

Unit Wt. Above Water Table: 115 pcf

Newmark Deformation

Cohesion: 0.1 psf

Phi: 32 °

Phi-B: 17 °

Silty Sand (5)

Model: Mohr-Coulomb

Unit Weight: 131 pcf

Unit Wt. Above Water Table: 126 pcf

Cohesion: 0.1 psf

Phi: 31 °

Phi-B: 16 °

Sandy Silt (6)

Model: Mohr-Coulomb

Unit Weight: 130 pcf

Unit Wt. Above Water Table: 125 pcf

Cohesion: 0.1 psf

Phi: 27 °

Phi-B: 14 °

Fly Ash (7)

Model: Mohr-Coulomb

Unit Weight: 90 pcf

Unit Wt. Above Water Table: 102 pcf

Cohesion: 0.1 psf

Phi: 27 °

Phi-B: 15 °

Rock Fill (9)

Model: Mohr-Coulomb

Unit Weight: 115 pcf

Cohesion: 0 psf

Phi: 38 °

Phi-B: 0 °

Slip Surface Entry and Exit

Left Projection: Range

Left-Zone Left Coordinate: (31, 590) ft

Left-Zone Right Coordinate: (64, 590.77358) ft

Left-Zone Increment: 5

Right Projection: Range

Right-Zone Left Coordinate: (134, 611) ft

Right-Zone Right Coordinate: (147, 611) ft

Right-Zone Increment: 5

Radius Increments: 10

Slip Surface Limits

Left Coordinate: (0, 593) ft

Right Coordinate: (310, 588) ft

Regions

	Material	Points	Area (ft ²)
Region 1	Sandy Silt (6)	1,3,4,5,6,2	5355
Region 2	Silty Sand (5)	7,8,4,3	2085
Region 3	Silty Sand (1)	7,9,36,35,34,33,32,42,10,12,13,14,29,8	973.49995
Region 4	Silty Sand (2)	11,37,38,39,16,12,10	420
Region 5	Silty Clay (4)	16,17,18,19,20,13,12	134
Region 6	Gravelly Sand (3)	41,17,16,39	148
Region 7	Silty Sand (2)	19,20,23,24,22	51.5
Region 8	Silty Sand (1)	40,26,21,18,17,41	19
Region 9	Silty Sand (2)	13,20,23,24,14	324
Region 10	Gravelly Sand (3)	21,27,28,22,19,18	121
Region 11	Fly Ash (7)	30,31,6,5,4,8,29	2399
Region 12	Rock Fill (9)	11,10,42,15,25,40,41,39,38,37	120.4339

Points

	X (ft)	Y (ft)
Point 1	0	555
Point 2	310	555
Point 3	0	576
Point 4	218	576
Point 5	248	561
Point 6	310	561
Point 7	0	586
Point 8	199	586
Point 9	0	590
Point 10	76	591
Point 11	82	592
Point 12	137	591
Point 13	139	591
Point 14	189	591
Point 15	106	602
Point 16	137	602
Point 17	137	610
Point 18	145	610
Point 19	145	602
Point 20	145	597
Point 21	149	610
Point 22	167	602
Point 23	148	600
Point 24	170	600

Newmark Deformation

Point 25	128	611
Point 26	147	611
Point 27	154	608
Point 28	159	608
Point 29	193	589
Point 30	201	588
Point 31	310	588
Point 32	49.5	590.5
Point 33	46.5	590.5
Point 34	31	590
Point 35	15.5	592
Point 36	0	593
Point 37	91	592
Point 38	107	600
Point 39	109	602
Point 40	130	611
Point 41	128	610
Point 42	74	590.96226

Critical Slip Surfaces

	Slip Surface	FOS	Center (ft)	Radius (ft)	Entry (ft)	Exit (ft)
1	195	2.75	(89.238, 632.496)	61.632	(147, 611)	(44.1974, 590.426)


Slices of Slip Surface: 195

	Slip Surface	X (ft)	Y (ft)	PWP (psf)	Base Normal Stress (psf)	Frictional Strength (psf)	Cohesive Strength (psf)
1	195	45.348695	589.2571	0	474.46624	320.03152	0.1
2	195	47.641025	587.04425	0	669.70015	451.71845	0.1
3	195	49.141025	585.69245	0	793.82407	476.97762	0.1
4	195	51.3882	583.91385	0	1032.4603	620.36472	0.1
5	195	55.1646	581.18885	0	1411.7303	848.25317	0.1
6	195	58.941005	578.86815	0	1721.5239	1034.3959	0.1
7	195	62.71741	576.9007	0	1991.1263	1196.3894	0.1
8	195	66.17134	575.3678	0	2222.2999	1132.3183	0.1
9	195	69.302805	574.2002	0	2413.5994	1229.7903	0.1
10	195	72.43427	573.22095	0	2609.3296	1329.5198	0.1
11	195	75	572.5396	0	2753.4299	1402.9426	0.1
12	195	77.5	572.011	0	2874.0821	1464.418	0.1
13	195	80.5	571.50505	0	3008.9453	1533.1342	0.1
14	195	83.5	571.1499	0	3138.5347	1599.1633	0.1
15	195	86.5	570.94285	0	3244.7254	1653.2702	0.1
16	195	89.5	570.8825	0	3327.9367	1695.6685	0.1
17	195	92.875	570.9998	0	3411.3721	1738.1809	0.1
18	195	96.625	571.33715	0	3470.244	1768.1776	0.1
19	195	100.375	571.9083	0	3491.1086	1778.8087	0.1
20	195	104.125	572.71995	0	3472.5924	1769.3742	0.1
21	195	106.5	573.3328	0	3443.903	1754.7562	0.1

Newmark Deformation

22	195	108	573.7983	0	3413.7009	1739.3675	0.1
23	195	111.435	575.05895	0	3300.7106	1681.796	0.1
24	195	115.63625	576.8377	0	3123.2615	1876.6449	0.1
25	195	119.16875	578.65735	0	2935.4014	1763.7671	0.1
26	195	122.70125	580.7822	0	2680.1674	1610.407	0.1
27	195	126.23375	583.25205	0	2385.5102	1433.3591	0.1
28	195	128.84675	585.2895	0	2143.6187	1288.0161	0.1
29	195	129.84675	586.1342	0	2030.7327	1369.7465	0.1
30	195	132.4039	588.6342	0	1588.5956	1071.5212	0.1
31	195	135.9039	592.2716	0	1133.122	793.42059	0.1
32	195	139	596.2922	0	869.89263	543.56924	0.1
33	195	143	602.643	0	500.92104	313.0102	0.1
34	195	145.80895	608.1224	0	260.43552	169.1288	0.1
35	195	146.80895	610.5	0	164.66091	111.06519	0.1

Title: Sporn Fly Ash Disposal Facility
 Comments: FESM - Location D (Crest)
 Railway Induced Vibration Loadings
 Up Stream Shallow Failure Surface
 File Name: FAP_H-H_Slope-US_Crest Accel.gsz
 Date: 5/3/2010



Newmark Deformation

Report generated using GeoStudio 2007, version 7.15. Copyright © 1991-2009 GEO-SLOPE International Ltd.

File Information

Title: Sporn Fly Ash Disposal Facility
Comments: FESM - Location D (Crest) Railway Induced Vibration Loadings Up Stream Shallow Failure Surface
Created By: Seth W. Frank, E.I.
Revision Number: 169
Last Edited By: Seth Frank
Date: 5/3/2010
Time: 10:39:44 AM
File Name: FAP_H-H_Slope-US_Crest Accel.gs7
Directory: E:\Final Analysis Files\FAP_H-H GA\Shallow\
Last Solved Date: 5/3/2010
Last Solved Time: 10:59:48 AM

Project Settings

Length(L) Units: feet
Time(t) Units: Seconds
Force(F) Units: lbf
Pressure(p) Units: psf
Strength Units: psf
Unit Weight of Water: 62.4 pcf
View: 2D

Analysis Settings

Newmark Deformation

Kind: SLOPE/W
Parent: Dynamic QUAKE/W
Method: QUAKE/W Newmark Deformation
Settings
Initial Stress: Parent Analysis
PWP Conditions Source: Parent Analysis
SlipSurface
Direction of movement: Left to Right
Use Passive Mode: No
Slip Surface Option: Entry and Exit
Critical slip surfaces saved: 1
Optimize Critical Slip Surface Location: Yes
Tension Crack
Tension Crack Option: (none)
FOS Distribution

Newmark Deformation

FOS Calculation Option: Constant

Time

Starting Time: 0 sec

Duration: 5.499 sec

of Steps: 5631

Advanced

Number of Slices: 30

Optimization Tolerance: 0.01

Minimum Slip Surface Depth: 5 ft

Optimization Maximum Iterations: 2000

Optimization Convergence Tolerance: 1e-007

Starting Optimization Points: 8

Ending Optimization Points: 16

Complete Passes per Insertion: 1

Driving Side Maximum Convex Angle: 5 °

Resisting Side Maximum Convex Angle: 1 °

Materials

Silty Sand (1)

Model: Mohr-Coulomb

Unit Weight: 130 pcf

Unit Wt. Above Water Table: 125 pcf

Cohesion: 0.1 psf

Phi: 34 °

Phi-B: 18 °

Silty Sand (2)

Model: Mohr-Coulomb

Unit Weight: 112 pcf

Unit Wt. Above Water Table: 107 pcf

Cohesion: 0.1 psf

Phi: 35 °

Phi-B: 18 °

Gravelly Sand (3)

Model: Mohr-Coulomb

Unit Weight: 110 pcf

Unit Wt. Above Water Table: 105 pcf

Cohesion: 0.1 psf

Phi: 33 °

Phi-B: 17 °

Silty Clay (4)

Model: Mohr-Coulomb

Unit Weight: 120 pcf

Unit Wt. Above Water Table: 115 pcf

Newmark Deformation

Cohesion: 0.1 psf

Phi: 32 °

Phi-B: 17 °

Silty Sand (5)

Model: Mohr-Coulomb

Unit Weight: 131 pcf

Unit Wt. Above Water Table: 126 pcf

Cohesion: 0.1 psf

Phi: 31 °

Phi-B: 16 °

Sandy Silt (6)

Model: Mohr-Coulomb

Unit Weight: 130 pcf

Unit Wt. Above Water Table: 125 pcf

Cohesion: 0.1 psf

Phi: 27 °

Phi-B: 14 °

Fly Ash (7)

Model: Mohr-Coulomb

Unit Weight: 90 pcf

Unit Wt. Above Water Table: 102 pcf

Cohesion: 0.1 psf

Phi: 27 °

Phi-B: 15 °

Rock Fill (9)

Model: Mohr-Coulomb

Unit Weight: 115 pcf

Cohesion: 0 psf

Phi: 38 °

Phi-B: 0 °

Slip Surface Entry and Exit

Left Projection: Range

Left-Zone Left Coordinate: (141.5, 611) ft

Left-Zone Right Coordinate: (159, 608) ft

Left-Zone Increment: 5

Right Projection: Range

Right-Zone Left Coordinate: (193.1477, 588.98154) ft

Right-Zone Right Coordinate: (232, 588) ft

Right-Zone Increment: 6

Radius Increments: 10

Slip Surface Limits

Left Coordinate: (0, 593) ft

Right Coordinate: (310, 588) ft

Regions

	Material	Points	Area (ft ²)
Region 1	Sandy Silt (6)	1,3,4,5,6,2	5355
Region 2	Silty Sand (5)	7,8,4,3	2085
Region 3	Silty Sand (1)	7,9,36,35,34,33,32,42,10,12,13,14,29,8	973.49995
Region 4	Silty Sand (2)	11,37,38,39,16,12,10	420
Region 5	Silty Clay (4)	16,17,18,19,20,13,12	134
Region 6	Gravelly Sand (3)	41,17,16,39	148
Region 7	Silty Sand (2)	19,20,23,24,22	51.5
Region 8	Silty Sand (1)	40,26,21,18,17,41	19
Region 9	Silty Sand (2)	13,20,23,24,14	324
Region 10	Gravelly Sand (3)	21,27,28,22,19,18	121
Region 11	Fly Ash (7)	30,31,6,5,4,8,29	2399
Region 12	Rock Fill (9)	11,10,42,15,25,40,41,39,38,37	120.4339

Points

	X (ft)	Y (ft)
Point 1	0	555
Point 2	310	555
Point 3	0	576
Point 4	218	576
Point 5	248	561
Point 6	310	561
Point 7	0	586
Point 8	199	586
Point 9	0	590
Point 10	76	591
Point 11	82	592
Point 12	137	591
Point 13	139	591
Point 14	189	591
Point 15	106	602
Point 16	137	602
Point 17	137	610
Point 18	145	610
Point 19	145	602
Point 20	145	597
Point 21	149	610
Point 22	167	602
Point 23	148	600
Point 24	170	600

Newmark Deformation

Point 25	128	611
Point 26	147	611
Point 27	154	608
Point 28	159	608
Point 29	193	589
Point 30	201	588
Point 31	310	588
Point 32	49.5	590.5
Point 33	46.5	590.5
Point 34	31	590
Point 35	15.5	592
Point 36	0	593
Point 37	91	592
Point 38	107	600
Point 39	109	602
Point 40	130	611
Point 41	128	610
Point 42	74	590.96226

Critical Slip Surfaces

	Slip Surface	FOS	Center (ft)	Radius (ft)	Entry (ft)	Exit (ft)
1	159	1.78	(189.993, 639.776)	50.892	(148.564, 610.218)	(193.148, 588.981)


Slices of Slip Surface: 159

	Slip Surface	X (ft)	Y (ft)	PWP (psf)	Base Normal Stress (psf)	Frictional Strength (psf)	Cohesive Strength (psf)
1	159	148.6421	610.10905	0	162.50377	109.61018	0.1
2	159	148.86015	609.80805	0	173.56961	112.71742	0.1
3	159	149.83335	608.54455	0	202.07218	131.22721	0.1
4	159	151.5	606.50875	0	246.07613	159.80371	0.1
5	159	153.16665	604.67035	0	281.88175	183.05615	0.1
6	159	154.94495	602.8981	0	310.09631	201.3789	0.1
7	159	156.47875	601.4846	0	443.07922	310.24741	0.1
8	159	157.65645	600.4846	0	675.69428	473.12623	0.1
9	159	158.62265	599.7046	0	805.26342	563.85151	0.1
10	159	159.8	598.81945	0	869.51491	608.84089	0.1
11	159	161.4	597.68625	0	952.55328	666.98499	0.1
12	159	163	596.64215	0	1020.6785	714.68676	0.1
13	159	164.6	595.6808	0	1074.7243	752.53005	0.1
14	159	166.2	594.7969	0	1115.6518	781.18778	0.1
15	159	167.75	594.0092	0	1143.5643	800.73237	0.1
16	159	169.25	593.3099	0	1160.3026	812.4526	0.1
17	159	170.68365	592.69475	0	1177.4832	824.48262	0.1
18	159	172.05095	592.1568	0	1190.1136	833.32653	0.1
19	159	173.41825	591.6637	0	1199.3232	839.77512	0.1
20	159	174.78555	591.2141	0	1205.2935	843.95563	0.1
21	159	176.2709	590.78865	0	1228.9742	828.95354	0.1

Newmark Deformation

22	159	177.7243	590.3906	0	1266.0058	853.93171	0.1
23	159	179.2277	590.04115	0	1296.4809	874.48738	0.1
24	159	180.73115	589.7393	0	1338.8804	903.08626	0.1
25	159	182.2346	589.4842	0	1369.3704	923.65202	0.1
26	159	183.738	589.2751	0	1389.4518	937.19708	0.1
27	159	185.2414	589.1115	0	1400.4422	944.61022	0.1
28	159	186.74485	588.99295	0	1403.8518	946.91003	0.1
29	159	188.2483	588.9191	0	1401.0401	945.01346	0.1
30	159	189.66665	588.88905	0	1392.8711	939.50342	0.1
31	159	191	588.898	0	1380.1791	930.94258	0.1
32	159	192.33335	588.9419	0	1364.0048	920.03288	0.1
33	159	193.0245	588.97405	0	1355.4562	914.26676	0.1
34	159	193.09835	588.9785	0	1355.3505	690.58557	0.1

Title: Sporn Fly Ash Disposal Facility
 Comments: FESM - Location D (Crest)
 Railway Induced Vibration Loadings
 Up Stream Deep Failure Surface
 File Name: FAP_H-H_Slope-US_Crest Accel.gsz
 Date: 5/3/2010



Newmark Deformation

Report generated using GeoStudio 2007, version 7.15. Copyright © 1991-2009 GEO-SLOPE International Ltd.

File Information

Title: Sporn Fly Ash Disposal Facility
Comments: FESM - Location D (Crest) Railway Induced Vibration Loadings Up Stream Deep Failure Surface
Created By: Seth W. Frank, E.I.
Revision Number: 173
Last Edited By: Seth Frank
Date: 5/3/2010
Time: 4:48:26 PM
File Name: FAP_H-H_Slope-US_Crest Accel.gsz
Directory: E:\Final Analysis Files\FAP_H-H GA\Deep\
Last Solved Date: 5/3/2010
Last Solved Time: 4:59:50 PM

Project Settings

Length(L) Units: feet
Time(t) Units: Seconds
Force(F) Units: lbf
Pressure(p) Units: psf
Strength Units: psf
Unit Weight of Water: 62.4 pcf
View: 2D

Analysis Settings

Newmark Deformation

Kind: SLOPE/W
Parent: Dynamic QUAKE/W
Method: QUAKE/W Newmark Deformation

Settings

Initial Stress: Parent Analysis
PWP Conditions Source: Parent Analysis

SlipSurface

Direction of movement: Left to Right
Use Passive Mode: No
Slip Surface Option: Entry and Exit
Critical slip surfaces saved: 1
Optimize Critical Slip Surface Location: Yes
Tension Crack
Tension Crack Option: (none)

FOS Distribution

FOS Calculation Option: Constant

Time

Starting Time: 0 sec

Duration: 5.499 sec

of Steps: 5631

Advanced

Number of Slices: 30

Optimization Tolerance: 0.01

Minimum Slip Surface Depth: 10 ft

Optimization Maximum Iterations: 2000

Optimization Convergence Tolerance: 1e-007

Starting Optimization Points: 8

Ending Optimization Points: 16

Complete Passes per Insertion: 1

Driving Side Maximum Convex Angle: 5 °

Resisting Side Maximum Convex Angle: 1 °

Materials

Silty Sand (1)

Model: Mohr-Coulomb

Unit Weight: 130 pcf

Unit Wt. Above Water Table: 125 pcf

Cohesion: 0.1 psf

Phi: 34 °

Phi-B: 18 °

Silty Sand (2)

Model: Mohr-Coulomb

Unit Weight: 112 pcf

Unit Wt. Above Water Table: 107 pcf

Cohesion: 0.1 psf

Phi: 35 °

Phi-B: 18 °

Gravelly Sand (3)

Model: Mohr-Coulomb

Unit Weight: 110 pcf

Unit Wt. Above Water Table: 105 pcf

Cohesion: 0.1 psf

Phi: 33 °

Phi-B: 17 °

Silty Clay (4)

Model: Mohr-Coulomb

Unit Weight: 120 pcf

Unit Wt. Above Water Table: 115 pcf

Newmark Deformation

Cohesion: 0.1 psf

Phi: 32 °

Phi-B: 17 °

Silty Sand (5)

Model: Mohr-Coulomb

Unit Weight: 131 pcf

Unit Wt. Above Water Table: 126 pcf

Cohesion: 0.1 psf

Phi: 31 °

Phi-B: 16 °

Sandy Silt (6)

Model: Mohr-Coulomb

Unit Weight: 130 pcf

Unit Wt. Above Water Table: 125 pcf

Cohesion: 0.1 psf

Phi: 27 °

Phi-B: 14 °

Fly Ash (7)

Model: Mohr-Coulomb

Unit Weight: 90 pcf

Unit Wt. Above Water Table: 102 pcf

Cohesion: 0.1 psf

Phi: 27 °

Phi-B: 15 °

Rock Fill (9)

Model: Mohr-Coulomb

Unit Weight: 115 pcf

Cohesion: 0 psf

Phi: 38 °

Phi-B: 0 °

Slip Surface Entry and Exit

Left Projection: Range

Left-Zone Left Coordinate: (128, 611) ft

Left-Zone Right Coordinate: (146, 611) ft

Left-Zone Increment: 5

Right Projection: Range

Right-Zone Left Coordinate: (209, 588) ft

Right-Zone Right Coordinate: (242, 588) ft

Right-Zone Increment: 6

Radius Increments: 10

Slip Surface Limits

Left Coordinate: (0, 593) ft

Right Coordinate: (310, 588) ft

Regions

Region	Material	Points	Area (ft ²)
Region 1	Sandy Silt (6)	1,3,4,5,6,2	5355
Region 2	Silty Sand (5)	7,8,4,3	2085
Region 3	Silty Sand (1)	7,9,36,35,34,33,32,42,10,12,13,14,29,8	973.49995
Region 4	Silty Sand (2)	11,37,38,39,16,12,10	420
Region 5	Silty Clay (4)	16,17,18,19,20,13,12	134
Region 6	Gravelly Sand (3)	41,17,16,39	148
Region 7	Silty Sand (2)	19,20,23,24,22	51.5
Region 8	Silty Sand (1)	40,26,21,18,17,41	19
Region 9	Silty Sand (2)	13,20,23,24,14	324
Region 10	Gravelly Sand (3)	21,27,28,22,19,18	121
Region 11	Fly Ash (7)	30,31,6,5,4,8,29	2399
Region 12	Rock Fill (9)	11,10,42,15,25,40,41,39,38,37	120.4339

Points

	X (ft)	Y (ft)
Point 1	0	555
Point 2	310	555
Point 3	0	576
Point 4	218	576
Point 5	248	561
Point 6	310	561
Point 7	0	586
Point 8	199	586
Point 9	0	590
Point 10	76	591
Point 11	82	592
Point 12	137	591
Point 13	139	591
Point 14	189	591
Point 15	106	602
Point 16	137	602
Point 17	137	610
Point 18	145	610
Point 19	145	602
Point 20	145	597
Point 21	149	610
Point 22	167	602
Point 23	148	600
Point 24	170	600

Newmark Deformation

Point 25	128	611
Point 26	147	611
Point 27	154	608
Point 28	159	608
Point 29	193	589
Point 30	201	588
Point 31	310	588
Point 32	49.5	590.5
Point 33	46.5	590.5
Point 34	31	590
Point 35	15.5	592
Point 36	0	593
Point 37	91	592
Point 38	107	600
Point 39	109	602
Point 40	130	611
Point 41	128	610
Point 42	74	590.96226

Critical Slip Surfaces

	Slip Surface	FOS	Center (ft)	Radius (ft)	Entry (ft)	Exit (ft)
1	391	2.12	(191.93, 639.025)	53.805	(146, 611)	(209, 588)

Slices of Slip Surface: 391

	Slip Surface	X (ft)	Y (ft)	PWP (psf)	Base Normal Stress (psf)	Frictional Strength (psf)	Cohesive Strength (psf)
1	391	146.31265	610.5	0	160.59657	108.32375	0.1
2	391	146.81265	609.71165	0	173.88004	112.91902	0.1
3	391	148	608.00705	0	256.31804	166.45488	0.1
4	391	149.97255	605.37805	0	316.66484	205.64455	0.1
5	391	151.91765	603.08265	0	365.45026	237.32618	0.1
6	391	153.4451	601.4319	0	509.48986	356.74864	0.1
7	391	154.4447	600.4319	0	722.0131	505.55902	0.1
8	391	155.91705	599.07365	0	869.3267	608.70911	0.1
9	391	157.97235	597.31075	0	982.33502	687.83839	0.1
10	391	160	595.7366	0	1091.2183	764.07926	0.1
11	391	162	594.32935	0	1181.7215	827.45027	0.1
12	391	164	593.0522	0	1249.0588	874.60041	0.1
13	391	166	591.8945	0	1294.8235	906.64515	0.1
14	391	167.33495	591.17215	0	1314.9288	920.72307	0.1
15	391	168.83495	590.44615	0	1388.9718	936.8733	0.1
16	391	171.06695	589.44335	0	1525.0999	1028.6929	0.1
17	391	173.20085	588.5981	0	1627.8763	1098.0164	0.1
18	391	175.33475	587.8558	0	1705.2759	1150.2231	0.1
19	391	177.4687	587.212	0	1759.5379	1186.8233	0.1
20	391	179.60265	586.663	0	1794.8675	1210.6534	0.1
21	391	181.73655	586.2059	0	1812.738	1222.7072	0.1


Newmark Deformation

22	391	183.83625	585.84285	0	1805.8775	1085.0807	0.1
23	391	185.90175	585.5692	0	1785.4823	1072.826	0.1
24	391	187.96725	585.37645	0	1756.5748	1055.4566	0.1
25	391	190	585.2643	0	1748.374	1050.5291	0.1
26	391	192	585.2297	0	1759.7982	1057.3935	0.1
27	391	194	585.2695	0	1762.4931	1059.0127	0.1
28	391	196	585.3839	0	1757.2488	1055.8616	0.1
29	391	198	585.57335	0	1744.8351	1048.4027	0.1
30	391	199.236	585.71925	0	1726.017	1037.0956	0.1
31	391	200.236	585.871	0	1694.0834	863.17863	0.1
32	391	202	586.18095	0	1657.0309	844.29941	0.1
33	391	204	586.60175	0	1630.3437	830.7016	0.1
34	391	206	587.10295	0	1613.9898	822.3689	0.1
35	391	208	587.68695	0	1604.0017	817.2797	0.1

**BOTTOM ASH DISPOSAL FACILITY
SECTION A-A
LIQUEFACTION ANALYSIS RESULTS**

Title: Sporn Bottom Ash Disposal Facility
 Comments: QUAKEW Finite Element Analysis
 Accelerations at Toe
 File Name: BAP_A-A_Quake_Toe Accel_Mesh.gsz
 Date: 5/3/2010


QUAKEW MESH




Title: Sporn Bottom Ash Disposal Facility
Comments: QUAKEW Finite Element Analysis
Accelerations at Toe
File Name: BAP_A-A_Quake_Toe Accel.gsz
Date: 5/3/2010

QUAKEW MESH WITH LIQUEFIED ZONES NOTE: NO LIQUEFACTION PREDICTED


ELEMENT THAT DOES NOT LIQUEFY UNDER THE MODELED CONDITIONS → 

ELEMENT THAT LIQUEFIES UNDER THE MODELED CONDITIONS → 



Title: Sporn Bottom Ash Disposal Facility
 Comments: QUAKEW Finite Element Analysis
 Accelerations at Crest
 File Name: BAP_A-A_Quake_Crest_Accel_Mesh.gsz
 Date: 5/3/2010

QUAKEW MESH




Title: Sporn Bottom Ash Disposal Facility
Comments: QUAKE/W Finite Element Analysis
Accelerations at Crest
File Name: BAP_A-A_Quake_Crest Accel.gsz
Date: 5/3/2010

QUAKE/W MESH WITH LIQUEFIED ZONES NOTE: NO LIQUEFACTION PREDICTED

ELEMENT THAT DOES NOT LIQUEFY UNDER THE MODELED CONDITIONS → 


ELEMENT THAT LIQUEFIES UNDER THE MODELED CONDITIONS → 



**FLY ASH DISPOSAL FACILITY
SECTION H-H
LIQUEFACTION ANALYSIS RESULTS**


Title: Sporn Fly Ash Disposal Facility
 Comments: QUAKEW Finite Element Analysis
 Accelerations at Toe Location C
 File Name: FAP_H-H_Quake_Toe Accel_Mesh.gsz
 Date: 5/3/2010

QUAKEW MESH




Title: Sporn Fly Ash Disposal Facility
Comments: QUAKEW Finite Element Analysis
Accelerations at Toe Location C
File Name: FAP_H-H_Quake_Toe Accel.gsz
Date: 5/3/2010

QUAKEW MESH WITH LIQUEFIED ZONES NOTE: NO LIQUEFACTION PREDICTED


ELEMENT THAT DOES NOT LIQUEFY UNDER THE MODELED CONDITIONS 

ELEMENT THAT LIQUEFIES UNDER THE MODELED CONDITIONS 



Title: Sporn Fly Ash Disposal Facility
 Comments: QUAKE/W Finite Element Analysis
 Accelerations at Crest Location D
 File Name: FAP_H-H_Quake_Crest Accel_Mesh.gsz
 Date: 5/3/2010

QUAKE/W MESH




Title: Sporn Fly Ash Disposal Facility
Comments: QUAKEW Finite Element Analysis
Accelerations at Crest Location D
File Name: FAP_H-H_Quake_Crest Accel.gsz
Date: 5/3/2010

QUAKEW MESH WITH LIQUEFIED ZONES NOTE: NO LIQUEFACTION PREDICTED

ELEMENT THAT DOES NOT LIQUEFY UNDER THE MODELED CONDITIONS → 


ELEMENT THAT LIQUEFIES UNDER THE MODELED CONDITIONS → 



APPENDIX VI

DRAWINGS





THESE DRAWINGS ARE PART OF A SET OF DESIGN INSTRUMENTS WHICH ALSO CONTAINS A WRITTEN TEXT. THAT WRITTEN TEXT EXPLAINS AND ELABORATES UPON THE INFORMATION SHOWN ON THESE DRAWINGS. THIS WRITTEN TEXT SHOULD ONLY BE USED IN CONJUNCTION WITH THE TEXT ON THESE DRAWINGS.

DATE	REVISIONS	BY

SITE MAP
FLY ASH & BOTTOM ASH DISPOSAL FACILITIES
PHILIP SPORN PLANT
 NEW HAVEN, WEST VIRGINIA

SCALE: AS SHOWN
 PREPARED FOR: AEP SERVICE CORPORATION

PREPARED BY: Geo/Environmental Associates, Inc.
USE PREVIOUS EDITIONS UNLESS OTHERWISE SPECIFIED

PROJECT: 09-367 DATE: 5-27-10 SHEET 1 OF 2


NOTES
 1. AS-BUILT TOPOGRAPHIC MAPPING PREPARED BY HENDERSON AERIAL SURVEYS, INC. DATED 5-22-07 AND PROVIDED BY AEP.

LEGEND

- A-J SAMPLED BOREHOLE
- D SAMPLED BOREHOLE WITH PIEZOMETER
- K VIBRATION MONITORING LOCATION


SECTION LINE
 K-K






BOTTOM ASH DISPOSAL FACILITY SECTION A-A


NOTES
 1. AS-BUILT SECTIONS ADAPTED FROM PREVIOUS SECTIONS PREPARED BY AEP AND FROM TOPOGRAPHIC MAPPING PREPARED BY HENDERSON AERIAL SURVEYS, INC., DATED 5-22-07.



FLY ASH DISPOSAL FACILITY SECTION H-H



FLY ASH DISPOSAL FACILITY SECTION K-K



THESE DRAWINGS ARE PART OF A SET OF DESIGN DOCUMENTS WHICH ALSO CONTAINS A WRITTEN TEXT THAT EXPLAINS SOME OF THE DETAILS SHOWN HEREIN AND THEREFORE THESE DRAWINGS SHOULD ONLY BE USED IN CONJUNCTION WITH THE TEXT.

DATE	REVISIONS	BY

SECTIONS
 FLY ASH & BOTTOM ASH DISPOSAL FACILITIES
 PHILIP SPORN PLANT
 NEW HAVEN, WEST VIRGINIA

SCALE: AS SHOWN
 PREPARED FOR: AEP SERVICE CORPORATION
 PREPARED BY: Geo/Environmental Associates, Inc.
 8506 OVERLOOK CIRCLE • KNOXVILLE, TENNESSEE 37919 • (615) 584-0844

APPENDIX VII

REFERENCES



REFERENCES

- ASTM D 854 "Standard Test Methods for Specific Gravity of Soil Solids by Water Pycnometer."
- ASTM D 1586 "Standard Test Method for Standard Penetration Test (SPT) and Split-Barrel Sampling of Soils."
- ASTM D 1587 "Standard Practice for Thin-Walled Tube Sampling of Soils for Geotechnical Purposes."
- ASTM D 2573 "Standard Test Method for Field Vane Shear Test in Cohesive Soil."
- ASTM D 4318 "Standard Test Methods for Liquid Limit, Plastic Limit, and Plasticity Index of Soils."
- ASTM D 4428 "Standard Test Methods for Crosshole Seismic Testing."
- ASTM D 4767 "Standard Test Method for Consolidated Undrained Triaxial Compression Test for Cohesive Soils."
- ASTM D 5084 "Standard Test Methods for Measurement of Hydraulic Conductivity of Saturated Porous Materials Using a Flexible Wall Permeameter."
- ASTM D 6519 "Standard Practice for Sampling of Soil Using the Hydraulically Operated Stationary Piston Sampler."
- Bowles, Joseph E. *Foundation Analysis and Design*. 4th ed. New York: Mc-Graw Hill, 1988. Print
- Craig, R.F. *Soil Mechanics*. 5th ed. London: Chapman & Hall, 1992. Print
- Dam Safety Rules*. West Virginia Department of Environmental Protection, Water Resources.
- Dynamic Modeling with QUAKE/W 2007, An Engineering Methodology*. 3rd ed. Calgary: Geo-Slope International, 2008. Print
- Forrester, Kevin. *Subsurface Drainage for Slope Stabilization*. Reston: American Society of Civil Engineers, 2001. Print
- Hardin, Bobby O. and Michael E. Kalinski. "Estimating the Shear Modulus of Gravelly Soils," *Journal of Geotechnical and Geoenvironmental Engineering*, ASCE, Vol. 131 No. 7, 867-875, 2005.
- Hardin, Bobby O. and Vincent P. Drnevich. "Shear Modulus and Damping In Soils: Measurement and Parameter Effects," *Journal of the Soil Mechanics and Foundations Division*, ASCE, 98:SM6, 603-624, 1972.



Holtz, Robert D. and William D. Kovacs. *An Introduction to Geotechnical Engineering*. Englewood Cliffs: Prentice-Hall, 1981. Print

Idriss, I.M. and R.W. Boulanger. "Semi-empirical Procedures for Evaluating Liquefaction Potential During Earthquakes," *Proceedings of the 11th International Conference on Soil Dynamics and Earthquake Engineering and the 3rd International Conference on Earthquake Geotechnical Engineering*, University of California, Berkeley, 2004.

Kalinski, M.E. and M.S.R. Thummaluru. "A New Free-Free Resonant Column Device for Measurement of G_{max} and D_{min} at Higher Confining Stresses," *Geotechnical Testing Journal*, Vol. 28 No. 2, 180-187, 2005.

Lambe, T. William, and Robert V. Whitman. *Soil Mechanics*. New York: John Wiley & Sons, 1969. Print

ProShake Ground Response Analysis Program, Version 1.1 User's Manual. Redmond: EduPro Civil Systems, Inc., 1998. Print

Seepage Modeling with SEEP/W 2007, An Engineering Methodology. 4th ed. Calgary: Geo-Slope International, 2008. Print

Stability Modeling with SLOPE/W 2007, An Engineering Methodology. 4th ed. Calgary: Geo-Slope International, 2008. Print

Towhata, Ikuo. *Geotechnical Earthquake Engineering*. Berlin: Springer, 2008. Print

The Ohio State University Research Project # 60005876. "Evaluation of Liquefaction Potential of Impounded Fly Ash." Department of Civil and Environmental Engineering and Geodetic Science, The Ohio State University, 2005. Print

Vucetic, Mladen. "Effect of Soil Plasticity on Cyclic Response," *Journal of Geotechnical Engineering*, ASCE, 117(1), 89-107, 1991.

