337-39

. .

DIRECTIONS

In cases of high head pressure, excessive scale, or heavy Education in the state of heavy Educ

In other cases and for regular treatment, add 2 ounces of Lester SLIMICIDE for each 100 gallons of water in the system. Treatment should be added near pump suction. A minimum 2 ounce dosage should be used even in systems with less than 100 gallons water.

A treatment with Lester SLIMICIDE once a month is usually sufficient to control growth of slime in a cooling tower. Repeat treatment if necessary. The frequency of dosage required in any system can only be determined by experience, as the amount and type of micro-organisms and other variables such as temperature, pH, sunlight, etc., will be different in each system. Overdosage will not harm the system, and is preferred to underdosage.



SLIMICIDE

For controlling algae and slime in cooling water systems. Foam controlled.

95.3%

M

Isopropyl alcohol and water.......

NET CONTENTS: I GALLON

MANUFACTURED BY

Cester Caboratories,

ATLANTA, GEORGIA



SLIMICIDE

For controlling algae and slime in cooling water systems. Foam controlled.

INERT INGREDIENTS:

Isopropyl alcohol and water......95.3%

NET CONTENTS: I GALLON

MANUFACTURED BY

Cester Caboratories, **NCORPORATED** **ATLANTA, GEORGIA**

CAUTION

Do not allow the water that contains Lester SLIMICIDE to come in contact with grass or plants. Do not use in drinking water or in swimming pools.

WARNING

Concentrate is FLAMMABLE. May be fatal if swallowed. May be absorbed through skin. Causes skin irritation. Keep away from heat and open flames. Keep container tightly closed when not in use. Do not get on skin, in eyes, or on clothing. In case of contact with skin, wash with soap and water. In case of contact with eyes, immediately flush with water and get medical attention.