



**LESTER 30
BACTERICIDE AND FUNGICIDE**

Active Ingredients		30%
Sodium Dimethyldithiocarbamate	15%	
Nabom (Disodium Ethylene Bisdithiocarbamate)	15%	
Inert Ingredients		70%

CONTENTS Liquid — See Markings on Top of Drum for Net Weight.
Do not re-use empty containers. Container should be destroyed by perforation or crushing. Discard container in a safe place.

CAUTION KEEP OUT OF REACH OF CHILDREN.
SEE OTHER PRECAUTIONS ON RIGHT PANEL

SOLD BY

LESTER LABORATORIES
INCORPORATED
ATLANTA, GEORGIA, U.S.A. 30344

CAUTION

KEEP OUT OF REACH OF CHILDREN

Causes eye and skin irritation. Do not get in eyes, on skin or on clothing. Wear goggles or face shield, rubber gloves and protective clothing (long sleeve shirt, long pants and boots) when handling. Harmful if swallowed. Avoid contamination of food and feed stuffs.

In case of contact, immediately flush eyes or skin with plenty of water for at least 15 minutes. For eyes, call a physician. Remove and wash contaminated clothing before re-use.

If swallowed, drink promptly a large quantity of milk, egg whites, gelatin solution or if these are not available, drink large quantities of water. Call a physician immediately.

CAUTION This product is toxic to fish. Treated effluent should not be discharged where it will drain into lakes, streams, ponds, or public water. Apply this product only as specified on the label.

WEIGHT 97 LB Gal
E.P.A. Registration No. 337-58 1983
E.P.A. Establishment No. 337 GA-1

ACCEPTED

ACCEPTED
FEB 10 1983
Under the Federal Insecticide, Fungicide, and Rodenticide Act, this product is registered under EPA Reg. No. 221-26

LESTER-30 is a highly effective product for controlling the growth of bacteria and fungi found in industrial recirculating cooling water towers, air washers and evaporative condensers

Industrial Recirculating Water Cooling Towers, Evaporative Condensers and Air Washer Systems

Dosages for industrial recirculating water systems will depend on the condition of the system prior to treatment initiation. Systems which are heavily contaminated should be cleaned first. Apply LESTER-30 to the cleaned system or when growth is first noticed, according to the following schedule:

Initial Dose: Apply 13.06 fluid ounces of product per 1,000 gallons of water in the system (120 ppm). This dose may be repeated once, twice or three times weekly or as required to control the growth of slime-forming organisms. LESTER-30 should be applied at a point where the product will be uniformly mixed.

Subsequent Dose: When microbial control is evident, add 2.18 to 4.36 fluid ounces of LESTER-30 per 1,000 gallons of water (20-40 ppm) in the system every three days or as needed. LESTER-30 should be applied at a point where the product will be uniformly mixed.