

THANE

slowly and
Remove
st five minutes,
son control


enter or
e. Have
allow.
y a

hing.
rater for 15-20
r doctor for

person is not
ten give artificial
if possible. Call
her treatment.

product into
or other
rements of a
ystem
y has been
t discharge
stems
e treatment
State Water

ing life or



STORAGE AND DISPOSAL

STORAGE: Freezes at 60°F.

Store in a warm place.

TRIS NITRO decomposes in the presence of alkaline materials. Protect from vapors of ammonia and amines during handling and storage to prevent deterioration and release of formaldehyde.

PESTICIDE DISPOSAL: Do not contaminate water, food, or feed by storage or disposal. Wastes resulting from the use of this product may be disposed of on site or at any approved waste disposal facility.

CONTAINER DISPOSAL: Triple rinse (or equivalent). Then offer for recycling or reconditioning or puncture and dispose of in a sanitary landfill, or by other procedures approved by state and local authorities.

DIRECTIONS FOR USE

It is a violation of Federal Law to use this product in a manner inconsistent with its labeling.

USE IN PAINTS, EMULSIONS, AND THICKENER SOLUTIONS

TRIS NITRO is effective as a preservative in water-containing systems, such as latex paints, resin emulsions, and thickener solutions at a concentration of 0.2 to 1.0 lb per 100 lb total formulation weight. TRIS NITRO may be added at any point in the manufacturing cycle. The recommended rate for preservation of a latex paint is 0.2 to 0.4 lb per 100 lb of the formulation. The recommended rate for preservation of resin emulsions and thickener solutions is approximately 0.4 lb per 100 lb of the formulation.

USE IN METALWORKING FLUIDS

In Diluted Fluids: A concentration of 1000 to 2000 ppm of active TRIS NITRO in the fluid is sufficient to control gross bacterial growth. Add 1-2 quarts of 50% aqueous TRIS NITRO per each 100 gallons of fluid.

Maintenance Dosage: Add 250 to 500 PPM of active TRIS NITRO weekly as required to maintain control of the system. The addition of 0.25 quart of 50% aqueous TRIS NITRO to each 100 gallons of fluid will provide a 250 ppm concentration.

In Concentrates: TRIS NITRO may be incorporated by the manufacturer in metal working fluid concentrate. The higher levels required in such concentrates will be stable as long as the pH is maintained in the range of 6 to 8. Above such pH levels rapid deterioration of TRIS NITRO may result in the release of noticeable levels of formaldehyde. Long-term stability tests should be carried out by the manufacturer on his specific formulation to ensure that the concentrate does not contain ingredients incompatible with TRIS NITRO stability. The amount to be incorporated will depend on the dilution factor recommended to be used when the concentrate is diluted for use. For efficient bacteriostatic activity, a concentration of 1000 to 2000 ppm of active TRIS NITRO in the diluted fluid is suggested.

USE IN RECIRCULATING WATER SYSTEMS

For control of bacteria in cooling towers, evaporative condensers, and closed recirculating water systems such as retort, rotary or hydrostatic heat sterilization processes used in the food industry. Treat the system with 5-1000 ppm of active TRIS NITRO.

Initial dose: When the system is noticeably fouled, add 6 oz.-1 gallon of 50% aqueous TRIS NITRO per 1000 gallons of water in the system. Repeat until control is achieved. Badly Fouled systems must be cleaned before initial treatment.

Subsequent dose: Add 2 oz.-1 quart of 50% aqueous TRIS NITRO per 1000 gallons of water in the system as needed to maintain control.

TRIS NITRO should be added at a convenient point which will provide uniform mixing.

USE IN OILFIELD WATER SYSTEMS

For controlling aerobic slime-forming bacteria (*Pseudomonas* sp.) and anaerobic sulfate-reducing bacteria (*Desulfovibrio* desulfuricans) in oilfield water systems, such as subsurface injection water, add 500-1000 ppm active TRIS NITRO depending on the severity of contamination. Additions should be made with a metering pump at the free-water knockouts before or after injection pumps and injection well headers.

Continuous-feed method: If the system is noticeably fouled, add 500-1000 ppm active TRIS NITRO (80-160 gallons of 50% aqueous TRIS NITRO per 2000 barrels of water) continuously until the desired degree of control is achieved. Subsequently, treat with 500 ppm active TRIS NITRO (80 gallons of 50% aqueous TRIS NITRO per 2000 barrels of water) continuously as needed to maintain control.

Intermittent or slug method: If the system is noticeably fouled, or to maintain control of the system, add 500-1000 ppm active TRIS NITRO (80-160 gallons of 50% aqueous TRIS NITRO per 2000 barrels of water) intermittently for 2-8 hours per day on from 1-4 days per week, depending on the severity of contamination.

USE AS A PRESERVATIVE FOR PACKAGED EMULSIONS, OR SUSPENSIONS SUCH AS DETERGENTS AND POLISHES CONTAINING WATER.-Not for use in California.

For control of bacterial contamination add 500-1000 ppm of active TRIS NITRO (1-2 gallons of 50% aqueous TRIS NITRO per 1000 gallons of formulation).

USE IN DRILLING MUDS

For control of sulfate-reducing bacteria in water-based drilling muds, add 0.5 quart-1 gallon of 50% aqueous TRIS NITRO to 1000 gallons of drilling mud.

464-663

8-9-2002

1/1