

PEROLIN ALGAE PREVENTIVE 902

ACTIVE INGREDIENTS

Methyldodecylbenzyl trimethyl ammonium chloride.....	3.6%
Methyldodecylxylylene bis (trimethyl ammonium chloride).....	0.9%
INERT INGREDIENTS.....	95.5%
TOTAL	100.0%

This product weighs 8.27 pounds/gallon.

**KEEP OUT OF REACH OF CHILDREN
WARNING**

SEE SIDE PANELS FOR PRECAUTIONARY STATEMENTS AND STATEMENT OF PRACTICAL TREATMENT



E.P.A. Establishment No. 09403-OH-01
E.P.A. Registration No. 486-4
Net Contents: Liquid

See Markings on Shipping Container for Net Weight

PRECAUTIONARY STATEMENTS

WARNING

Hazards to Humans and Domestic Animals

Causes substantial, but temporary, eye injury. Do not get in eyes or on clothing. Wear goggles or face shield. Harmful if swallowed. Wash thoroughly with soap and water after handling. Remove contaminated clothing and wash before reuse.

Causes skin irritation. Do not get on skin or on clothing.

STATEMENT OF PRACTICAL TREATMENT

In case of contact, immediately flush eyes or skin with plenty of water. Get medical attention. If swallowed, drink promptly a large quantity of milk, egg whites, gelatin solution; or if these are not available, drink large quantities of water. Avoid alcohol.

NOTE TO PHYSICIAN: Probable mucosa! damage may contraindicate the use of gastric lavage.

Seller makes no warranty, expressed or implied, concerning the use of this product other than indicated on the label. Buyer assumes all risk of use and/or handling of this material, when such use and/or handling is contrary to label instructions.

**INDUSTRIAL RECIRCULATING WATER
COOLING TOWERS AND
EVAPORATIVE CONDENSERS**

Dosages for industrial recirculating cooling towers or evaporative condensers will depend on the condition of the system prior to treatment initiation. Systems which are heavily contaminated should be cleaned first. Apply Perolin Algae Preventive 902 to the cleaned system or when growth is first noticed, according to the following schedule:

Initial Dose: Apply 1 to 1.5 gallons of Perolin Algae Preventive 902 per each 1000 gallons of water (1000-1500 ppm) in the system. This dose may be repeated once, twice, or three times weekly or as required to control the growth of algae or slime-forming bacteria.

Subsequent Dose: When microbial control is evident, add 1 to 1.5 quarts of Perolin Algae Preventive 902 per each 1000 gallons of water (250-370 ppm) in the system every three days or as needed to maintain good control.

Apply Perolin Algae Preventive 902 at a point in the system where uniform mixing and even distribution will occur, such as the cooling tower basin or sump.

