

527-108

12-04-2003

42

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

DEC 4 2003

Rochester Midland Corporation
333 Hollenbeck Street
Rochester, N. Y. 14621

Attention: Valerie Kromer
Regulatory Specialist

Subject: ML-17G
EPA Registration No. 527-108
Amendment Dated September 5, 2003

The amendment referred to above, submitted in connection with registration under the Federal Insecticide, Fungicide and Rodenticide Act (FIFRA) as amended, is acceptable.


- To revise the product labeling

General Comment

A stamped copy of the accepted labeling is enclosed for your records.

If you have any questions concerning this letter, please contact Martha Terry at (703) 308-6217.

Sincerely,



Marshall Swindell
Product Manager 33
Regulatory Management Branch 1
Antimicrobial Division (7510C)

Enclosure

CONCURRENCES

SYMBOL								
SURNAME								
DATE								

IF IN EYES: Hold eye open and rinse slowly and gently with water for 15-20 minutes. Remove contact lenses, if present, after the first 5 minutes, then continue rinsing eye.

IF ON SKIN OR CLOTHING: Take off contaminated clothing. Rinse skin immediately with plenty of water for 15-20 minutes.

IF INHALED: Move person to fresh air. If person is not breathing, call 911 or an ambulance, then give artificial respiration, preferably by mouth-to-mouth, if possible. Call a poison control center or doctor for treatment advice. Have the product container or label with you when calling a poison control center or doctor or going for treatment.

IF SWALLOWED: Call a poison control center or doctor immediately for treatment advice. Have person sip a glass of water if able to swallow. Do not induce vomiting unless told to do so by a poison control center or doctor. Do not give anything by mouth to an unconscious person.

NOTE TO PHYSICIAN: Probable mucosal damage may contraindicate the use of gastric lavage. Medical Emergency Telephone 1-800-535-5053 (U.S.). Outside the U.S. 1-352-323-8000.

FORM 4407-C-BULK
(Rev. 4/3/03)

10364050

RECEIVED
9-11-03

PRECAUTIONARY STATEMENTS

HAZARDS TO HUMANS AND DOMESTIC ANIMAL
DANGER: CORROSIVE. Causes eye and skin damage. Harmful if swallowed. Do not get in eyes, on skin, or on clothing. Avoid contamination of food. Wear goggles of face and rubber gloves when handling. Wash thoroughly with soap and water after handling and before eating, drinking, chewing gum, or using tobacco. Refer to the ML-17G Material Safety Data Sheet for other safety information.

ENVIRONMENTAL HAZARDS


This pesticide is toxic to fish. Do not discharge effluent containing this product into lakes, streams, ponds, estuaries, oceans or other waters unless in accordance with the requirements of a National Pollutant Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not discharge effluent containing this product to sewer systems without previously notifying the local sewage treatment plant authority. For guidance contact your state Water Board or Regional Office of the EPA.

DIRECTIONS FOR USE

It is a violation of federal law to use this product in a manner inconsistent with its label. The Use of ML-17G in industrial and/or commercial recirculating cooling tower systems and industrial air washing systems will control microbiological growth and slime.

EPA Est. No. 527-NY-1

EPA Est. No. 527-L-1



WATER ENERGY DIVISION

ML-17G


MICROBIOCIDE FOR CONTROL OF MICROORGANISMS IN COOLING WATER AND INDUSTRIAL AIR-WASH SYSTEMS

EPA REG. No. 527-108

ACTIVE INGREDIENT	
Potassium dimethylglycinate	25.0%
OTHER INGREDIENTS	75.0%
TOTAL	100.0%

This product contains 2.3 lbs of active ingredient per gallon and weighs 9.2 lb per gallon.

KEEP OUT OF REACH OF CHILDREN
DANGER
See Side Panel for Precautionary Statements

NET WEIGHT: 275 lbs 

COOLING TOWER SYSTEMS: Prior to use, the system should be cleaned to remove algal growth, microbiological slime or other deposits. Based on the Total amount of water in the system, make an initial treatment 4.5 to 6.8 liquid ounces (40-60 ppm) of ML-17G per 1000 gallons of water. Repeat this dosage until control is attained. Every days or as needed, make maintenance additions of 2.3 liquid ounces (20-60 ppm) of ML-17G per 1000 gallons. Frequency of addition depends upon the amount of bleed and the microbiological problem severity. Additions shot made to the sump of recirculating cooling tower systems

INDUSTRIAL AIR-WASHING SYSTEMS: For use only in systems with effective mist-eliminations. Clean the system to remove bacterial slime or other deposits present. An initial dose of 10.6-13.6 liquid ounces (93-120 ppm) of ML-17G per 1000 gallons of water in the system is recommended. Repeat dosage until control is attained. Maintenance additions of 13.6 liquid ounces (70-120ppm) of ML-17G per 1000 gal of water should be made every 1-5 days, or as needed. The frequency of additions will depend on the amount of bleedoff and the bacterial problem severity. Additions may be made to the sump or water collection trays of the air-wash system.



ROCHESTER MIDLAND CORPORATION
333 HOLLENBECK STREET
ROCHESTER, NY 14621
www.RochesterMidland.com

ACCEPTED

DEC 04 2003

Under the Federal Insecticide, Fungicide, and Rodenticide Act as amended, for the pesticide, registered under EPA Reg. No. 527-108