

707-133

06/29/2010

1/7

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
WASHINGTON, D.C. 20460



United States
Environmental Protection
Agency

Office of Pesticide Programs

Rohm and Haas Company
100 Independence Mall West
Philadelphia, PA 19106-2399

JUN 29 2010

Attention: Valerie Phillips

Subject: KATHON™ WT 1.5% Industrial Microbicide
EPA Registration No. 707-133
Notification Dated May 28, 2010

This will acknowledge receipt of your notification, submitted under the provisions of FIFRA Section 3(c)(9).

Proposed Notification

- To add language for "Refillable Containers" per PR Notice 2007-4

General comments

Based on a review of the submitted material, the following comments apply.

The Notification is in compliance with PR Notice 98-10 and is acceptable. This information has been added to your file.

If you have any questions concerning this letter, please contact Martha Terry at (703) 308-6217.

Sincerely,

A handwritten signature in cursive script that reads "M. Swindell".

Marshall Swindell
Product Manager 33
Regulatory Management Branch 1
Antimicrobials Division (7510P)

NOTIFICATION

Please read instructions on reverse before completing form.

Form Approved. OMB No. 2070-0060

	United States Environmental Protection Agency Washington, DC 20460	<input type="checkbox"/> Registration <input type="checkbox"/> Amendment <input checked="" type="checkbox"/> Other	OPP Identifier Number
--	---	--	-----------------------

Application for Pesticide - Section I

1. Company/Product Number Rohm and Haas Co. / 707-133	2. EPA Product Manager Mr. Marshall Swindell	3. Proposed Classification <input checked="" type="checkbox"/> None <input type="checkbox"/> Restricted
4. Company/Product (Name) Rohm and Haas Co. / KATHON(tm) WT 1.5% Industrial Microbicide	PM# 33	
5. Name and Address of Applicant (Include ZIP Code) Rohm and Haas Company 100 Independence Mall West Philadelphia, PA 19106-2399 <input type="checkbox"/> Check if this is a new address	6. Expedited Review. In accordance with FIFRA Section 3(c)(3) (b)(i), my product is similar or identical in composition and labeling to: EPA Reg. No. _____ Product Name _____	

Section - II

<input type="checkbox"/> Amendment - Explain below.	<input type="checkbox"/> Final printed labels in response to Agency letter dated _____
<input type="checkbox"/> Resubmission in response to Agency letter dated _____	<input type="checkbox"/> "Me Too" Application.
<input checked="" type="checkbox"/> Notification - Explain below.	<input type="checkbox"/> Other - Explain below.

Explanation: Use additional page(s) if necessary. (For section I and Section II.)

Notification to add label language per PR Notice 2007-4

Section - III

1. Material This Product Will Be Packaged In:				2. Type of Container	
Child-Resistant Packaging <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Unit Packaging <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Water Soluble Packaging <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		<input type="checkbox"/> Metal	<input checked="" type="checkbox"/> Plastic
* Certification must be submitted	If "Yes" Unit Packaging wgt. No. per container	If "Yes" Package wgt. No. per container		<input type="checkbox"/> Glass	<input type="checkbox"/> Paper
3. Location of Net Contents Information <input checked="" type="checkbox"/> Label <input type="checkbox"/> Container	4. Size(s) Retail Container 60ml, 125ml, 1 pt, 1 qt, 1, 5, 30, 55, 200, 300, 5000 gal	5. Location of Label Directions <input type="checkbox"/> on label		Other (Specify) _____	
6. Manner in Which Label is Affixed to Product <input checked="" type="checkbox"/> Lithograph Paper glued Stenciled <input type="checkbox"/> Other _____					

Section - IV

1. Contact Point (Complete items directly below for identification of individual to be contacted, if necessary, to process this application.)		
Name Valerie T. Phillip	Title Regulatory Specialist	Telephone No. (include Area Code) 215.641.7696
Certification I certify that the statements I have made on this form and all attachments thereto are true, accurate and complete. I acknowledge that any knowingly false or misleading statement may be punishable by fine or imprisonment or both under applicable law.		6. Date Application Received (Stamped)
2. Signature 	3. Title Regulatory Specialist	
4. Typed Name Valerie T. Phillip	5. Date May 28, 2010	

33
3/7
ROHM AND HAAS COMPANY INDEPENDENCE MALL WEST PHILADELPHIA, PA 19105, U.S.A.
TELEPHONE (215) 592-3000
CABLE ADDRESS: ROHMHAAS TELEX 845-247 TWX 710-670-5335 TELECOPIER (215) 592-3377



A Wholly Owned Subsidiary of The Dow Chemical Company

REPLY TO:
RESEARCH LABORATORIES
727 NORRISTOWN ROAD
SPRING HOUSE, PA 19477
(215) 641-7000
(215) CH 2-0400

NOTIFICATION

May 28, 2010

Document Processing Desk 7502P (E-SUB)
U.S. EPA – Office of Pesticide Programs
Room S-4900, One Potomac Yard
2777 South Crystal Drive
Arlington, VA 22202-4501
Attn: Marshall Swindell (PM 33)

Subject: KATHON™ WT 1.5% Industrial Microbicide
EPA Reg. No. 707-133
Label Amendment per PR Notice 2007-4

Dear Mr. Swindell,

Please find enclosed an application to amend the label for the Rohm and Haas Company Product KATHON™ WT 1.5% Industrial Microbicide (EPA Reg. No 707-133).


This label was already approved for the update to PR-Notice 2007-4 on 10-1-09. The purpose of this notification is to just add the language for "Refillable Containers".

Administrative items included to support this amendment are as follows:

1. Application form # 8570-1
2. Five (5) paper copies of proposed label

Please contact me with questions regarding this submission.

Sincerely,


Valerie T. Phillip
Regulatory Specialist
DMC
215-641-7696

/enclosures

4/7

KATHON™ WT 1.5%

Industrial Microbicide for use in Industrial Process Water Systems, Recirculating Water Cooling Towers, Air Washer Systems, Oil Field Injection Waters, Wood Mildew Control, Papermill Slime Control, Dispersed Pigments, Recirculating Closed Loop Water Cooling Systems, Brewery Pasteurizer/Can Warmer/Retort Water Systems, Air Conditioner/Refrigeration Condensate Water Systems, Coal Slurry Systems, Evaporative Condenser Water Systems, Hydrostatic Sterilizer Water Systems, Influent Water Filtration Systems, Immersion Ultrasonic Tank Water, Reverse Osmosis and Ultra Filtration Systems, Industrial Scrubbing Systems, Industrial Wastewater Treatment Systems, Laboratory Equipment Water Baths, Sewage Systems, Paint Spray Booth Systems, Recirculating Electrodeposition Systems, and Polymer Latices.



ACTIVE INGREDIENTS:

5-Chloro-2-methyl-4-isothiazolin-3-one	1.11%
2-Methyl-4-isothiazolin-3-one	0.39%

INERT INGREDIENTS:	98.50%
Total:	100.00%

KEEP OUT OF REACH OF CHILDREN DANGER FIRST AID

- IF ON SKIN:**
- Take off contaminated clothing.
 - Rinse skin immediately with plenty of water for 15-20 min.
 - Call a poison control center or doctor for treatment advice.
- IF IN EYES:**
- Hold eye open and rinse slowly and gently with water for 15-20 min.
 - Remove contact lenses, if present, after first 5 min. then continue rinsing eye.
 - Call a poison control center or doctor for treatment advice.
- IF INHALED:**
- Move person to fresh air.
 - If person is not breathing, call 911 or an ambulance, then give artificial respiration, preferably mouth-to- mouth if possible.
 - Call a poison control center or doctor for further treatment advice.
- IF SWALLOWED:**
- Call a poison control center or doctor immediately for treatment advice.
 - Do not induce vomiting unless told to do so by a poison control center or doctor.
 - Have person sip a glass of water if able to swallow. Do not give anything to an unconscious person.

Have the product container or label with you when calling a poison control center or doctor, or going for treatment.


IN CASE OF EMERGENCY CALL ROHM AND HAAS COMPANY 215-592-3000

NOTE TO PHYSICIAN: Probable mucosal damage may contraindicate the use of gastric lavage. Measures against circulatory shock, respiratory depression and convulsions may be necessary.

SEE SIDE PANELS FOR ADDITIONAL PRECAUTIONARY STATEMENTS.

PRECAUTIONARY STATEMENTS HAZARDS TO HUMANS AND DOMESTIC ANIMALS

DANGER
CORROSIVE
CAUSES IRREVERSIBLE EYE DAMAGE AND SKIN BURNS
MAY CAUSE ALLERGIC SKIN REACTION
HARMFUL IF INHALED
HARMFUL IF SWALLOWED OR ABSORBED THROUGH THE SKIN



5/7

Do not get in eyes, on skin, or on clothing. Mixers, loaders and others exposed to this product must wear: long-sleeved shirt and long pants; chemical resistant gloves such as nitrile or butyl rubber, shoes plus socks; goggles and face shield; and chemical resistant apron. Discard clothing or other absorbent materials that have been drenched or heavily contaminated with this product's concentrate. Do not reuse them. Follow manufacturer's instructions for cleaning/maintaining PPE. If no such instructions for washables exist, use detergent and hot water. Keep and wash PPE separately from other laundry. Users should wash hands before eating, drinking, chewing gum, using tobacco or using the toilet. Users should remove clothing immediately if pesticide gets inside. Then wash thoroughly and put on clean clothing. Users should remove PPE immediately after handling this product. Wash the outside of gloves before removing. As soon as possible, wash thoroughly. This product may cause skin sensitization reactions in some people.

ENVIRONMENTAL HAZARDS

This chemical is toxic to aquatic plants, fish and aquatic invertebrates. Do not discharge effluent containing this product into lakes, streams, ponds, estuaries, oceans, or other waters unless in accordance with the requirements of a National Pollutant Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not discharge effluent containing this product to sewer systems without previously notifying the local sewage treatment plant authority. For guidance contact your State Water Board or Regional Office of the EPA. Do not contaminate water by cleaning of equipment or disposal of waste. Apply this pesticide only as specified on this label

STORAGE AND DISPOSAL

PESTICIDE STORAGE

Do not contaminate water, food or feed by storage, disposal or cleaning of equipment. Do not apply this product in a way that will contact workers or other persons.

PESTICIDE DISPOSAL

Pesticide wastes are acutely hazardous. Improper disposal of excess pesticide or rinsate is a violation of Federal law. If these wastes cannot be disposed of by use according to label instructions, contact your State Pesticide or Environmental Control Agency or the Hazardous Waste representative at the nearest EPA Regional Office for guidance.

CONTAINER DISPOSAL

Nonrefillable container. Do not reuse or refill this container. Triple rinse or pressure rinse container (or equivalent) promptly after emptying. Then offer for recycling or reconditioning, or puncture and dispose of in a sanitary landfill, or by procedures approved by state and local authorities.

Refillable container. Refill this container with pesticide only. Do not reuse this container for any other purpose. Cleaning of the container before final disposal is the responsibility of the person disposing of the container. Cleaning before refilling is the responsibility of the refiller. To clean container before final disposal, empty contents into application equipment and triple rinse. Pour or pump rinsate into application equipment or rinsate collection system. Then offer for recycling if available, or puncture and dispose of in a sanitary landfill, or by incineration, or by other procedures allowed by state and local authorities

GENERAL

CONSULT FEDERAL, STATE, OR LOCAL DISPOSAL AUTHORITIES FOR APPROVED ALTERNATIVE PROCEDURES

CONDITIONS OF SALE AND WARRANTY


Rohm and Haas warrants that this product conforms to its chemical description and is reasonably fit for the purpose stated on the label only when used in accordance with label directions and as defined the Directions for Use on this label. ROHM AND HAAS MAKES NO OTHER EXPRESS OR IMPLIED WARRANTIES, EITHER OF MERCHANTABILITY OR FITNESS, FOR A PARTICULAR USE. Handling, storage, and use of the product by Buyer or User are beyond the control of Rohm and Haas and Seller. Risks such as ineffectiveness or other unintended consequences resulting from, but not limited to, failure to follow directions will be assumed by the Buyer or User. TO THE EXTENT PERMITTED BY LAW, NEITHER ROHM AND HAAS NOR SELLER SHALL BE LIABLE FOR CONSEQUENTIAL, SPECIAL OR INDIRECT DAMAGES RESULTING FROM THE HANDLING, STORAGE OR USE OF THIS PRODUCT

Date of Manufacture: location for date
EPA Reg. No. 707-133
EPA Est. No. establishment number

DIRECTIONS FOR USE

It is a violation of Federal law to use this product in a manner inconsistent with its labeling

For the control of microbial biofilms, bacteria, algae, and fungi, add Kathon WT 1.5% microbicide to: industrial process water systems, industrial recirculating water cooling towers, industrial recirculating closed loop water cooling systems, brewery pasteurizers, can warmers, retort water systems, industrial scrubbing systems, evaporative condenser water systems, hydrostatic sterilizer water systems, air conditioner/refrigeration condensate water systems, coal slurry systems, immersion



ultrasonic tank water, laboratory equipment water baths and influent water filtration systems. Add Kathon WT 1.5% microbicide at some point in the system to insure uniform mixing.

INITIAL DOSE: When the system is noticeably fouled, apply 148 - 883 ppm Kathon WT 1.5% microbicide (1.26 - 7.46 pound or 19 - 113 fluid ounce of Kathon WT 1.5% per 1000 gallon of water in the system.) Repeat until control is achieved. Badly fouled systems should be cleaned before treatment is begun.

SUBSEQUENT DOSE: When microbial control is evident, add 35 - 219 ppm Kathon WT 1.5% microbicide (0.3 - 1.86 pound or 4.5 - 28 fluid ounce of Kathon WT 1.5% per 1000 gallon of water in the system) weekly or as needed to maintain control.

DISPERSED PIGMENT PRESERVATION

Kathon WT 1.5% microbicide is recommended for the control of microbial biofilms, bacteria and fungi in the manufacture and storage of dispersed pigments such as kaolin and montmorillite clays, titanium dioxide, calcium carbonate, calcium sulfate, barium sulfate, magnesium silicate, and kieselguhr used in paint and paper productions. Add 0.43-1.65 pound of Kathon WT 1.5% (195-750 gram) to each 1000 pound (453 kilogram) of fluid to provide 425 to 1675 ppm product (6.25-25 ppm active isothiazolones).

AIR WASHER SYSTEMS/ PAINT SPRAY BOOTHS

Add to the air washer sump, chill water sump, or paint spray booth to insure uniform mixing, 35 - 883 ppm Kathon WT 1.5% microbicide (0.3 - 7.46 pound or 4.5 - 113 fluid ounce of Kathon WT 1.5% per 1000 gallon of water in the system) depending upon the severity of contamination to control microbial biofilms, bacteria, fungi, and algae which cause fouling in industrial air washer systems and paint spray booths.

INTERMITTENT OR SLUG METHOD

INITIAL DOSE: When the system is noticeably fouled, apply 148 - 883 ppm Kathon WT 1.5% microbicide (1.26 - 7.46 pound or 19 - 113 fluid ounce of Kathon WT 1.5% per 1000 gallon of water in the system.) Repeat until control is achieved.

SUBSEQUENT DOSE: When microbial control is evident, add 35 - 219 ppm Kathon WT 1.5% microbicide (0.3 - 1.86 pound or 4.5 - 28 fluid ounce of Kathon WT 1.5% per 1000 gallon of water) in the system weekly or as needed to maintain control. Badly fouled systems should be cleaned before treatment is begun.

CONTINUOUS FEED METHOD

INITIAL DOSE: When the system is noticeably fouled, apply 148 - 883 ppm Kathon WT 1.5% microbicide (1.26 - 7.46 pound or 19 - 113 fluid ounce of Kathon WT 1.5% per 1000 gallon of water in the system.)

SUBSEQUENT DOSE: Maintain this treatment level by adding a continuous feed of 35 - 219 ppm Kathon WT 1.5% (0.3 - 1.86 pound or 4.5 - 28 fluid ounce of Kathon WT 1.5% per 1000 gallon of makeup water). Badly fouled systems must be cleaned before initial treatment.

NOTE: For use only in systems that maintain effective mist-eliminating components.

OIL FIELD INJECTION WATERS

For the control of microbial biofilm-forming and sulfate-reducing bacteria in oil and gas field water systems, including enhanced recovery injection fluids, drilling, fracturing and completion fluids, slug treat with 67 - 332 ppm Kathon WT 1.5% microbicide depending on the severity of contamination.

INITIAL DOSE: Add 166 - 332 ppm Kathon WT 1.5% (6.9 - 13.9 gallon or 58.0 - 116.8 pound Kathon WT 1.5% per 1000 barrel of water) at a point in the system where it will be uniformly mixed. Repeat treatment after three days or as needed until control is achieved.

SUBSEQUENT DOSE: Add 67-166 ppm Kathon WT 1.5% (2.8 - 6.9 gallon or 23.5 - 58.0 pound Kathon WT 1.5% per 1000 barrel of water) every seven days or as needed to maintain control

RECIRCULATING ELECTRODEPOSITION SYSTEMS

METHOD OF ADDITION

Kathon WT 1.5% microbicide is recommended as a tankside additive for the control of microbial biofilms, bacteria, fungi, and algae in recirculating electrodeposition systems and associated rinse systems. Alternatively, Kathon WT 1.5% microbicide may be added through the components of the electrodeposition paint prior to their addition to the electrodeposition system.

TANKSIDE ADDITION TO ELECTRODEPOSITION SYSTEMS

Kathon WT 1.5% microbicide should be dispensed into the recirculating rinse system, ultrafilter permeate, or final distilled rinse system at a point to ensure uniform mixing.

INITIAL DOSE: When the system is noticeably fouled, add 667-2333 ppm Kathon WT 1.5% microbicide (6.7-23.3 gallon per 10,000 gallon of fluid in the system). This will provide 10-35 ppm of active ingredient. Repeat until control is achieved.

SUBSEQUENT DOSE: When microbial control is evident, add 333-1000 ppm Kathon WT 1.5% microbicide (3.3-10 gallon per 10,000 gallon of fluid in the system). This will provide 5-15 ppm of active ingredient. A change of frequency of treatment may be required depending upon the rate of dilution of the preservative with the makeup fluid, the nature and severity of contamination, level of control required, filtration effectiveness and system design.

TREATMENT OF ELECTRODEPOSITION PAINT COMPONENTS

INITIAL DOSE OF PAINT COMPONENTS

Kathon WT 1.5% microbicide should be added to the resin, pigment, or other component of the electrodeposition paint at a level to ensure that the final use-dilution fluid will contain 333-2333 ppm product (5-35 ppm active ingredient).

SUPPLEMENTAL TANKSIDE DOSING OF ELECTRODEPOSITION SYSTEMS

If additional microbial control is necessary, Kathon WT 1.5% microbicide may be added to the electrodeposition system tankside to supplement microbicide incorporated through paint components.

INITIAL DOSE: If the system becomes noticeably fouled, add 667 - 2333 ppm Kathon WT 1.5% microbicide (6.7 - 23.3 gallon per 10,000 gallon of fluid in the system). This will provide 10 - 35 ppm of active ingredient. Repeat until control is achieved

SUBSEQUENT DOSE: When microbial control is evident, add 333-1000 ppm Kathon WT 1.5% microbicide (3.3-10 gallon per 10,000 gallon of fluid in the system) weekly or as needed. This will provide 5-15 ppm of active ingredient.

NOTE: Regardless of the manner of incorporation, the total active ingredient level in the system should at no time exceed 35 ppm (equivalent to 2333 ppm Kathon WT 1.5% microbicide or 23.3 gallon per 10,000 gallon system fluid).

POLYMER LATEX PRESERVATION

Kathon WT 1.5% microbicide is recommended for the control of bacteria and fungi in the manufacture and storage of synthetic and natural polymer latices including: acrylic, styrene/butadiene, carboxylated styrene/butadiene, ethylene/vinyl acetate, biopolymers intended for industrial use, such as a xanthum gum, gum arabic, guar gum, protein-derived polymers, starches, casein-derived polymers latices; and solution polymers. Add 0.43-3.3 pound of Kathon WT 1.5% (195 gram-1.5 kilogram) to each 1000 pound (453 kilogram) of emulsion to provide 425-3350 ppm product (6.25-50 ppm active isothiazolones).

NOTE: To insure uniform mixing, add Kathon WT 1.5% to latex or solutions slowly with agitation. The actual required concentrations will depend upon such factors as the specific substance to be treated, frequency of repeated microbial contamination expected, and level of production required.

WOOD AND WOOD PRODUCTS

Kathon WT 1.5% microbicide is recommended for the protection of wood and wood products, such as landscape timbers, fences, posts, pilings, cross ties, decks, and similar exterior structures from mold and mildew. Treat southern yellow pine, hemlock, ponderosa pine, and other soft woods with 148 - 1000 ppm Kathon WT 1.5% (1.26 - 8.4 pound or 13 - 128 fluid ounce of Kathon WT 1.5% per 1000 gallon) as an aqueous dip or pressure treatment for mold and mildew control. Thoroughly wet and allow to dry. A single application will afford protection for 12 weeks.

ULTRA FILTRATION UNITS AND NON-MEDICAL/NON-POTABLE REVERSE OSMOSIS SYSTEMS

Kathon WT 1.5% Microbicide is recommended for the control of microbial biofilms, bacteria and fungi in ultra filtration units and non-medical/non-potable reverse osmosis systems. Use of Kathon WT 1.5% microbicide in potable water or dialysis is prohibited. Add 10 - 333 ppm of Kathon WT 1.5% microbicide (0.15 - 5 ppm active ingredient) into industrial ultra filtration or reverse osmosis systems by either continuous feed or periodic injection. Compatibility of Kathon WT 1.5% microbicide with reverse osmosis membranes should be confirmed with membrane manufacturers.

For the control of bacteria and fungi in carbon beds, add 10 - 333 ppm of Kathon WT 1.5% microbicide (0.15 - 5 ppm active ingredient) by either continuous or batch feed.

For periodic membrane cleaning, add 0.4 - 1.0 lb of Kathon WT 1.5% microbicide to every 120 gallon of cleaning solution (6 - 15 ppm active ingredient).

Badly fouled systems should be cleaned before treatment is begun.

INDUSTRIAL WASTEWATER TREATMENT SYSTEMS AND SEWAGE SYSTEMS

Kathon WT 1.5% microbicide is recommended for the control of microbial biofilms, bacteria, fungi, and algae in industrial wastewater treatment and sewage systems. Do not discharge effluent containing this product to sewer systems without previously notifying the local sewage treatment plant authority.

INITIAL DOSE: When the system is noticeably fouled, apply 148 - 883 ppm Kathon WT 1.5% microbicide (1.26 - 7.46 pound or 19 - 113 fluid ounce of Kathon WT 1.5% per 1000 gallon of water in the system.) Repeat until control is achieved. Badly fouled systems should be cleaned before treatment is begun.

SUBSEQUENT DOSE: When microbial control is evident, add 35 - 219 ppm Kathon WT 1.5% microbicide (0.3 - 1.86 pound or 4.5 - 28 fluid ounce of Kathon WT 1.5% per 1000 gallon of water in the system) weekly or as needed to maintain control.

PAPERMILLS

For the control of microbial biofilms, bacteria, algae and fungi, add Kathon WT 1.5% microbicide to the Beater, Hydropulper, or Fan or Broke Storage Pumps or some other point in the system to insure uniform mixing.

Apply 0.44 to 1.5 lb (7 - 23 fluid ounce) of Kathon WT 1.5% microbicide per ton (dry basis) of pulp or paper produced as a slug dose. If needed, repeat daily. Badly fouled systems should be cleaned before initial treatment.

Kathon WT 1.5% Microbicide weighs 8.4 lb/gallon.

