

Maintenance Treatment

After microbial control has been established (or to prevent fouling of a clean system) use the following treatment:

If all of the water in the system is lost by blow-down every 4-7 days, add 0.04 pounds (2/3 ounces av.) to 0.06 pounds (1 ounce av.) of Microbicide 336 CT per 1000 gallons of water in the system (equivalent to about 4 to 6 ppm active ingredient) once a week, or as needed to maintain control. If all of the water in the system is lost by blow-down more rapidly (e.g., every 1-3 days), dose the system as described above two or three times per week or as needed to maintain control. Badly fouled systems should be cleaned before this treatment is begun.

Point of Addition

Microbicide 336 CT should be added to the basin, to the distribution boxes, or at any other point where it will be rapidly and uniformly dispersed throughout the system.

Use of Formulation

If Microbicide 336 CT is incorporated into a formulation, add the formulation to cooling tower systems at the levels (based on Microbicide 336 CT) recommended above for the removal of microorganisms from fouled tower or the maintenance of microbial control.

Nov 13 1972
 UNDER TEST
 FUNGICIDE
 FOR EDUCATIONAL
 ED UTN EX 733-9

KELITE DISINFECTANT CLEANER 100

Cross-infection is of major housekeeping concern not only in hospitals, but in schools, institutions, and industry. KELITE DISINFECTANT CLEANER 100 is formulated for this problem area. It both cleans and disinfects effectively when used as directed. Its hard surface disinfecting action will reduce the hazard of cross-infection.

Two ounces of KELITE DISINFECTANT CLEANER 100 per gallon of water will deodorize bathrooms, garbage storage areas, and other areas where bacterial growth can cause mal odors.

WARNING

Keep out of reach of children. Causes severe eye and skin irritation. Do not get in eyes, on skin, or on clothing. Harmful if swallowed. Avoid contamination of food.

FIRST AID:

In case of contact, immediately flush eyes or skin with plenty of water for at least 15 minutes. For eyes, call a physician. Remove and wash all contaminated clothing before reuse. If swallowed, drink promptly a large quantity of water. Avoid alcohol. Call a physician immediately.

CHEMICALS GROUP



ALLIED-KELITE PRODUCTS DIV.

Chemicals Group Europe, Oberlandstrasse 98, 3700 Spiez, Switzerland
 2400 East Devon Avenue, Des Plaines, Illinois 60018, Telephone (312) 297-1570

SALES-SERVICE OFFICES IN PRINCIPAL CITIES

Plants in Berkeley Heights, N.J./ Detroit, Michigan/ Chicago/ Los Angeles

Cleaner—Disinfectant—Deodorizer—Fungicide
 for Hospital and Institutional Use

AOAC PHENOL COEFFICIENTS

Staph. aureus (ATCC No. 6538)	100
Salmonella typhosa (ATCC No. 6539)	50

ACTIVE INGREDIENTS

Didecyl dimethyl ammonium chloride	4.5 %
Tetrasodium ethylenediamine tetraacetate	2.0 %
Sodium carbonate	1.0 %
Sodium metasilicate, anhydrous	0.5 %
INERT INGREDIENTS	<u>92.0 %</u>
	100.00%

EPA REGISTRATION NO. 733-9

Net Contents:

WARNING

KEEP OUT OF REACH OF CHILDREN.

CAUSES SEVERE EYE AND SKIN IRRITATION.

SEE LEFT PANEL FOR ADDITIONAL PRECAUTIONARY STATEMENTS

USE DIRECTIONS:

Apply KELITE DISINFECTANT CLEANER 100 to hard surfaces such as frames with a cloth or mop. For preliminary cleaning may be required.

For Hospitals & Nursing Homes: Use 2 ounces per gallon of water.

At two ounces per gallon use-level CLEANER 100 is effective against Staphylococcus aureus, Salmonella coli, and pathogenic fungi. Germ the first four organisms has been Use-Dilution Test. Fungicidal per against T. interdigitale by the AOAC

For Schools, Institutional and Industrial use: 1 ounce per gallon of water.

At one ounce per gallon use-level CLEANER 100 delivers excellent performance. It is effective against Staphylococcus choleraesuis, Escherichia coli, and the athlete's foot fungus. The same confirm suitable performance for

Rinse empty container with water.