

Please read instructions on reverse before completing form.

Form Approved OMB No. 2270-0060, Approval expires 07-31-98



United States  
Environmental Protection Agency  
Washington, DC 20460

Registration  
 Amendment  
 Other

OPP Identifier Number  
246707

Application for Pesticide - Section I

1. Company/Product Name 875-140	2. EPA Product Manager	3. Product Classification <input checked="" type="checkbox"/> None <input type="checkbox"/> Restricted
4. Company/Product Name 800-10	PM#	
5. Name and Address of Applicant (Include ZIP Code) Diversey Corp. 12025 Tech Center Drive Livonia, MI 48150-2193 <input type="checkbox"/> Check if this is a new address	6. Expedited Review. In accordance with FIFRA Section 3(c)(3) (b)(i), my product is similar or identical in composition and labeling to: EPA Reg. No. _____ Product Name _____	

Resubmission - Explain Below  
 Re-submission - Agency letter  
 Notification - Explain Below  
 Other - Explain Below

Notification of compliance with FIFRA Section 3(c)(3) (b)(i) attached herewith

**BEST AVAILABLE COPY**

1. Child-Resistant Packaging <input type="checkbox"/> Yes <input type="checkbox"/> No	Unit Packaging <input type="checkbox"/> Yes <input type="checkbox"/> No If "Yes" Unit Packaging wgt. No. per container	Water Soluble Packaging <input type="checkbox"/> Yes <input type="checkbox"/> No If "Yes" Package wgt. No. per container	2. Type of Container <input type="checkbox"/> Metal <input type="checkbox"/> Plastic <input type="checkbox"/> Glass <input type="checkbox"/> Paper <input type="checkbox"/> Other (Specify)
* Certification must be submitted			
3. Location of Net Contents Information <input type="checkbox"/> Label <input type="checkbox"/> Container	4. Size(s) Retail Container	5. Location of Label Directions <input type="checkbox"/> On Label <input type="checkbox"/> On Labeling accompanying product	
6. Manner in Which Label is Affixed to Product <input checked="" type="checkbox"/> Lithograph <input type="checkbox"/> Paper glued <input type="checkbox"/> Stenciled		<input type="checkbox"/> Other	

Section - IV

1. Contact Point (Complete items directly below for identification of individual to be contacted, if necessary, to process this application.)

Name Henry P. Katstra	Title Manager Regulatory Affairs	Telephone No. (Include Area Code) 313-458-2444
--------------------------	-------------------------------------	---

<p><b>Certification</b></p> <p>I certify that the statements I have made on this form and all attachments thereto are true, accurate and complete. I acknowledge that any knowingly false or misleading statement may be punishable by fine or imprisonment or both under applicable law.</p>		6. Date Application Received (Stamped)
2. Signature 	3. Title Manager Regulatory Affairs	
4. Typed Name Henry P. Katstra	5. Date August 20, 1995	



**Precautionary Statements:**

**Hazards to Humans and Domestic Animals.**

**KEEP OUT OF REACH OF CHILDREN.**

**CAUTION:**

harmful if swallowed. Avoid breathing vapors. Avoid contact with skin, eyes, or clothing. Causes eye irritation. Remove contaminated clothing and wash before wearing.

**ENVIRONMENTAL HAZARDS** - This pesticide is toxic to fish. Do not discharge effluent containing this product into lakes, streams, ponds, estuaries, oceans or other waters unless in accordance with the requirements of a National Pollutant Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not discharge effluent containing this product to sewer systems without previously notifying the local sewage treatment plant authority. For additional information, contact your local or State environmental agency.

**STORAGE AND DISPOSAL:**

Do not contaminate water, food, or feed by storage or disposal.

**STORAGE:** Keep container closed when not in use.

**PESTICIDE DISPOSAL:** Containers resulting from the use of this product may be disposed of on-site or at an authorized waste disposal facility.

**METAL CONTAINERS:** This container is made of metal. Therefore, it is not suitable for recycling or reconditioning, or puncture and reuse in a sanitary landfill, or other procedures approved by state and local authorities.


**PLASTIC CONTAINERS** - This container is made of plastic (or equivalent). Therefore, it is not suitable for recycling or reconditioning, or puncture and reuse in a sanitary landfill, or incineration, or, if allowed by state and local authorities, by burning. If burned, stay out of smoke.

**BEST AVAILABLE COPY**



02320487

294  
NPDES Statement Modified to  
PR-93-10 language.



For Industry Use Only

FOR THE CONTROL OF ANY BIOFOULING  
DEVELOPING IN GET MEDICAL TOWER  
OR CHIMNEY TOWER

**ACTIVE INGREDIENT:**

Poly [oxyethylene (dimethyliminio) ethylene  
(dimethyliminio) ethylene dichloride] .....


**INERT INGREDIENTS:** .....

Net Content: 330 Gallons (12.5 L) of active  
8.67% concentration.

U.S. Patent No. 4,171,000

**KEEP OUT OF REACH OF  
CHILDREN.**

**STATEMENT OF PRACTICAL TREATMENT:**  
In case of eye contact, flush immediately with water for  
GET MEDICAL ATTENTION. If skin contact occurs, flush  
with water. If irritation develops, GET MEDICAL ATTENTION.  
If these are not available, drink large quantities of milk, egg white  
or water. If these are not available, drink large quantities of  
CALL A PHYSICIAN IMMEDIATELY.



**Diversey Corp. • Livonia, MI 48150-2111**  
24 HOUR EMERGENCY TELEPHONE • Medical: 303 592 1024 • Transportation: (CHEMTREC) 800 424 9300  
24-HOUR MESSAGE CENTER: 800 438 2647

**Net Contents 330 Gal.**


PMS 354 • 8.5 X 15"



3 7 4

NPDES Statement Modified to PR-93-'0 language.

**BEST AVAILABLE CONTROL**



For Industry Use Only



FOR USE IN CONTROLLING BACTERIAL AND ALGAL GROWTH OCCURRING IN OPEN AND CIRCULATING WATER, COOLING TOWER

**ACTIVE INGREDIENT:**

Poly [oxyethylene (dimethyliminio) ethylene	1.7%
4,4'-methylenebis(2-chlorophenol)	13.3%
<b>INERT INGREDIENT</b>	<b>100.0%</b>

This product contains 0.17% of active ingredient by weight. Net weight 8.67 lb. per gallon. U.S. Patent No. 4,012,019

**KEEP OUT OF REACH OF CHILDREN.**

**CAUTION:**

**STATEMENT OF PRACTICAL TREATMENT:** If eye contact occurs, flush immediately with water for at least 15 minutes and GET MEDICAL ATTENTION. If skin contact occurs, flush area with water. If irritation develops, GET MEDICAL ATTENTION. If swallowed, drink promptly a large quantity of milk, egg whites, gelatin solutions, or, if these are not available, drink large quantities of water. Avoid alcohol. CALL A PHYSICIAN IMMEDIATELY.

**DIRECTIONS FOR**

It is a violation of the...  
APPLICATION:  
1. PRECLEANING - precleaning of heat exchangers. Mechanically remove scale with brushes and high pressure water. Plug plugging equipment for the return line. Flush bucket sludges from...  
COOLING TOWER: intermittent dosing... 4 to 10 mg/l...

...necessary to...  
subsequent GCC-70... ounces per 1000...  
gallons of system...  
badly fouled system...

Diversey Corp. • Livonia MI 48150-2193 • 313 458 5000  
24 HOUR EMERGENCY TELEPHONE • Modicon (Call Collect) 303 592 1024 • Transportation (CREMTREC) 800 424 9300  
24-HOUR MESSAGE CENTER: 800 438 2647 (In Continental U.S.A.)

**Net Contents 330 Gal (1249.1 L)**



EPA Registration No. 87  
EPA Establishment No.:  
875-WI-1 [1] 875-OH-1  
875-TX-3 [3] 875-PA-1  
875-CA-2 [4]  
Bracketed number is the

A(95,507)cp/xt

4 7 4.



**DIRECTIONS FOR USE:**

It is a violation of Federal Law to use this product in a manner inconsistent with its labeling.

**APPLICATIONS:**

**PRECLEANING** - To avoid unnecessary depletion of the GCO-10, precleaning of heavily fouled systems is recommended.

Mechanically remove as much reachable growth as possible with brushes and high pressure hose. Prevent loosened sludge from plugging equipment by placing a screen fence around the opening for the return line. Flush loosened matter out basin drain. Pump or bucket sludges from sumps and hot/cold wells.

**COOLING TOWERS/OPEN RECIRCULATING SYSTEMS -**

Intermittent or stop treatment - After precleaning, turn off bleed for 4 to 12 hours. Do not use any other treatment during period of

50 fluid ounces per 1000 gallons of water. If necessary, use enough GCO-10 necessary to achieve control. When control is evident, open bleed off valve and return to normal treatment. Maintain control with subsequent GCO-10 treatments using GCO-10 at 9 to 90 fluid ounces per 1000 gallons of water. Frequency of treatment depends upon the system and local conditions.

**CONTINUOUS FEED METHOD - Final Dose:** When the system is not fouled, use 9 to 90 fluid ounces of GCO-10 per 1000 gallons of system water. Slowly open bleed off valve by pumping a continuous feed of 9 to 90 fluid ounces of GCO-10 per 1000 gallons of water. Close system and blowdown.

Badly fouled systems must be cleaned before treatment is begun.



**BEST AVAILABLE COPY**

EPA Registration No. 875-140

EPA Establishment No.:

875-WI-1 (1) 875-OH-1 (5)

875-TX-3 (3) 875-PA-1 (8)

875-CA-2 (4)

Bracketed number is the first digit of the batch number.