





DIRECTIONS FOR USE

Hercules® MB 121 controls bacteria, yeasts, fungi, and algae in industrial recirculating water-cooling towers. Badly fouled systems must be cleaned before treatment is begun.

INITIAL DOSE: When the system is noticeably fouled, apply a dose of 6 to 13

fluid oz av of MB 121 per 1,000 gallons of water in the system.

Repeat until control is achieved.

SUBSEQUENT DOSE:

When microbial control is evident, add 4 to 8 fluid az av of MB 121 per 1,000 gallons of water in the system one to three times per week, or as needed to maintain control. The product should be applied to a point in the system where it will be uniformly mixed.

TANGER: Keep out of reach of children.

Cate the period of absorbed through skin. Combustible. Do not get in eyes, on skin, or on clothing. Avoid breathing vapor or mist. Keep container closed. Use with adequate ventilation. Wear rubber gloves and goggles or face shield when handling concentrate. Wash thoroughly after handling. Do not use, pour, spill, or store near heat or open flame.

FIRST AID: In case of contact, immediately wash eyes with plenty of water

for at least 15 minutes; call a physician.

CAUTION: This product is toxic to fish and wildlife. Treated effluent should

not be discharged where it will drain into lakes, streams, ponds,

or public water.

DRUM

Do not reuse empty drum. Return to drum reconditioner or

DISPOSAL: destroy by perforating or crushing and burying in a safe place.