



OFFICE OF CHEMICAL SAFETY AND POLLUTION PREVENTION

WASHINGTON, D.C. 20460

October 9, 2024

Joanna Holcombe
Senior Product Regulatory Specialist
Innovative Water Care, LLC
Solenis
Electronic Transmittal: jholcombe@solenis.com

Subject: Notification per PRN 98-10 – To remove redundant statement, correct typos,
and add optional marketing content
Product Name : HTH DRY CHLORINATOR GRANULAR FOR SWIMMING POOLS
EPA Registration Number: 1258-1069
Received Date: 08/16/2024
Action Case Number: 00626285

Dear Joanna Holcombe:

The Agency is in receipt of your Application for Pesticide Notification under Pesticide Registration Notice (PRN) 98-10 for the above referenced product. The Antimicrobials Division (AD) has conducted a review of this request for its applicability under PRN 98-10 and finds that the action requested falls within the scope of PRN 98-10.

The label submitted with the application has been stamped "Notification" and will be placed in our records.

Should you wish to add/retain a reference to the company's website on your label, then please be aware that the website becomes labeling under the Federal Insecticide Fungicide and Rodenticide Act and is subject to review by the Agency. If the website is false or misleading, the product would be misbranded and unlawful to sell or distribute under FIFRA section 12(a)(1)(E). 40 CFR 156.10(a)(5) lists examples of statements EPA may consider false or misleading. In addition, regardless of whether a website is referenced on your product's label, claims made on the website may not substantially differ from those claims approved through the registration process. Therefore, should the Agency find or if it is brought to our attention that a website contains false or misleading statements or claims substantially differing from the EPA approved registration, the website will be referred to the EPA's Office of Enforcement and Assurance.

If you have any questions, please contact Casscius Colbert by email at colbert.casscius@epa.gov.

Sincerely,

Casscius Colbert, Risk Manager (31)

For:

Demson Fuller, Product Manager (32)
Regulatory Management Branch I
Antimicrobials Division (7510M)
Office of Pesticide Programs

Note to reviewer:

[Items in brackets [AAA] are optional and may/may not be included on final label]

{Items in braces {AAA} are for information purposes and will not appear on final label}

HTH® DRY CHLORINATOR GRANULAR FOR SWIMMING POOLS

Active Ingredient:

Calcium Hypochlorite 68%

Other Ingredients: 32%

Total: 100%

[Minimum Available Chlorine 65%]

KEEP OUT OF REACH OF CHILDREN

[MANTENGASE FUERA DEL ALCANCE DE LOS NIÑOS]

DANGER [PELIGRO]

Contamination or improper use may cause fire, explosion or the release of toxic gases. Do not allow product to contact any foreign matter, including other water treatment products. If product is exposed to small amounts of water, it can react violently to produce heat and toxic gases and spatter. Do not add water to this product. Add only into water. {The following optional statement is for use on residential use swimming pool and spa products} [Do not mix this product with a small amount of water. Only add directly to your [pool] {or} [spa.] Highly Corrosive. Causes skin and eye damage. May be fatal if swallowed.

~~Read all precautionary statements on label and first aid statements before use.~~

{Note to reviewer: Although this product has a "Danger" signal word, as per the EPA label review manual "The Agency may permit reasonable variations in the placement of the First Aid statement as long as the reference statement, "See First Aid (or Statement of Practical Treatment) on (identify appropriate panel)" appears on the front panel." If the First Aid Statements are placed on the front panel of the final graphic label, the statement below will not be used-}

See [left]-[right]-[back]-[side] panel for Precautionary and First Aid Statements

Sold by:

Innovative Water Care, LLC

2475 PINNACLE DR.

WILMINGTON, DE 19803

EPA Reg. No. 1258-1069

EPA EST. NO. _____ [Superscript used in Lot Number]

Net Wt. _____

NOTIFICATION

Reg. No. 1258-1069

The applicant has certified that no changes, other than those reported to the Agency have been made to the labeling. The Agency acknowledges this notification by letter dated:

10/09/2024

HTH® Dry Chlorinator Granular for Swimming Pools

EPA Reg. No.: 1258-1069

EPA Draft Label 2024-08-16

Page 1 of 26

4-17-13 Note: The word "Superchlorination" added to Opening Your Pool and Algae Control Directions on p. 6 as a non-notification)

5-14-13 Note: The word "length" incorrectly repeated in the "To Determine Your Pool Capacity" chart for oval. It was corrected to "width" via non-notification to match previously approved labels.

PRECAUTIONARY STATEMENTS

HAZARDS TO HUMANS AND DOMESTIC ANIMALS

DANGER: Highly corrosive. Causes skin and eye damage. May be fatal if swallowed. Irritating to nose and throat.

- Open in a well-ventilated area. Avoid breathing dust and fumes.
- Do not get in eyes, on skin, or on clothing. Do not handle with bare hands. Wear goggles and use rubber gloves. For additional skin protection, wear long sleeves and long pants.
- Remove and wash contaminated clothing before reuse.
- Wash thoroughly with soap and water after handling.
- Only use utensils that are thoroughly clean and dry.

FIRST AID:

IF IN EYES: Hold eye open and rinse slowly and gently with water for 15-20 minutes. Remove contact lenses, if present, after the first 5 minutes, then continue rinsing eye. Call a poison control center or doctor for treatment advice.

IF ON SKIN OR CLOTHING: Take off contaminated clothing. Rinse skin immediately with plenty of water for 15-20 minutes. Call a poison control center or doctor for treatment advice.

IF SWALLOWED: Call a poison control center or doctor immediately for treatment advice. Have person sip a glass of water if able to swallow. Do not induce vomiting unless told to do so by a poison control center or doctor. Do not give anything by mouth to an unconscious person.

IF INHALED: Move person to fresh air. If person is not breathing, call 911 or an ambulance, then give artificial respiration, preferably mouth-to-mouth if possible. Call a poison control center or doctor for further treatment advice. Have the product container or label with you when calling a poison control center or doctor, or going for treatment.

NOTE TO PHYSICIAN: Probable mucosal damage may contraindicate the use of gastric lavage.

IN CASE OF EMERGENCY CALL: 1-800-654-6911

PHYSICAL AND CHEMICAL HAZARDS:

If product is exposed to small amounts of water, it can react violently to produce heat and toxic gases and spatter. Do not add water to this product. Add only into water.

- [Do not mix this product with a small amount of water. Only add this product directly to your pool or spa.] *{This statement will appear on Pool and Spa use labels only.}*
- Do not allow to become wet or damp before use.

Can react with other materials, including other water treatment products, to cause intense fire, explosion, and the release of toxic gases.

- Keep all foreign matter, including other water treatment products, away from this product.
- Do not allow this product to contact other water treatment products. *{Note to reviewer: The following statement is optional for products labeled for skimmer use}* [If used with a skimmer, make sure skimmer is completely clean and free of residue from other water treatment products before putting this product in a skimmer.]

Exposure to heat can cause this product to rapidly decompose, leading to intense fire, explosion, and the release of toxic gases.

- Store in a cool, dry, well-ventilated area.

Strong oxidizing agent. This product can increase fire intensity. Keep away from heat and from flame and burning material (like a lighted cigarette).

{Environmental hazards statement for end-use products in containers less than 5 gallons (liquid) or less than 50 pounds (solid, dry weight) use only the first sentence. All others use full paragraph.}

ENVIRONMENTAL HAZARDS: This pesticide is toxic to fish and aquatic organisms. Do not discharge effluent containing this product into lakes, ponds, streams, estuaries, oceans or public waters unless in accordance with the requirements of a National Pollutant Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not discharge effluent containing this product to sewer systems without previously notifying the local sewage treatment plant authority. For guidance contact your State Water Board or Regional Office of the EPA.

~~{OPTIONAL MARKETING CLAIMS}~~

~~{Kills bacteria}, {Controls algae}, {Destroys organic contaminants}
{Eliminates bacteria}
{Destroys bacteria}
{Controls algae, kills bacteria and destroys organic contaminants in {pools} {spas & hot tubs}}
{Dry, free-flowing form}
{Concentrated chlorinating agent}
{68% available chlorine}
{Fast-acting}
{Quick-dissolving}
{Sanitizes pool water}
{Swimming pool sanitizer}
{Chlorinating granules for multipurpose uses}
{Chlorinating granules for multiple {swimming} pool {and spa} uses}
{Will not cause over stabilization}
{Contains no cyanuric acid}
{Good for all pool surfaces}~~

~~{Step 1: Balance}
{Step 2: Sanitize}
{Step 3: Shock}
{Step 4: Prevent Algae}~~

~~{[HTH] [POOLIFE] [Brand Name] HELPLINE
[866 HTH POOL] [866 4 POOL FUN]
[Toll Free}~~

~~Call 7 days a week with your questions concerning pool water care. 8:00 a.m. 10:00 p.m. Eastern Time}~~

~~{For questions concerning pool water care, call the Pool Breeze® Helpline at 1-888-433-3020. Customer Care Specialists are available 7 days a week from 8:00 A.M. 10:00 P.M. E[S]T.}~~

~~{HTH®}, {Seek It®}, {Super Seek It®} and {pH Plus®} [Pulsar®], [DryTee®], [ConstantChlor®], [CCH®] (brand name) are registered trademarks of Arch Chemicals, Inc.}~~

~~{The [poolife] [brand] logo is a trademark of Arch Chemicals, Inc.}~~





[Visit [US] [www.\[brand\].com](http://www.[brand].com)]

[Visit [US] [www.\[brand\].mag.com](http://www.[brand].mag.com)]

[Visit (brand) [www.\[brand\].com](http://www.[brand].com)]

HTH® Dry Chlorinator Granular for Swimming Pools

EPA Reg. No.: 1258-1069

EPA Draft Label 2024-08-16

Page 4 of 26

4-17-13 Note: The word "Superchlorination" added to Opening Your Pool and Algae Control Directions on p. 6 as a non-notification)

5-14-13 Note: The word "length" incorrectly repeated in the "To Determine Your Pool Capacity" chart for oval. It was corrected to "width" via non-notification to match previously approved labels.

{If the following Spanish statement is used, it must appear directly above DIRECTIONS FOR USE.}

Si usted no entiende la etiqueta, busque a alguien para que se la explique a usted en detalle. (If you do not understand the label, find someone to explain it to you in detail.)

DIRECTIONS FOR USE: It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

READ ALL PRECAUTIONARY STATEMENTS BEFORE USE.

{For commercial pool, municipal, and industrial labels} [This product is a concentrated chlorinating agent in a dry, free-flowing form which controls the growth of algae, kills bacteria, and destroys organic contaminants in pools, spas and hot tubs.]

{Use 1(a)-Pools}

[WHY YOU SHOULD USE THIS PRODUCT: This is a highly effective, multi-purpose product that [sanitizes], [clarifies], [helps] prevent[s] algae and [shock treats your pool]. It is convenient, easy to use, and won't over-stabilize your pool. [For [crystal] [clear] [clean] pool water, follow our 4 step pool care program: Step 1: Test and adjust pool water balance, Step 2: Chlorinate and clarify, Step 3: Shock treat your pool at least once a week, and Step 4: Add algaecide regularly [where needed]. [For best results, follow a weekly program with [brand] System. Consult your authorized [brand] dealer for advice on the system that best suits your pool and your lifestyle.] [Take a pool water sample to your authorized [brand] dealer regularly for a detailed water analysis.]

{Small pools (500 gallons to less than 10,000 gallons) and pools 10,000 gallons and above}

HOW TO USE: [Do not pre-mix this product before adding it to your pool. Only add this product directly to your pool or skimmer.] *{When contents are in a resealable container}* [Use only a clean, dry [scoop] [lid] to measure this product]. [Do not use the [scoop] [lid] for any other purpose.] *{When contents are in a single use bag for use as a shock for pools 10,000 gallons or larger}*

[Use entire contents of bag when opened]. If any granules settle to the bottom of the pool use brush to disperse.

[Method for dosing directly into pool:]

Add the recommended dosage of this product during evening hours while the filter pump is running. When adding this product to your pool, broadcast the product evenly over a wide area in the deepest part of the pool. If any granules settle to the bottom of the pool use brush to disperse.

[Method for skimmer addition:

[Use this method to avoid bleaching vinyl liner or paint.] Make sure that filter pump is on and properly recirculating through skimmer. Empty skimmer of all chemicals and/or debris. Contamination may cause an explosion or the release of toxic gases. Do not use this method when an automatic chemical dispensing device (e.g., feeder) is present. Pour this product slowly into skimmer, making sure that the material is drawn into the system at the same rate: do not allow this material to accumulate as toxic gases may be generated.]

WATER BALANCE: For best product performance, swimmer comfort, and [crystal] [clear] [clean] water: Maintain pH in the range of 7.2 to 7.6. Maintain total alkalinity in the range of 60 to 120 *{retail brands only}*. *{Commercial brands for very large commercial or municipal pools will use [60 to 100]}* parts per million (ppm). Maintain calcium hardness above 200 ppm. Use a reliable test kit that measures all these ranges. Use [brand] Pool Care Products to make adjustments. Follow label directions for each product.

Do not enter pool until the free available chlorine residual is 1- 4 ppm for each of the below noted water treatment applications. *{For Industrial/Municipal pool labels: [Reenter pool when residual is 1-4 ppm]}*

OPENING YOUR POOL: For best results, see the “WATER BALANCE” section [above] before treatment. Always adjust and maintain pH in the 7.2 to 7.6 range. Follow “SHOCK TREATMENT / **SUPERCHLORINATION**” directions on this package. Allow 30 minutes for product to disperse. Test free available chlorine residual with a pool test kit. Repeat treatment as needed.

[ROUTINE CHLORINATION: For best results, see “WATER BALANCE” section [above] before treatment. Throughout the pool season, adjust and maintain pH at 7.2–7.6. Check available chlorine with a suitable test kit.]

{For small pools 500 gallons to less than 10,000 gallons}

[Each 0.1-0.4 ounces of this product will provide approximately 1-4 ppm available chlorine in 500 gallons of water. Maintain these conditions for proper operation by frequent testing with a test kit. Follow “HOW TO USE” directions on this package.]

{For pools 10,000 gallons and larger}

[FOR UNSTABILIZED POOLS: Add 6-8 ounces of this product per 10,000 gallons of pool water daily or as often as needed to maintain the free available chlorine residual at 1 – 4 ppm. Follow “HOW TO USE” directions on this package.

FOR POOLS STABILIZED USING [brand] STABILIZER AND CONDITIONER: Add 3–4 ounces per 10,000 gallons every other day or as often as needed to maintain the free available chlorine residual at 1-4 ppm. Follow “HOW TO USE” directions on this package.]

{For pools 10,000 gallons and larger}

[SHOCK TREATMENT / SUPERCHLORINATION: For best results, see “WATER BALANCE” and “HOW TO USE” sections [above] before treatment. Every 7 days, or as necessary to prevent pool problems, shock treat / superchlorinate the pool by adding 10-20 ounces [one bag {for 16 oz containers}] of this product per 10,000 gallons of water to provide 5 to 10 ppm available chlorine. Additional shock treatments may be required to correct problems which are caused by visible algae, high bathing loads, heavy wind and rainstorms. Additional shock treatments may also be required to correct problems such as unpleasant odors and eye irritation. Check the available chlorine with a suitable test kit.]

{For pools 10,000 gallons and larger}

[ALGAE CONTROL: Follow “SHOCK TREATMENT / **SUPERCHLORINATION**” directions on this label. Add this product as close as possible to any algae on the sides or bottom of the pool. If necessary, repeat the treatment. To prevent possible staining or bleaching, take the following steps immediately after treatment: Thoroughly clean pool by brushing surface of algae growth, vacuum and cycle through filter.]

[For preventative algae control: Shock treatment should control algae. However, if problems persist use your preferred [brand] [spa] algaecide product regularly. Follow label directions on [the algaecide] {or} [that product.]

{Labels of resealable containers used to treat pools 10,000 gallons and larger}

[WINTERIZING: For best results, see “WATER BALANCE” section [above] before treatment. Gradually add 30 ounces of this product per 10,000 gallons of pool water that is clear and clean. This provides 15 ppm free available chlorine. Follow “HOW TO USE” directions on this package. Run the filter pump until granules are completely dissolved. Cover the pool with a pool cover. Prepare the heater, pump and filter components for winterizing by following manufacturer's directions.]

[TO DETERMINE YOUR POOL CAPACITY IN U.S. GALLONS, USE THE APPROPRIATE FORMULA BELOW:
POOL SHAPE FORMULA (Use measurements in feet only)

Shape of Pool	Gal. Water (Dimensions in Feet)
Rectangular	Length x Width x Avg. Depth x 7.5
Round	Diameter x Diameter x Avg. Depth x 5.9
Oval	Max. Length x Max. Width x Avg. Depth x 5.9
Free Form	Surface Area (Sq. Feet) x Avg. Depth x 7.5

HTH® Dry Chlorinator Granular for Swimming Pools

EPA Reg. No.: 1258-1069

EPA Draft Label 2024-08-16

Page 6 of 26

4-17-13 Note: The word “Superchlorination” added to Opening Your Pool and Algae Control Directions on p. 6 as a non-notification)

5-14-13 Note: The word “length” incorrectly repeated in the “To Determine Your Pool Capacity” chart for oval. It was corrected to “width” via non-notification to match previously approved labels.

{Use 1(b) - Pools} {Mass Brands for Puerto Rico}

[WHY YOU SHOULD USE THIS PRODUCT: This is a highly effective, multi-purpose product that [sanitizes], [clarifies], [helps] prevent[s] algae and [shock treats your pool]. It is convenient, easy to use, and won't overstabilize your pool. [For crystal clean pool water, [the makers of [brand] recommend] {or} [follow] the following 4 step pool care program: Step 1: Test and balance water, Step 2: Sanitize, Step 3. Shock at least once a week, and Step 4: Add algaecide as directed.]

[For best results, follow a weekly program with our [brand] System Consult your authorized [brand] dealer for advice on the system that best suits your pool and your lifestyle.] [Take a pool water sample to your authorized [brand] dealer regularly for a detailed water analysis.] [Additional shocking to keep water clean and clear is recommended after rain and heavy winds; high number of swimmers; increased water temperature, and/or increased frequency of pool usage.]

{For commercial pool, municipal, and industrial labels}

[This product is a concentrated chlorinating agent in a dry free-flowing form that controls the growth of algae, kills bacteria, and destroys organic contaminants in pools, spas and hot tubs.]

{Small pools (500 gallons to less than 10,000 gallons) and pools 10,000 gallons and above}

How To Use: [Do not pre-mix this product before adding it to your pool]. [Only add this product directly to your pool or skimmer.] {When contents are in a resealable container} [Use only a clean, dry [scoop] lid to measure this product.] [Do not use the [scoop] [lid] for any other purpose.] {When contents are in a single use bag for use as a shock for pools 10,000 gallons or larger} [Use entire contents when opened.]

[Method for dosing directly into pool:]

Add the recommended dosage of this product during evening hours while the filter pump is running. When adding this product to your pool, broadcast the product evenly over a wide area in the deepest part of the pool. If any granules settle to the bottom of the pool, use brush to disperse.

[Method for skimmer addition:

[Use this method to avoid bleaching vinyl liner or paint.] Make sure that filter pump is on and properly recirculating through skimmer. Empty skimmer of all chemicals and/or debris. Contamination may cause an explosion or the release of toxic gases. Do not use this method when an automatic chemical dispensing device (e.g. feeder) is present. Pour this product slowly into skimmer, making sure that the material is drawn into the system at the same rate. Do not allow this material to accumulate as toxic gases may be generated.]

[Water Balance: For best product performance, swimmer comfort, and crystal clear water: Maintain pH in the range of 7.2 to 7.6. [Allow the pH adjusters to dissolve and disperse before adding this product to the pool.] Maintain total alkalinity in the range of 60 to 120 (retail brands only) *{Commercial brands for very large commercial municipal pools will use 160 to 100}* parts per million (ppm). Maintain calcium hardness above 200 ppm. [Maintain available chlorine level at 1-4 ppm.] Use a reliable test kit that measures all these ranges. Use [brand] Pool Care Products to make adjustments. Follow label directions for each product. Do not enter pool until the free available chlorine residual is 1-4 ppm for each of the below noted water treatment applications. Re-entry into treated pools is prohibited above levels of 4 ppm for risk of bodily injury. *{For Industrial / Municipal pool labels}* [Reenter pool when residual is 1-4 ppm].

[Water Balance For best product performance, swimmer comfort, and crystal clear water, use [brand] pool care products to maintain the following water balance:

	Acceptable Range for Balance
pH	7.2 – 7.6
Total Alkalinity	60 – 120 ppm
Calcium Hardness	Above 200 ppm
Available Chlorine	1 – 4 ppm

Follow label directions for each product and allow each product to dissolve and disperse before adding additional products to the pool. Use a reliable test kit that measures all these ranges.

HTH® Dry Chlorinator Granular for Swimming Pools

EPA Reg. No.: 1258-1069

EPA Draft Label 2024-08-16

Page 7 of 26

4-17-13 Note: The word "Superchlorination" added to Opening Your Pool and Algae Control Directions on p. 6 as a non-notification)

5-14-13 Note: The word "length" incorrectly repeated in the "To Determine Your Pool Capacity" chart for oval. It was corrected to "width" via non-notification to match previously approved labels.

OPENING YOUR POOL: For best results, see the "WATER BALANCE" section [above] before treatment. [Always] test and] adjust and maintain pH in the 7.2 to 7.6 range. Allow the pH adjusters to dissolve and disperse before adding this product to the pool.] *{The following statement added to protect consumers against vinyl liner bleaching due to low pH and chlorination}* 1. Follow "[POOL] SHOCK TREATMENT" directions on this package. 2. Allow 30 minutes for product to disperse. 3. Test free available chlorine residual with a pool test kit. 4. Repeat dosage, as needed, until the free available chlorine residual is 1-4 ppm. [For best results during the season, follow the [brand] 4 Step Program. Re-entry into treated pools is prohibited above levels of 4 ppm for risk of bodily injury. [Test free available chlorine residual with a pool test kit. Repeat treatment as needed.]

[Note: For all dosages, please refer to the tables to find your exact dosage for your pool or body of water that needs treatment.]

[ROUTINE CHLORINATION: For best results, see Water Balance section [above] before treatment. Throughout the pool season, adjust and maintain pH at 7.2 - 7.6. Check available chlorine with a suitable test kit. *{The following statement added to protect consumers against vinyl liner bleaching due to low pH and chlorination}* Allow the pH adjusters to dissolve and disperse before adding this product to the pool. *{For small pools 500 gallons to less than 10,000 gallons}* [Each 0.1-0.4 ounces of this product will provide approximately 1-4 ppm available chlorine in 500 gallons of water. Maintain these conditions for proper operation by frequent testing with a test kit. Follow "HOW TO USE" directions on this package.]

[Follow HOW TO USE directions to maintain [a 500-10,000 gallon] pool]

Desired Chlorine Residual	Dosage For Stabilized Pool	Dosage For Un-stabilized Pool
1 – 4 ppm	0.3 – 0.4 ounces per 1,000 gallons	0.6 – 0.8 ounces per 1,000 gallons

{For pools 10,000 gallons and larger}

As a preventative treatment, you should shock treat your pool once a week to prevent pool problems. In addition to weekly shock treatment, you should shock treat to remedy problems which occur when bather loads are high, water appears hazy or dull, unpleasant odors or eye irritation occurs, after heavy wind and rainstorms, or if algae does develop with resulting green color and slimy feeling walls.

[POOL] SHOCK TREATMENT: Add the recommended dosages of this product while the filter pump is running. Adjust and maintain pH to 7.2 to 7.6 with [brand] pH Plus or [brand] pH Minus. Follow label directions. Allow the pH adjusters to dissolve and disperse before adding this product to the pool. When adding this product to your pool, broadcast this product evenly over a wide area of the deepest part of the pool.

DOSAGE RATE:

{For pools 10,000 gallons and larger}

[POOL] SHOCK TREATMENT / SUPER CHLORINATION: For best results, see "WATER BALANCE" and "HOW TO USE" section [above] before treatment. Every 7 days, or as necessary to prevent pool problems, shock treat / super chlorinate the pool by adding 10 to 20 ounces of this product per 10,000 gallons of water to yield 5 to 10 ppm available chlorine by weight. Re-entry into treated pools is prohibited above levels of 4 ppm for risk of bodily injury.

[Additional shock treatments may be required to correct problems which are caused by visible algae, high bathing loads, heavy wind and rainstorms. Additional shock treatments may also be required to correct problems such as unpleasant odors and eye irritation. Check the available chlorine with a suitable test kit. Do not reenter the pool until the chlorine residual is 1 to 4 ppm.] Re-entry into treated pools is prohibited above levels of 4 ppm for risk of bodily injury.

{For pools 10,000 gallons and larger}

[ALGAE CONTROL: 1. Follow "SHOCK TREATMENT" directions on this label. 2. Add this product as close as possible to any algae on the sides or bottom of the pool. 3. Do not enter pool until the free available chlorine residual is 14 ppm.

HTH® Dry Chlorinator Granular for Swimming Pools

EPA Reg. No.: 1258-1069

EPA Draft Label 2024-08-16

Page 8 of 26

4-17-13 Note: The word "Superchlorination" added to Opening Your Pool and Algae Control Directions on p. 6 as a non-notification)

5-14-13 Note: The word "length" incorrectly repeated in the "To Determine Your Pool Capacity" chart for oval. It was corrected to "width" via non-notification to match previously approved labels.

[Reentry into treated pools is prohibited above levels of 4 ppm for risk of bodily injury.] 4. If necessary, repeat the treatment. 5. To prevent possible staining or bleaching, take the following steps immediately after treatment: Thoroughly clean pool by brushing surface of algae growth, vacuum and cycle through filter. For preventative algae control, use your preferred [brand] algaecide product regularly [However, if problems persist use your preferred [brand] [spa] algaecide product regularly. Follow label directions an [the algaecide] {or} [that product.]]

{Labels of resealable containers (2 lbs. or more) used to treat pools 10 000 gallons and larger}

[WINTERIZING: For best results, see "WATER BALANCE" section [above] before treatment. While the water is still clear and clean, prepare for long periods of disuse by gradually 42 ounces of this product per 10,000 gallons of pool water that is clear and clean. This provides 15 ppm free available chlorine. Follow "HOW TO USE" directions on this package. Run the filter pump until granules are completely dissolved. Cover the pool with a [plastic] pool cover. Prepare the heater pump and filter components for winterizing by following manufacturer's directions.]

[TO DETERMINE YOUR POOL CAPACITY IN U.S. GALLONS, USE THE APPROPRIATE FORMULA BELOW:
POOL SHAPE FORMULA (Use measurements in feet only)]

Shape of Pool	Gal. Water (Dimensions in Feet)
Rectangular	Length x Width x Avg. Depth x 7.5
Round	Diameter x Diameter x Avg. Depth x 5.9
Oval	Max. Length x Max. Length x Avg. Depth x 5.9
Free Form	Surface Area (Sq. Feet) x Avg. Depth x 7.5

{Use 2-Spas}

[Spa & Hot Tubs][How To Use: For best results, see "WATER BALANCE" section [below] before treatment. Maintain these conditions for proper operation by frequent testing with a test kit. Do not allow cyanuric acid level to exceed 100 ppm. It is recommended that spas and hot tubs be drained every 30-90 days, more often under heavy use. Consult manufacturer's recommendations concerning the compatibility of chlorine sanitizers with their equipment. Some oils, lotions, fragrances, cleansers, etc., may cause foaming or cloudy water and may react with chlorine sanitizers to reduce their efficacy. If circulation is low, stir water after addition of chlorine or other chemicals.

[Water Balance: For best product performance, comfort, and [crystal] [clear] [clean] water: Maintain pH in the range of 7.2 to 7.6. Maintain total alkalinity in the range of 60 to 120 parts per million (ppm). Maintain calcium hardness above 200 ppm. Use a reliable test kit that measures all these ranges. Use [brand] Spa Care Products to make adjustments. Follow label directions for each product.

Do not enter spa or hot tub until the free available chlorine residual is less than 5 ppm for the below noted spa applications.

[Opening Your Spa] Startup (Freshly Filled): For best results, see "WATER BALANCE" section [above] before treatment. Turn on circulation system and ensure that it is operating properly. Add one (1) ounce of this product to provide approximately 10 ppm available chlorine for each 500 gallons of water. Check the free available chlorine (FAC) and if less than 4-5 ppm, repeat as needed.

[Routine Chlorination For] Regular Use: For best results, see "WATER BALANCE" section [above] before treatment. Turn on circulation system and ensure that it is operating properly. Scatter 0.3-0.5 ounces of this product per 500 gallons over the surface of the water. Test for free available chlorine and add additional product if necessary to maintain 3-5 ppm FAC while unit is in use.

Shock Treatment: After each use, shock treat with one (1) ounce of this product to provide approximately 10 ppm available chlorine per 500 gallons of water, to control odors and algae. Repeat as needed.

[For preventative algae control: Shock treatment should control algae. However, if problems persist use your preferred [brand] [spa] algaecide product regularly. Follow label directions on that product.]

HTH® Dry Chlorinator Granular for Swimming Pools

EPA Reg. No.: 1258-1069

EPA Draft Label 2024-08-16

Page 9 of 26

4-17-13 Note: The word "Superchlorination" added to Opening Your Pool and Algae Control Directions on p. 6 as a non-notification)

5-14-13 Note: The word "length" incorrectly repeated in the "To Determine Your Pool Capacity" chart for oval. It was corrected to "width" via non-notification to match previously approved labels.

Extended Non-use Period: For best results, see "WATER BALANCE" section [above] before treatment. During extended non-use periods when the unit is not being used add 1.1 ounces of this product per 500 gallons twice a week with the circulation system running or as needed to maintain 3-5 ppm free available chlorine.]

{Use 3}

[HUBBARD AND IMMERSION TANKS - Add 0.5 oz. of this product per 100 gallons of water before patient use to obtain a chlorine residual of 25 ppm, as determined by a suitable test kit. Adjust and maintain the water pH to between 7.2 and 7.6. After each use drain the tank. Add 0.5 oz. to a bucket of water and circulate this solution through the agitator of the tank for 15 minutes and then rinse out the solution. Clean tank thoroughly and dry with clean cloths.]

[HYDROTHERAPY TANKS – Add 1 oz. of this product per 1,000 gallons of water to obtain a minimum chlorine residual of 1 ppm, as determined by a suitable chlorine test kit, after satisfying any chlorine demand. Tank should not be entered until the chlorine residual is below 3 ppm. Adjust and maintain the water pH to between 7.2 and 7.6. Operate pool filter pump continuously. Drain pool weekly, and clean before refilling.]

{Use 4} [SANITIZATION OF NONPOROUS FOOD CONTACT SURFACES:

RINSE METHOD - A solution of 100 ppm available chlorine may be used in the sanitizing solution if a chlorine test kit is available. Solutions containing an initial concentration of 100 ppm available chlorine must be tested and adjusted periodically to insure that the available chlorine does not drop below 50 ppm. Prepare a 100 ppm sanitizing solution by thoroughly mixing 1 oz. of this product with 40 gallons of water. If no test kit is available, prepare a sanitizing solution by thoroughly mixing 1 oz. of this product with 20 gallons of water to provide approximately 200 ppm available chlorine by weight.

Clean equipment surfaces in the normal manner. Prior to use, rinse all surfaces thoroughly with the sanitizing solution, maintaining contact with the sanitizer for at least 2 minutes. If solution contains less than 50 ppm available chlorine, as determined by a suitable test kit, either discard the solution or add sufficient product to re-establish a 200 ppm residual. Do not rinse equipment with water after treatment and do not soak equipment overnight. Sanitizers used in automated systems may be used for general cleaning but may not be reused for sanitizing purposes.

IMMERSION METHOD - A solution of 100 ppm available chlorine may be used in the sanitizing solution if a chlorine test kit is available. Solutions containing an initial concentration of 100 ppm available chlorine must be tested and adjusted periodically to insure that the available chlorine does not drop below 50 ppm. Prepare a 100 ppm sanitizing solution by thoroughly mixing 1 oz. of this product with 40 gallons of water. If no test kit is available, prepare a sanitizing solution by thoroughly mixing 1 oz. of this product with 20 gallons of water to provide approximately 200 ppm available chlorine by weight.

Clean equipment in the normal manner. Prior to use, immerse equipment in the sanitizing solution for at least 2 minutes and allow the sanitizer to drain. If solution contains less than 50 ppm available chlorine, as determined by a suitable test kit, either discard the solution or add sufficient product to re-establish a 200 ppm residual. Do not rinse equipment with water after treatment.

Sanitizers used in automated systems may be used for general cleaning but may not be reused for sanitizing purposes.

FLOW/PRESSURE METHOD - Disassemble equipment and thoroughly clean after use. Assemble equipment in operating position prior to use. Prepare a volume of a 200 ppm available chlorine sanitizing solution equal to 110 % of volume capacity of the equipment by mixing the product in a ratio of 1 oz. product with 20 gallons of water. Pump solution through the system until full flow is obtained at all extremities, the system is completely filled with the sanitizer and all air is removed from the system. Close drain valves and hold under pressure for at least 2 minutes to insure contact with all internal surfaces. Remove some cleaning solution from drain valve and test with a chlorine test kit. Repeat entire cleaning/sanitizing process if effluent contains less than 50 ppm available chlorine.

CLEAN-IN-PLACE METHOD - Thoroughly clean equipment after use. Prepare a volume of a 200 ppm available chlorine sanitizing solution equal to 110 % of volume capacity of the equipment by mixing the product in a ratio of 1 oz.

HTH® Dry Chlorinator Granular for Swimming Pools

EPA Reg. No.: 1258-1069

EPA Draft Label 2024-08-16

Page 10 of 26

4-17-13 Note: The word "Superchlorination" added to Opening Your Pool and Algae Control Directions on p. 6 as a non-notification)

5-14-13 Note: The word "length" incorrectly repeated in the "To Determine Your Pool Capacity" chart for oval. It was corrected to "width" via non-notification to match previously approved labels.

product with 20 gallons of water. Pump solution through the system until full flow is obtained at all extremities, the system is completely filled with the sanitizer and all air is removed from the system. Close drain valves and hold under pressure for at least 10 minutes to insure contact with all internal surfaces. Remove some cleaning solution from drain valve and test with a chlorine test kit. Repeat entire cleaning/ sanitizing process if effluent contains less than 50 ppm available chlorine.

[{Added:} COARSE] SPRAY METHOD - Preclean all surfaces after use. Use a 200 ppm available chlorine solution to control bacteria, mold or fungi and a 600 ppm solution to control bacteriophage. Prepare a 200 ppm sanitizing solution of sufficient size by thoroughly mixing the product in a ratio of 1 oz. product with 20 gallons of water. Prepare a 600 ppm solution by thoroughly mixing the product in a ratio of 3 oz. product with 20 gallons of water. Use spray equipment which can resist hypochlorite solutions. Always empty and rinse spray equipment with potable water after use. Thoroughly spray all surfaces until wet, allowing excess sanitizer to drain. Vacate area for at least 2 hours. Prior to using equipment, rinse all surfaces treated with a 600 ppm solution with a 200 ppm solution.]

{Use 5} [SANITIZATION OF POROUS FOOD CONTACT SURFACES:

RINSE METHOD - Prepare a 600 ppm solution by thoroughly mixing 3 oz. of this product with 20 gallons of water. Clean surfaces in the normal manner. Rinse all surfaces thoroughly with the 600 ppm solution, maintaining contact for at least 2 minutes. Prepare a 200 ppm sanitizing solution by thoroughly mixing 1 oz. of this product with 20 gallons of water. Prior to using equipment, rinse all surfaces with a 200 ppm available chlorine solution. Do not rinse and do not soak equipment overnight.

IMMERSION METHOD - Prepare a 600 ppm solution by thoroughly mixing, in an immersion tank, 3 oz. of this product with 20 gallons of water. Clean equipment in the normal manner. Prepare a 200 ppm sanitizing solution by thoroughly mixing 1 oz. of this product with 20 gallons of water. Prior to using, immerse equipment in the 200 ppm sanitizing-solution for at least 2 minutes and allow the sanitizer to drain. Do not rinse and do not soak equipment overnight.

[COARSE] SPRAY METHOD - Preclean all surfaces after use. Prepare a 600 ppm available chlorine sanitizing solution of sufficient size by thoroughly mixing the product in a ratio of 3 oz. product with 20 gallons of water. Use spray equipment which can resist hypochlorite solutions. Always empty and rinse spray equipment with potable water after use. Thoroughly spray all surfaces until wet, allowing excess sanitizer to drain. Vacate area for at least 2 hours. Prior to using equipment, rinse all surfaces with a 200 ppm available chlorine solution. Prepare a 200 ppm sanitizing solution by thoroughly mixing 1 oz. of this product with 20 gallons of water.]

{Use 6} [SANITIZATION OF NONPOROUS NON-FOOD CONTACT SURFACES:

RINSE METHOD - Prepare a sanitizing solution by thoroughly mixing 1 oz. of this product with 20 gallons of water to provide approximately 200 ppm available chlorine by weight. Clean equipment surfaces in the normal manner. Prior to use, rinse all surfaces thoroughly with the sanitizing solution, maintaining contact with the sanitizer for at least 2 minutes. Do not rinse equipment with water after treatment and do not soak equipment overnight.

IMMERSION METHOD - Prepare a sanitizing solution by thoroughly mixing, in an immersion tank, 1 oz. of this product with 20 gallons of water to provide approximately 200 ppm available chlorine by weight. Clean equipment in the normal manner. Prior to use, immerse equipment in the sanitizing solution for at least 2 minutes and allow the sanitizer to drain. Do not rinse equipment with water after treatment.

[COARSE] SPRAY METHOD - Preclean all surfaces after use. Prepare a 200 ppm available chlorine sanitizing solution of sufficient size by thoroughly mixing the product in a ratio of 1 oz. product with 20 gallons of water. Use spray equipment which can resist hypochlorite solutions. Prior to using equipment, thoroughly spray all surfaces until wet, allowing excess sanitizer to drain. Vacate area for at least 2 hours.]

{Use 7} [DISINFECTION OF NONPOROUS NON-FOOD CONTACT SURFACES:

RINSE METHOD - Prepare a disinfecting solution by thoroughly mixing 3 oz. of this product with 20 gallons of water to provide approximately 600 ppm available chlorine by weight. Clean equipment surfaces in the normal manner. Prior to

use, rinse all surfaces thoroughly with the disinfecting solution, maintaining contact with the solution for at least 10 minutes. Do not rinse equipment with water after treatment and do not soak equipment overnight.

IMMERSION METHOD - Prepare a disinfecting solution by thoroughly mixing, in an immersion tank, 3 oz. of this product with 20 gallons of water to provide approximately 600 ppm available chlorine by weight. Clean equipment in the normal manner. Prior to use, immerse equipment in the disinfecting solution for at least 10 minutes and allow the sanitizer to drain. Do not rinse equipment with water after treatment.]

{Use 8} [SANITIZATION OF POROUS NON-FOOD CONTACT SURFACES:

RINSE METHOD - Prepare a sanitizing solution by thoroughly mixing 3 oz. of this product with 20 gallons of water to provide approximately 600 ppm available chlorine by weight. Clean surfaces in the normal manner. Prior to use, rinse all surfaces thoroughly with the sanitizing solution, maintaining contact with the sanitizer for at least 2 minutes. Do not rinse equipment with water after treatment and do not soak equipment overnight.

IMMERSION METHOD - Prepare a sanitizing solution by thoroughly mixing, in an immersion tank, 3 oz. of this product with 20 gallons of water to provide approximately 600 ppm available chlorine by weight. Clean equipment in the normal manner. Prior to use, immerse equipment in the sanitizing solution for at least 2 minutes and allow the sanitizer to drain. Do not rinse equipment with water after treatment.

[COARSE] SPRAY METHOD - After cleaning, sanitize non-food contact surfaces with 600 ppm available chlorine by thoroughly mixing the product in a ratio of 3 oz. of this product with 20 gallons of water. Use spray equipment which can resist hypochlorite solutions. Always empty and rinse spray equipment with potable water after use. Prior to using equipment, thoroughly spray all surfaces until wet, allowing excess sanitizer to drain. Vacate area for at least 2 hours.]

{Use 9} [SEWAGE & WASTEWATER EFFLUENT TREATMENT - The disinfection of sewage effluent must be evaluated by determining the total number of coliform bacteria and/or fecal coliform bacteria (as determined by the Most Probable Number (MPN) procedure) of the chlorinated effluent has been reduced to or below the maximum permitted by the controlling regulatory jurisdiction.

On the average, satisfactory disinfection of secondary wastewater effluent can be obtained when the chlorine residual is 0.5 ppm after 15 minutes contact. Although the chlorine residual is the critical factor in disinfection, the importance of correlating chlorine residual with bacterial kill must be emphasized. The MPN of the effluent, which is directly related to the water quality standards requirements, should be the final and primary standard and the chlorine residual should be considered an operating standard valid only to the extent verified by the coliform quality of the effluent.

The following are critical factors affecting wastewater disinfection:

1. Mixing: It is imperative that the product and the waste water be instantaneously and completely flash mixed to assure reaction with every chemically active soluble and particulate component of the waste water.
2. Contacting: Upon flash mixing, the flow through the system must be maintained.
3. Dosage/Residual Control: Successful disinfection is extremely dependent on response to fluctuating chlorine demand to maintain a predetermined, desirable chlorine level. Secondary effluent should contain 0.2 to 1.0 ppm chlorine residual after a 15 to 30 minute contact time. A reasonable average of residual chlorine is 0.5 ppm after 15 minutes contact time.]

{Use 10} [SEWAGE AND WASTEWATER TREATMENT:

EFFLUENT SLIME CONTROL - Apply a 100 to 1,000 ppm available chlorine solution at a location which will allow complete mixing. Prepare this solution by mixing 2 to 20 oz. of this product with 100 gallons of water. Once control is evident, apply a 15 ppm available chlorine solution. Prepare this solution by mixing 0.3 oz. of this product with 100 gallons of water.

FILTER BEDS: SLIME CONTROL - Remove filter from service, drain to a depth of 1 ft. above filter sand, and add 16 oz. of product per 20 sq. ft. evenly over the surface. Wait 30 minutes before draining water to a level that is even with the top of the filter. Wait for 4 to 6 hours before completely draining and backwashing filter.]

{Use 11} [DISINFECTION OF DRINKING WATER (EMERGENCY/PUBLIC/INDIVIDUAL SYSTEMS:

PUBLIC SYSTEMS - [Mix a ratio of 1 oz. of this product to 6,000 gallons of water.] {or} [Mix a ratio of 10 oz. to 30 oz. of this product into 10 gallons of water to make a 0.5% to 1.5% solution. {added to provide a smaller quantity of feeder solution when needed}] Begin feeding this solution with a hypochlorinator until a free available chlorine residual of at least 0.2 ppm and no more than 0.6 ppm is attained throughout the distribution system. Check water frequently with a chlorine test kit. Bacteriological sampling must be conducted at a frequency no less than that prescribed by the National Primary Drinking Water Regulations. Contact your local Health Department for further details.

INDIVIDUAL SYSTEMS: DUG WELLS - Upon completion of the casing (lining) wash the interior of the casing (lining) with a 100 ppm available chlorine solution using a stiff brush. This solution can be made by thoroughly mixing 1 oz. of this product into 40 gallons of water. After covering the well, pour the sanitizing solution into the well through both the pipe sleeve opening and the pipeline. Wash the exterior of the pump cylinder also with the sanitizing solution. Start pump and pump water until strong odor of chlorine in water is noted. Stop pump and wait at least 24 hours. After 24 hours flush well until all traces of chlorine have been removed from the water. Contact your local Health Department for further details.

INDIVIDUAL WATER SYSTEMS: DRILLED, DRIVEN & BORED WELLS - Run pump until water is as free from turbidity as possible. Pour a 100 ppm available chlorine sanitizing solution into the well, this solution can be made by thoroughly mixing 1 oz. of this product into 40 gallons of water. Add 5 to 10 gallons of clean, chlorinated water to the well in order to force the sanitizer into the rock formation. Wash the exterior of pump cylinder with the sanitizer. Drop pipeline into well, start pump and pump water until strong odor of chlorine in water is noted. Stop pump and wait at least 24 hours. After 24 hours flush well until all traces of chlorine have been removed from the water. Deep wells with high water levels may necessitate the use of special methods for introduction of the sanitizer into the well. Consult your local Health Department for further details.

INDIVIDUAL WATER SYSTEMS: FLOWING ARTESIAN WELLS - Artesian wells generally do not require disinfection. If analyses indicate persistent contamination, the well should be disinfected. Consult your local Health Department for further details.

EMERGENCY DISINFECTION - When boiling of water for 1 minute is not practical, water can be made potable by using this product. Prior to addition of the sanitizer, remove all suspended material by filtration or by allowing it to settle to the bottom. Decant the clarified, contaminated water to a clean container and add 1 grain of this product to 1 gallon of water. One grain is approximately the size of the letter "o" in this sentence. Allow the treated water to stand for 30 minutes. Properly treated water should have a slight chlorine odor. If not, repeat dosage and allow the water to stand an additional 15 minutes. The treated water can then be made palatable by pouring it between clean containers for several times.]

{Use 12} [PUBLIC WATER SYSTEMS:

RESERVOIRS - ALGAE CONTROL- Hypochlorinate streams feeding the reservoir. Suitable feeding points should be selected on each stream at least 50 yards upstream from the points of entry into the reservoir.

MAINS - Thoroughly flush section to be sanitized by discharging from hydrants. Permit a water flow of at least 2.5 feet per minute to continue under pressure while injecting this product by means of a hypochlorinator. Stop water flow when a chlorine residual test of 50 ppm is obtained at the low pressure end of the new main section after a 24 hour retention time. When chlorination is completed, the system must be flushed free of all heavily chlorinated water.

NEW TANKS, BASINS, ETC. - Remove all physical soil from surfaces. Place 4 oz. of this product for each 5 cubic feet of working capacity (500 ppm available chlorine). Fill to working capacity and allow to stand for at least 4 hours. Drain and flush with potable water and place into surface.

NEW FILTER SAND - Apply 16 oz. of this product for each 150 to 200 cubic feet of sand. The action of the product dissolving as the water passes through the bed will aid in sanitizing the new sand.

NEW WELLS - Flush the casing with a 50 ppm available chlorine solution of water containing 1 oz. of this product for each 100 gallons of water. The solution should be pumped or fed by gravity into the well after thorough mixing with agitation. The well should stand for several hours or overnight under chlorination. It may then be pumped until a representative raw water sample is obtained. Bacterial examination of the water will indicate whether further treatment is necessary.

EXISTING EQUIPMENT - Remove equipment from service, thoroughly clean surfaces of all physical soil. Sanitize by placing 4 oz. of this product for each 5 cubic feet capacity (approximately 500 ppm available chlorine). Fill to working capacity and let stand at least 4 hours. Drain and place in service. If the previous treatment is not practical, surfaces may be sprayed with a solution containing 1 oz. of this product for each 5 gallons of water (approximately 1,000 ppm available chlorine). After drying, flush with water and return to service.]

{Use 13} [EMERGENCY DISINFECTION AFTER FLOODS:

WELLS - Thoroughly flush contaminated casing with a 500 ppm available chlorine solution. Prepare this solution by mixing 1 oz. of this product with 10 gallons of water. Backwash the well to increase yield and reduce turbidity, adding sufficient chlorinating solution to the backwash to produce a 10 ppm available chlorine residual, as determined by a chlorine test kit. After the turbidity has been reduced and the casing has been treated, add sufficient chlorinating solution to produce a 50 ppm available chlorine residual. Agitate the well water for several hours and take a representative water sample. Treat well again if water samples are biologically unacceptable.

RESERVOIRS - In case of contamination by overflowing streams, establish hypochlorinating stations upstream of the reservoir. Chlorinate the inlet water until the entire reservoir obtains a 0.2 ppm available chlorine residual, as determined by a suitable chlorine test kit. In case of contamination from surface drainage, apply sufficient product directly to the reservoir to obtain a 0.2 ppm available chlorine residual in all parts of the reservoir.

BASINS, TANKS, FLUMES, ETC. - Thoroughly clean all equipment, then apply 4 oz. of product per 5 cu. ft. of water to obtain 500 ppm available chlorine, as determined by a suitable test kit. After 24 hours drain, flush, and return to service. If the previous method is not suitable, spray or flush the equipment with a solution containing 1 oz. of this product for each 5 gallons of water (1,000 ppm available chlorine). Allow to stand for 2 - 4 hours, flush and return to service.

FILTERS - when the sand filter needs replacement, apply 16 oz. of this product for each 150 to 200 cubic feet of sand. When the filter is severely contaminated, additional product should be distributed over the surface at the rate of 16 oz. per 20 sq. ft. Water should stand at a depth of 1 foot above the surface of the filter bed for 4 to 24 hours. When filter beds can be back washed of mud and silt, apply 16 oz. of this product per each 50 sq. ft., allowing the water to stand at a depth of 1 foot above the filter sand. After 30 minutes, drain water to the level of the filter. After 4 to 6 hours drain, and proceed with normal back washing.

DISTRIBUTION SYSTEM - Flush repaired or replaced section with water. Establish a hypochlorinating station and apply sufficient product until a consistent available chlorine residual of at least 10 ppm remains after a 24-hour retention time. Use a chlorine test kit.]

{Use 14} [EMERGENCY DISINFECTION AFTER FIRES:

CROSS CONNECTIONS OR EMERGENCY CONNECTIONS - Hypochlorination or gravity feed equipment should be set up near the intake of the untreated water supply. Apply sufficient product to give a chlorine residual of at least 0.1 to 0.2 ppm at the point where the untreated supply enters the regular distribution system. Use a chlorine test kit.]

{Use 15} [EMERGENCY DISINFECTION AFTER DROUGHTS:

SUPPLEMENTARY WATER SUPPLIES - Gravity or mechanical hypochlorite feeders should be set up on a supplementary line to dose the water to a minimum chlorine residual of 0.2 ppm after a 20 minute contact time. Use a chlorine test kit.

WATER SHIPPED IN BY TANKS, TANK CARS, TRUCKS, ETC. -Thoroughly clean all containers and equipment. Spray a 500 ppm available chlorine solution and rinse with potable water after 5 minutes. This solution is made by mixing 1 oz. of this product for each 10 gallons of water. During the filling of the containers, dose with sufficient amounts of this product to provide at least a 0.2 ppm chlorine residual. Use a chlorine test kit.]

{Use 16} [EMERGENCY DISINFECTION AFTER MAIN BREAKS:

MAINS - Before assembly of the repaired section, flush out mud and soil. Permit a water flow of at least 2.5 feet per minute to continue under pressure while injecting this product by means of a hypochlorinator. Stop water flow when a chlorine residual test of 50 ppm is obtained at the low pressure end of the new main section after a 24 hour retention time. When chlorination is completed, the system must be flushed free of all heavily chlorinated water.]

{Use 17} [COOLING TOWER/EVAPORATIVE CONDENSER WATER:

SLUG FEED METHOD - Initial dose: When system is noticeably fouled, apply 10 to 20 oz. of this product per 10,000 gallons of water in the system to obtain from 5 to 10 ppm available chlorine. Repeat until control is achieved. Subsequent dose: When microbial control is evident, add 2 oz. of this product per 10,000 gallons of water in the system daily, or as needed to maintain control and keep the chlorine residual at 1 ppm. Badly fouled systems must be cleaned before treatment is begun.

INTERMITTENT FEED METHOD - Initial Dose: When system is noticeably fouled, apply 10 to 20 oz. of this product per 10,000 gallons of water in the system to obtain 5 to 10 ppm available chlorine. Apply half (or 1/3, 1/4, or 1/5) of this initial dose when half (or 1/3, 1/4, or 1/5) of the water in the system has been lost by blow down. Subsequent Dose: When microbial control is evident, add 2 oz. of this product per 10,000 gallons of water in the system to obtain a 1 ppm residual. Apply half (or 1/3, 1/4, or 1/5) of this initial dose when half (or 1/3, 1/4, or 1/5) of the water in the system has been lost by blow down. Badly fouled systems must be cleaned before treatment is begun.

CONTINUOUS FEED METHOD - Initial dose: when system is noticeably fouled, apply 10 to 20 oz. of this product per 10,000 gallons of water in the system to obtain 5 to 10 ppm available chlorine. [Subsequent Dose: Maintain this treatment level by starting a continuous feed of 2 oz. of this product per 10,000 gallons of water lost by blow down to maintain a 1 ppm residual. Badly fouled systems must be cleaned before treatment is begun.] [Subsequent Dose: When microbial control is evident, add 2 oz. of this product per 10,000 gallons of water in the system daily, or as needed to maintain control and keep the chlorine residual at 1 ppm. Badly fouled systems must be cleaned before treatment is begun.]

{Use 18} [LAUNDRY SANITIZERS: HOUSEHOLD LAUNDRY SANITIZERS

IN SOAKING SUDS - Thoroughly mix 1 Tbs. of this product to 10 gallons of wash water to provide 200 ppm available chlorine. Wait 5 minutes, then add soap or detergent. Immerse laundry for at least 11 minutes prior to starting the wash/rinse cycle.

IN WASHING SUDS - Thoroughly mix 1 Tbs. of this product to 10 gallons of wash water containing clothes to provide 200 ppm available chlorine. Wait 5 minutes, then add soap or detergent and start the wash/rinse cycle.

COMMERCIAL LAUNDRY SANITIZERS - Wet fabrics or clothes should be spun dry prior to sanitization. Thoroughly mix 1 oz. of this product with 20 gallons of water to yield 200 ppm available chlorine. Promptly after mixing the sanitizer, add the solution into the prewash prior to washing fabrics/clothes in the regular wash cycle with a good detergent. Test the level of available chlorine if solution has been allowed to stand. Add more of this product if the available chlorine level has dropped below 200 ppm.

[FEDERALLY INSPECTED MEAT & POULTRY PLANT LAUNDRY SANITIZERS - Wet fabrics which contact meat or poultry products directly or indirectly should be spun dry prior to sanitization. Thoroughly mix 1 oz. of this product with 20 gallons of water to yield 200 ppm available chlorine. Promptly after mixing the sanitizer, add the solution into the prewash prior to washing fabrics in the regular wash cycle with a good detergent. Test the level of available chlorine if solution has been allowed to stand. Add more of this product if the available chlorine level has dropped below 200 ppm. Thoroughly rinse fabrics with potable water at the end of the laundering operation.]

{Use 19} [FARM PREMISES - Remove all animals, poultry, and feed from premises, vehicles, and enclosures. Remove all litter and manure from floors, walls and surfaces of barns, pens, stalls, chutes and other facilities occupied or traversed by animals or poultry. Empty all troughs, racks and other feeding and watering appliances. Thoroughly clean all surfaces with soap or detergent and rinse with water. To disinfect, saturate all surfaces with a solution of at least 1000 ppm available chlorine for a period of 10 minutes. A 1000 ppm solution can be made by thoroughly mixing 2 oz. of this product with 10 gallons of water. Immerse all halters, ropes and other types of equipment used in handling and restraining animals or poultry, as well as the cleaned forks, shovels and scrapers used for removing litter and manure. Ventilate buildings, cars, boats and other closed spaces. Do not house livestock or poultry or employ equipment until

chlorine has been dissipated. All treated feed racks, mangers, troughs, automatic feeders, fountains and waterers must be rinsed with potable water before reuse.]

{Use 20} [PULP AND PAPER MILL PROCESS WATER SYSTEMS: SLUG FEED METHOD - Initial Dose: When system is noticeably fouled, apply 10 to 20. oz. of this product per 10,000 gallons of water in the system to obtain from 5 to 10 ppm available chlorine. Repeat until control is achieved.

Subsequent Dose: When microbial control is evident, add 2 oz. of this product per 10,000 gallons of water in the system daily, or as needed to maintain control and keep the chlorine residual at 1 ppm. Badly fouled systems must be cleaned before treatment is begun.

INTERMITTENT FEED METHOD - Initial Dose: when system is noticeably fouled, apply 10 to 20 oz. of this product per 10,000 gallons of water in the system to obtain 5 to 10 ppm available chlorine. Apply half (or 1/3, 1/4, or 1/5) of this initial dose when half (or 1/3, 1/4, or 1/5) of the water in the system has been lost by blow down.

Subsequent Dose: When microbial control is evident, add 2 oz. of this product per 10,000 gallons of water in the system to obtain a 1 ppm residual. Apply half (or 1/3, 1/4, or 1/5) of this initial dose when half (or 1/3, 1/4, or 1/5) of the water in the system has been lost by blow down. Badly fouled systems must be cleaned before treatment is begun.

CONTINUOUS FEED METHOD - Initial dose: When system is noticeably fouled, apply 10 to 20 oz. of this product per 10,000 gallons of water in the system to obtain 5 to 10 ppm available chlorine.

[Subsequent Dose: Maintain this treatment level by starting a continuous feed of 2 oz. of this product per 10,000 gallons of water lost by blow down to maintain a 1 ppm residual. Badly fouled systems must be cleaned before treatment is begun.]

[Subsequent Dose: When microbial control is evident, add 2 oz. of this product per 10,000 gallons of water in the system daily, or as needed to maintain control and keep the chlorine residual at 1 ppm. Badly fouled systems must be cleaned before treatment is begun.]

{Use 21} [AGRICULTURAL USES:

POST-HARVEST PROTECTION - Potatoes can be sanitized after cleaning and prior to storage by spraying with a sanitizing solution at a level of 1 gallon of sanitizing solution per 1 ton of potatoes. Thoroughly mix 1 oz. of this product in 10 gallons of water to obtain 500 ppm available chlorine.

Disinfect leaf cutting bee cells and bee boards by immersion in a solution containing 1 ppm available chlorine for 3 minutes. Allow cells to drain for 2 minutes and dry for 4 to 5 hours or until no chlorine odor can be detected. This solution is made by thoroughly mixing 1/4 Tsp. of this product to 200 gallons of water. The bee domicile is disinfected by spraying with a 0.1 ppm solution until all surfaces are thoroughly wet. Allow the domicile to dry until all chlorine odor has dissipated.

FOOD EGG SANITIZATION - Thoroughly clean all eggs. Thoroughly mix 1 oz. of this product with 20 gallons of warm water to produce a 200 ppm available chlorine solution. The sanitizer temperature should not exceed 130°F. Spray the warm sanitizer so that the eggs are thoroughly wetted. Allow the eggs to thoroughly dry before casing or breaking. Do not apply a potable water rinse. The solution should not be reused to sanitize eggs.

FRUIT & VEGETABLE WASHING - Thoroughly clean all fruits and vegetables in a wash tank. Thoroughly mix 1 oz. of this product in 200 gallons of water to make a sanitizing solution of 25 ppm available chlorine. After draining the tank, submerge fruit or vegetables for 2 minutes in a second wash tank containing the recirculating sanitizing solution. Spray rinse vegetables with the sanitizing solution prior to packaging. Rinse fruit with potable water only prior to packaging.

SEEDS - To control bacterial spot (Xanthomonas vesticatoria) on Pimento seeds, initially remove moist seeds from ripe fruits. To control surface fungi and bacteria on tomato seeds initially wash seeds. Immediately soak seeds in 39,000 ppm solution for 15 minutes with continuous agitation. After treatment rinse seeds in potable water for 15 minutes. Dry seeds to normal moisture. The solution may be made by mixing 8 oz. of this product with 1 gallon of water.

MUSHROOMS - To control bacterial blotch (*Pseudomonas tolaasii*), use a 100 to 200 ppm solution prior to watering mushroom production surfaces. This solution may be made by mixing 0.2 to 0.4 oz. of this product with 10 gallons of water. First application should begin when pins form, and thereafter, between breaks on a need basis depending on the occurrence of bacterial blotch. This product may be applied directly to pins to control small infection foci. Apply 1.5 to 2.0 oz. per square foot of growing space.

POST-HARVEST ROOTS - To control and reduce the spread of soft rot causing organisms in water and on sweet potatoes (*Ipomoea batatas*), spray or dip the potatoes with a 150 to 500 ppm solution for 2 to 5 minutes. Thoroughly mix 0.3 to 1.0 oz. of this product per 10 gallons of water to obtain this solution. Monitor the chlorine concentration and change the solution after one hour or as needed.]

{Use 22} [AQUACULTURAL USES:

FISH PONDS - Remove fish from ponds prior to treatment. Thoroughly mix 20 oz. of this product to 10,000 gallons of water to obtain 10 ppm available chlorine. Add more product to the water if the available chlorine level is below 1 ppm after 5 minutes. Return fish to pond after the available chlorine level reaches zero.

FISH POND EQUIPMENT - Thoroughly clean all equipment prior to treatment. Thoroughly mix 1 oz. of this product in 20 gallons of water to obtain 200 ppm available chlorine. Porous equipment should soak for one hour.

[MAINE] LOBSTER PONDS - Remove lobsters, seaweed etc. from ponds prior to treatment. Drain the pond. Thoroughly mix 1,200 oz. of this product in 10,000 gallons of water to obtain at least 600 ppm available chlorine. Apply so that all barrows, gates, rock and dam are treated with product. Permit high tide to fill the pond and then close gates. Allow water to stand for 2 to 3 days until the available chlorine level reaches zero. Open gates and allow 2 tidal cycles to flush the pond before returning lobsters to pond.

CONDITIONING LIVE OYSTERS - Thoroughly mix 1 oz. of this product in 10,000 gallons of water at 50 to 70°F to obtain 0.5 ppm available chlorine. Expose oysters to this solution for at least 15 minutes, monitoring the available chlorine level so that it does not fall below 0.05 ppm. Repeat entire process if the available chlorine level drops below 0.05 ppm or the temperature falls below 50°F.

CONTROL OF SCAVENGERS IN FISH HATCHERY PONDS - Prepare a solution containing 200 ppm of available chlorine by mixing 0.5 oz. of product with 10 gallons of water. Pour into drained pond potholes. Repeat if necessary. Do not put desirable fish back into refilled ponds until chlorine residual has dropped to 0 ppm, as determined by a test kit.]

{Use 23} [SANITIZATION OF DIALYSIS MACHINES: Flush equipment thoroughly with water prior to using this product. Thoroughly mix 7 oz. of this product to 60 gallons of water to obtain at least 600 ppm available chlorine. Immediately use this product in the hemodialysate system allowing for a minimum contact time of 15 minutes at 20°C. Drain system of the sanitizing solution and thoroughly rinse with water. Discard and DO NOT reuse the spent sanitizer. Rinsate must be monitored with a suitable test kit to insure that no available chlorine remains in the system.

This product is recommended for decontaminating single and multipatient hemodialysate systems. This product has been shown to be an effective disinfectant (virucide, fungicide, bactericide, pseudomonicide) when tested by AOAC and EPA test methods. This product may not totally eliminate all vegetative microorganisms in hemodialysate delivery systems due to their construction and/or assembly, but can be relied upon to reduce the number of microorganisms to acceptable levels when used as directed. This product should be used in a disinfectant program which includes bacteriological monitoring of the hemodialysate delivery system. This product is NOT recommended for use in hemodialysate or reverse osmosis (RO) membranes. Consult the guidelines for hemodialysate systems available from the Hepatitis Laboratories, CDC, Phoenix, AZ 85021.]

{Use 24} [TOILET BOWL SANITIZERS: These products are marketed as individual packages for placement in the toilet. Therefore, use directions are not appropriate.][*Claims are limited to sanitization. No claims for disinfection are permitted*]

{Use 25} [ASPHALT OR WOOD ROOFS AND SIDINGS: To control fungus and mildew, first remove all physical soil by brushing and hosing with clean water, and apply a 5,000 ppm available chlorine solution. Mix 1 oz. of this product per gallon of water and brush or spray roof or siding. After 30 minutes, rinse by hosing with clean water.]

{Use 26} [BOAT BOTTOMS: To control slime on boat bottoms, sling a plastic tarp under boat, retaining enough water to cover the fouled bottom area, but not allowing water to enter enclosed area. This envelope should contain approximately 500 gallons of water for a 14 foot boat. Add 3.5 oz. of this product to this water to obtain a 35 ppm available chlorine concentration. Leave immersed for 8 to 12 hours. Repeat if necessary. Do not discharge the solution until the free chlorine level has dropped to 0 ppm, as determined by a swimming pool test kit.]

{Use 27} [ARTIFICIAL SAND BEACHES: To sanitize the sand, spray a 500 ppm available chlorine solution containing 0.1 oz. of this product per gallon of water at frequent intervals. Small areas can be sprinkled with a watering can.]

{Use 28} [FOOD PROCESSING PLANTS:

TREATMENT OF FEDERALLY INSPECTED MEAT & POULTRY PLANT POTABLE WATER SUPPLIES - Solutions of this product containing 1% available chlorine will effectively disinfect the water supply in Federally Inspected Meat & Poultry Plants. The solutions should be fed into the water supply by a hypochlorinator on the intake side of the pump. An available chlorine residual of 0.1 to 0.6 ppm must be maintained throughout the water distribution system to assure adequate disinfection. A regular testing program should be initiated to make sure that the proper chlorine residuals are present at all times. To make a 1% solution, mix 10 ounces of this product into 5 gallons of water.]

[COOLING WATER IN CANNERIES - Solutions of this product containing 1% available chlorine will sanitize cooling water, protect canned goods from contamination and spoilage and prevent staining of cans. The solution should be fed at a point to provide uniform distribution of solution throughout the cooling tanks or channels to reach a concentration of 2 ppm available chlorine. Check every two or three hours to be sure that an available chlorine residual of 2 ppm is maintained throughout the cooling system. To make a 1% solution, mix 10 ounces of this product into 5 gallons of water.]

POULTRY DRINKING WATER - Spray or flush with a solution containing 1 oz. of this product for every gallon of water. Treat poultry drinking water to a dosage of 1 to 5 ppm available chlorine by adding 1 to 5 oz. of this product per 1,000 gallons of water.

FISH FILLETING - Eviscerated and degilled fish removed from the fishing vessel are placed in a wash tank of seawater or fresh water which has been treated with enough product to produce a chlorine residual of 25 ppm, as determined by a test kit. Remove fish from treated water 24 to 48 hours before filleting. After scaling, the fish are again washed in a 25 ppm solution, and are ready for filleting.

PECAN CRACKING AND DYEING - Prepare a 1000 ppm available chlorine soaking solution by adding 1 oz. of this product for each 5 gallons of water to obtain a 1000 ppm available chlorine content. Soak for a minimum of 10 minutes. After removal, age pecans for 24 hours. Before bleaching, pecans are placed in a rotary cleaner where they are washed, drained, and soaked in a 2% sulphuric acid bath at 80 to 90°F for 1 minute. Transfer to a solution containing 100 oz. of this product for each 100 gallons of water (5000 ppm). After 4 to 8 minutes, they are drained and washed in a 1% sulphuric acid bath at 80 to 90°F. They are then dried.

STORAGE & DISPOSAL:

{Nonrefillable container - household/residential use}

[Keep this product dry in its tightly closed container when not in use. Store in a cool, dry, well-ventilated area. Keep away from heat or open flame. Nonrefillable container. Do not reuse or refill this container. Rinse empty container thoroughly with water to dissolve all material prior to disposal. Offer for recycling if available. Do not contaminate food or

HTH® Dry Chlorinator Granular for Swimming Pools

EPA Reg. No.: 1258-1069

EPA Draft Label 2024-08-16

Page 19 of 26

4-17-13 Note: The word "Superchlorination" added to Opening Your Pool and Algae Control Directions on p. 6 as a non-notification)

5-14-13 Note: The word "length" incorrectly repeated in the "To Determine Your Pool Capacity" chart for oval. It was corrected to "width" via non-notification to match previously approved labels.

feed by storage or disposal or cleaning of equipment. FOR DISPOSAL OF A CONTAMINATED OR DECOMPOSING PRODUCT SEE EMERGENCY HANDLING.]

{Refillable container – household/residential use}

[Keep this product dry in its tightly closed container when not in use. Store in a cool, dry, well-ventilated area. Keep away from heat or open flame. Do not contaminate food or feed by storage or disposal or cleaning of equipment. FOR DISPOSAL OF A CONTAMINATED OR DECOMPOSING PRODUCT SEE EMERGENCY HANDLING. Refillable container. Refill this container with calcium hypochlorite only. Do not use this container for any other purpose. Rinse empty container thoroughly with water to dissolve all material prior to disposal.]

{Nonrefillable container - non-household/residential use}

[Keep this product dry in its tightly closed container when not in use. Store in a cool, dry, well-ventilated area. Keep away from heat or open flame. Do not contaminate food or feed by storage or disposal or cleaning of equipment. FOR DISPOSAL OF A CONTAMINATED OR DECOMPOSING PRODUCT SEE EMERGENCY HANDLING. Nonrefillable container. Do not reuse this container. Offer for recycling if available. Rinse empty container thoroughly with water to dissolve all material prior to disposal.]

{Refillable container – non-household/residential use}

[Keep this product dry in its tightly closed container when not in use. Store in a cool, dry, well-ventilated area. Keep away from heat or open flame. Do not contaminate food or feed by storage or disposal or cleaning of equipment. FOR DISPOSAL OF A CONTAMINATED OR DECOMPOSING PRODUCT SEE EMERGENCY HANDLING. Refillable container. Refill this container with calcium hypochlorite only. Do not use this container for any other purpose. Cleaning of this container before final disposal is the responsibility of the person disposing of the container. Cleaning before refilling is the responsibility of the refiller. Rinse empty container thoroughly with water to dissolve all material prior to disposal.]

EMERGENCY HANDLING: In case of contamination or decomposition do not reseal container. Immediately remove container to an open and well-ventilated outdoor area by itself. Flood with large amounts of water until the material is dissolved. Dispose of contaminated material in an approved landfill area.

{BEGIN - OPTIONAL MARKETING CLAIMS CONTENT}

{Kills bacteria}, {Controls algae}, {Destroys organic contaminants}

{Eliminates bacteria}

{Destroys bacteria}

{Controls algae, kills bacteria and destroys organic contaminants in [pools] [spas & hot tubs]}

{Dry, free-flowing form}

{Concentrated chlorinating agent}

{68% available chlorine}

{Fast acting}

{Quick dissolving}

{Sanitizes pool water}

{Swimming pool sanitizer}

{Chlorinating granules for multipurpose uses}

{Chlorinating granules for multiple [swimming] pool [and spa] uses}

{Will not cause over stabilization}

{Contains no cyanuric acid}

{Good for all pool surfaces}

{Brand Specific Marketing Content}

{Note to reviewer: Icons are representative, colors and fonts are subject to match brand standards on the final printed label.}



{Marketing Content Related to Pools/Spas/Hot Tubs}

{Note to reviewer: The following are representative images.}

Representative image of a swimming pool:

HTH® Dry Chlorinator Granular for Swimming Pools


EPA Reg. No.: 1258-1069

EPA Draft Label 2024-08-16


Page 21 of 26

4-17-13 Note: The word "Superchlorination" added to Opening Your Pool and Algae Control Directions on p. 6 as a non-notification)

5-14-13 Note: The word "length" incorrectly repeated in the "To Determine Your Pool Capacity" chart for oval. It was corrected to "width" via non-notification to match previously approved labels.



Representative image of pool/spa/hot tub water:




Representative image of a beach ball:



Representative image of a floatie:



Representative image of flip-flops:



Representative images of people {Note to reviewer: Images of people in or near pools/spas/hot tubs **WILL NOT** depict application of this product. They are only in reference to use of a pool/spa/hot tub that has been treated according to label directions.}



HTH® Dry Chlorinator Granular for Swimming Pools

EPA Reg. No.: 1258-1069

EPA Draft Label 2024-08-16

Page 22 of 26

4-17-13 Note: The word "Superchlorination" added to Opening Your Pool and Algae Control Directions on p. 6 as a non-notification)

5-14-13 Note: The word "length" incorrectly repeated in the "To Determine Your Pool Capacity" chart for oval. It was corrected to "width" via non-notification to match previously approved labels.



{Product Support}

[HTH] [POOLIFE] [Brand Name] HELPLINE

[866-HTH-POOL] [866-4-POOL-FUN]

[Toll Free]

Call 7 days a week with your questions concerning pool water care. 8:00 a.m. – 10:00 p.m. Eastern Time

[For questions concerning pool water care, call the Pool Breeze® Helpline at 1-888-433-3029. Customer Care Specialists are available 7 days a week from 8:00 A.M. – 10:00 P.M. E[S]T.]

[Visit [US] [www.\[brand\].com](http://www.[brand].com)]

[Visit [US] [www.\[brand\]mag.com](http://www.[brand]mag.com)]

[Visit (brand) [www.\[brand\].com](http://www.[brand].com)]

For product questions/support [from [brand] pool [[and]&] spa] care experts:

[Call][HELPLINE][Consumer Engagement Center][Toll-Free]: [brand number] [866-HTH-Pool]

Chat online: [hthpools.com][www.PoolBreeze.com] [www.Poolife.com] [www.GLBPool.com] [www.LeisureTimeSpa.com]

[www.PristineBlue.com] [www.SironaSpaCare.com] [www.Baquacil.com] [www.appliedbio.net]

[www.cchpoolcare.com] [www.pulsarsystems.net] [www.constantchlor.com]

For product [questions][support]

For product questions/support [from [brand] pool [[and]&] spa] care experts:

For questions concerning pool water care, call the [brand] Helpline at [brand number].

[We're available] [insert days and hours]

Visit: [hthpools.com][www.PoolBreeze.com] [www.Poolife.com] [www.GLBPool.com] [www.LeisureTimeSpa.com]

[www.PristineBlue.com] [www.SironaSpaCare.com] [www.Baquacil.com] [www.appliedbio.net]

[www.cchpoolcare.com] [www.pulsarsystems.net] [www.constantchlor.com]

{Icons are representative, colors, fonts and outline shape are subject to match brand standards and are subject to change on the final printed label. Copy used with the icon can be interchanged with associated claims}



{Steps}

[Step 1: Balance]

[Step 2: Sanitize]

[Step 3: Shock]

[Step 4: Prevent Algae]

HTH® Dry Chlorinator Granular for Swimming Pools

EPA Reg. No.: 1258-1069

EPA Draft Label 2024-08-16

4-17-13 Note: The word "Superchlorination" added to Opening Your Pool and Algae Control Directions on p. 6 as a non-notification)

5-14-13 Note: The word "length" incorrectly repeated in the "To Determine Your Pool Capacity" chart for oval. It was corrected to "width" via non-notification to match previously approved labels.

{Alternative three step program marketing statements available to all labels. Steps 1, 2, and 3 will only be available to their respective product type/ approved use. We have included all statements here for clarity purposes.}

[STEP 1] [SANITIZE]

[SANITIZERS] [The key to maintaining a crystal clear pool is a steady routine of sanitization. [Brand name] sanitizers are designed to kill bacteria, algae and other living organisms. [Brand Name] Sanitizers have built-in protection from the sun to maximize chlorine life.]

[The key to maintaining a crystal clear pool is a steady routine of sanitization. [Brand name] sanitizers are designed to kill bacteria and algae. [Brand Name] Sanitizers have built-in protection from the sun to maximize chlorine life.]

[STEP 2] [SHOCK-OXIDIZE]

[Shock Oxidizer]

[Weekly shock-oxidizing your pool eliminates odors, restores water clarity and reduces the demand on the sanitizer.]

[STEP 3] [ALGAE PREVENTION]

[ALGAECIDES]

[Algaecides add an extra layer of pool protection, while creating a more pleasant swimming environment. [Brand Name] algaecides safeguard your pool, preventing all types of algae.]

[Algaecides add an extra layer of pool protection, while creating a more pleasant swimming environment. [Brand Name] algaecides safeguard your pool, killing and preventing algae.]

[BALANCE][BALANCERS] [Properly balanced water prevents corrosion and staining. It will also optimize the performance of your sanitizer. Using [Brand Name] balancers, as needed, simplifies the balancing act to help achieve properly balanced water.]

[SUPPLEMENT] [SUPPLEMENTS]

[Prevent specific water problems with [Brand Name] supplements. The perfect complement to your pool care regimen, [Brand Name] offers a variety of cleaners, clarifiers and stain removers.]

{Stop - Do Not Mix}



{Testing}

Free App

[HTH]

Test to Swim™ [App]

{Icons are representative, colors, fonts and outline shape are subject to match brand standards on the final printed label. Copy used with the icon can be interchanged with associated claims}



{Trademark}

[HTH®], [Sock It®], [Super Sock It®] and [pH Plus®] [Pulsar®], [DryTec®], [ConstantChlor®], [CCH®] (brand name) are registered trademarks of Arch Chemicals, Inc.

[The [poolife][brand] logo is a trademark of Arch Chemicals, Inc.]

[Brand name] and the [brand] logo are trademarks of Innovative Water Care, LLC. or its affiliates.

[Brand name] and [Product name] are trademarks of Innovative Water Care, LLC. or its affiliates.

[Brand name][.] the [brand] logo and [Product name] are trademarks of Innovative Water Care, LLC. or its affiliates.

[Brand name] is a trademark of Innovative Water Care, LLC. or its affiliates.

The [brand] logo is a trademark of Innovative Water Care, LLC. or its affiliates.

[HTH®], [Sock It®], [Super Sock It®] and [pH Plus®] [Pulsar®], [DryTec®], [ConstantChlor®], [CCH®] (brand name) are registered trademarks of Innovative Water Care, LLC. or its affiliates.

Requested Alternate Brand Names:

Approved Alternate Brand Names:

Constant Chlor Dry Chlorinator Granular

HTH ActiClean Granules

HTH Active Cleaning Granules

HTH Clean 'n' Scrub Chlorinator

HTH Clean 'n' Scrub Granules

HTH Clean 'n' Scrub Granules Chlorinator

HTH DynaClean Granules

HTH DynaShock

HTH Granular Chlorinator Chlorinator

HTH HydroClean Granules

HTH KineticShock

HTH Poolife Active Cleaning Granules Chlorinator

HTH Sock It Fast Action Formula

HTH Sock It Fast Shock Formula

HTH Sock It Quick Kill Formula

HTH Sock It Rapid Shock Formula

HTH Vital Shock

Pool Breeze Pool Care System Granular 68

Pool Choice Granular

Poolife ActiClean Granules Shock

Poolife Active Cleaning Granules Chlorinator

Poolife Clean Shock

Poolife DynaShock

Poolife Exclusive Pool Care Collection Active Cleaning Granules Chlorinator

Poolife HydroClean Granules

Poolife KineticShock

Poolife Vital Shock

HTH® Dry Chlorinator Granular for Swimming Pools

EPA Reg. No.: 1258-1069

EPA Draft Label 2024-08-16

Page 25 of 26

4-17-13 Note: The word "Superchlorination" added to Opening Your Pool and Algae Control Directions on p. 6 as a non-notification)

5-14-13 Note: The word "length" incorrectly repeated in the "To Determine Your Pool Capacity" chart for oval. It was corrected to "width" via non-notification to match previously approved labels.

{END – OPTIONAL MARKETING CONTENT}