

1258-1237

5/7/2014

1/23



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

WASHINGTON, DC 20460

OFFICE OF CHEMICAL SAFETY
AND POLLUTION PREVENTION

Leigh Ann Richardson
Arch Chemicals, Inc.
5660 New Northside Drive
Suite 1100
Atlanta, GA 30328

MAY 7 2014

Subject: HTH Pool Shock
EPA Reg. No. 1258-1237
Application Date: April 4, 2014
Receipt Date: April 7, 2014

Dear Ms. Richardson:

This acknowledges receipt of your notification, submitted under the provision of PR Notice 98-10, FIFRA section 3(c)9.

Proposed Notification:

- Add Spanish statements to front panel
- Add optional marketing statements to pages 4 and 5
- Add pool kit instructions on page 10 for pools openings and closings

General Comments:

Based on a review of the material submitted, the following comment applies:

Please note that the English translation of the Spanish text must appear on the label. And should you wish to add/retain a reference a company's website on your label, then please be aware that the website becomes labeling under the Federal Insecticide Fungicide and Rodenticide Act and is subject to review by the Agency. If the website is false or misleading, the product would be misbranded and unlawful to sell or distribute under FIFRA section 12(a)(1)(E). 40 CFR 156.10(a)(5) list examples of statements EPA may consider false or misleading. In addition, regardless of whether a website is referenced on your product's label, claims made on the website may not substantially differ from those claims approved through the registration process. Therefore should the Agency find or if it is brought to our attention that a website contains false or misleading statements or claims substantially differing from the EPA approved registration, the website will be referred to the EPA's Office of Enforcement and Compliance Assurance. This notification application is acceptable and has been made a part of the file for this product.

2/23

Should you have any questions or comments concerning this letter, please contact me at Henson.Wanda@epa.gov or call (703) 308-6345.

Sincerely,

A handwritten signature in black ink that reads "Wanda Y. Henson". The signature is written in a cursive style with a large, stylized "W" and "H".

Wanda Y. Henson (Team 32)
Environmental Protection Specialist
Regulatory Management Branch II
Antimicrobials Division (7510P)

EPA	United States Environmental Protection Agency Washington, DC 20460	<input checked="" type="checkbox"/> Registration <input type="checkbox"/> Amendment <input type="checkbox"/> Other	OPP Identifier Number
------------	---	--	-----------------------

Application for Pesticide - Section I

1. Company/Product Number 1258-1237	2. EPA Product Manager Demson Fuller	3. Proposed Classification <input checked="" type="checkbox"/> None <input type="checkbox"/> Restricted
4. Company/Product (Name) HTH Pool Shock	PM# 32	
5. Name and Address of Applicant (Include ZIP Code) Arch Chemicals, Inc. 1200 Bluegrass Lakes Parkway Alpharetta, GA 30004 <input type="checkbox"/> Check if this is a new address		6. Expedited Review. In accordance with FIFRA Section 3(c)(3)(b)(I), my product is similar or identical in composition and labeling to: EPA Reg. No. Product Name:

Section - II

<input type="checkbox"/> Amendment - Explain below.	<input type="checkbox"/> Final printed labels in response to Agency letter dated _____
<input type="checkbox"/> Resubmission in response to Agency letter dated _____	<input type="checkbox"/> "Me Too" Application
<input checked="" type="checkbox"/> Notification - Explain below.	<input type="checkbox"/> Other - Explain below

Explanation: Use additional page(s) if necessary. (For Section I and Section II.)

Not Subject to PRIA

Label Notification to request to add optional marketing language and abbreviated instructions. Refer to cover letter for details.

This notification is consistent with the provisions of PR-Notice 98-10 and EPA regulations at 40 CFR 152.46, and no other changes have been made to the labeling or the confidential statement of formula of this product. I understand that it is a violation of 18 U.S.C. Sec. 1001 to willfully make any false statement to EPA. I further understand that if this notification is not consistent with the terms of PR Notice 98-10 and 40 CFR 152.46, this product may be in violation of FIFRA and I may be subject to enforcement action and penalties under sections 12 and 14 of FIFRA.

Signature: *Leigh Ann Richardson* Date: **4/4/2014**

Section - III

1. Material This Product Will Be Packaged In:				2. Type of Container	
Child-Resistant Packaging <input checked="" type="checkbox"/> Yes* <input type="checkbox"/> No *Certification must be submitted	Unit Packaging <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If "Yes" Unit Packaging wgt. No. per container	Water Soluble Packaging <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If "Yes" Package wgt. No. per container		<input type="checkbox"/> Metal <input checked="" type="checkbox"/> Plastic <input type="checkbox"/> Glass <input type="checkbox"/> Paper <input type="checkbox"/> Other (Specify)	
3. Location of Net Contents Information <input checked="" type="checkbox"/> Label <input checked="" type="checkbox"/> Container		4. Size(s) Retail Container various		5. Location of Label Directions <input checked="" type="checkbox"/> On Label <input checked="" type="checkbox"/> On labeling accompanying product	
6. Manner in Which Label is Affixed to Product <input type="checkbox"/> Lithograph <input type="checkbox"/> Other <input checked="" type="checkbox"/> Paper glued <input checked="" type="checkbox"/> Stenciled					

Section - IV

1. Contact Point (Complete items directly below for identification of individual to be contacted, if necessary, to process this application)		
Name Leigh Ann Richardson	Title Sr. Regulatory Associate	Telephone No. (Include Area Code) 678-624-5094
Certification I certify that the statements I have made on this form and all attachments thereto are true, accurate and complete. I acknowledge that any knowingly false or misleading statement may be punishable by fine or imprisonment or both under applicable law.		6. Date Application Received (Stamped)
2. Signature <i>Leigh Ann Richardson</i>	3. Title Sr. Regulatory Associate	
4. Typed Name Leigh Ann Richardson	5. Date 4/4/2014	

Mr. Demson Fuller (PM-32)
Document Processing Desk (NOTIF)
U.S. Environmental Protection Agency
Office of Pesticide Programs (7510P)
Room S-4900, One Potomac Yard
2777 South Crystal Drive
Arlington, VA, 22202-4501

Arch Chemicals, Inc.
1200 Bluegrass Lakes Parkway
Alpharetta, GA 30004

Leigh Ann Richardson
Regulatory Assurance
Phone: 678-624-5894
Fax: 678-624-5678
Email: leighann.richardson@lonza.com

April 4, 2014

SUBJECT: HTH Pool Shock, EPA Reg. No. 1258-1237
Application for Label Notification

Dear Mr. Fuller:

I am submitting an application to make the following changes to the above named product label:

1. On the front panel, add the following optional statements in Spanish:
 - a. MANTÉNGASE FUERA DEL ALCANCE DE LOS NIÑOS
 - b. PELIGRO
2. On page 4, add the following optional marketing statements:
 - a. Visit us: www.hthpools.com
 - b. sold by weight, not volume
3. On page 5, add the following optional marketing claims to be used on a pool kit label:
 - a. For opening or closing your pool
 - b. Treats up to 20,000 gallons
 - c. Ideal for pools ranging from 10,000 to 20,000 gallons
 - d. HTH® Balancers and Sanitizers sold separately
 - e. Convenient and easy to use kit for opening or closing your pool
 - f. The HTH® Pool Care Kit is ideal for opening your pool or closing your pool
 - g. For best results, use with other HTH® pool care products
 - h. Includes 10 Bonus Test Strips

4. On page 10, add the following instructions to be used on a pool kit label:

For Pool Opening:

Prepare the pool:

1. Remove cover and raise the water level as needed per the pool manufacturer's directions.
2. Reconnect hoses, circulation and electrical equipment, then start pump.

Prepare the water:

1. Circulate water for at least 8 hours, then test using the **HTH® 6-Way Test Strips**.
2. Balance Total Alkalinity, pH, and Calcium Hardness using the appropriate **HTH®** products.
3. Add the **HTH® Algae Guard™ Granular** through the skimmer. Follow the directions on the product label for opening dose amounts based on pool volume.
4. Next, broadcast the **HTH® Metal Control Granular** over the deepest part of the pool. Maintain circulation for 24 – 48 hours.

[Items in brackets [AAA] are optional and may/may not be included on final label]
{Items in braces {AAA} are for information purposes and will not appear on final label}

HTH® POOL SHOCK

ACTIVE INGREDIENT:

CALCIUM HYPOCHLORITE	47.6%
OTHER INGREDIENTS	52.4%
TOTAL	100.0%

Minimum Available Chlorine 45 %

NOTIFICATION
Date Reviewed: 5-7-14
Reviewed By: PH

KEEP OUT OF REACH OF CHILDREN
[MANTÉNGASE FUERA DEL ALCANCE DE LOS NIÑOS]

DANGER [PELIGRO]

Contamination or improper use may cause fire, explosion or the release of toxic gases. Do not allow product to contact any foreign matter, including other water treatment products. If product is exposed to small amounts of water, it can react violently to produce heat and toxic gases and spatter. **Do not add water to this product. Add only into water.** {The following optional statement is for use on residential use swimming pool and spa products.} [Do not mix this product with a small amount of water. Only add directly to your pool.] Corrosive. Causes irreversible eye damage and skin burns. Harmful if swallowed, inhaled, or absorbed through the skin.

Read all precautionary statements on label and all first aid statements before use.

[See [side] [back] panel for [first aid and] precautionary statements.]

FIRST AID:

IF IN EYES: Hold eye open and rinse slowly and gently with water for 15-20 minutes. Remove contact lenses, if present, after the first 5 minutes, then continue rinsing eye. Call a poison control center or doctor for treatment advice.

IF ON SKIN OR CLOTHING: Take off contaminated clothing. Rinse skin immediately with plenty of water for 15-20 minutes. Call a poison control center or doctor for treatment advice.

IF SWALLOWED: Call a poison control center or doctor immediately for treatment advice. Have person sip a glass of water if able to swallow. Do not induce vomiting unless told to do so by a poison control center or doctor. Do not give anything by mouth to an unconscious person.

IF INHALED: Remove person to fresh air. If person is not breathing, call 911 or an ambulance, then give artificial respiration, preferably mouth-to-mouth if possible. Call a poison control center or doctor for further treatment advice.

Have the product container or label with you when calling a poison control center or doctor, or going for treatment.

NOTE TO PHYSICIAN: Probable mucosal damage may contraindicate the use of gastric lavage.

IN CASE OF EMERGENCY CALL: 1-800-654-6911

PRECAUTIONARY STATEMENTS

HAZARDS TO HUMANS AND DOMESTIC ANIMALS

DANGER. Corrosive. Causes irreversible eye damage and skin burns. Harmful if swallowed, or absorbed through skin.

- Open in a well ventilated area. Avoid breathing dust and fumes.
- Do not get in eyes, on skin or on clothing. Wear goggles and rubber gloves. For additional protection of skin, wear long sleeves and long pants.
- Wash hands after handling and before eating, drinking, chewing gum, using tobacco or using the toilet.
- Remove contaminated clothing and wash clothing before reuse.

PHYSICAL and CHEMICAL HAZARDS:

DANGER. If product is exposed to small amounts of water, it can react violently to produce heat and toxic gas and spatter. Do not add water to this product. Add only into water.

- [Do not mix this product with a small amount of water. Only add this product directly to your pool.] {This statement will appear on Pool use labels only.}
- Do not allow to become wet or damp before use.

Can react with other materials, including other water treatment products, to cause fire, explosion, and the release of toxic gases.

- Keep all foreign matter, including other water treatment products, away from this product.
- Use only clean dry utensils to dispense this product.
- Do not allow this product to contact other water treatment products. If used with a skimmer, make sure skimmer is completely clean and free of residue from other water treatment products before putting this product in a skimmer.
- Avoid spilling this product.

Exposure to heat can cause this product to rapidly decompose, leading to fire, explosion, and the release of toxic gases.

- Store in a cool, dry, well ventilated area away from heat or open flame.

Strong oxidizing agent. This product can increase fire intensity.

- Keep away from heat and from flame and burning material (like a lighted cigarette).

{First sentence of paragraph below for 50 lb. containers or less; complete paragraph for all other sizes}

ENVIRONMENTAL HAZARD: This pesticide is toxic to fish and aquatic organisms. Do not discharge effluent containing this product into lakes, ponds, streams, estuaries, oceans, or other waters unless in accordance with the requirements of a National Pollutant Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not discharge effluent containing this product to sewer systems without previously notifying the local sewage treatment plant authority. For guidance contact your State Water Board or Regional Office of the EPA.

STORAGE & DISPOSAL:

{Nonrefillable container - household/residential use}

[Keep this product dry in its tightly closed container when not in use. Store in a cool, dry, well-ventilated area. Keep away from heat or open flame. Nonrefillable container. Do not reuse or refill this container. Rinse empty container thoroughly with water to dissolve all material prior to disposal. Offer for recycling if available. Do not contaminate food or feed by storage or disposal or cleaning of equipment. FOR DISPOSAL OF A CONTAMINATED OR DECOMPOSING PRODUCT SEE EMERGENCY HANDLING.]

{Nonrefillable container – single-use, non-resealable package}

[Keep this product dry in its tightly closed container. Store in a cool, dry, well-ventilated area. Keep away from heat or open flame. Nonrefillable container. Do not reuse or refill this container. Rinse empty container thoroughly with water to dissolve all material prior to disposal. Offer for recycling if available. Do not contaminate food or feed by storage or disposal or cleaning of equipment. FOR DISPOSAL OF A CONTAMINATED OR DECOMPOSING PRODUCT SEE EMERGENCY HANDLING.]

8/23

{Refillable container – household/residential use}

[Keep this product dry in its tightly closed container when not in use. Store in a cool, dry, well-ventilated area. Keep away from heat or open flame. Do not contaminate food or feed by storage or disposal or cleaning of equipment. FOR DISPOSAL OF A CONTAMINATED OR DECOMPOSING PRODUCT SEE EMERGENCY HANDLING. Refillable container. Refill this container with calcium hypochlorite only. Do not use this container for any other purpose. Rinse empty container thoroughly with water to dissolve all material prior to disposal.]

{Nonrefillable container - non-household/residential use}

[Keep this product dry in its tightly closed container when not in use. Store in a cool, dry, well-ventilated area. Keep away from heat or open flame. Do not contaminate food or feed by storage or disposal or cleaning of equipment. FOR DISPOSAL OF A CONTAMINATED OR DECOMPOSING PRODUCT SEE EMERGENCY HANDLING. Nonrefillable container. Do not reuse this container. Offer for recycling if available. Rinse empty container thoroughly with water to dissolve all material prior to disposal.]

{Refillable container – non-household/residential use}

[Keep this product dry in its tightly closed container when not in use. Store in a cool, dry, well-ventilated area. Keep away from heat or open flame. Do not contaminate food or feed by storage or disposal or cleaning of equipment. FOR DISPOSAL OF A CONTAMINATED OR DECOMPOSING PRODUCT SEE EMERGENCY HANDLING. Refillable container. Refill this container with calcium hypochlorite only. Do not use this container for any other purpose. Cleaning of this container before final disposal is the responsibility of the person disposing of the container. Cleaning before refilling is the responsibility of the refiller. Rinse empty container thoroughly with water to dissolve all material prior to disposal.]

EMERGENCY HANDLING: In case of contamination or decomposition - Do not reseal container. Immediately remove container to an open and well-ventilated outdoor area by itself. Flood with large amounts of water until the material is dissolved. Dispose of container and any remaining material in an approved landfill area.

Sold by
Arch Chemicals, Inc.
P.O. Box 724438
Atlanta, GA 31139-1438


EPA Reg. No. 1258-1237
Net Wt. xxxx

EPA Est. No. xxxx

[HTH] [brand]®, pH Plus®, Sock It®, Super Sock It®, and Duration® are registered trademarks of Arch Chemicals, Inc.

Clean 'n Scrub, Shock 'n Swim, and the [HTH] [brand] logo are trademarks of Arch Chemicals, Inc.

[HTH® and the HTH® Logo are registered trademarks of Arch Chemicals, Inc.]





{Optional} []



**[[HTH] [HTH POOLIFE] (Brand Name) HELPLINE
[866-HTH-POOL] [866-4-POOL-FUN]**

Toll Free

Call 7 days a week with your questions concerning [pool] water care. 8:00 a.m. - 10:00 p.m. Eastern Time]

{OPTIONAL MARKETING CLAIMS}

[For Pop-Up Pools]

[Kills bacteria] [Controls Algae] [Destroys organic contaminants]

[Controls algae, kills bacteria and destroys organic contaminants in [pools] [spas & hot tubs]]

[Eliminates bacteria]

[Destroys bacteria]

[Sanitizes pool water]

[Swimming pool sanitizer]

[Routine Chlorinator]

[47% available chlorine]

[Concentrated chlorinating agent]

[Shock Treatment [and] Superchlorinator for Swimming Pools and Spas]

[Chlorinating granules for multiple pool and spa uses]

[Chlorinating granules for multipurpose uses]

[Restores a crystal clarity to pool water]

[No need to predissolve] {only for swimming pool & spa products}

[Buffered Sanitizer]

[Buffered for pH control]

[Oxidizer]

[Removes organic waste and produces sparkling clean swimming pool water]

[For pool startup and weekly shock treatment]

[For heavy bather loads or after heavy rains]

[Will not cause over-stabilization]

[Will not cause cyanuric acid to [form] {or} [build up] in your pool]

[Contains no cyanuric acid]

[Good for all pool surfaces]

[Fast acting]
[Quick dissolving]
[Dry, free-flowing form]

[Convenient]
[Easy to use]
[Multipurpose Product]

[Clarifies]
[Convenient Routine Chlorinator]
[Use only with Pulsar chlorinator systems]
[Use only with Constant Chlor chlorinator systems]

[Sanitizes water]
[Step 1: Balance]
[Step 2: Sanitize]
[Step 3: Shock]
[Step 4: Prevent Algae]

[Step 1]
[Step 2]

{Optional statement for inclusion on dealer direct brands}

[Step 1. Sanitize

Step 2. Shock

Step 3. Add Algaecide]

[Maintain] {Optional statement for use on labels with spa directions for use}.

{Optional – refers to product guide on this label}
[brand] Spa Product Guide

Maintain

Step 1

Step 2

Step 3

Enhance

Prevent]

[Use Our 4 Simple Steps For A Beautiful Pool!

1 balance your pool water

2 sanitize to keep bacteria away

3 shock to maintain water clarity

4 prevent algae from growing]

[Spend more time in your pool and less time cleaning]

[With our legacy of excellence, you can trust us with your pool care]

[We are proud to be the do-it-yourself pool care experts with over 80 years of experience, continual research and product innovation.]

[Need Help? Easy to use pool and spa care tips and detailed product information are just a click away. Simply log on to www.hthpools.com, or call 1-866-HTH-POOL.]

{[recycle symbol] Made from 10% recycled paper]

[Visit us: www.hthpools.com]

[sold by weight, not volume]

DIRECTIONS FOR USE:

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

READ ALL PRECAUTIONARY STATEMENTS BEFORE USE.

[This product is a concentrated chlorinating agent.] [It is in a dry, free-flowing form.] [It kills bacteria, controls algae and destroys organic contaminants in pools.]

{Some use sites may not appear on all commercial labels.}

{Use 1}[[SWIMMING POOLS]

[WHY YOU SHOULD USE THIS PRODUCT: This is a highly effective, multi-purpose product that sanitizes], [clarifies], [helps] prevent[s] algae and [shock treats your pool]. It is convenient, easy to use, and won't over-stabilize your pool. [For crystal clear pool water, [the makers of [brand] recommend] {or} [follow] the following 4 step pool care program: Step 1: Test and balance water, Step 2: Sanitize, Step 3: Shock at least once a week, and Step 4: Add algaecide as directed.]

[For best results, follow a weekly program with our [brand] System. Consult your authorized [brand] dealer for advice on the system that best suits your pool and your lifestyle.] [Take a pool water sample to your authorized [brand] dealer regularly for a detailed water analysis.]

[Additional shocking to keep water clean and clear is recommended after: rain and heavy winds; high number of swimmers; increased water temperature; and/or increased frequency of pool usage.]

{For commercial pool, municipal, and industrial labels:}

[This product is a concentrated chlorinating agent in a dry, free-flowing form that controls the growth of algae, kills bacteria, and destroys organic contaminants in pools, spas and hot tubs.]

{Small pools (500 gallons to less than 10,000 gallons) and pools 10,000 gallons and above}

How To Use: [Do not pre-mix this product before adding it to your pool]. [Only add this product directly to your pool or skimmer.] {When contents are in a resealable container} **[Use only a clean, dry [scoop] lid to measure this product]. [Do not use the [scoop] [lid] for any other purpose.]** {When contents are in a single use bag for use as a shock for pools 10,000 gallons or larger} [Use entire contents when opened].

[Method for dosing directly into pool:]

Add the recommended dosage of this product during evening hours while the filter pump is running. When adding this product to your pool, broadcast the product evenly over a wide area in the deepest part of the pool. If any granules settle to the bottom of the pool, use brush to disperse.

[Method for skimmer addition:

[Use this method to avoid bleaching vinyl liner or paint.] Make sure that filter pump is on and properly recirculating through skimmer. Empty skimmer of all chemicals and/or debris. Contamination may cause an explosion or the release of toxic gases. Do not use this method when an automatic chemical dispensing device (e.g. feeder) is present. Pour this product slowly into skimmer, making sure that the material is drawn into the system at the same rate; do not allow this material to accumulate as toxic gases may be generated.]

[Water Balance: For best product performance, swimmer comfort, and crystal clear water: Maintain pH in the range of 7.2 to 7.6. [Allow the pH adjusters to dissolve and disperse before adding this product to the pool.] Maintain total alkalinity in the range of 60 to 120 {retail brands only} {Commercial brands for very large commercial or municipal pools will use [60 to 100]} parts per million (ppm). Maintain calcium hardness above 200 ppm. [Maintain available chlorine level at 1-4 ppm.] Use a reliable test kit that measures all these ranges. Use [brand] Pool Care Products to make adjustments. Follow label directions for each product. Do not enter pool until the free available chlorine residual is 1- 4 ppm for each of the below noted water treatment applications. Re-entry into treated pools is prohibited above levels of 4 ppm for risk of bodily injury. {For Industrial/Municipal pool labels: [Reenter pool when residual is 1-4 ppm].

{For pools 10,000 gallons and larger}

As a preventative treatment, you should shock treat your pool once a week to prevent pool problems. In addition to weekly shock treatment, you should shock treat to remedy problems which occur when bather loads are high, water appears hazy or dull, unpleasant odors or eye irritation occur, after heavy wind and rainstorms, or if algae does develop with resulting green color and slimy feeling walls.

POOL SHOCK TREATMENT: Add the recommended dosages of this product while the filter pump is running. Adjust and maintain pH to 7.2 to 7.6 with [brand] pH Plus or [brand] pH Minus. Follow label directions. Allow the pH adjusters to dissolve and disperse before adding this product to the pool. When adding this product to your pool, broadcast this product evenly over a wide area of the deepest part of the pool.

DOSAGE RATE:

{For all packaging except one time dose single use bags}

[SHOCK TREATMENT / SUPER CHLORINATION: For best results, see "WATER BALANCE" and "HOW TO USE" sections above before treatment. Every 7 days, or as necessary to prevent pool problems, shock treat / super chlorinate the pool by adding 14 to 28 ounces of this product per 10,000 gallons of water to yield 5 to 10 ppm available chlorine by weight. Re-entry into treated pools is prohibited above levels of 4 ppm for risk of bodily injury.

{End of section -For all packaging except one time single use bags}

{For one time dose single use bags, use the following verbiage:}

{8 ounce bag:} **[SHOCK TREATMENT / SUPER CHLORINATION:** For best results, see "WATER BALANCE" and "HOW TO USE" sections above before treatment. Every 7 days, or as necessary to prevent pool problems, shock treat / super chlorinate the pool by adding 8 to 16 ounces (one to two bags) per 5,700 gallons of water to yield 5 to 10 ppm available chlorine by weight. Re-entry into treated pools is prohibited above levels of 4 ppm for risk of bodily injury. {End of 8 ounce bag}

{10 ounce bag:} **[SHOCK TREATMENT / SUPER CHLORINATION:** For best results, see "WATER BALANCE" and "HOW TO USE" sections above before treatment. Every 7 days, or as necessary to prevent pool problems, shock treat / super chlorinate the pool by adding 10 to 20 ounces (one to two bags) per 7,000 gallons of water to yield 5 to 10 ppm available chlorine by weight. Re-entry into treated pools is prohibited above levels of 4 ppm for risk of bodily injury. {End of 10 ounce bag}

{12 ounce bag:} **[SHOCK TREATMENT / SUPER CHLORINATION:** For best results, see "WATER BALANCE" and "HOW TO USE" sections above before treatment. Every 7 days, or as necessary to prevent pool problems, shock treat / super chlorinate the pool by adding 12 to 24 ounces (one to two bags) per 8,500 gallons of water to yield 5 to 10 ppm available chlorine by weight. Re-entry into treated pools is prohibited above levels of 4 ppm for risk of bodily injury. {End of 12 ounce bag}

{14 ounce bag:} **[SHOCK TREATMENT / SUPER CHLORINATION:** For best results, see "WATER BALANCE" and "HOW TO USE" sections above before treatment. Every 7 days, or as necessary to prevent pool problems, shock treat / super chlorinate the pool by adding 14 to 28 ounces (one to two bags) per 10,000 gallons of water to yield 5 to 10 ppm available chlorine by weight. Re-entry into treated pools is prohibited above levels of 4 ppm for risk of bodily injury. {End of 14 ounce bag}

{16 ounce bag:} **[SHOCK TREATMENT / SUPER CHLORINATION:** For best results, see "WATER BALANCE" and "HOW TO USE" sections above before treatment. Every 7 days, or as necessary to prevent pool problems, shock treat /super chlorinate the pool by adding 16 to 32 ounces (one to two bags) per 11,500 gallons of water to yield 5 to 10 ppm available chlorine by weight. Re-entry into treated pools is prohibited above levels of 4 ppm for risk of bodily injury. {End of 16 ounce bag}

[Use entire contents of bag when opened.]

14/
23

[Additional shock treatments may be required to correct problems which are caused by visible algae, high bathing loads, heavy wind and rainstorms. Additional shock treatments may also be required to correct problems such as unpleasant odors and eye irritation. Check the available chlorine with a suitable test kit. Do not reenter the pool until the chlorine residual is 1 to 4 ppm.] Re-entry into treated pools is prohibited above levels of 4 ppm for risk of bodily injury.

{End of dosage instructions for one time dose single use bags}

{For pools 10,000 gallons and larger}

[SHOCK TREATMENT / SUPERCHLORINATION: For best results, see "WATER BALANCE" and "HOW TO USE" sections above before treatment. Every 7 days, or as necessary to prevent pool problems, shock treat / superchlorinate the pool by adding 14-28 ounces of this product per 10,000 gallons of water to provide 5 to 10 ppm available chlorine. Additional shock treatments may be required to correct problems which are caused by visible algae, high bathing loads, heavy wind and rainstorms. Additional shock treatments may also be required to correct problems such as unpleasant odors and eye irritation. Check the available chlorine with a suitable test kit. Do not reenter the pool until the chlorine residual is 1 to 4 ppm.] Re-entry into treated pools is prohibited above levels of 4 ppm for risk of bodily injury.]

{For pools 10,000 gallons and larger}

[ALGAE CONTROL: 1. Follow "SHOCK TREATMENT" directions on this label. 2. Add this product as close as possible to any algae on the sides or bottom of the pool. 3. Do not enter pool until the free available chlorine residual is 1-4 ppm. [Re-entry into treated pools is prohibited above levels of 4 ppm for risk of bodily injury.] 4. If necessary, repeat the treatment. 5. To prevent possible staining or bleaching, take the following steps immediately after treatment: Thoroughly clean pool by brushing surface of algae growth, vacuum and cycle through filter. For preventative algae control, use your preferred [brand] algaecide product regularly. **[However, if problems persist use your preferred [brand] [spa] algaecide product regularly. Follow label directions on [the algaecide] {or} [that product.]]**

{Labels of resealable containers {2 lbs. or more} used to treat pools 10,000 gallons and larger}

[WINTERIZING: For best results, see "WATER BALANCE" section above before treatment. While the water is still clear and clean, prepare for long periods of disuse by gradually adding 42 ounces of this product per 10,000 gallons of pool water that is clear and clean. This provides 15 ppm free available chlorine. Follow "HOW TO USE" directions on this package. Run the filter pump until granules are completely dissolved. Cover the pool with a [plastic] pool cover. Prepare the heater, pump and filter components for winterizing by following manufacturer's directions.]

[TO DETERMINE YOUR POOL CAPACITY IN U.S. GALLONS, USE THE APPROPRIATE FORMULA BELOW:


POOL SHAPE FORMULA (Use measurements in feet only)

RECTANGULAR - Length x Width x Average Depth x 7.5 = Total Gallons.

ROUND - Diameter x Diameter x Average Depth x 5.9 = Total Gallons.

OVAL - Maximum Length x Maximum Width x Average Depth x 5.9 = Total Gallons.

FREE FORM - Surface Area (Sq. Feet) x Average Depth x 7.5 = Total Gallons]



{optional instructions for pool kit}

[For Pool Opening:

Prepare the pool:

1. Remove cover and raise the water level as needed per the pool manufacturer's directions.
2. Reconnect hoses, circulation and electrical equipment, then start pump.


Prepare the water:

1. Circulate water for at least 8 hours, then test using the **HTH® 6-Way Test Strips**.
2. Balance Total Alkalinity, pH, and Calcium Hardness using the appropriate **HTH®** products.
3. Add the **HTH® Algae Guard™ Granular** through the skimmer. Follow the directions on the product label for opening dose amounts based on pool volume.
4. Next, broadcast the **HTH® Metal Control Granular** over the deepest part of the pool. Maintain circulation for 24 – 48 hours.
5. Broadcast the **HTH® Shock 'N Swim** over the deepest part of the pool according to "Opening Your Pool" instructions on product label.
6. Add your preferred **HTH®** sanitizer as needed and maintain free available chlorine level between 1 – 4 ppm. Follow normal maintenance routine.

For Pool Closing:

1. Balance the water and clean the filter using **HTH®** products.
2. With the pump and filter operating, broadcast the **HTH® Shock 'N Swim** over the deepest part of the pool according to "Pool Shock Treatment" instructions on product label.
3. Next, add the proper closing dose of **HTH® Algae Guard™ Granular** through the skimmer.
4. Broadcast the **HTH® Metal Control Granular** over the deepest part of the pool. Maintain circulation for 24 – 48 hours.
5. Follow equipment manufacturer's directions to winterize the pump, filter, and other pool equipment.

[Follow label directions for each of these products. [See side panel.]]



16/
23

{Use 2} [SPA & HOT TUBS]

[How To Use: For best results, see "WATER BALANCE" section below before treatment. Maintain these conditions for proper operation by frequent testing with a test kit. Do not allow cyanuric acid level to exceed 100 ppm. It is recommended that spas and hot tubs be drained every 30-90 days, more often under heavy use. Consult manufacturer's recommendations concerning the compatibility of chlorine sanitizers with their equipment. Some oils, lotions, fragrances, cleansers, etc., may cause foaming or cloudy water and may react with chlorine sanitizers to reduce their efficacy. If circulation is low, stir water after addition of chlorine or other chemicals.]

Water Balance: For best product performance, comfort and crystal clear water, use [brand] spa care products to maintain the following water balance:

	Acceptable Range for Balance
pH	7.2-7.6
Total Alkalinity	60-120 ppm
Calcium Hardness	Above 200 ppm
Available Chlorine	1-4 ppm

Follow label directions for each product and allow each product to dissolve and disperse before adding additional products to the pool. Use a reliable test kit that measures all these ranges. Re-entry into treated spas is prohibited with chlorine levels above 5 ppm for risk of bodily injury.]

It is recommended that spas and hot tubs be drained every 30-90 days, more often under heavy use. Consult manufacturer's recommendations concerning the compatibility of chlorine sanitizers with their equipment.]

[Opening Your Spa] Startup (Freshly Filled): For best results, see "WATER BALANCE" section above before treatment. Turn on circulation system and ensure that it is operating properly. Add one (1) ounce of this product to provide approximately 10 ppm available chlorine for each 500 gallons of water. Check the free available chlorine (FAC) and if less than 4-5 ppm, repeat as needed.

[SPA/HOT-TUB: [Routine Chlorination For] Regular Use: For best results, see "WATER BALANCE" section above before treatment. Turn on circulation system and ensure that it is operating properly. Scatter up to 0.7 ounces of this product per 500 gallons over the surface of the water to obtain 5 ppm free available chlorine. Test for free available chlorine and add additional product if necessary to maintain 3-5 ppm FAC while unit is in use. Do not enter the spa until chlorine residual reaches 1-5 ppm. Re-entry into treated spa is prohibited above levels of 5 ppm for risk of bodily injury. Test for free available chlorine and add additional product if necessary to attain a chlorine concentration of 1-5 ppm FAC.

Shock Treatment: After each use, shock treat with 1.4 oz. of this product to provide approximately 10 ppm available chlorine per 500 gallons of water, to control odors and algae. Repeat as needed. [For preventative algae control: Shock treatment should control algae. However, if problems persist use your preferred [brand] [spa] algacide product regularly. Follow label directions on that product.]

Extended Non-use Period: For best results, see "WATER BALANCE" section above before treatment. During extended non-use periods when the spa or hot tub is not being used add 2 ounces of this product per 500 gallons twice a week with the circulation system running or as needed to maintain acceptable chlorine concentration.]

{Use 3} [HUBBARD AND IMMERSION TANKS - Add 1.4 oz. of this product per 200 gallons of water before patient use to obtain a chlorine residual of 25 ppm, as determined by a suitable test kit. Adjust and maintain the water pH to between 7.2 and 7.6. After each use drain the tank. Add 0.5 oz. to a bucket of water and circulate this solution through the agitator of the tank for 15 minutes and then rinse out the solution. Clean tank thoroughly and dry with clean cloths.]

[HYDROTHERAPY TANKS – Add 1.4 oz. of this product per 1,000 gallons of water to obtain a minimum chlorine residual of 1 ppm, as determined by a suitable chlorine test kit, after satisfying any chlorine demand. Pool should not be entered until the chlorine residual is below 3 ppm. Adjust and maintain the water pH to between 7.2 and 7.6. Operate pool filter pump continuously. Drain pool weekly, and clean before refilling.]

{Use 4} [SANITIZATION OF NONPOROUS NON-FOOD CONTACT SURFACES:

[RINSE METHOD - Prepare a sanitizing solution by thoroughly mixing 1.5 oz. of this product with 20 gallons of water to provide approximately 200 ppm available chlorine by weight. Clean equipment surfaces in the normal manner. Prior to use, rinse all surfaces thoroughly with the sanitizing solution, maintaining contact with the sanitizer for at least 2 minutes. Do not rinse equipment with water after treatment and do not soak equipment overnight.]

[IMMERSION METHOD - Prepare a sanitizing solution by thoroughly mixing, in a immersion tank, 1.5 oz. of this product with 20 gallons of water to provide approximately 200 ppm available chlorine by weight. Clean equipment in the normal manner. Prior to use, immerse equipment in the sanitizing solution for at least 2 minutes and allow the sanitizer to drain. Do not rinse equipment with water after treatment.]

[[COARSE] SPRAY METHOD - Preclean all surfaces after use. Prepare a 200 ppm available chlorine sanitizing solution of sufficient size by thoroughly mixing the product in a ratio of 1.5 oz. product with 20 gallons of water. Use spray equipment which can resist hypochlorite solutions. Prior to using equipment, thoroughly spray all surfaces until wet, allowing excess sanitizer to drain. Vacate area for at least 2 hours.]]

{Use 5} [DISINFECTION OF NONPOROUS NON-FOOD CONTACT SURFACES:

[RINSE METHOD - Prepare a disinfecting solution by thoroughly mixing 4.4 oz. of this product with 20 gallons of water to provide approximately 600 ppm available chlorine by weight. Clean equipment surfaces in the normal manner. Prior to use, rinse all surfaces thoroughly with the disinfecting solution, maintaining contact with the solution for at least 10 minutes. Do not rinse equipment with water after treatment and do not soak equipment overnight.]

[IMMERSION METHOD - Prepare a disinfecting solution by thoroughly mixing, in an immersion tank, 4.4oz. of this product with 20 gallons of water to provide approximately 600 ppm available chlorine by weight. Clean equipment in the normal manner. Prior to use, immerse equipment in the disinfecting solution for at least 10 minutes and allow the sanitizer to drain. Do not rinse equipment with water after treatment.]]

{Use 6} [SANITIZATION OF POROUS NON-FOOD CONTACT SURFACES:

[RINSE METHOD - Prepare a sanitizing solution by thoroughly mixing 4.4 oz. of this product with 20 gallons of water to provide approximately 600 ppm available chlorine by weight. Clean surfaces in the normal manner. Prior to use, rinse all surfaces thoroughly with the sanitizing solution, maintaining contact with the sanitizer for at least 2 minutes. Do not rinse equipment with water after treatment and do not soak equipment overnight.]

[IMMERSION METHOD - Prepare a sanitizing solution by thoroughly mixing, in an immersion tank, 4.4 oz. of this product with 20 gallons of water to provide approximately 600 ppm available chlorine by weight. Clean equipment in the normal manner. Prior to use, immerse equipment in the sanitizing solution for at least 2 minutes and allow the sanitizer to drain. Do not rinse equipment with water after treatment.]

[[COARSE] SPRAY METHOD - After cleaning, sanitize non-food contact surfaces with 600 ppm available chlorine by thoroughly mixing the product in a ratio of 4.4 oz. of this product with 20 gallons of water. Use spray equipment which can resist hypochlorite solutions. Always empty and rinse spray equipment with potable water after use. Prior to using equipment, thoroughly spray all surfaces until wet, allowing excess sanitizer to drain. Vacate area for at least 2 hours.]]

{Use 7} [SEWAGE & WASTEWATER EFFLUENT TREATMENT - The disinfection of sewage effluent must be evaluated by determining the total number of coliform bacteria and/or fecal coliform bacteria (as determined by the Most Probable Number (MPN) procedure) of the chlorinated effluent has been reduced to or below the maximum permitted by the controlling regulatory jurisdiction. On the average, satisfactory disinfection of secondary wastewater effluent can be obtained when the chlorine residual is 0.5 ppm after 15 minutes contact. Although the chlorine residual is the critical factor in disinfection, the importance of correlating chlorine residual with bacterial kill must be emphasized. The MPN of the effluent, which is directly related to the water quality standards requirements, should be the final and primary standard and the chlorine residual should be considered an operating standard valid only to the extent verified by the coliform quality of the effluent. The following are critical factors affecting wastewater disinfection: 1. Mixing: It is imperative that the product and the waste water be instantaneously and completely flash mixed to assure reaction with every chemically active soluble and particulate component of the waste water. 2. Contacting: Upon flash mixing, the flow through the system must be maintained. 3. Dosage/Residual Control: Successful disinfection is extremely dependent on response to fluctuating chlorine demand to maintain a predetermined, desirable chlorine level. Secondary effluent should contain 0.2 to 1.0 ppm chlorine residual after a 15 to 30 minute contact time. A reasonable average of residual chlorine is 0.5 ppm after 15 minutes contact time.]

{Use 8} [SEWAGE AND WASTEWATER TREATMENT:

[EFFLUENT SLIME CONTROL - Apply a 100 to 1,000 ppm available chlorine solution at a location which will allow complete mixing. Prepare this solution by mixing 3 to 29 oz. of this product with 100 gallons of water. Once control is evident, apply a 15 ppm available chlorine solution. Prepare this solution by mixing 0.5 oz. of this product with 100 gallons of water.]

[FILTER BEDS: SLIME CONTROL - Remove filter from service, drain to a depth of 1 ft. above filter sand, and add 23 oz. of product per 20 sq. ft. evenly over the surface. Wait 30 minutes before draining water to a level that is even with the top of the filter. Wait for 4 to 6 hours before completely draining and backwashing filter.]]

{Use 9} [DISINFECTION OF DRINKING WATER (EMERGENCY/PUBLIC/INDIVIDUAL SYSTEMS:

[PUBLIC SYSTEMS - Mix a ratio of 1.5 oz. of this product to 6,000 gallons of water.] {or} [Mix a ratio of 10 oz. to 30 oz. of this product into 10 gallons of water to make a 0.5% to 1.5% solution. Begin feeding this solution with a hypochlorinator until a free available chlorine residual of at least 0.2 ppm and no more than 0.6 ppm is attained throughout the distribution system. Check water frequently with a chlorine test kit. Bacteriological sampling must be conducted at a frequency no less than that prescribed by the National Primary Drinking Water Regulations. Contact your local Health Department for further details.]

[INDIVIDUAL SYSTEMS: DUG WELLS - Upon completion of the casing (lining) wash the interior of the casing (lining) with a 100 ppm available chlorine solution using a stiff brush. This solution can be made by thoroughly mixing 1.5 oz. of this product into 40 gallons of water. After covering the well, pour the sanitizing solution into the well through both the pipe sleeve opening and the pipeline. Wash the exterior of the pump cylinder also with the sanitizing solution. Start pump and pump water until strong odor of chlorine in water is noted. Stop pump and wait at least 24 hours. After 24 hours flush well until all traces of chlorine have been removed from the water. Contact your local Health Department for further details.]

[INDIVIDUAL WATER SYSTEMS: DRILLED, DRIVEN & BORED WELLS - Run pump until water is as free from turbidity as possible. Pour a 100 ppm available chlorine sanitizing solution into the well, this solution can be made by thoroughly mixing 1.5 oz. of this product into 40 gallons of water. Add 5 to 10 gallons of clean, chlorinated water to the well in order to force the sanitizer into the rock formation. Wash the exterior of pump cylinder with the sanitizer. Drop pipeline into well, start pump and pump water until strong odor of chlorine in water is noted. Stop pump and wait at least 24 hours. After 24 hours flush well until all traces of chlorine have been removed from the water. Deep wells with high water levels may necessitate the use of special methods for introduction of the sanitizer into the well. Consult your local Health Department for further details.]

19/
23

[INDIVIDUAL WATER SYSTEMS: FLOWING ARTESIAN WELLS - Artesian wells generally do not require disinfection. If analyses indicate persistent contamination, the well should be disinfected. Consult your local Health Department for further details.]

[EMERGENCY DISINFECTION - When boiling of water for 1 minute is not practical, water can be made potable by using this product. Prior to addition of the sanitizer, remove all suspended material by filtration or by allowing it to settle to the bottom. Decant the clarified, contaminated water to a clean container and add 2 grains of this product to 1 gallon of water. One grain is approximately the size of the letter "o" in this sentence. Allow the treated water to stand for 30 minutes. Properly treated water should have a slight chlorine odor. If not, repeat dosage and allow the water to stand an additional 15 minutes. The treated water can then be made palatable by pouring it between clean containers for several times.]]

{Use 10} [PUBLIC WATER SYSTEMS:

[RESERVOIRS - ALGAE CONTROL- Hypochlorinate streams feeding the reservoir. Suitable feeding points should be selected on each stream at least 50 yards upstream from the points of entry into the reservoir.]

[MAINS - Thoroughly flush section to be sanitized by discharging from hydrants. Permit a water flow of at least 2.5 feet per minute to continue under pressure while injecting this product by means of a hypochlorinator. Stop water flow when a chlorine residual test of 50 ppm is obtained at the low pressure end of the new main section after a 24 hour retention time. When chlorination is completed, the system must be flushed free of all heavily chlorinated water.]

[NEW TANKS, BASINS, ETC. - Remove all physical soil from surfaces. Place 3.6 oz. of this product for each 5 cubic feet of working capacity (500 ppm available chlorine). Fill to working capacity and allow to stand for at least 4 hours. Drain and flush with potable water and return to surface.]

[NEW FILTER SAND - Apply 32 oz. of this product for each 150 to 200 cubic feet of sand. The action of the product dissolving as the water passes through the bed will aid in sanitizing the new sand.]

[NEW WELLS - Flush the casing with a 50 ppm available chlorine solution of water containing 2 oz. of this product for each 100 gallons of water. The solution should be pumped or fed by gravity into the well after thorough mixing with agitation. The well should stand for several hours or overnight under chlorination. It may then be pumped until a representative raw water sample is obtained. Bacterial examination of the water will indicate whether further treatment is necessary.]

[EXISTING EQUIPMENT - Remove equipment from service, thoroughly clean surfaces of all physical soil. Sanitize by placing 6 oz. of this product for each 5 cubic feet capacity (approximately 500 ppm available chlorine). Fill to working capacity and let stand at least 4 hours. Drain and place in service. If the previous treatment is not practical, surfaces may be sprayed with a solution containing 1.5 oz. of this product for each 5 gallons of water (approximately 1,000 ppm available chlorine). After drying, flush with water and return to service.]]

{Use 11} [EMERGENCY DISINFECTION AFTER FLOODS:

[WELLS - Thoroughly flush contaminated casing with a 500 ppm available chlorine solution. Prepare this solution by mixing 1.5 oz. of this product with 10 gallons of water. Backwash the well to increase yield and reduce turbidity, adding sufficient chlorinating solution to the backwash to produce a 10 ppm available chlorine residual, as determined by a chlorine test kit. After the turbidity has been reduced and the casing has been treated, add sufficient chlorinating solution to produce a 50 ppm available chlorine residual. Agitate the well water for several hours and take a representative water sample. Treat well again if water samples are biologically unacceptable.]

[RESERVOIRS - In case of contamination by overflowing streams, establish hypochlorinating stations upstream of the reservoir. Chlorinate the inlet water until the entire reservoir obtains a 0.2 ppm available chlorine residual, as determined by a suitable chlorine test kit. In case of contamination from surface drainage, apply sufficient product directly to the reservoir to obtain a 0.2 ppm available chlorine residual in all parts of the reservoir.]

[BASINS, TANKS, FLUMES, ETC. - Thoroughly clean all equipment, then apply 6 oz. of product per 5 cu. ft. of water to obtain 500 ppm available chlorine, as determined by a suitable test kit. After 24 hours drain, flush, and return to service. If the previous method is not suitable, spray or flush the equipment with a solution containing 1 oz. of this product for each 5 gallons of water (1,000 ppm available chlorine). Allow to stand for 2 - 4 hours, flush and return to service.]

[FILTERS - when the sand filter needs replacement, apply 24 oz. of this product for each 150 to 200 cubic feet of sand. When the filter is severely contaminated, additional product should be distributed over the surface at the rate of 24 oz. per 20 sq. ft. Water should stand at a depth of 1 foot above the surface of the filter bed for 4 to 24 hours. When filter beds can be back washed of mud and silt, apply 24 oz. of this product per each 50 sq. ft., allowing the water to stand at a depth of 1 foot above the filter sand. After 30 minutes, drain water to the level of the filter. After 4 to 6 hours drain, and proceed with normal back washing.]


[DISTRIBUTION SYSTEM - Flush repaired or replaced section with water. Establish a hypochlorinating station and apply sufficient product until a consistent available chlorine residual of at least 10 ppm remains after a 24-hour retention time. Use a chlorine test kit.]]

{Use 12} [EMERGENCY DISINFECTION AFTER FIRES: CROSS CONNECTIONS OR EMERGENCY CONNECTIONS - Hypochlorination or gravity feed equipment should be set up near the intake of the untreated water supply. Apply sufficient product to give a chlorine residual of at least 0.1 to 0.2 ppm at the point where the untreated supply enters the regular distribution system. Use a chlorine test kit.]

{Use 13} [EMERGENCY DISINFECTION AFTER DROUGHTS: [SUPPLEMENTARY WATER SUPPLIES - Gravity or mechanical hypochlorite feeders should be set up on a supplementary line to dose the water to a minimum chlorine residual of 0.2 ppm after a 20 minute contact time. Use a chlorine test kit.]

[WATER SHIPPED IN BY TANKS, TANK CARS, TRUCKS, ETC. -Thoroughly clean all containers and equipment. Spray a 500 ppm available chlorine solution and rinse with potable water after 5 minutes. This solution is made by mixing 1.5 oz. of this product for each 10 gallons of water. During the filling of the containers, dose with sufficient amounts of this product to provide at least a 0.2 ppm chlorine residual. Use a chlorine test kit.]

{Use 14} [EMERGENCY DISINFECTION AFTER MAIN BREAKS: MAINS - Before assembly of the repaired section, flush out mud and soil. Permit a water flow of at least 2.5 feet per minute to continue under pressure while injecting this product by means of a hypochlorinator. Stop water flow when a chlorine residual test of 50 ppm is obtained at the low pressure end of the new main section after a 24 hour retention time. When chlorination is completed, the system must be flushed free of all heavily chlorinated water.]



{Use 15} [COOLING TOWER/EVAPORATIVE CONDENSER WATER:

[SLUG FEED METHOD - Initial dose: When system is noticeably fouled, apply 15-30 oz. of this product per 10,000 gallons of water in the system to obtain from 5 to 10 ppm available chlorine. Repeat until control is achieved. Subsequent dose: When microbial control is evident, add 2 oz. of this product per 10,000 gallons of water in the system daily, or as needed to maintain control and keep the chlorine residual at 1 ppm. Badly fouled systems must be cleaned before treatment is begun.

[INTERMITTENT FEED METHOD - Initial Dose: When system is noticeably fouled, apply 15-30 oz. of this product per 10,000 gallons of water in the system to obtain 5 to 10 ppm available chlorine. Apply half (or 1/3, 1/4, or 1/5) of this initial dose when half (or 1/3, 1/4, or 1/5) of the water in the system has been lost by blow down. Subsequent Dose: When microbial control is evident, add 4 oz. of this product per 10,000 gallons of water in the system to obtain a 1 ppm residual. Apply half (or 1/3, 1/4, or 1/5) of this initial dose when half (or 1/3, 1/4, or 1/5) of the water in the system has been lost by blow down. Badly fouled systems must be cleaned before treatment is begun.]

[CONTINUOUS FEED METHOD - Initial dose: when system is noticeably fouled, apply 15-30 oz. of this product per 10,000 gallons of water in the system to obtain 5 to 10 ppm available chlorine. Subsequent Dose: Maintain this treatment level by starting a continuous feed of 3 oz. of this product per 10,000 gallons of water lost by blow down to maintain a 1 ppm residual. Badly fouled systems must be cleaned before treatment is begun.]]

{Use 16} [LAUNDRY SANITIZERS:

[HOUSEHOLD LAUNDRY SANITIZERS-] [IN SOAKING SUDS - Thoroughly mix 1.5 oz. of this product to 10 gallons of wash water to provide 200 ppm available chlorine. Wait 5 minutes, then add soap or detergent. Immerse laundry for at least 11 minutes prior to starting the wash/rinse cycle.] **[IN WASHING SUDS** - Thoroughly mix 1.5 oz. of this product to 20 gallons of wash water containing clothes to provide 200 ppm available chlorine. Wait 5 minutes, then add soap or detergent and start the wash/rinse cycle.]

[COMMERCIAL LAUNDRY SANITIZERS - Wet fabrics or clothes should be spun dry prior to sanitization. Thoroughly mix 1.5 oz. of this product with 20 gallons of water to yield 200 ppm available chlorine. Promptly after mixing the sanitizer, add the solution into the prewash prior to washing fabrics/clothes in the regular wash cycle with a good detergent. Test the level of available chlorine if solution has been allowed to stand. Add more of this product if the available chlorine level has dropped below 200 ppm.]

[FEDERALLY INSPECTED MEAT & POULTRY PLANT LAUNDRY SANITIZERS - Wet fabrics which contact meat or poultry products directly or indirectly should be spun dry prior to sanitization. Thoroughly mix 1.5 oz. of this product with 20 gallons of water to yield 200 ppm available chlorine. Promptly after mixing the sanitizer, add the solution into the prewash prior to washing fabrics in the regular wash cycle with a good detergent. Test the level of available chlorine if solution has been allowed to stand. Add more of this product if the available chlorine level has dropped below 200 ppm. Thoroughly rinse fabrics with potable water at the end of the laundering operation.]]

{Use 17} [FARM PREMISES: Remove all animals, poultry, and feed from premises, vehicles, and enclosures. Remove all litter and manure from floors, walls and surfaces of barns, pens, stalls, chutes and other facilities occupied or traversed by animals or poultry. Empty all troughs, racks and other feeding and watering appliances. Thoroughly clean all surfaces with soap or detergent and rinse with water. To disinfect, saturate all surfaces with a solution of at least 1,000 ppm available chlorine for a period of 10 minutes. A 1,000 ppm solution can be made by thoroughly mixing 3 oz. of this product with 10 gallons of water. Immerse all halters, ropes and other types of equipment used in handling and restraining animals or poultry, as well as the cleaned forks, shovels and scrapers used for removing litter and manure. Ventilate buildings, cars, boats and other closed spaces. Do not house livestock or poultry or employ equipment until chlorine has been dissipated. All treated feed racks, mangers, troughs, automatic feeders, fountains and waterers must be rinsed with potable water before reuse.]

{Use 18} [PULP AND PAPER MILL PROCESS WATER SYSTEMS:

[SLUG FEED METHOD - Initial Dose: When system is noticeably fouled, apply 15-30 oz. of this product per 10,000 gallons of water in the system to obtain from 5 to 10 ppm available chlorine. Repeat until control is achieved. Subsequent Dose: When microbial control is evident, add 2.9 oz. of this product per 10,000 gallons of water in the system daily, or as needed to maintain control and keep the chlorine residual at 1 ppm. Badly fouled systems must be cleaned before treatment is begun.]

[INTERMITTENT FEED METHOD - Initial Dose: when system is noticeably fouled, apply 15-30 oz. of this product per 10,000 gallons of water in the system to obtain 5 to 10 ppm available chlorine. Apply half (or 1/3, 1/4, or 1/5) of this initial dose when half (or 1/3, 1/4, or 1/5) of the water in the system has been lost by blow down. Subsequent Dose: When microbial control is evident, add 2.9 oz. of this product per 10,000 gallons of water in the system to obtain a 1 ppm residual. Apply half (or 1/3, 1/4, or 1/5) of this initial dose when half (or 1/3, 1/4, or 1/5) of the water in the system has been lost by blow down. Badly fouled systems must be cleaned before treatment is begun.]

[CONTINUOUS FEED METHOD - Initial dose: When system is noticeably fouled, apply 15-30 oz. of this product per 10,000 gallons of water in the system to obtain 5 to 10 ppm available chlorine. Subsequent Dose: Maintain this treatment level by starting a continuous feed of 2.9 oz. of this product per 10,000 gallons of water lost by blow down to maintain a 1 ppm residual. Badly fouled systems must be cleaned before treatment is begun.]]

{Use 19} [AQUACULTURAL USES:

[FISH PONDS - Remove fish from containerized ponds prior to treatment. Thoroughly mix 30 oz. of this product to 10,000 gallons of water to obtain 10 ppm available chlorine. Add more product to the water if the available chlorine level is below 1 ppm after 5 minutes. Return fish to pond after the available chlorine level reaches zero.]

[FISH POND EQUIPMENT - Thoroughly clean all equipment prior to treatment. Thoroughly mix 1.5 oz. of this product to 20 gallons of water to obtain 200 ppm available chlorine. Porous equipment should soak for one hour.]

[MAINE LOBSTER PONDS - Remove lobsters, seaweed etc. from ponds prior to treatment. Drain the pond. Thoroughly mix 1,900 oz. of this product to 10,000 gallons of water to obtain at least 600 ppm available chlorine. Apply so that all barrows, gates, rock and dam are treated with product. Permit high tide to fill the pond and then close gates. Allow water to stand for 2 to 3 days until the available chlorine level reaches zero. Open gates and allow 2 tidal cycles to flush the pond before returning lobsters to pond.]

[CONDITIONING LIVE OYSTERS - Thoroughly mix 1.5 oz of this product to 10,000 gallons of water at 50 to 70°F to obtain 0.5 ppm available chlorine. Expose oysters to this solution for at least 15 minutes, monitoring the available chlorine level so that it does not fall below 0.05 ppm. Repeat entire process if the available chlorine level drops below 0.05 ppm or the temperature falls below 50°F.]

[CONTROL OF SCAVENGERS IN FISH HATCHERY PONDS - Prepare a solution containing 200 ppm of available chlorine by mixing 1.5 oz. of product with 20 gallons of water. Pour into drained pond potholes. Repeat if necessary. Do not put desirable fish back into refilled ponds until chlorine residual has dropped to 0 ppm, as determined by a test kit.]]

{Use 20} [SANITIZATION OF DIALYSIS MACHINES: Flush equipment thoroughly with water prior to using this product. Thoroughly mix 10.2 oz. of this product to 60 gallons of water to obtain at least 600 ppm available chlorine. Immediately use this product in the hemodialysate system allowing for a minimum contact time of 15 minutes at 20°C. Drain system of the sanitizing solution and thoroughly rinse with water. Discard and **DO NOT** reuse the spent sanitizer. Rinsate must be monitored with a suitable test kit to insure that no available chlorine remains in the system.

This product is recommended for decontaminating single and multipatient hemodialysate systems. This product has been shown to be an effective disinfectant (virucide, fungicide, bactericide, pseudomonicide) when tested by AOAC and EPA test methods. This product may not totally eliminate all vegetative microorganisms in hemodialysate delivery systems due to their construction and/or assembly, but can be relied upon to reduce the number of microorganisms to acceptable levels when used as directed. This product should be used in a disinfectant program which includes bacteriological monitoring of the hemodialysate delivery system. This product is NOT recommended for use in hemodialysate or reverse osmosis (RO) membranes. Consult the guidelines for hemodialysate systems available from the Hepatitis Laboratories, CDC, Phoenix, AZ 85021.]

{Use 21} [TOILET BOWL SANITIZERS: These products are marketed as individual packages for placement in the toilet. Therefore, use directions are not appropriate.]

{Use 22} [ASPHALT OR WOOD ROOFS AND SIDINGS: To control fungus and mildew, first remove all physical soil by brushing and hosing with clean water, and apply a 5,000 ppm available chlorine solution. Mix 1.5 oz. of this product per gallon of water and brush or spray roof or siding. After 30 minutes, rinse by hosing with clean water.]

{Use 23} [BOAT BOTTOMS: To control slime on boat bottoms, sling a plastic tarp under boat, retaining enough water to cover the fouled bottom area, but not allowing water to enter enclosed area. This envelope should contain approximately 500 gallons of water for a 14 foot boat. Add 5 oz. of this product to this water to obtain a 35 ppm available chlorine concentration. Leave immersed for 8 to 12 hours. Repeat if necessary. Do not discharge the solution until the free chlorine level has dropped to 0 ppm, as determined by a swimming pool test kit.]

{Use 24} [ARTIFICIAL SAND BEACHES: To sanitize the sand, spray a 500 ppm available chlorine solution containing 1.5 oz per 10 gallons of water at frequent intervals. Small areas can be sprinkled with a watering can.]

