

T-30-1

NOT REVIEWED  
In Accordance with EPA Notice 82-2.  
Based on the Labeling Listed

**ACTIVE INGREDIENT:**

2-(Thiocyanomethylthio)benzothiazole ..... 30%

INERT INGREDIENTS ..... 70%

**KEEP OUT OF REACH OF CHILDREN  
DANGER**

**PRECAUTIONARY STATEMENTS**

**HAZARDS TO HUMANS AND DOMESTIC ANIMALS**

**DANGER:** Causes irreversible eye damage. Causes skin irritation. This product may cause allergic skin reactions. Harmful if swallowed. Do not get in eyes, on skin, or on clothing. Wear goggles or face shield and rubber gloves when handling. Wash thoroughly with soap and water after handling. Remove contaminated clothing and wash before reuse.

**STATEMENT OF PRACTICAL TREATMENT:** *If in eyes,* flush with plenty of water. Get medical attention. *If on skin,* wash with plenty of soap and water. Get medical attention. *If swallowed,* drink promptly a large quantity of milk, egg whites, gelatin solution or, if these are not available, drink large quantities of water. Avoid alcohol. Get medical attention.

*Consult your physician:* Probable mucosal damage may contraindicate gastric lavage.

**ENVIRONMENTAL HAZARDS:** This pesticide is toxic to fish. Do not apply in marine and/or estuarine oil fields. Do not discharge effluent containing this active ingredient into lakes, streams, ponds, estuaries, oceans, or public waters unless this product is specifically identified and addressed in an NPDES permit. Do not discharge effluent containing this product to sewer systems without previously notifying the sewage treatment plant authority. For guidance contact your State Water Board or Regional Office of the EPA.

**PHYSICAL AND CHEMICAL HAZARDS:** Do not use or store near heat or open flame.

Manufactured by:  
**BUCKMAN LABORATORIES, INC.**  
1256 NORTH McLEAN BOULEVARD  
MEMPHIS, TN 38108

EPA REG. NO. 1448-149 EPA EST. NO. \_\_\_\_\_

NET CONTENTS \_\_\_\_\_

**DIRECTIONS FOR USE**

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

**COOLING TOWERS:** T-30-1 is used to protect cooling tower wood against soft or surface rot and internal or dry rot. It is applied by spraying or painting a dispersion containing 0.5 to 0.7% T-30-1 in water onto the clean wood surfaces. The amount applied should provide 0.6 to 0.8 lb. T-30-1 per 1000 ft.<sup>2</sup> of wood surface. Soft or surface rot can also be inhibited by periodic shock doses of T-30-1 to the recirculating cooling water at the tower basin or cold well. The dosage should provide 1.25 lb. of T-30-1 per 1000 gal. of water, and the bleedoff should be stopped for 4 to 6 hr. after treatment. The shock treatment should be repeated every four months.

**COOLING WATER:** T-30-1 is used to control algae, bacteria, and fungi in industrial recirculating cooling water systems. Before treatment is begun, the system should be cleaned thoroughly to remove old algal growth, microbiological slime, and other deposits. System should then be drained, flushed, refilled with water, and treated with an initial dose of 0.6 to 3.7 fl. oz. of T-30-1 per 1000 gal. water in the system. Subsequent additions of 0.2 to 1.2 fl. oz. per 1000 gal. should be made every 1 to 5 days, depending on amount of bleedoff and severity of microbiological fouling.

**DRILLING FLUIDS:** To inhibit bacterial and fungal degradation of the fluids or muds used in the drilling of wells, T-30-1 is incorporated in the drilling fluid at concentrations of 0.05 to 0.25% based on the total wet weight of the fluid.

**PETROLEUM SECONDARY RECOVERY:** T-30-1 is used to control sulfate reducing bacteria, slime forming bacteria and fungi in oil field water, polymer, or miscellar floods, water disposal systems, and other oil field water systems at dosage rates of 0.2 to 3.7 fl. oz. of T-30-1 per 1000 gal of water treated. Additions should be made continuously or intermittently by means of a metering pump at the free water knockouts, before or after injection pumps and injection well headers. **Continuous Feed Method:** When system is noticeably fouled, add 0.6 to 3.7 fl. oz. T-30-1 per 1000 gal of water continuously until desired degree of control is achieved. Then treat with 0.2 to 1.2 fl. oz. T-30-1 per 1000 gal of water continuously, or as needed to maintain control. **Intermittent or Slug Method:** When system is noticeably fouled, or to maintain control, add 0.6 to 3.7 fl. oz. T-30-1 per 1000 gal of water for 4 to 8 hr per day and 1 to 4 times per week, or as needed to maintain control.

**CUTTING FLUIDS:** T-30-1 is used to inhibit bacterial and fungal degradation of water-based and water-soluble or emulsifiable cutting fluids and coolants used in metalworking operations. It should be added to the cutting fluid at a rate that will provide 2.5 to 250 parts per million T-30-1 (weight/weight) after final dilution with water. T-30-1 can be added after the dilution or can be added to the concentrate before dilution at a rate of 125 to 1250 parts per million in order to provide the required concentration in the diluted fluid.

**STORAGE & DISPOSAL**

Do not contaminate water, food, or feed by storage or disposal.  
**PESTICIDE STORAGE** Do not expose to extreme temperatures. Do not stack more than five drums high. Drums should be opened in well ventilated areas. Leaking or damaged drums should be placed in overpack drums for disposal. Spills should be absorbed in sawdust or sand and disposed of in a sanitary landfill.  
**PESTICIDE DISPOSAL** Pesticide wastes are acutely hazardous. Improper disposal of excess pesticide, spray mixture, or residue is a violation of Federal law. If these wastes cannot be disposed of by use according to label instructions, contact your State Pesticide or Environmental Control Agency, or the Hazardous Waste representative at your EPA Regional Office for guidance.  
**CONTAINER DISPOSAL** Triple rinse (or equivalent). Then offer for recycling or reconditioning, or puncture and dispose of in a sanitary landfill, or by other procedures approved by state and local authorities.

1448-149 PM 31

1061

L

-1

**NOTE:** Changes in labeling formula differing in substance from that accepted in connection with this registration must be submitted to and accepted by the Registration Division prior to use of the label in commerce. In any correspondence on this product always refer to the above U.S. EPA registration number.

On the basis of information furnished by the registrant, the above named pesticide is hereby Registered/Reregistered under the Federal Insecticide, Fungicide, and Rodenticide Act.

A copy of the labeling accepted in connection with this Registration/Reregistration is returned herewith.

Registration is in no way to be construed as an indorsement or approval of this product by this Agency. In order to protect health and the environment, the Administrator, on his motion, may at any time suspend or cancel the registration of a pesticide in accordance with the Act. The acceptance of any name in connection with the registration of a product under this Act is not to be construed as giving the registrant a right to exclusive use of the name or to its use if it has been covered by others.

This product is conditionally registered in accordance with FIFRA section 6(d)(1) and you:

1. Submit data for final registration/reregistration of your product under FIFRA section 6(d)(1) when the Agency requires all registrants of similar products to submit such data.

2. Add the phrase "EPA Registration No. 1446-149" to your label before you release the product for shipment.

3. Submit five (5) copies of your final printed labeling before you release the product for shipment. Refer to the A-79 enclosure for a further description of final printed labeling.

If these conditions are not complied with, the registration will be subject to cancellation in accordance with FIFRA section 6(e). Your release for shipment of the product constitutes acceptance of these conditions.

A stamped copy of the label is enclosed for your records.

*John H. Lee*  
John H. Lee

Product Manager (31)  
Antimicrobial Program Branch  
Registration Division (TS-767C)

Inclosures

ATTACHMENT IS APPLICABLE

SIGNATURE OF APPROVING OFFICIAL

DATE