

ACTIVE INGREDIENT(S)	
Poly[oxyethylene(dimethyliminio)ethylene(dimethyliminio)ethylene	
dichloride]	30.0
INERT INGREDIENTS	70.0
TOTAL	100.0

KEEP OUT OF REACH OF CHILDREN CAUTION

	FIRST AID
If in Eyes	- Hold eye open and rinse slowly and gently with water for 15-20 minutes Remove contact lenses, if present, after the first 5 minutes, then continue rinsing eye Call a poison control center or doctor for further treatment advice.
If on Skin, Clothes	- Take off contaminated clothing Rinse skin immediately with plenty of water for 15-20 minutes, - Call a poison control center or doctor for treatment advice.
If Swallowed	- Call poison control center or doctor immediately for treatment advice Have person sip a glass of water, if able to swallow Do not induce vomiting unless told to do so by the poison control center or doctor Do not give anything by mouth to an unconscious person.
If Inhaled	- Move person to fresh air If person is not breathing, call 911 or an ambulance, then give artificial respiration, preferably b mouth-to-mouth if possible Call a poison control center or doctor for further treatment advice.

HOT LINE NUMBER

Have the product container or label with you when calling a Poison Control Center or doctor or going for treatment. You may also contact 901-278-0330 or 1-800-BUCKMAN for emergency medical treatment information

Precautionary Statements

HAZARDS TO HUMANS AND DOMESTIC ANIMALS

CAUTION: Harmful if swallowed. Avoid breathing vapors. Avoid contact with skin, eyes, or clothing. Wash thoroughly with soap and water after handling.

ENVIRONMENTAL HAZARDS: This pesticide is toxic to fish and aquatic organisms. Do not contaminate water by cleaning of equipment or disposal of waste. Do not discharge effluent containing this product into lakes, streams. ponds, estuaries, oceans or other waters unless in accordance with the requirements of a National Pollutant Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not discharge effluent containing this product to sewer systems without previously notifying the local sewage treatment plant authority. For guidance contact your State Water Board or Regional Office of the EPA.

Directions for Use


It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

W-30-2 is used to control algae, bacteria, and fungi in recirculating commercial and industrial water cooling towers and systems. Prior to its use, systems must be cleaned to remove algal growth, microbiological slime, and other deposits. An initial slug addition of 1.90 to 4.75 fluid ounces of W-30-2 per 1000 gallons of water to provide a concentration of 16 to 40 parts per million of W-30-2 based on the total weight of water in the system, is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 0.47 to 4.75 fluid ounces of W-30-2 per 1000 gations of water (4 to 40 parts per million of W-30-2) should be employed every 2 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers, W-30-2 is used to control bacteria in industrial air-washing systems that maintain effective mist eliminating components. Prior to its use, systems should be cleaned to remove bacterial slime and other deposits. An initial slug dose of 7.1 to 11.9 fluid ounces of W-30-2 per 1000 gallons of water is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 4.8 to 11.9 fluid ounces of W-30-2 per 1000 gallons of water should be employed each 1 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and severity of the bacterial problem. Slug addition may be made to the sump or to the water collection travs of the airwash system.

W-30-2 is used to control the growth of algae in decorative fountains, which do not contain fish. For maximum effectiveness, decorative fountains should be cleaned prior to using W-30-2. Decorative fountains having just visible algae growth require an initial dose of 2 to 4 fluid ounces of W-30-2 per 1000 gallons of water. For treatment of a freshly cleaned decorative fountain, add initially 1 to 2 fluid ounces of W-30-2 per 1,000 gations of water. Subsequent additions of 0.5 to 0.8 fluid ounces of W-30-2 should be made every 5 to 7 days after initial treatment for maintenance. W-30-2 is used to control the growth of algae in swimming pools, exterior spas, whirlpools, hot tubs, decorative fountains, and ponds that do not contain fish. For maximum effectiveness pools, spas, whirlpools, hot tubs, decorative fountains, and ponds containing heavy growth of algae should be cleaned prior to using W-30-2. For pools having just visible algae growth add an initial dose of 24 to 36 fluid ounces of W-30-2 per 10,000 gallons of water and remove settled algae debris by cleaning. For treatment of a freshly cleaned and filled pool add initially 13 to 24 fluid ounces of W-30-2 per 10,000 gations of water. Subsequent additions of 4 to 9 fluid ounces of W-30-2 should be made every 5 to 7 days after initial treatment for maintenance.

Spas, whirlpools, hot tubs, decorative fountain, and ponds having just visible algae growth require an initial dose of 2 to 4 ounces of W-30-2 per 1000 gallons of water. Subsequent additions of 0.5 to 0.8 fluid ounces of W-30-2 should be made every 5 to 7 days after initial treatment for maintenance. W-30-2 will prevent growth of most algae during the off-season winter months when pools are not in use. For pools, which have been properly treated during the swimming season and are free of visible algae, add 13 to 21 fluid ounces of algaecide per 10,000 gallons of water. If at the end of swimming season pools have some visible algae growth, add 25 to 37 fluid ounces per 10,000 gallons. It is necessary that a uniform distribution of algaecide, throughout the water and the pool be made for maximum effectiveness. If pool is not covered, it may be necessary to repeat the treatment one or more times during the season. W-30-2 is compatible with those chemicals normally used to treat pools and spas and is effective at both acid and alkaline pH.

W-30-2 can be used in pools and spas treated with chlorine chemicals and may reduce the amount of those chemicals normally required. However, do not mix W-30-2 with concentrated dry or liquid chlorine products.



Storage and Disposal

Do not contaminate water, food, or feed by storage or disposal

PESTICIDE STORAGE: Do not stack more than four drums high. Leaking or damaged drums should be placed in overpack drums for disposal. Spills should be absorbed in sawdust or sand and disposed of in a sanitary landfill. Keep container closed when not in use.

PESTICIDE DISPOSAL: Wastes resulting from the use of this product may be disposed of on site or at an approved waste disposal facility.

CONTAINER DISPOSAL PLASTIC: Triple rinse (or equivalent). Then offer for recycling or reconditioning, or puncture and dispose of in a sanitary landfill, by incineration, or, if allowed by state and local authorities, by burning, if burned, stay out of smoke. METAL: Triple rinse (or equivalent). Then offer for recycling or reconditioning, or puncture and dispose of in a sanitary landfill, or by other procedures approved by state and local authorities.

STORAGE: Do not contaminate water, food or feed by storage or disposal. Keep container closed when not in use. Leaking or damaged containers should be placed in plastic bag and discarded in trash. Mop up spills with clear water. All peaticides should be kept out of reach of children and stored away from food. DISPOSAL: Do not reuse empty container. Wrap container and place in trash.

Manufactured by

Buckman Laboratories, Inc.

1256 North McLean Blvd. Memphis, Tennessee 38108, USA

(901) 278-0330 or 1-800-BUCKMAN

EPA Est. No. EPA Reg. No.

1448-TN-1 1448-233

Product Weight

8.9 lbs/gal. 1.07 kg/l

Net contents are marked on the container

HMIS / NPCA Ratings

Reactivity

Last Revision

1/16/2004