

PRECAUTIONARY STATEMENTS
HAZARDS TO HUMANS AND
DOMESTIC ANIMALS

DANGER

CORROSIVE. CAUSES SEVERE BURNS OF EYES. EYE CONTACT MAY CAUSE LOSS OF VISION. MAY BURN THE SKIN MAY BE HARMFUL OR FATAL IF SWALLOWED. Do not get in eyes, on skin or on clothing. Chemical Worker's Goggles must be worn when handling. Wash thoroughly with soap and water after handling.

ENVIRONMENTAL HAZARDS

This product is toxic to fish. Do not discharge effluent containing this product into lakes, streams, ponds, estuaries, oceans, or other waters unless in accordance with the requirements of a National Pollutant Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not discharge effluent containing this product to sewer systems without previously notifying the local sewage treatment plant authority. For guidance contact your State Water Board or Regional Office of the EPA.

STORAGE AND DISPOSAL

Do not contaminate water, food, or feed by storage or disposal.

STORAGE: Protect from freezing and temperatures in excess of 140 deg. F. Keep container closed when not in use. If contents are spilled or leaked due to container damage, collect liquid with absorbent material and dispose of in accordance with local, state and federal pesticide disposal regulations.

PESTICIDE DISPOSAL: Pesticide wastes are acutely hazardous. Improper disposal of excess pesticide, spray mixture, or rinsate is a violation of Federal Law. If these wastes cannot be disposed of by use according to label instructions, contact your State Pesticide or Environmental Control Agency, or the Hazardous Waste representative at the nearest EPA Regional Office for guidance.

CONTAINER DISPOSAL: Triple rinse (or equivalent). Then offer for recycling or reconditioning, or puncture and dispose of in a sanitary landfill, or by other procedures approved by state and local authorities.

ACCEPTED

309 24 1987

Under the Federal Insecticide, Fungicide, and Rodenticide Act as amended, for the pesticide, registered under EPA Reg. No. 1706-182

DIRECTIONS FOR USE

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

NOTE: Add RO Plus 7288 separately to the system. Do not mix it with other additives, in order to avoid decomposition of RO Plus 7288 due to high pH of many additive formulations.

BADLY FOULED SYSTEMS MUST BE CLEANED BEFORE TREATMENT IS BEGUN AFTER CLEANING, FLUSH SYSTEM WITH PERMEATE TO REMOVE ANY RESIDUAL CLEANER.

NALCO

**RO PLUS®
7288**

A MICROORGANISM CONTROL CHEMICAL FOR THE TREATMENT OF ULTRA FILTRATION UNITS AND NON-MEDICAL/NON-POTABLE REVERSE OSMOSIS MEMBRANES AND PERIPHERAL SYSTEMS

ACTIVE INGREDIENT:	
2,2-Dibromo-3-nitropropionamide.....	20%
INERT INGREDIENTS.....	80%
Total.....	100%

Weight/Cal. = 10.6 pounds

KEEP OUT OF REACH OF CHILDREN

DANGER

STATEMENT OF PRACTICAL TREATMENT

IF IN EYES: Immediately flush with plenty of water for at least 15 minutes. Call a physician.

IF ON SKIN: Immediately wash with soap and plenty of water. Remove contaminated clothing and wash before reuse. Get medical attention if irritation persists.

IF SWALLOWED: Immediately induce vomiting by giving two glasses of water and sticking finger down throat. Repeat until vomit is clear. Call a physician. Never give anything by mouth to an unconscious person.

SEE SIDE PANEL FOR ADDITIONAL PRECAUTIONARY STATEMENTS.

NALCO CHEMICAL COMPANY

6216 WEST 66TH PLACE CHICAGO, IL 60638

EMERGENCY TELEPHONE NUMBER
(800) 462-5378

FOR CONTROL OF BACTERIAL FOULING

For controlling bacterial fouling of ultra filtration units, non-medical or non-potable reverse osmosis membranes and peripheral systems (where approved for compatibility by the membrane manufacturer or demonstrated by other means to be compatible), add this product to the system inlet water or before any other contaminated area ahead of the Reverse Osmosis or Ultra-filtration unit. Addition should be made with a metering pump on an intermittent basis depending on the severity of contamination when treatment is begun, and the guidelines specified by the membrane manufacturer or demonstrated by other means to be compatible. During use of this product for ultrafiltration units and reverse osmosis membranes, both permeate and reject water should be directed to the drain. Once treatment has been completed, rinsing with feedwater should be continued until conductivity values in the permeate are at or below values before treatment with this product.

INITIAL DOSE: When the system is noticeably fouled, add 0.05-0.1 gal RO Plus 7288/1000 gal of feedwater (50-100 ppm). Repeat until control is achieved or as specified by guidelines recommended by the membrane manufacturer or demonstrated by other means to be compatible. Minimum contact time should be 15 minutes.

SUBSEQUENT DOSE: When microbial control is evident, add 0.025-0.1 gal RO Plus 7288/1000 gal of feedwater (24-100 ppm) as needed to maintain control or as specified by guidelines recommended by the membrane manufacturer or demonstrated by other means to be compatible.

<FOR INDUSTRIAL USE ONLY>

EPA REGISTRATION NO.: 1706-182
EPA ESTABLISHMENT NO.: 464-NI-1

PM 31 1706-182 6/24/97 Page 1-2/1