

**PRECAUTIONARY STATEMENTS  
HAZARDS TO HUMANS AND DOMESTIC  
ANIMALS**

**KEEP OUT OF REACH OF CHILDREN  
CAUTION. AVOID CONTACT WITH SKIN, EYES  
OR CLOTHING. In case of contact immediately flush  
eyes or skin with plenty of water. Get medical  
attention if irritation persists.**

**ENVIRONMENTAL HAZARDS**

This product is toxic to fish and aquatic vertebrates. Do not use in facilities discharging directly or indirectly to estuarine or marine environments. Do not discharge into lakes, streams, ponds, or public waters unless in accordance with the requirements of a National Pollutant Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not discharge effluent containing this product to sewer systems without previously notifying the sewage treatment plant authority. For guidance contact your State Water Board or Regional Office of the EPA.

Limit residues of Poly (dimethyldiallyl ammonium chloride) in the finished potable water to more than 50 ppm.

**STORAGE AND DISPOSAL**

**Prohibitions:** Do not contaminate water, food, or feed by storage, disposal. Keep container closed when not in use.

**Pesticide Disposal:** Pesticide wastes are toxic. Improper disposal of excess pesticide, spray mixture or rinsate is a violation of Federal law. If these wastes cannot be disposed of by use according to label instructions, contact your State Pesticide or Environmental Control Agency, or the Hazardous Waste representative at the nearest EPA Regional Office for guidance.

**Container Disposal:** Plastic Containers: Triple rinse (or equivalent). Then offer for recycling or reconditioning, or puncture and dispose of in a sanitary landfill, or by incineration, or, if allowed by State or Local authorities, by burning. If burned, stay out of smoke.

<sup>TM</sup> VeliGON is a trademark of Calgon Corporation



**VeliGON<sup>TM</sup> CL-M  
WATER TREATMENT FOR THE CONTROL OF  
MOLLUSCS IN WATER SUPPLIES**

**ACTIVE INGREDIENT**

Poly (dimethyldiallyl ammonium chloride).....	39.8%
<b>INERT INGREDIENTS.....</b>	<b>60.2%</b>
<b>Total.....</b>	<b>100.0%</b>

**KEEP OUT OF REACH OF CHILDREN  
CAUTION**

**FIRST AID**

- **IF IN EYES:** Hold eyes open and rinse slowly and gently with water for 15-20 minutes. Remove contact lenses, if present, after the first 5 minutes, then continue rinsing. Call a poison control center or doctor for treatment advice.
- **IF SWALLOWED:** Call a poison control center or doctor immediately for treatment advice. Have person sip a glass of water if able to swallow. Do not induce vomiting unless told by a poison control center or doctor.
- **IF ON SKIN:** Take off contaminated clothing. Rinse skin immediately with plenty of water for 15-20 minutes. Call a poison control center or doctor for treatment advice.
- **IF INHALED:** Move person to fresh air. If person is not breathing, call 911 or ambulances, then give artificial respiration, preferably mouth-to-mouth, if possible. Call a poison control center or doctor for treatment advice.
- Have the MSDS with you when calling a poison control center or a doctor, or going for treatment.

See side panel for additional precautionary statements.

EPA Reg. No. 1706-223      EPA Est. No. 1706-PA-01

**NET WEIGHT SHOWN ELSEWHERE ON CONTAINER**

**ONDEO Nalco Company  
Ondeo Nalco Center  
Naperville, IL 60563-1198  
EMERGENCY PHONE NO.: (800) 424-9300**

**DIRECTIONS FOR USE**

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

VeliGON CL-M should be added to the system at a rate of 0.6 fluid ounces of VeliGON CL-M per 1000 gallons of intake water. Additions should occur at a point sufficiently inside the intake pipe to prevent any release of VeliGON CL-M into the intake source (5 to 10 feet for normal flow operations). Addition should be made through a supply line placed inside the intake pipe or in some locations as to ensure that no contamination of public waters occurs in the event of a break. Feed exits must be equipped with a pressure check valve at the feed line exit to seal the feed line when intake flow stops. Feed pumps must be designed to shut down when intake pumps stop. Planned shut downs shall require feed pumps to be stopped 1/2 hour prior to shut down.

PDADMAC  
CERTIFIED TO ANSI/NSF 60



POTABLE WATER MAXIMUM NSF DOSAGE 25 MG/L  
PLANT No. 12: USA

**ACCEPTED**

JUN 05 2003

Under the Federal Insecticide, Fungicide, and Rodenticide Act as amended, for the pesticide, registered under EPA Reg. No. 1706-223

1706-223

6-5-2003

1/1  
SVEZ