

**PRECAUTIONARY STATEMENTS
HAZARDS TO HUMANS AND DOMESTIC
ANIMALS**

CAUTION. AVOID CONTACT WITH SKIN, EYES OR CLOTHING. In case of contact immediately flush eyes or skin with plenty of water. Get medical attention if irritation persists.

ENVIRONMENTAL HAZARDS

This product is toxic to fish and aquatic vertebrates. Do not use in facilities discharging directly or indirectly to estuarine or marine environments. Do not discharge into lakes, streams, ponds, or public waters unless in accordance with the requirements of a National Pollutant Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not discharge effluent containing this product to sewer systems without previously notifying the sewage treatment plant authority. For guidance contact your State Water Board or Regional Office of the EPA.

Limit residues of Poly (dimethyldiallyl ammonium chloride) in the finished potable water to more than 50 ppm.

STORAGE AND DISPOSAL

Prohibitions: Do not contaminate water, food, or feed by storage, disposal. Keep container closed when not in use.

Pesticide Disposal; Pesticide wastes are toxic. Improper disposal of excess pesticide, spray mixture or rinsate is a violation of Federal Law. If these wastes cannot be disposed of by use according to label instructions, contact your State Pesticide or Environmental Control Agency, or the Hazardous Waste representative at the nearest EPA Regional Office for guidance.

Container Disposal: Plastic Containers: Triple rinse (or equivalent). Then offer for recycling or reconditioning, or puncture and dispose of in a sanitary landfill, or by incineration, or, if allowed by State or Local authorities, by burning. If burned, stay out of smoke.

® VeligON is a trademark of Calgon Corporation



VeligON™ L-M

**WATER TREATMENT FOR THE CONTROL OF
MOLLUSCS IN WATER SUPPLIES**

ACTIVE INGREDIENTS

| | |
|---|--------------|
| Poly (dimethyldiallyl ammonium chloride)..... | 17.5% |
| INERT INGREDIENTS..... | 82.5% |
| Total..... | 100.0% |

**KEEP OUT OF REACH OF CHILDREN
CAUTION**

FIRST AID

- **IF IN EYES:** Hold eyes open and rinse slowly and gently with water for 15-20 minutes. Remove contact lenses, if present, after the first 5 minutes, then continue rinsing. Call a poison control center or doctor for treatment advice.
- **IF SWALLOWED:** Call a poison control center or doctor immediately for treatment advice. Have person sip a glass of water if able to swallow. Do not induce vomiting unless told by a poison control center or doctor.
- **IF ON SKIN:** Take off contaminated clothing. Rinse skin immediately with plenty of water for 15-20 minutes. Call a poison control center or doctor for treatment advice.
- **IF INHALED:** Move person to fresh air. If person is not breathing, call 911 or ambulances, then give artificial respiration, preferably mouth-to-mouth, if possible. Call a poison control center or doctor for treatment advice.
- Have the MSDS with you when calling a poison control center or a doctor, or going for treatment

See side panel for additional precautionary statements.

EPA Reg. No. 1706-224 EPA Est. No. 10445-PA-01
EPA Est. No. 10445-TX-01

**Ondeo Nalco Company
Ondeo Nalco Center
Naperville, IL 60563-1198**

EMERGENCY PHONE NO.: (800) 424-9300

DIRECTIONS FOR USE

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.


VeligON L-M should be added to the system at a rate of 0.68 fluid ounces of VeligON L-M per 1000 gallons of intake water. Additions should occur at a point sufficiently inside the intake pipe to prevent any release of VeligON L-M into the intake source (5 to 10 feet for normal flow operations). Addition should be made through a supply line placed inside the intake pipe or in some locations as to ensure that no contamination of public waters occurs in the event of a break. Feed exits must be equipped with a pressure check valve at the feed line exit to seal the feed line when intake flow stops. Feed pumps must be designed to shut down when intake pumps stop. Planned shut downs shall require feed pumps to be stopped ½ hour prior to shut down.

PDADMAC
CERTIFIED TO ANSI/NSF 60



POTABLE WATER MAXIMUM NSF DOSAGE 50 MG/L
PLANT No. 12: USA

NET CONTENTS SHOWN ELSEWHERE ON CONTAINER



SVEZ

1706-224

6-5-2003