

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
WASHINGTON, D.C. 20460



Office of Pesticide Programs

Nalco Company  
1601 West Diehl Road  
Naperville, IL 60563

FEB 26 2013

Attention: Linda J. Fane  
Regulatory Affairs/Commercial Biocides

**Subject: VeliGON TL-M**  
EPA Registration No. 1706-226  
Amendment Dated December 14, 2012

The amendment, submitted in connection with registration under the Federal Insecticide, Fungicide and Rodenticide Act (FIFRA), as amended, is acceptable.

**Proposed Amendment**

- Revised Product Labeling

**General Comments**

A stamped copy of the "accepted" product label is enclosed for your records.

If you have any questions concerning this letter, please contact Martha Terry at (703) 308-6217.

Sincerely

Marshall Swindell  
Product Manager 33  
Regulatory Management Branch 1  
Antimicrobials Division (7510P)

Enclosure

**PRECAUTIONARY STATEMENTS  
HAZARDS TO HUMANS AND  
DOMESTIC ANIMALS**

**KEEP OUT OF REACH OF CHILDREN  
CAUTION. AVOID CONTACT WITH SKIN, EYES OR CLOTHING.  
In case of contact immediately flush eyes or skin with plenty of water.  
Get medical attention if irritation persists.**

**ENVIRONMENTAL HAZARDS**  
This product is toxic to fish and aquatic vertebrates. Do not use in facilities discharging directly or indirectly to estuarine or marine environments. Do not discharge into lakes, streams, ponds, or public waters unless in accordance with the requirements of a National Pollutant Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not discharge effluent containing this product to sewer systems without previously notifying the sewage treatment plant authority. For guidance contact your State Water Board or Regional Office of the EPA.

Limit residues of Poly (dimethyldiallyl ammonium chloride) in the finished potable water to no more than 50 ppb (0.05 ppm).

**STORAGE AND DISPOSAL**

**Prohibitions:** Do not contaminate water, food, or feed by storage, disposal. Keep container closed when not in use.

**Pesticide Disposal:** Pesticide wastes are toxic. Improper disposal of excess pesticide, spray mixture or rinsate is a violation of Federal Law. If these wastes cannot be disposed of by use according to label instructions, contact your State Pesticide or Environmental Control Agency, or the Hazardous Waste representative at the nearest EPA Regional Office for guidance.

**(Instructions for refillable containers:)**

**Container Disposal:** Refillable container. Refill this container with pesticide only. Do not reuse this container for any other purpose. Cleaning the container before final disposal is the responsibility of the person disposing of the container. Cleaning before refilling is the responsibility of the refiller. To clean the container before final disposal, empty the remaining contents from this container into application equipment or mix tank. Fill the container about 10 percent full with water. Agitate vigorously or recirculate water with the pump for 2 minutes. Pour or pump rinsate into application equipment or rinsate collection system. Repeat this rinsing procedure two more times. Then offer for recycling, if available, or reconditioning, or puncture and dispose of in a sanitary landfill, or by other procedure approved by state and local authorities.

**(Instructions for non-refillable containers greater than 5 gallons:)**

**Container Disposal:** Non-refillable container. Do not reuse or refill this container. Offer for recycling, if available. Triple rinse (or equivalent) container promptly after emptying. Triple rinse as follows: Empty remaining contents into application equipment or a mix tank. Fill the container 1/4 full with water. Replace and tighten closures. Tip container on its side and roll it back and forth, ensuring at least one complete revolution, for 30 seconds. Stand the container on its end and tip it back and forth several times. Turn the container over onto its other end and tip it back and forth several times. Empty the rinsate into application equipment or a mix tank or store rinsate for later use or disposal. Repeat this procedure two more times. Then offer for recycling, if available, or reconditioning, or puncture and dispose of in a sanitary landfill, or by other procedure approved by state and local authorities.

**(Instructions for non-refillable containers 5 gallons or less:)**

Revised: 10/22/2012

PRODUCT IS NOT REGULATED DURING TRANSPORTATION

**Container Disposal:** Non-refillable container. Do not reuse or refill this container. Offer for recycling, if available. Triple rinse (or equivalent) container promptly after emptying. Triple rinse as follows: Empty remaining contents into application equipment or a mix tank and drain for 10 seconds after the flow begins to drip. Fill the container 1/4 full with water and recap. Shake for 10 seconds. Pour rinsate into application equipment or a mix tank or store rinsate for later use or disposal. Drain for 10 seconds after the flow begins to drip. Repeat this procedure two more times. Then offer for recycling, if available, or reconditioning, or puncture and dispose of in a sanitary landfill, or by other procedure approved by state and local authorities.



**VelIGON™ TL-M**

**WATER TREATMENT FOR THE CONTROL OF MOLLUSCS IN  
WATER SUPPLIES**

**ACTIVE INGREDIENTS**

Poly (dimethyldiallyl ammonium chloride).....	19.8%
INERT INGREDIENTS.....	80.2%
Total.....	100.0%

**KEEP OUT OF REACH OF CHILDREN  
CAUTION**

**FIRST AID**

- IF IN EYES: Hold eyes open and rinse slowly and gently with water for 15-20 minutes. Remove contact lenses, if present, after the first 5 minutes, then continue rinsing. Call a poison control center or doctor for treatment advice.
- IF SWALLOWED: Call a poison control center or doctor immediately for treatment advice. Have person sip a glass of water if able to swallow. Do not induce vomiting unless told by a poison control center or doctor.
- IF ON SKIN: Take off contaminated clothing. Rinse skin immediately with plenty of water for 15-20 minutes. Call a poison control center or doctor for treatment advice.
- IF INHALED: Move person to fresh air. If person is not breathing, call 911 or ambulances, then give artificial respiration, preferably mouth-to-mouth, if possible. Call a poison control center or doctor for treatment advice.
- Have the MSDS with you when calling a poison control center or a doctor, or going for treatment.

See side panel for additional precautionary statements.

EPA Reg. No. 1706-226	EPA Est. No. 1706-PA-01
	EPA Est. No. 1706-CA-01
	EPA Est. No. 1706-LA-01
	EPA Est. No. 68708-WY-1

**Nalco Company**

1601 West Diehl Road  
Naperville, IL 60563-1198  
EMERGENCY PHONE NO.: (800) 424-9300

DI

It is a violation of Federal Law with its labeling.

VelIGON TL-M should be used of VelIGON TL-M per 1 occur at a point sufficient; VelIGON TL-M into the operations). Addition show the intake pipe or in some public waters occurs in the with a pressure check valve pumps stop. Planned shut hour prior to shut down.

NET CONTENTS SHOWN EL

MA  
PLA  
A  
with  
EPA  
FEI

Under the Fed  
Fungicide, and  
amended, for r  
registered unde  
1706-

2/3

**MENTS  
AND  
S**

**CHILDREN**

**in with plenty of water.**

**ARDS**

ites. Do not use in facilities  
r marine environments. Do  
: public waters unless in  
tional Pollutant Discharge  
rmitting authority has been  
ischarge effluent containing  
usly notifying the sewage  
your State Water Board or

am chloride) in the finished

**SAL**

storage, disposal. Keep container  
disposal of excess pesticide, spray  
astes cannot be disposed of by use  
or Environmental Control Agency,  
gional Office for guidance.

ainer with pesticide only. Do not  
ntainer before final disposal. is the  
Cleaning before refilling is the  
inal disposal, empty the remaining  
mix tank. Fill the container about  
ulate water with the pump for 2  
r rinseate collection system. Repeat  
ing, if available, or reconditioning,  
r procedure approved by state and

**can 5 gallons:)**

re or refill this container. Offer for  
r promptly after emptying. Triple  
equipment or a mix tank. Fill the  
Triple container on its side and roll it  
or 30 seconds. Stand the container  
c container over onto its other end  
nto application equipment or a mix  
procedure two more times. Then  
culture and dispose of in a sanitary  
authorities.  
**or less:)**

**Container Disposal:** Non-refillable container. Do not reuse or refill this container. Offer for recycling, if available. Triple rinse (or equivalent) container promptly after emptying. Triple rinse as follows: Empty remaining contents into application equipment or a mix tank and drain for 10 seconds after the flow begins to drip. Fill the container 1/4 full with water and recap. Shake for 10 seconds. Pour rinseate into application equipment or a mix tank or store rinseate for later use or disposal. Drain for 10 seconds after the flow begins to drip. Repeat this procedure two more times. Then offer for recycling, if available, or reconditioning, or puncture and dispose of in a sanitary landfill, or by other procedure approved by state and local authorities.



**VeliGON™ TL-M**

**WATER TREATMENT FOR THE CONTROL OF MOLLUSCS IN WATER SUPPLIES**

**ACTIVE INGREDIENTS**

Poly (dimethylallyl ammonium chloride).....	19.8%
INERT INGREDIENTS.....	80.2%
Total.....	100.0%

**KEEP OUT OF REACH OF CHILDREN**

**CAUTION**

**FIRST AID**

- IF IN EYES: Hold eyes open and rinse slowly and gently with water for 15-20 minutes. Remove contact lenses, if present, after the first 5 minutes, then continue rinsing. Call a poison control center or doctor for treatment advice.
- IF SWALLOWED: Call a poison control center or doctor immediately for treatment advice. Have person sip a glass of water if able to swallow. Do not induce vomiting unless told by a poison control center or doctor.
- IF ON SKIN: Take off contaminated clothing. Rinse skin immediately with plenty of water for 15-20 minutes. Call a poison control center or doctor for treatment advice.
- IF INHALED: Move person to fresh air. If person is not breathing, call 911 or ambulances, then give artificial respiration, preferably mouth-to-mouth, if possible. Call a poison control center or doctor for treatment advice.
- Have the MSDS with you when calling a poison control center or a doctor, or going for treatment.

See side panel for additional precautionary statements.

EPA Reg. No. 1706-226  
EPA Est. No. 1706-PA-01  
EPA Est. No. 1706-CA-01  
EPA Est. No. 1706-LA-01  
EPA Est. No. 68708-WY-1

**Nalco Company**

1601 West Diehl Road  
Naperville, IL 60563-1198

**EMERGENCY PHONE NO.: (800) 424-9300**

**PRODUCT IS NOT REGULATED DURING TRANSPORTATION**

**DIRECTIONS FOR USE**

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

VeliGON TL-M should be added to the system at a rate of 0.6 fluid ounces of VeliGON TL-M per 1000 gallons of intake water. Additions should occur at a point sufficiently inside the intake pipe to prevent any release of VeliGON TL-M into the intake source (5 to 10 feet for normal flow operations). Addition should be made through a supply line placed inside the intake pipe or in some locations as to ensure that no contamination of public waters occurs in the event of a break. Feed exits must be equipped with a pressure check valve at the feed line exit to seal the feed line when intake flow stops. Feed pumps must be designed to shut down when intake pumps stop. Planned shut downs shall require feed pumps to be stopped 1/2 hour prior to shut down.



Certified to NSF/ANSI 60

OFFICIAL NAME: PDA2MAC

MAXIMUM NSF DOSAGE - 50 MG/L  
PLANTS NO. 109, 111 AND 140: USA

**NET CONTENTS SHOWN ELSEWHERE ON CONTAINER**

**ACCEPTED  
With COMMENTS  
EPA Letter Dated:**

**FEB 26 2013**

*Under the Federal Insecticide, Fungicide, and Rodenticide Act as amended, for the pesticide registered under EPA Reg. No.*

*1706-226*