

1706-231

02/02/2010

1/4



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
WASHINGTON, DC 20460

FEB - 2 2010

OFFICE OF  
PREVENTION,  
PESTICIDES  
AND TOXIC SUBSTANCES

Juli Mann  
Paralegal Specialist  
1330 Connecticut Avenue, NW  
Washington, DC 20036-1795

Subject: **AG-451**  
EPA Registration Number: 1706-231  
Notification Date: January 15, 2010  
EPA Receipt Date: January 15, 2010

Dear Ms. Mann:

This will acknowledge receipt of your notification, submitted under the provisions of PR Notice 2007-4.

**Proposed Notification:**

- Updating Container Disposal statements
- Editorial correction of a typographical error
- Addition of statement to aid in identification of the proper establishment number

**General Comment:**


Based on a review of the submitted materials, your notification to update the Container Disposal statements, correct a typographical error, and to add a statement to aid in the identification of the proper establishment number is acceptable and a part of the records on file.

Should you have any questions concerning this letter, please contact Heather Garvie at (703) 308-0034 or by email address at [garvie.heather@epa.gov](mailto:garvie.heather@epa.gov).

Sincerely,

A handwritten signature in cursive script, appearing to read "Jacqueline McFarlane".

Jacqueline McFarlane  
(Acting) Product Manager (34)  
Regulatory Management Branch II  
Antimicrobials Division (7510P)

United States <b>EPA Environmental Protection Agency</b> Washington, DC 20460		<b>Registration</b> <input type="checkbox"/> Amendment <input checked="" type="checkbox"/> Other	OPP Identifier Number
<b>Application for Pesticide – Section I</b>			
1. Company/Product Number 1706-231		2. EPA Product Manager ShaRon Carlisle	
4. Company/Product (Name) <b>AG-451</b>		3. Proposed Classification <input checked="" type="checkbox"/> None <input type="checkbox"/> Restricted	
5. Name and Address of Applicant (Include ZIP Code) Nalco Company 1601 West Diehl Road Naperville, IL 60563  <input type="checkbox"/> Check if this is a new address		6. <b>Expedited Review.</b> In accordance with FIFRA Section 3(c)(3) (b)(i), my product is similar or identical in composition and labeling to: EPA Reg. No. _____  Product Name _____	
<b>Section - II</b>			
<input type="checkbox"/> Amendment – Explain below. <input type="checkbox"/> Resubmission in response to Agency letter dated _____ <input checked="" type="checkbox"/> Notification – Explain Below.		<input type="checkbox"/> Final printed labels in response to Agency letter dated _____ <input type="checkbox"/> "Me Too" Application <input type="checkbox"/> Other – Explain Below.	
<b>Explanation:</b> Use additional page(s) if necessary. (For Section I and Section II.) <b>Notification of label changes to incorporate revised container handling statements per PR Notice 2007-4 and an additional minor label revision and typographical correction per PR Notice 98-10.</b> This notification is consistent with the guidance in PR Notice 2007-4 and PR Notice 98-10 and the requirements of EPA's regulations at 40 CFR §§ 152.46, 156.10, 156.140, 156.144, 156.146, and 156.156. No other changes have been made to the labeling or the Confidential Statement of Formula for this product. I understand that it is a violation of 18 U.S.C. Sec. 1001 to willfully make any false statement to EPA. I further understand that if the amended label is not consistent with the requirements of 40 CFR §§ 152.46, 156.10, 156.140, 156.144, 156.146, and 156.156, this product may be in violation of FIFRA and I may be subject to enforcement action and penalties under sections 12 and 14 of FIFRA. <b>FORWARD CORRESPONDENCE for this action to: Juli Mann, Steptoe &amp; Johnson LLP, 1330 Connecticut Ave., NW, Washington, D.C. 20036.</b>			
<b>Section - III</b>			
<b>1. Material This Product Will Be Packaged In:</b>			
Child-Resistant Packaging <input type="checkbox"/> Yes <input type="checkbox"/> No	Unit Packaging <input type="checkbox"/> Yes <input type="checkbox"/> No	Water Soluble Packaging <input type="checkbox"/> Yes <input type="checkbox"/> No	2. Type of Container <input type="checkbox"/> Metal <input type="checkbox"/> Plastic <input type="checkbox"/> Glass <input type="checkbox"/> Paper <input type="checkbox"/> Other (Specify) _____
* <b>Certification must be submitted</b> If "Yes" Unit Packaging wgt.    No. per Container		If "Yes" Packaging wgt.    No. per Container	
3. Location of Net Contents Information <input type="checkbox"/> Label <input type="checkbox"/> Container		4. Size(s) Retail Container	
5. Location of Label Directions <input type="checkbox"/> On Label <input type="checkbox"/> On Labeling accompanying product		6. Manner in Which Label is Affixed to Product <input type="checkbox"/> Lithograph <input type="checkbox"/> Other _____ <input type="checkbox"/> Paper Glued <input type="checkbox"/> Stenciled	
<b>Section - IV</b>			
<b>1. Contact Point (Complete items directly below for identification of individual to be contacted, if necessary, to process this application...)</b>			
Name Juli Mann		Title Paralegal Specialist, Steptoe & Johnson	
		Telephone No. (Include Area Code) 202-429-3095	
<b>Certification</b> I certify that the statements I have made on this form and all attachments thereto are true, accurate and complete and I acknowledge that any knowingly false or misleading statement may be punishable by fine or imprisonment or both under applicable law			6. Date Application Received (Stamped)    
2. Signature 		3. Title Paralegal Specialist, Agent for Nalco Company	
4. Typed Name Juli Mann		5. Date January 15, 2010	

STEP TOE & JOHNSON LLP  
ATTORNEYS AT LAW

WRITER'S DIRECT DIAL  
202.429.3095

1330 Connecticut Avenue, NW  
Washington, DC 20036-1795  
Tel 202.429.3000  
Fax 202.429.3902  
step toe.com

January 15, 2010

*Via Hand Delivery*

ShaRon Carlisle, Acting Product Manager 34  
Antimicrobials Division (AD)  
c/o Document Processing Desk (NOTIF)  
Office of Pesticide Programs (7510P)  
U.S. Environmental Protection Agency  
Room S-4900, One Potomac Yard  
2777 South Crystal Drive  
Arlington, VA 22202-4501

**Re: Notification to update label per PR Notice 2007-4 and PR Notice 98-10**

**Product: AG-451 (EPA Reg. No. 1706-231)**

Dear Ms. Carlisle:

Please find enclosed a notification to update the container handling statements per PR Notice 2007-4. Additionally, the following minor label revisions were incorporated:


- A statement to aid in identification of the proper establishment number.
- A correction of a typographic error in the last sentence of the Personal Protective Equipment paragraph: "PE" was changed to "PPE."

The revised and updated language is highlighted in yellow on the enclosed label.

Documents included with this submission include an Application Form (EPA Form 8570-1) and one copy of the updated label.

Correspondence for this matter should be sent to me at the Washington, D.C. address identified above. If you require any further information please contact me at (202) 429-3095. Thank you for your attention to this matter.

Sincerely,



Juli Mann  
Paralegal Specialist



INDUSTRIAL MICROBIOCIDES

ACTIVE INGREDIENT:  
2,2-Dibromo-3-nitropropionamide.....5%  
INERT INGREDIENTS.....95%  
TOTAL.....100%

Weight: 9.6 lbs./gal. (1.15 kg/liter)

## KEEP OUT OF REACH OF CHILDREN DANGER

### FIRST AID

- IF IN EYES: Hold eye open and rinse slowly and gently with water for 15-20 minutes. Remove contact lenses, if present, after the first 5 minutes, then continue rinsing. Call a poison control center or doctor for treatment advice.
- IF INHALED: Move person to fresh air. If person is not breathing, call 911 or an ambulance, then give artificial respiration, preferably mouth-to-mouth if possible. Call a poison control center or doctor for further treatment advice.
- IF SWALLOWED: Call a poison control center or doctor immediately for treatment advice. Have person sip a glass of water if able to swallow. Do not induce vomiting unless told by a poison control center or doctor. Do not give anything to an unconscious person.
- IF ON SKIN: Take off contaminated clothing. Rinse skin immediately with plenty of water for 15-20 minutes. Call a poison control center or doctor for treatment advice.

NOTE TO PHYSICIAN: Probable mucosal damage may contraindicate the use of gastric lavage. Measures against circulatory shock, respiratory depression and convulsion may be needed. Have the product container or label with you when calling a poison control center or doctor or going to treatment.

For emergency information on AG-451 call the National Pesticides Information Center at 1-800-858-7378, 6:30 AM to 4:30 PM Pacific time (PT), seven days a week. During other times, call the poison control center 1-800-222-1222.

### PERSONAL PROTECTIVE EQUIPMENT

Applicators and other handlers must wear: coveralls over long-sleeved shirt and long pants, socks and chemical-resistant footwear, goggles or face shield, and chemical resistant gloves (such as barrier laminate or butyl nitrile/neoprene rubber, PVC, or viton).

Follow manufacturer's instructions for cleaning/maintaining PPE. If no such instructions for washables, use detergent and hot water. Keep and wash PPE separately from other laundry.

### User Safety Recommendations

Users must wash hands before eating, drinking, chewing gum, using tobacco, or using the toilet. Users must remove clothing immediately if pesticide gets inside. Then wash thoroughly and put on clean clothing. Users must remove PPE immediately after handling this product. Wash the outside of gloves before removing. As soon as possible, wash thoroughly and change into clean clothing.

### Application Restrictions:

Do not apply this product in a way that will contact workers or other persons, either directly or through drift. Only protected handlers may be in the area during application.

### Engineering Controls:

When handlers use closed metering systems the handler requirements may be reduced or modified to long-sleeved shirt, long pants, shoes and socks.

### PRECAUTIONARY STATEMENTS

#### HAZARDS TO HUMANS AND DOMESTIC ANIMALS

**DANGER. CORROSIVE:** Causes irreversible eye damage. May be fatal if inhaled or swallowed. Causes skin irritation. Do not get in eyes, on skin or on clothing. Do not breathe dust. When loading or handling wear protective eyewear (goggles or face shield), long-sleeved shirt and long pants, socks, shoes, chemically resistant gloves and a NIOSH approved respirator. Prolonged or frequently repeated skin contact may cause allergic reactions in some individuals. Wash thoroughly with soap and water after handling and before eating, drinking, chewing gum, or using tobacco. Remove and wash contaminated clothing separated from other before reuse.

### ENVIRONMENTAL HAZARDS

This pesticide is toxic to fish and invertebrates. Do not discharge effluent containing this product into lakes, streams, ponds, estuaries, oceans, or other waters unless in accordance with the requirements of a National Pollutant Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Secondary biological treatment of DBNPA effluent is required for all uses except for use in secondary oil recovery systems. Do not discharge effluent containing this product to sewer systems without previously notifying the local sewage treatment plant authority. For guidance, contact your State Water Board or Regional Office of the EPA.

### DIRECTION FOR USE

It is a violation of Federal Law to use this product in a manner inconsistent with its labeling.

Controls bacteria, fungi, and algae in industrial recirculating water cooling tower systems, and in once-through fresh and seawater industrial cooling water systems; controls slime-forming bacteria and fungi, and yeasts in paper mills, metalworking fluids containing water, and enhanced oil recovery systems.

NOTE: Add AG-451 separately to the system. Do not mix it with other additives, in order to avoid decomposition of AG-451 due to the high pH of many additive formulations.

### IN RECIRCULATING WATER SYSTEMS

AG-451 aids in the control of bacterial, fungal, and algal slimes in evaporative condensers, commercial and industrial cooling towers, industrial water scrubbing systems, and brewery pasteurizers. For optimum performance, add AG-451 at a point of uniform mixing. Addition may be continuous or intermittent (slug) depending on the severity of contamination when treatment is begun. When a metering pump is not used for addition, care should be exercised in handling. Refer to precautionary statements.

Badly fouled systems must be cleaned before treatment is begun.

### FOR THE CONTROL OF BACTERIA

**INTERMITTENT (SLUG) METHOD - INITIAL DOSE:** When the system is noticeably fouled, add 2.4 - 4.9 fluid ounces of AG-451 per 1000 gallon of water in the system (22-44 ppm). Repeat until control is achieved.

**SUBSEQUENT DOSE:** When microbial control is evident, add 1.2 - 4.8 fluid ounces of AG-451 per 1000 gallons of water in the system (11 - 44 ppm) every four days or as needed to maintain control.

**CONTINUOUS FEED METHOD - INITIAL DOSE:** When the system is noticeably fouled, 2.4 - 4.9 fluid ounces of AG-451 per 1000 gallon of water in the system (22-44 ppm).

**SUBSEQUENT DOSE:** Maintain this level by pumping a continuous feed of 0.5 - 2.4 fluid ounces of AG-451 per 1000 gallon of water (4 - 22 ppm) lost from the system by bleedoff.

### FOR CONTROL OF FUNGI AND ALGAE

**INTERMITTENT OR SLUG METHOD - INITIAL DOSE:** When the system is noticeably fouled, add 25 - 49 fluid ounces of AG-451 per 1000 gallon of water in the system (221-438 ppm). Repeat until control is achieved.

**SUBSEQUENT DOSE:** When microbial control is evident, add 15 - 49 fluid ounces of AG-451 per 1000 gallon of water in the system (135-438 ppm) daily, or as needed to maintain control.

**CONTINUOUS FEED METHOD - INITIAL DOSE:** When the system is noticeably fouled add 25 - 49 fluid ounces of AG-451 per 1000 gallon of water in the system (221-438 ppm).

**SUBSEQUENT DOSE:** Maintain treatment level by pumping a continuous feed of 15 - 49 fluid ounces of AG-451 per 1000 gallon of water in the system (135-438 ppm) per day. Badly fouled systems must be cleaned before treatment is begun.

### IN PAPER MILLS

For control of bacterial, fungal, and yeast growths in pulp, paper and paperboard mills, add AG-451 at the rate of 7.7 - 19.2 fluid ounces per ton of pulp or paper (dry basis). Addition may be continuous or intermittent, depending upon the type of system and the severity of the contamination. It should be made with a metering pump at a location that will ensure uniform distribution of AG-451 in the mass of fiber and water, such as the beaters, jordan inlet or discharge, broke chest, furnish chests, save-alls, and white-water tanks.

Heavily fouled systems should be boiled out, then treated with 7.7 - 19.2 fluid ounces of AG-451 per ton of paper (dry basis), as necessary for control. Moderately fouled systems should be treated continuously with 19.2 - 25.9 fluid ounces of AG-451 per ton of paper (dry basis) until the slime accumulation is controlled. Additional rates can then be reduced to 7.7 - 19.2 fluid ounces of AG-451 per ton of paper on a continuous or intermittent basis, as needed for control. Dislodged slime may cause breaks in the paper and a clean up of the paper machine may be advisable. Slightly fouled systems should be treated continuously with 7.7 - 19.2 fluid ounces of AG-451 per ton of paper (dry basis) until the slime is controlled, then added on an intermittent basis to maintain control.

### IN AIR WASHER SYSTEMS

Add 1 - 32 fluid ounces of AG-451 per 1000 gallons of water in the system (9-285 ppm), depending on the severity of the contamination to control slime-forming bacteria and fungi in the industrial air washing system. NOTE: For use only in industrial air washer systems that maintain effective mist eliminating components. Badly fouled systems must be cleaned before treatment is begun.

**INTERMITTENT (SLUG) METHOD - INITIAL DOSE:** When the system is noticeably fouled, add 20 - 32 fluid ounces of AG-451 per 1000 gallon of water in the system (178-285 ppm). Repeat until control is achieved.

**SUBSEQUENT DOSE:** When microbial control is evident, add 1 - 16 fluid ounces of AG-451 per 1000 gallon of water in the system (9-142 ppm) every 2 days or as needed to maintain control.

**CONTINUOUS FEED METHOD - INITIAL DOSE:** When the system is noticeably fouled add 20 - 32 fluid ounces of AG-451 per 1000 gallon of water in the system (178-285 ppm).

**SUBSEQUENT DOSE:** Maintain treatment level by pumping a continuous feed of 1 - 16 fluid ounces of AG-451 per 1000 gallon of water in the system (9-142 ppm) per day.

### IN METALWORKING FLUIDS CONTAINING WATER

This product is effective in metalworking fluid concentrates which have been diluted with water at ratios of 1:100 - 1:4. For controlling (or inhibiting) the growth of bacteria, fungi, and yeasts that may deteriorate metalworking fluids that contain water, add AG-451 to the fluid collection tank. Additions should be made with a metering pump.

**INTERMITTENT (SLUG) METHOD - INITIAL DOSE:** When the system is noticeably fouled, add 1.0 gallon of AG-451 per 1000 gallons of metalworking fluid to the system. Repeat until control is achieved. **SUBSEQUENT DOSE:** When microbial control is evident, add 0.4 - 0.8 gallons of AG-451 per 1000 gallons of metalworking fluid per day, or as needed to maintain control. Additions can be made continuously or intermittently. Slug the system as required.

### ONCE-THROUGH INDUSTRIAL COOLING WATER SYSTEMS

For controlling bacteria, fungi, and algae in once-through and closed-cycle fresh air-cooled water cooling systems, cooling ponds, canals & lagoons, add AG-451 to the system inlet water or before other contaminated areas in the system. Addition should be made with a metering pump. It may be continuous or intermittent depending on severity of contamination when treatment is begun, and retention time in system.

DOT: NOT REGULATED DURING TRANSPORTATION, PER 49CFR 173.154(D), IF TRANSPORTED IN PACKAGE COMPATIBLE WITH THIS MATERIAL  
ICAO & IMDG: UN3265, CORROSIVE LIQUID, ACIDIC, ORGANIC, N.O.S. (DBNPA: 2,2-Dibromo-3-Nitropropionamide), 8, PG III

### FOR CONTROL OF BACTERIA

**INTERMITTENT METHOD - INITIAL DOSE:** When the system is noticeably fouled, add 24-48 ppm AG-451. Minimum treatment intervals should be 15 minutes. Repeat until control is achieved. **SUBSEQUENT DOSE:** When microbial control is evident, add 12-48 ppm AG-451 intermittently as needed to maintain control.

**CONTINUOUS FEED METHOD - INITIAL DOSE:** When the system is noticeably fouled, add 24-48 ppm AG-451 continuously to the system. **SUBSEQUENT DOSE:** When microbial control is evident, pump a continuous feed of 4-24 ppm AG-451 continuously to the system. Badly fouled systems must be cleaned before treatment is begun.

### FOR CONTROL OF FUNGI AND ALGAE

**INTERMITTENT METHOD - INITIAL DOSE:** When the system is noticeably fouled add 240-472 ppm AG-451 to the system. The minimum treatment interval should be 15 minutes. Repeat until control is achieved. **SUBSEQUENT DOSE:** When microbial control is evident, add 144-472 ppm AG-451 to the system daily, or as needed to maintain control. The minimum treatment interval should be 15 minutes. Badly fouled systems must be cleaned before treatment is begun.

**CONTINUOUS FEED METHOD - INITIAL DOSE:** When the system is noticeably fouled add 240-472 ppm AG-451 to the system. **SUBSEQUENT DOSE:** When microbial control is evident, pump a continuous feed of 144-472 ppm AG-451 to the system. Badly fouled systems must be cleaned before treatment is begun.

### IN ENHANCED OIL RECOVERY SYSTEMS

For controlling slime-forming bacteria, yeasts and fungi in oil field water, polymer or mycelar floods, water disposal systems, or other oil field water systems, add 0.4 - 25 gallons of AG-451 per 2400 barrels of water, depending on the severity of contamination. Additions should be made with a metering pump either continuously or intermittently.

**CONTINUOUS FEED METHOD:** When the system is noticeably fouled, add 3.2 - 25 gallons of AG-451 per 2400 barrels of water continuously until the desired degree of control is achieved. Subsequently treat with 0.4 - 4.8 gallons of AG-451 per 2400 barrels of water continuously or as needed to maintain control.

**INTERMITTENT (SLUG) METHOD:** When the system is noticeably fouled, or to maintain control of the system, add 3.2 - 25 gallons of AG-451 per 2400 barrels of water intermittently for 4-8 hours per day or as needed depending on the severity of contamination. Addition of AG-451 may be made at the free water knockouts, before or after the injection pumps and injection well headers. NOTE: For control of bacteria, yeast and fungi in aqueous solutions of biopolymer used in flooding operations, add 4.8 - 25 gallons of AG-451 per 2400 barrels of water. Additions of AG-451 should be made with a metering pump immediately after the preparation of the aqueous biopolymer solution to prevent loss of viscosity.

### STORAGE AND DISPOSAL

Do not contaminate water, food, or feed by storage or disposal.

**PESTICIDE STORAGE:** To maintain product quality, store at temperatures below 60°C. Keep container tightly closed when not in use.

**PESTICIDE DISPOSAL:** Pesticide wastes are acutely hazardous. Improper disposal of excess pesticide, spray mixture, or rinsate is a violation of Federal Law. If these wastes cannot be disposed of by use according to label instructions, contact your State Pesticide or Environmental Control Agency, or the Hazardous Waste representative at the nearest EPA Regional Office for guidance.

(Instructions for refillable containers:)

**CONTAINER HANDLING:** Refillable container. Refill this container with pesticide only. Do not reuse this container for any other purpose. Cleaning the container before final disposal is the responsibility of the person disposing of the container. Cleaning before refilling is the responsibility of the refiller. To clean the container before final disposal, empty the remaining contents from this container into application equipment or mix tank. Fill the container about 10 percent full with water. Agitate vigorously or recirculate water with the pump for 2 minutes. Pour or pump rinsate into application equipment or rinsate collection system. Repeat this rinsing procedure two more times. Then offer for recycling, if available, or reconditioning, or puncture and dispose of in a sanitary landfill, or by other procedure approved by state and local authorities.

(Instructions for non-refillable containers greater than 5 gallons:)

**CONTAINER HANDLING:** Non-refillable container. Do not reuse or refill this container. Triple rinse (or equivalent) container promptly after emptying. Triple rinse as follows: Empty remaining contents into application equipment or a mix tank. Fill the container ¼ full with water. Replace and tighten closures. Tip container on its side and roll it back, ensuring at least one complete revolution, for 30 seconds. Stand the container on its end and tip it back and forth several times. Turn the container over onto its other end and tip it back and forth several times. Empty the rinsate into application equipment or a mix tank or store rinsate for later use or disposal. Repeat this procedure two more times. Then offer for recycling, if available, or reconditioning, or puncture and dispose of in a sanitary landfill, or by other procedure approved by state and local authorities.

(Instructions for non-refillable containers 5 gallons or less:)

**CONTAINER HANDLING:** Non-refillable container. Do not reuse or refill this container. Triple rinse (or equivalent) container promptly after emptying. Triple rinse as follows: Empty remaining contents into application equipment or a mix tank and drain for 10 seconds after the flow begins to drip. Fill the container ¼ full with water and recap. Shake for 10 seconds. Pour rinsate into application equipment or a mix tank or store rinsate for later use or disposal. Drain for 10 seconds after the flow begins to drip. Repeat this procedure two more times. Then offer for recycling, if available, or reconditioning, or puncture and dispose of in a sanitary landfill, or by other procedure approved by state and local authorities.

NET CONTENTS SHOWN ELSEWHERE ON CONTAINER.

EPA REG. NO. 1706-231

EPA EST. NO. 1706-PA-1

EPA EST. NO. 1706-OH-1

Letters in ( ) that match the prefix in batch number identify the establishment number

Nalco Company

1601 West Diehl Road

Naperville, IL 60563-1198

Emergency Phone No.: (800) 424-9300

[Batch/Lot Number: \_\_\_\_\_] Note to EPA Reviewer: Batch/Lot number may or may not appear on the label.