

Net Contents Gallons

ACCEPTED
OCT 9 1975
8759
1760-27

AMPICIDE 9

ACTIVE INGREDIENTS
Disodium cyanodithioimidocarbonate ... 3.68 per cent
Potassium N-methyldithiocarbamate 5.07 per cent
INERT INGREDIENT: Water by weight 91.25%

Weight per gallon 8.81 lbs.
Weight of active ingredient 0.77 lbs.

WARNING

KEEP OUT OF THE REACH OF CHILDREN

Causes eye damage and skin irritation. Do not get in eyes, on skin, or on clothing. Wear goggles or face shield and rubber gloves when handling. Harmful or fatal if swallowed. Avoid contamination of food.

FIRST AID: In case of contact, immediately flush eyes or skin with plenty of water for at least 15 minutes. For eyes, call a physician. Remove and wash contaminated clothing before reuse.

If swallowed, give patient doses of powdered charcoal immediately or all he can swallow of raw egg white, milk, gruel, or flour and water. Then induce vomiting with salt, soap or mustard in warm water. Call a physician immediately.

Do not reuse empty drum. Return to drum conditioner or destroy by perforating or crushing and burying in a safe place.

This product is toxic to fish. Treated effluent should not be discharged where it will drain into lakes, streams, ponds or public water. Apply this product only as specified on this label.

APPLICATIONS

AMPICIDE 9 is used to inhibit the growth of algae, bacteria and fungi, in recirculating commercial and industrial cooling water systems. Before treatment with AMPICIDE 9 systems must be cleaned to remove algal growth, microbiological slime and other deposits. Then the system should be treated with an initial slug addition of 6.9 to 13.9 fluid ounces of AMPICIDE 9 per 1,000 gallons of water in the system. Repeat the initial dosage until control is evident. Subsequent slug additions of 2.3 to 13.9 fluid ounces of AMPICIDE 9 per 1,000 gallons of water should be made every 1 to 5 days or as needed. The required frequency of treatment depends on the relative amount of bleedoff and the severity of the microbiological problem. Slug additions of AMPICIDE 9 should be made into the sump of water cooling towers.

Manufactured By

AMPION CORPORATION

4 88 47th Avenue

Long Island City, New York 11101

EPA Reg No. 1760-27