NATIONAL

CINVAC.

For Use in Industrial Recirculating Water Cooling Towers under 25,000 Tons, Where Treated Effluent Is Discharged into A Sanitary Sewage System or Similar Sewage Treatment Facility, for Control of Algae and to Reduce The Number of Living Algae.

Do Not Use Where Cooling Tower Effluent Is Discharged Directly into Lakes, Ponds, Streams or Public Waters.

ACTIVE INGREDIENT:

CAUTION:

KEEP OUT OF REACH OF CHILDREN HARMFUL IF SWALLOWED AVOID CONTAMINATION OF FOOD AND FEED

EPA Reg. No. 1769-234-AA

NET CONTENTS:

NATIONAL CHEMSEARCH 2727 CHEMSEARCH BLVD., IMMIG, TEXAS 75062

Eautorn Plant Stouts Ln., Monmouth Junction, N.J. Western Plant 932 Kifer Rd., Sunnyvale, Calif
NATIONAL CHEMSEARCH div. of USAchem Inc. **Copyright 1975 National Chemse inch. Sorp
BALLAS + ST. LOWIS + MACKEMBACK + DEVERLY HILLS + MONAMPOLIS | PRINTE. TH U.S.A.

DIRECTIONS FOR USE

Badly fouled systems must be cleaned before treatment is begun. Begin treatment when the system is in jeopardy of becoming affected or after cleaning systems whose efficiency is already impaired. Apply at a point in the system where CIMACIDE will be uniformly mixed such as the tower sump.

INITIAL DOSE: When the system is just noticeably fouled, apply 96 (7.5 ppm of active ingredient) to 154 (12 ppm of active ingredient) fluid ounces of CIMACIDE per 1000 gallons of water in the system. Apply half of this initial dose when half of the water in the system has been lost by blowdown.

ACCEPTED

OCT 14 1975

Under the Foderal Inserticide, Fungicide, and Regenticide Act, as amended, for the permittee registered under EPA Reg. No. 1769-234

FOR INDUSTRIAL OR INSTITUTIONAL USE ONLY

SUBSEQUENT DOSE: When control of microbial growth is evident, apply 26 (2 ppm active ingredient) to 58 (1.5 ppm active ingredient) fluid ounces of CIMACIDE per 1000 gallons of water in the system. Apply half of the subsequent dose when half of the water in the system has been lost by blowdown.

CAUTION: CIMACIDE should not be used in towers where the treated water will come into contact with lawns, trees, shrubs or other desirable plants.

Use only in industrial recirculating water cooling towers under 25,000 tons (250,000 gallons capacity).

environmental cautions: Use only in systems where treated effluent is discharged into a sanitary sewage system or similar sewage treatment facility. Do not use where cooling tower effluent is discharged directly to lakes, ponds, streams or public waters. Do not contaminate water by cleaning of equipment or disposal of wastes. Apply this product only as specified on this label.

NOTE: Do not reuse empty container. Destroy and bury in a safe place or return to a drum reconditioner.

8-75

EPA Est. No. 4140

CA-1 IN-1 NJ-1 PR-1 TX-1