

44/ 19-8V

# TOWERCIDE 5

155-76

Percent by weight 5.0%

etive ingredient Poly [axyethylene (dimethyliminio)ethylene(dimethyliminio) ethylene dichlaride)

95 0% 1

nertingredient Weight per gelfon Weight of ective ingredient per gelinn

8 13 (b) 0 42 (b)

## KEEP OUT OF REACH OF CHILDREN.

See Right Side Panel for Additional Precautions.

FOR COMMERCIAL AND INDUSTRIAL USE ONLY, OR FOR SALE TO, USE, AND STORAGE BY SERVICE PERSONS.

Manufactured For

BEST DOCUMENT AVAILABLE

### PARECAUTIONARY STATEMENT HAZARDOUS TO HUMANS AND DOMESTIC

CAUTION: Hermful if swallowed. Avoid breating sepors. Avoid contact with skin, eyes, or clothing-FIRST AID: If swallowed, drink promptly a large quantity of milk, egg whites, gelatin solution, or if these are not svaliable, drink large quantities of water. Avoid slooked, CALL PHYSICIAN IMMEDIATELY.

ÉNVIRONMENTAL HAZARDS: This pesticide is toxic to fish. Keep out lakes, streams, or ponds. Permits may be required for discharges containing this pesticide into lakes, streams, ponds, or public water. For guidance, contact the regional office of the Environmental Protection Agency.

#### STORAGE AND DISPOSAL

Keep container closed when not in use. Do not contaminate water, food, or feed by storage, disposal or cleaning of equipment.

Rinsate that cannot be used reprocessed should be disposed of in a landfill approved for pesticides or by other approved states and local procedure Open dumping prohibited.

Wastes resulting from the use of this product may be disposed of on site or at an approved waste disposal facility.

Container disposal: Triple rinse or equivalent. Then offer for recycling or reconditioning, or puncture and dispose of in a sanitary landfill, or by other procedures approved by state and local authorit is

CONTROL

NET CO

## **APPLICATION**

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

DECORATIVE FOUNTAINS: This product is used to control the growth of algae in decorative fountains containing heavy growth of algae growth should be cleaned prior to using product. Decorative fountains having visible algae require an initial just dose of 17 to 28 fluid ounces of product per 1000 gallons of water. For treatment of freshly cleaned and filled decorative fountains, add initially 9 to 17 fluid ounces of product per 1000 gallons of water. Subsequent additions of 3 to 9 fluid ounces of product should be made every 5 to 7 days after jiel treatment for maintenance. This product is mpatible with those chemicals normally used to treat decorative fountains and is effective at both acid and alkaline pH. This product can be used in decorative fountains treated with chlorine chemicals any may reduce the amount of those chemicals normally required. However, do not mix this product with concentrated dry or liquid chlorine products.

## **APPLICATION**

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

AIRWASHERS: This product is used to control bacteria in industrial airwashing systems that maintain effective mist eliminating components. Prior to its use systems should be cleaned to remove bacterial stime and other deposits. An initial dose of 49.95 to 83.25 fluid ounces of product per 1000 gallons of water is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 33.75 to 83.25 fluid ounces of product per 1000 gallons of water should be employed each 1 to 5 days, or as needed.

The frequency of addition depends upon the relative amount of bleedoff and the severity of the bacteria problem. Stug additions should be made to the sump or water collection trays of the airwashing systems.

BEST DOCUMENT AVAILABLE

## **APPLICATION**

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

This product is used to control algae, bacteria, and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algal growth, microbiological slime and other deposits. An initial slug application of 13.5 to 36.3 fluid ounces of concentrate per 1000 gallons of water to provide a concentration of 96 to 240 parts per million of this product based on the total weight of water in the system is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 3.6 to 36.3 fluid ounces of concentrate per 1000 gallons of water (24 to 240 parts per million of concentrate) should be employed every 2 to 5 days as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.

E P.A. Reg. No. 2155 - 76 EPA EST 2155 GA 1

4944 040281 I. Schneid, Inc. 1429 Fairmont Ave., NT Atlanta, CA 30531-4601

Gentleren:

BEST DOCUMENT AVAILABLE

.....

Subject: Towercide 5
EPA Registration No. 2155-76
Amendment Application of April 9, 1984

The amendment referred to above, substitud in connection with registration under FIFRA, is acceptable provided that you:

- 1. Hake the labeling changes listed below before you release the product for shipment bearing the amended labeling:
  - a. Change the heading "Application" to "Directions for Use."
- 2. Subsit five (5) copies of your final printed labeling before you release the product for shipment. Refer to the  $\Lambda = 70$  Enclosure for a further description of final printed labeling.

If these conditions are not complicituith, the redistration vill be subject to cancellation in accordance with FIFPA sec. 6(e). Your release for shipment of the product bearing the amended labeling constitutes acceptance of these conditions.

A stamped copy of the labeling is enclosed for your records.

Sincerely years,

Product Manager (32)

Disinfectants Branch Dedictration Division (PS-7676)

Fnclesure

DD/DIS:DCV-45695:P.O.Ast include: over:5 7-724:94-54:4/20/84:561.5/3/84

N. MACNIS								
FIMECE D								
Marant P	L							
DATE D								
MA Form 1	320 1 /4 81.						OFFIC	CIAL FILE COPY