

# TOWERCIDE 10

Active ingredient	Poly[oxyethylene (dimethyliminol)ethylene dimethyliminol ethylene dichloride]	Percent by weight	10.0%
Inert ingredient			90.0%
Weight per gallon		8.49 lbs	
Weight of active ingredient per gallon		0.85 lb	

KEEP OUT OF REACH OF CHILDREN.

CAUTION

See Right Side Panel for Additional Precautions.

FOR COMMERCIAL AND INDUSTRIAL USE ONLY, OR FOR  
SALE TO, USE, AND STORAGE BY SERVICE PERSONS.  
Manufactured For

## PRECAUTIONARY STATEMENTS HAZARDOUS TO HUMANS AND DOMESTIC ANIMALS

**CAUTION:** Harmful if swallowed. Avoid breathing vapors. Avoid contact with skin, eyes, or clothing.

**FIRST AID:** If swallowed, drink promptly a large quantity of milk, egg whites, gelatin solution, or if these are not available, drink large quantities of water. Avoid alcohol. **CALL PHYSICIAN IMMEDIATELY.**

**ENVIRONMENTAL HAZARDS:** This pesticide is toxic to fish. Keep out lakes, streams, or ponds. Permits may be required for discharges containing this pesticide into lakes, streams, ponds, or public water. For guidance, contact the regional office of the Environmental Protection Agency.

### STORAGE AND DISPOSAL

Keep container closed when not in use. Do not contaminate water, food, or feed by storage, disposal or cleaning of equipment.

Rinsate that cannot be used or reprocessed should be disposed of in a landfill approved for pesticides or by other approved states and local procedure. Open dumping prohibited.

Wastes resulting from the use of this product may be disposed of on site or at an approved waste disposal facility.

Container disposal: Triple rinse or equivalent. Then offer for recycling or reconditioning, or puncture and dispose of in a sanitary landfill, or by other procedures approved by state and local authorities.

CONTROL

NET CONT. 5

2155 78

## APPLICATION

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

**DECORATIVE FOUNTAINS:** This product is used to control the growth of algae in decorative fountains containing heavy growth of algae should be cleaned prior to using product. Decorative fountains having visible algae growth require an initial dose of 8 to 12 fluid ounces of product per 1000 gallons of water. Subsequent additions of 1 to 3 fluid ounces of product should be made every 5 to 7 days after initial treatment for maintenance. This product is compatible with those chemicals normally used to treat decorative fountains and is effective at both acid and alkaline pH. This product can be used in decorative fountains treated with chlorine chemicals and may reduce the amount of those chemicals normally required. However, do not use this product with concentrated dry or liquid chlorine products.

## APPLICATION

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

**AIRWASHERS:** This product is used to control bacteria in industrial airwashing systems that maintain effective mist eliminating components. Prior to its use systems should be cleaned to remove bacterial slime and other deposits. An initial dose of 24.7 to 41.2 fluid ounces of product per 1000 gallons of water is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 16.9 to 41.2 fluid ounces of product per 1000 gallons of water should be employed each 1 to 5 days, or as needed.

The frequency of addition depends upon the relative amount of bleedoff and the severity of the bacteria problem. Slug additions should be made to the sump or water collection trays of the airwashing systems.

## APPLICATION

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

This product is used to control algae, bacteria, and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algal growth, microbiological slime and other deposits. An initial slug application of 6.13 to 15.32 fluid ounces of concentrate per 1000 gallons of water to provide a concentration of 48 to 120 parts per million of this product based on the total weight of water in the system is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 1.53 to 15.32 fluid ounces of concentrate per 1000 gallons of water (12 to 120 parts per million of concentrate) should be employed every 2 to 5 days as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.

BEST DOCUMENT AVAILABLE

I. Schneid, Inc.  
1429 Fairmont Ave., NE  
Atlanta, GA 30381-4601

Gentlemen:

Subject: Toveride 10  
EPA Registration No. 2154-70  
Amendment Application of April 9, 1984

The amendment referred to above, submitted in connection with registration under FIFRA, is acceptable provided that you:

1. Make the labeling changes listed below before you release the product for shipment bearing the amended labeling:


a. Change the heading "Application" to "Directions for Use."

2. Submit five (5) copies of your final printed labeling before you release the product for shipment. Refer to the A-79 Enclosure for a further description of final printed labeling.

If these conditions are not complied with, the registration will be subject to cancellation in accordance with FIFRA sec. 6(e). Your release for shipment of the product bearing the amended labeling constitutes acceptance of these conditions.

A stamped copy of the labeling is enclosed for your records.

Sincerely yours,



Robert J. Gannon (12)  
Administrative Branch  
Registration Division (1-21-70)

Enclosure

MAIL ROOM - 12/1/84 1:57 PM 42nd, 5/3/84

SEARCHED		SERIALIZED		INDEXED		FILED	
SYMBOL							
SUBNAME							
DATE							

EPA Form 132-42

OFFICIAL FILE COPY