

5710-97

Culligan

2938-6
 RECEIVED
 APR 9 1972
 TO ATTACH COMMENTS.

IO-CHEM. TREATMENT M-22

FOR CONTROL OF BACTERIA AND ALGAE

ACTIVE INGREDIENTS: Poly [oxyethylene (dimethylimino) ethylene (dimethylimino) ethylene dichloride]	30.0%
INERT INGREDIENTS:	70.0%
TOTAL	100.0%

Do not reuse container. Rinse empty container thoroughly with water and discard. "EPA Reg. No. 2938-6"

DIRECTIONS FOR USE:

M-22 is used to control algae, bacteria and fungi in commercial and industrial water cooling towers. Prior to its use systems must be cleaned to remove algae growth, microbiological slime and other deposits. An initial slug addition of 1.9 to 4.6 fluid ounces of M-22 per 1000 gallons of water, to provide a concentration of 17 to 42 parts per million based on total weight of water in the system is recommended. Subsequent slug additions of 0.44 to 4.4 fluid ounces of

M-22 per 1000 gallons of water (4 to 40 part per million) should be employed with the frequency of addition depending upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water of cooling towers. M-22 may be added continuously to the makeup water to maintain a concentration of 4 to 40 parts per million (0.44 to 4.4 fluid ounces) per 1000 gallons of bleedoff.

CAUTION: - KEEP OUT OF REACH OF CHILDREN.

Harmful if swallowed. Avoid contact with skin and eyes. In case of contact flush with plenty of water for at least 15 minutes. If eye irritation persists get medical attention. Avoid contamination of food.

This product is toxic to fish. Do not add treated effluent to lakes, streams or ponds. Do not contaminate water by cleaning of equipment or disposal of waste. Use only as directed on label.

