# Culligan

## CHEMICAL TREATMENT M-23

|                             | Percent | bу   | weight  |
|-----------------------------|---------|------|---------|
| ACTIVE INGREDIENT           |         |      | . 10.0% |
| Poly (oxyethylene (dimeth   |         |      |         |
| ene (dimethyliminio)—ethy   |         |      | _       |
|                             |         | 0.09 | %       |
| INERT INGREDIENT            |         |      | . 90.0% |
| Weight per gallon           | 8.49 p  | oun  | ds      |
| Weight of active ingredient | •       |      |         |
| gallon                      | •       |      |         |
| EPA Reg. No                 | 2       | 2938 | -9      |

### CAUTION

#### KEEP OUT OF REACH OF CHILDREN

#### **APPLICATION**

Chemical treatment M-23 is used to control algae, bacteria, and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algal growth, microbiological slime and other deposits. An initial slug addition of 6.13 to 15.32 fluid ounces of Chemical Treatment M-23 per 1000 gallons of water to provide a concentration of 48 to 120 parts per million of Chemical Treatment M-23 based on the total weight of water in the system is recommended. Repeat initial M-23 based on the total weight of water in the system is recommended. Repeat initial dosage in the system is recommended. Repeat initial dosage in

until control is evident. Subsequent slug additions of 1.53 to 15.31 fluid ounces of Chemical Treatment M-23 per 1000 gallons of water (12 to 120 parts per million of Chemical Treatment M-23) should be employed every 2 to 5 days or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.

Causes eye damage and skin irritation. Do not get in eyes, on skin, or on clothing. Wear goggles or face shield and rubber gloves when handling. Harmful or fatal if swallowed. Avoid contamination of food.

FIRST AID: In case of contact, flush with plenty of water for at least 15 minutes. If eye irritation persists, get medical attention. CALL PHYSICIAN IMMEDIATELY.

Do not reuse empty drum. Return to drum reconditioner or destroy by perforating or crushing and burying in a safe place.

This product is toxic to fish. Do not discharge treated effluent where it will drain into lakes, streams, or ponds. Do not contaminate water by cleaning of equipment or disposal of wastes. Use only as directed on label.



NORTHBROOK, ILLINOIS · SAN BERNARDINO, CALIFORNIA · BRUSSELS, BELGIUM MISSISSAUGA, ONTARIO, CANADA · BOLOGNA, ITALY

