

NET CO' NTS

501 L

3837-40
ACCEPTED

November 18, 1974

U.S. DEPT. OF AGRICULTURE
FEDERAL INSECTICIDE
AND RODENTICIDE ACT
EPA REG. NO. 3837-40
EPA EST. 3837-MO-1

NO ADDED COMMENTS.

**For Control of Algal, Fungal and Bacterial
Slime In Industrial Recirculating Water
Cooling Systems**

Active Ingredients*	90%
Sodium Pentachlorophenate	79%
Sodium Salts of Other Chlorophenols	11%
Inert Ingredients	10%

*Calculated as sodium pentachlorophenate (molecular weight 288.3)

EPA Registration No. 3837-40
EPA EST. 3837-MO-1

WARNING

HARMFUL DUST—CAUSES SKIN IRRITATION—INJURIOUS TO EYES—MAY BE HARMFUL OR FATAL IF SWALLOWED OR ABSORBED THROUGH SKIN—DO NOT GET IN EYES, ON SKIN OR CLOTHING—DO NOT BREATHE DUST—WEAR CHEMICAL WORKERS' GOGGLES WHEN HANDLING.

FIRST AID: If swallowed, induce vomiting by sticking finger down the throat or by giving an emetic such as 2 tablespoonsful of salt in a glass of warm water. Repeat until vomit is clear. Call a physician. Never give anything by mouth to an unconscious person.

See Side Panel for Additional Required Cautions.

In case of eye contact, flush eyes immediately with plenty of water for at least 15 minutes and get medical attention. In case of skin contact, wash with soap and plenty of water. Wash contaminated clothing before re-use.

NOTE TO PHYSICIAN: This product is a metabolic stimulant. Causes hyperthermia. Treat symptomatically.

**WASH THOROUGHLY AFTER HANDLING
FOR INDUSTRIAL USE ONLY**

KEEP PACKAGE TIGHTLY CLOSED WHEN NOT IN USE

Do not reuse empty container. Dispose of it by burying it with waste, or by burning it. Stay away from smoke or fumes.

This product is toxic to fish and wildlife. Treated effluent should not be discharged where it will drain into lakes, streams, ponds, or public waters. Apply this product only as specified on this label.

DIRECTIONS

Applications—Water Treatment—To control algal, fungal, and bacterial-induced slimes in industrial recirculating water-cooling systems.

Initial Dose: When the system is noticeably fouled, apply 0.2-0.7 lb. of this product per 1,000 gallons of water in the system. Repeat until control is achieved.

Subsequent Doses: When microbial control is evident, add 0.2-0.4 lb. of this product per 1,000 gallons of water in the system weekly, or as needed to maintain control. Badly fouled systems must be cleaned before treatment is begun.

Begin treatment when the system is in jeopardy of becoming affected or after cleaning systems whose efficiency is already impaired. Apply at a point in the system where the product will be uniformly mixed.

MANUFACTURED BY

LUBAR COMPANY

1708 Campbell

Kansas City, Missouri 64108