

DIRECTIONS FOR USE

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

RECIRCULATING COOLING WATER SYSTEMS

BETZ Slimicide C-67 aids in the control of bacterial, fungal and algal slimes in evaporative condensers, heat exchange water systems, commercial and industrial cooling towers, influent systems such as flow through, infilco units, filters, lagoons etc., industrial water scrubbing systems and brewery pasteurizers.

This product may be added to the systems either continuously or intermittently or as needed. The frequency of feeding and duration of the treatment will depend upon the severity of the problem.

BADLY FOULED SYSTEMS must be cleaned before treatment is begun.

FOR CONTROL OF BACTERIA AND FUNGI

INITIAL DOSE: When the system is noticeably fouled, add 0.9 to 2.2 fluid ounces to 1000 gallons of water in the system or 8 to 20 ppm. Repeat until control is achieved.

SUBSEQUENT DOSE: When microbial control is evident, add 0.2 to 2.2 fluid ounces to 1000 gallons of water in the system or 2 to 20 ppm every 2 to 5 days or as needed to maintain control.

BLC746 8108

CONTINUOUS FEED METHOD

INITIAL DOSE: When the system is noticeably fouled, add 0.9 to 2.2 fluid ounces to 1000 gallons of water in the system or 8 to 20 ppm.

SUBSEQUENT DOSE: Continuously feed to maintain a dosage of 0.2 to 2.2 fluid ounces to 1000 gallons of water in the system or 2 to 20 ppm.

FOR CONTROL OF ALGAE INTERMITTENT OR SLUG METHOD

INITIAL DOSE: When the system is noticeably fouled, add 0.9 to 2 2 fluid ounces to 1000 gallons of water in the system or 8 to 20 ppm. Repeat until control is achieved.

SUBSEQUENT DOSE: When microbial control is evident, add 0.2 to 2.2 fluid ounces to 1000 gallons of water in the system or 2 to 20 ppm every 2 to 5 days or as needed to maintain control.

CONTINUOUS FEED METHOD

INITIAL DOSE: When the system is noticeably fouled, add 0.9 to 2.2 fluid ounces to 1000 gallons of water in the system or 8 to 20 ppm.

SUBSEQUENT DOSE: Continuously feed to maintain a dosage of 0.2 to 2.2 fluid ounces to 1000 gallons of water in the system or 2 to 20 ppm.

(Directions for use continued on right panel.)

PRECAUTIONARY

HAZARDS TO HUM

DOMESTIC AN

CAUTIC

HARMFUL IF SWALLOW! I eyes, on skin or on clothing vapors or mist. Avoid and feed products.

ENVIRONMENTA

This pesticide is toxic to charge into lakes, stream water unless in accordapermit. For guidance co: Office of the EPA. Do not by cleaning of container disposal of wastes. Applias specified on this labe

PROTECT FROM

DO NOT STO

ELEVATED TEMPI

Slimicide C-67 LIME CONTROL AGENT

1 [

ACCEPTED 20 NOV 1981

3876-140

PUNGICUS AND RODENTICUS AC POR SCOROSIC POSCOR MICHIGAN

PRECAUTIONARY STATEMENTS
HAZARDS TO HUMANS AND
DOMESTIC ANIMALS

CAUTION

HARMFUL IF SWALLOWED. Do not get into eyes, on skin or on clothing. Avoid breathing vapors or mist. Avoid storage near food and feed products.

ENVIRONMENTAL HAZARDS

This pesticide is toxic to fish. Do not discharge into lakes, streams, ponds or public water unless in accordance with a NPDES permit. For guidance contact your Regional Office of the EPA. Do not contaminate water by cleaning of container and equipment or disposa of wastes. Apply this product only as specified on this label.

PROTECT FROM FREEZING

DO NOT STORE AT

ELEVATED TEMPERATURES

Contents: LIQUID

*Inert ingredients include solubilizing and dispersing agents

EPA Reg. No. 3876-140
WEIGHT PER GALLON OF PRODUCT
9.6 Pounds

CAUTION

STATEMENT OF PRACTICAL TREATMENT

In case of contact with skin, wash well with soap and water.

In case of contact with eyes, flush promptly and thoroughly with clear water for at least 15 minutes. Immediately contact physician.

If swallowed, drink promptly a large quantity of milk, egg whites, gelatin solution, or if these are not available, drink large quantities of water. Avoid alcohol, Immediately contact physician.

Immediately remove and wash contaminated clothing before reuse. Wash thoroughly after handling.

AIR WASHERS

For use only in industrial air washer systems that maintain effective mist eliminating components.

BETZ Slimicide C-67 controls slime-forming bacteria and fungi in industrial air washer systems. Add 3.3 to 5.55 fluid ounces to 1000 gallons of water in the system or 30 to 51 ppm depending upon the severity of contamination.

INTERMITTENT OR SLUG METHOD

INITIAL DOSE: When the system is noticerbly fouled, add 3.33 to 5.55 fluid ounces Slimicide C-67 to 1000 gallons of water to the system or 30 to 51 ppm. Repeat until control is achieved.

SUBSEQUENT DOSE: When microbial control is evident, add 2.25 to 5.55 fluid ounces to 1000 gallons of water in the system or 21 to 51 ppm every 2 to 5 days or as needed to maintain control.

BADLY FOULED SYSTEMS must be cleaned before treatment is begun.

CONTINUOUS FEED METHOD

INITIAL DOSE: When the system is noticeably fouled, add 3.3 to 5.55 fluid ounces Slimicide C-67 to 1000 gallons of water in the system or 30 to 51 ppm.

SUBSEQUENT DOSE: Maintain this level by pumping a continuous feed of 2.25 to 5.55 fluid ounces of Slimicide C-67 per 1000 gallons of water in the system per day or 21 to 51 ppm.

Do n

stord

BADL

fore

hibst Pesti chen of the butter

Tripl med or d bury suit prov

Do rins prot su t

arc

Tech len i

BETZ Laboratories, Inc./TREVOSE, PENNSYLVANIA/U.S.A./19047

eed to ounces or 2 to

ceably

)0 gal-

main-

ices to

or 2 to

iceably

o 1000

0 ppm.

ntrol is

o 1000

20 ppm

aintain

riceably

o 1000

mag 0^o

pm.

panel.)

ictured for



ACCEPTED 20 NOV 1981 3874-140

Contents: LIQUID

*Inert ingredients include solubilizing and dispersing agents.

EPA Reg. No. 3876-140
EIGHT PER GALLON OF PRODUCT
9.6 Pounds

EP OUT OF REACH OF CHILDREN CAUTION

TEMENT OF PRACTICAL TREATMENT

se of contact with skin, wash well with and water.

se of contact with eyes, flush promptly thoroughly with clear water for at least natures. Immediately contact physician.

callowed, drink promptly a large quanpermilk, egg whites, gelatin solution, or lesse are not available, drink large quanper water. Avoid alcohol, Immediately act physician.

ediately remove and wash contamia clothing before reuse. Wash thorally after handling.

AIR WASHERS

For use only in industrial air washer systems that maintain effective mist eliminating components.

BETZ Slimicide C-67 controls slime-forming bacteria and fungi in industrial air washer systems. Add 3.3 to 5.55 fluid ounces to 1000 gallons of water in the system or 30 to 51 ppm depending upon the severity of contamination.

INTERMITTENT OR SLUG METHOD

INITIAL DOSE: When the system is noticeably fouled, add 3.33 to 5.55 fluid ounces Slimicide C-67 to 1000 gallons of water to the system or 30 to 51 ppm. Repeat until control is achieved.

SUBSEQUENT DOSE: When microbial control is evident, add 2.25 to 5.55 fluid ounces to 1000 gallons of water in the system or 21 to 51 ppm every 2 to 5 days or as needed to maintain control.

BADLY FOULED SYSTEMS must be cleaned before treatment is begun.

CONTINUOUS FEED METHOD

INITIAL DOSE: When the system is noticeably fouled, add 3.3 to 5.55 fluid ounces Slimicide C-67 to 1000 gallons of water in the system or 30 to 51 ppm.

SUBSEQUENT DOSE: Maintain this level by pumping a continuous feed of 2.25 to 5.55 fluid ounces of Slimicide C-67 per 1000 gallons of water in the system per day or 21 to 51 ppm.

BADLY FOULED SYSTEMS must be cleaned before treatment is begun.

STORAGE AND DISPOSAL

Do not contaminate water, food or feed by storage or disposal. Open dumping is prohibited. Do not reuse empty container.

Pesticide or rinsate that cannot be used or chemically reprocessed should be disposed of in a landfill approved for pesticides or buried in a safe place away from water supplies.

Triple rinse metal container or equivalent method before sending to drum conditioner or destroying by perforation or crushing and burying in a safe place. Do not reuse. Consult Federal, state or local authorities for approved alternative procedures.

Do not reuse empty plastic container. Triple rinse and incinerate or dispose of in a approved landfill or bury in a safe place. Consult Federal, state or local authorities for approved alternative procedures.

FOR INDUSTRIAL USE ONLY

Technical advice regarding specific site problems is available from BETZ.

NET WEIGHT AND VOLUME
As Marked on Container

SE, PENNSYLVANIA/U.S.A./19047