

ANCO ALGICIDE NO.

CAUTION
KEEP OUT OF THE REACH OF CHILDREN

Harmful if swallowed. Avoid contact with skin and eyes. In case of contact flush with plenty of water for at least 15 minutes. If eye irritation persists get medical attention. Avoid contamination of food.

This product is toxic to fish. Do not add treated effluent to lakes, streams or ponds. Do not contaminate water by cleaning of equipment or disposal of waste. Use only as directed on label.

Do not reuse empty container. Destroy it by perforating or crushing. Bury or discard in a safe place.

EPA Reg. No. 3931-6

COMPOSITION		Percent by weight
Active Ingredient		10.0%
Poly [oxyethylene (dimethyliminio) ethylene (dimethyliminio)-ethylene dichloride]		
Inert Ingredient		90.0%
Weight per gallon	8.52	pounds
Weight of active ingredient per gallon	0.85	pounds

Sold By
ANDERSON CHEMICAL COMPANY
Dallas Macon Memphis

bac
trial
be
and
fluid
galle
part
tota
Sub
of
(12
sho
freq
of b
Slug
cool

ANCO ALGICIDE NO. 44

ACCEPTED
JUL 17 1973
UNDER THE FEDERAL INSECTICIDE
FUNGICIDE AND RODENT-CIDE ACT
FOR ECONOMIC POISON REGISTERED
UNDER NO. 3921-6 SUBJECT
TO ATTACHED COMMENTS.

COMPOSITION		Percent by weight
Active Ingredient		10.0%
Poly [oxyethylene (dimethyliminio) ethylene (dimethyliminio)-ethylene dichloride]		
Inert Ingredient		90.0%
Weight per gallon	8.52	pounds
Weight of active ingredient per gallon	0.85	pounds

APPLICATION

ANCO ALGICIDE NO. 44 is used to control algae, bacteria, and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algal growth, microbiological slime and other deposits. An initial slug addition of 6.0 to 15.0 fluid ounces of ANCO ALGICIDE NO. 44 per 1000 gallons of water, to provide a concentration of 48 to 120 parts per million of ANCO ALGICIDE NO. 44 based on the total weight of water in the system is recommended. Subsequent slug additions of 1.5 to 15.0 fluid ounces of ANCO ALGICIDE NO. 44 per 1000 gallons of water (12 to 120 parts per million of ANCO ALGICIDE NO. 44) should be employed every 2 to 5 days or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.

Sold By

ANDERSON CHEMICAL COMPANY

Dallas

Macon

Memphis

Net Contents as shown on drum