

4389-76

PACIFIC CHEMICAL

division Pabco National Corp.



APPLIED SCIENCE

500 7th Ave. South, Kirkland, Washington 98033 • (206) 827-8711

MICROCIDE L-65

Controls bacteria and algae in industrial recirculating water cooling towers

DIRECTIONS FOR USE GENERAL CLASSIFICATION

For use in industrial recirculating water cooling towers.

INDUSTRIAL RECIRCULATING WATER COOLING TOWERS

For control of bacteria in industrial recirculating water cooling towers, add 2.4 oz. (68 g) of Microcide L-65 per 1,000 gal. of water in the system. Subsequently, maintain the level by pumping a continuous feed of 0.24 oz. (6.8 g) of water in the system, or by blowdown.

FOR CONTROL OF BACTERIA

Intermittent or Slug Method
Initial Dose: When the system is not heavily fouled, add 2.4 oz. (68 g) of Microcide L-65 per 1,000 gal. of water in the system. Subsequently, maintain the level by pumping a continuous feed of 0.24 oz. (6.8 g) of water in the system, or by blowdown.

Subsequent Dose: When the system is heavily fouled, add 4.8 oz. (136 g) of Microcide L-65 per 1,000 gal. of water in the system. Subsequently, maintain the level by pumping a continuous feed of 0.24 oz. (6.8 g) of water in the system, or by blowdown.

Badly fouled systems must be cleaned by any method of your choice.

Continuous Feed Method
Initial Dose: When the system is not heavily fouled, add 2.4 oz. (68 g) of Microcide L-65 per 1,000 gal. of water to the system. Subsequently, maintain the level by pumping a continuous feed of 0.24 oz. (6.8 g) of water in the system, or by blowdown.

DIRECTIONS CONTINUED ON OPPOSITE PANEL

ACTIVE INGREDIENT

2,2-Dibromo-3-nitropropionamide 5%

INERT INGREDIENTS

PRECAUTIONARY STATEMENTS

HAZARDS TO HUMANS and DOMESTIC ANIMALS

DANGER:

KEEP OUT OF REACH OF CHILDREN.

Caution: May be harmful if swallowed. Causes severe eye irritation. Wash thoroughly with plenty of water. Avoid contact with skin. Wash thoroughly with plenty of water when handling.

FIRST AID: If swallowed, take 10-15 glasses of water immediately, with plenty of water for at least 15 minutes and get medical attention. If on skin, wash with soap and plenty of water. Wash thoroughly before eating.

If swallowed, induce vomiting by sticking finger down the throat or by giving soapy or strong salty water to drink. Repeat until vomit is clear. Call a physician. Never give anything by mouth to an unconscious person. Wash face and hands thoroughly after handling.

ENVIRONMENTAL HAZARDS: This pesticide is toxic to fish. Do not contaminate water by cleaning of equipment or disposal of waste. Discharge permits may be required. For guidance contact the regional office of the Environmental Protection Agency.

FOR CONTROL OF ALGAE

For control of algae in industrial recirculating water cooling towers, add 2.4 oz. (68 g) of Microcide L-65 per 1,000 gal. of water in the system.

Intermittent or Slug Method

Initial Dose: When the system is not heavily fouled, add 2.4 oz. (68 g) of Microcide L-65 per 1,000 gal. of water in the system. Subsequently, maintain the level by pumping a continuous feed of 0.24 oz. (6.8 g) of water in the system, or by blowdown.

Subsequent Dose: When the system is heavily fouled, add 4.8 oz. (136 g) of Microcide L-65 per 1,000 gal. of water in the system. Subsequently, maintain the level by pumping a continuous feed of 0.24 oz. (6.8 g) of water in the system, or by blowdown.

Badly fouled systems must be cleaned by any method of your choice.

Continuous Feed Method

Initial Dose: When the system is not heavily fouled, add 2.4 oz. (68 g) of Microcide L-65 per 1,000 gal. of water to the system. Subsequently, maintain the level by pumping a continuous feed of 0.24 oz. (6.8 g) of water in the system, or by blowdown.

Subsequent Dose: When the system is heavily fouled, add 4.8 oz. (136 g) of Microcide L-65 per 1,000 gal. of water to the system. Subsequently, maintain the level by pumping a continuous feed of 0.24 oz. (6.8 g) of water in the system, or by blowdown.

STORAGE AND DISPOSAL: Keep container tightly closed. Do not reuse empty container. Destroy label along with waste in an approved landfill area.

NET CONTENTS 55 gal (208 liters)

E.P.A. Registration No. 4389-76
E.P.A. Est. No. 4389-WA-1