

BEST DOCUMENT AVAILABLE

FRONT LABEL

E.P.A. REG. NO. 4828-  
E.P.A. EST. NO. 4828-PA-1

SENTRY

Low Foam Water Treatment Microbiocide  
For  
Building and Industrial Cooling Towers

Active Ingredients  
Dioctyl Dimethyl Ammonium Chloride..... 10%  
Ethyl Alcohol..... 2%  
Inert Ingredients..... 88%  
Total ..... 100%

KEEP OUT OF REACH OF CHILDREN

DANGER

REFER TO ADDITIONAL CAUTIONS ON BACK PANEL

Net Content \_\_\_\_\_ Gallons

Manufactured By

ABCO INCORPORATED

230 Industry Boulevard, North Huntingdon, Pa. 15642

376

#4828-101  
No Pump

12

▼ BEST DOCUMENT AVAILABLE

DIRECTIONS

PRECAUTIONARY STATEMENTS  
Hazard to Humans

**DANGER:**

Keep Out of Reach of Children. Corrosive. Causes severe eye and skin damage. Do not get in eyes, on skin, or on clothing. Wear goggles or face shield and rubber gloves when handling. Harmful or fatal if swallowed. Avoid contamination of food.

ENVIRONMENTAL HAZARDS

This product is toxic to fish. Treatment effluent should not be discharged where it will drain into lakes, streams, ponds, or public water.

PHYSICAL HAZARDS

Do not use, pour, spill or store near heat or open flame.

DIRECTIONS FOR USE

GENERAL CLASSIFICATION

It is a violation of Federal Law to use this product in a manner inconsistent with its labeling.

STORAGE AND DISPOSAL

-DO NOT CONTAMINATE WATER, FOOD, OR FEED BY STORAGE OR DISPOSAL.

-OPEN DUMPING IS PROHIBITED.

-DO NOT REUSE EMPTY CONTAINER.

PESTICIDE DISPOSAL

PESTICIDE THAT CANNOT BE USED, OR CHEMICALLY PROCESSED SHOULD BE DISPOSED OF IN A LANDFILL APPROVED FOR PESTICIDES OR BURIED IN A SAFE PLACE AWAY FROM WATER SUPPLIES.

CONTAINER DISPOSAL

DISPOSE OF IN AN INCINERATOR OF LANDFILL APPROVED FOR PESTICIDE CONTAINERS, BURY IN A SAFE PLACE OR RETURN TO DRUM RECONDITIONER

To control algae and algae slimes, use Sentry Low Foam Water Treatment Microbiocide as directed. Sentry will control algae and algae slimes found in recirculating cooling tower waters and not introduce a foam problem.

Sentry is economical to use, because it is concentrated. Handle with care.

Sentry helps clean and loosen slime debris from cooling systems. For best results, slug feed. The frequency of addition of Sentry needed depends on many factors. For best results follow this procedure:

1. Initially use 16 fluid ounces per 200 gallons of water to be treated (60 PPM active quaternary).

Should the above dosage not give satisfactory results, use 21 fluid ounces per 200 gallons of water.

Repeat initial dose every seven days or increase the frequency if needed.

2. When the above treatment level is successful, use 6 to 9 fluid ounces per 200 gallons of water to maximize efficiency. Repeat weekly as needed.

Should slime develop again, return to initial dosage.

Cooling tower waters that are inherently low in algae growth may be adequately controlled by lower range of these dosages. Slug feed every seven days. Dilute the appropriate amount of Sentry in 1 to 2 gallons of water, then add to the sump of tower.

Should tower be heavily fouled, a pre-cleaning is required.

**DANGER**

STATEMENT OF PRACTICAL TREATMENT

In case of contact, immediately flush eyes or skin with plenty of water for at least 15 minutes. For eyes, call a physician. Remove and wash contaminated clothing before reuse.

If swallowed, drink promptly a large quantity of milk, egg whites, gelatin solution; or if these are not available, drink large quantities of water. Avoid alcohol. Call a physician immediately.

NOTE TO PHYSICIAN: Probable mucosal damage may contraindicate the use of gastric lavage. Measures against circulatory shock, respiratory depression, and convulsion may be needed.

Seller makes no warranty, expressed or implied concerning the use of this product other than indicated on the label. Buyer assumes all risk of use and/or handling of this material when such use and/or handling is contrary to label instructions.

ABCO INCORPORATED

376

230 Industry Boulevard,

North Huntingdon, Pa. 15642

13