Panther 611 MF Cooling Tower Algaecide-Slinicide

5136-16

ACTIVE INGREDIENT: Poly[oxyethylene (dimethyliminio) ethylene- (dimethyliminio) ethylene dichloride)	. 10.0 %
INERT INGREDIENT	90.0 %
This product contains 0.85 lb. of active ingredient per gallor 8.49 lb. per gallon.	n and weighs

## **KEEP OUT OF REACH OF CHILDREN**

## **CAUTION**

## PRECAUTIONARY STATEMENTS HAZARDS TO HUMANS AND DOMESTIC ANIMALS

CAUTION: Harmful if swallowed. Avoid breathing vapors. Avoid contact with skin, eyes, or clothing.

FIRST AID: If swallowed, drink promptly a large quantity of milk, egg whites, gelatin solution, or, if these are not available, drink large quantities of water. Avoid alcohol. Call a physician immediately.

ENVIRONMENTAL HAZARDS: This pesticide is toxic to fish. Keep out of lakes, streams, or ponds. Permits may be required for discharges containing this pesticide into lakes, streams, ponds, or public water. For guidance, contact the regional office of the Environmental Protection Agency.

## GENERAL CLASSFICATION

It is a violation of Federal la	w to use this product in a manner in
consistent with its labeling.	·

Pantner 611 NF Cooling Tower Algaec is ased in confro algae, bacteria,
and fungi in recirculating commercial and industrial water cooling towers. Prior to
its use, systems must be cleaned to remove algal growth, microbiological slime.
and other deposits. An initial slug addition of 6.13 to 15.32 fluid ounces
of Panther 611 NF Cooling Tower per 1000 gallons of water
to provide a concentration of 48 to 120 parts per million of
the section of the term of the
, cases on the total weight of water
in the system, is recommended. Repeat initial dosage until control is evident.
Subsequent slug additions of 1.53 to 15.32 fluid ounces of Panther 611 NF Cooling Tower per 1000 gallons of water (12)
to 120 parts per million of Panther 611 NF Cooling Tower should
be employed every 2 to 5 days, or as needed. The frequency of addition depends
be employed every 2 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological prob-
upon the relative amount of bleedoff and the severity of the microbiological prob- lem. Slug additions should be made in the sump of water cooling towers.
upon the relative amount of bleedoff and the severity of the microbiological prob-
upon the relative amount of bleedoff and the severity of the microbiological prob- lem. Slug additions should be made in the sump of water cooling towers. Panther 611 NF Cooling Tower is used to control bacteria in industrial
upon the relative amount of bleedoff and the severity of the microbiological prob- lem. Slug additions should be made in the sump of water cooling towers.  Panther 611 NF Cooling Tower is used to control bacteria in industrial air-washing systems that maintain effective mist eliminating components. Prior to its use, systems should be cleaned to remove bacterial slime and other
upon the relative amount of bleedoff and the severity of the microbiological prob- lem. Slug additions should be made in the sump of water cooling towers.  Panther 611 NF Cooling Tower is used to control bacteria in industrial air-washing systems that maintain effective mist eliminating components. Prior to its use, systems should be cleaned to remove bacterial slime and other
upon the relative amount of bleedoff and the severity of the microbiological prob- lem. Slug additions should be made in the sump of water cooling towers.  Panther 611 NF Cooling Tower is used to control bacteria in industrial air-washing systems that maintain effective mist eliminating components. Prior to its use, systems should be cleaned to remove bacterial slime and other
upon the relative amount of bleedoff and the severity of the microbiological prob- lem. Slug additions should be made in the sump of water cooling towers.  Panther 611 NF Cooling Tower is used to control bacteria in industrial air-washing systems that maintain effective mist eliminating components. Prior to its use, systems should be cleaned to remove bacterial slime and other deposits. An initial slug dose of 24.7 to 41.2 fluid ounces of Panther 611 NF Cooling Tower per 1000 gallons of water is recom-
upon the relative amount of bleedoff and the severity of the microbiological prob- lem. Slug additions should be made in the sump of water cooling towers.  Panther 611 NF Cooling Tower is used to control bacteria in industrial air-washing systems that maintain effective mist eliminating components. Prior to its use, systems should be cleaned to remove bacterial slime and other deposits. An initial slug dose of 24.7 to 41.2 fluid ounces of Panther 611 NF Cooling Tower per 1000 gallons of water is recom-
upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers. Panther 611 NF Cooling Tower is used to control bacteria in industrial air-washing systems that maintain effective mist eliminating components. Prior to its use, systems should be cleaned to remove bacterial slime and other deposits. An initial slug dose of 24.7 to 41.2 fluid ounces of Panther 611 NF Cooling Tower per 1000 gallons of water is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 16.9 to 41.2 fluid ounces of Panther 611 NF Cooling Tower
upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.  Panther 611 NF Cooling Tower is used to control bacteria in industrial air-washing systems that maintain effective mist eliminating components. Prior to its use, systems should be cleaned to remove bacterial slime and other deposits. An initial slug dose of 24.7 to 41.2 fluid ounces of Panther 611 NF Cooling Tower per 1000 gallons of water is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 16.9 to 41.2 fluid ounces of Panther 611 NF Cooling Tower per 1000 gallons of water should be employed each 1 to 5 days, or as needed. The
upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.  Panther 611 NF Cooling Tower is used to control bacteria in industrial air-washing systems that maintain effective mist eliminating components. Prior to its use, systems should be cleaned to remove bacterial slime and other deposits. An initial slug dose of 24.7 to 41.2 fluid ounces of Panther 611 NF Cooling Tower per 1000 gallons of water is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 16.9 to 41.2 fluid ounces of Panther 611 NF Cooling Tower per 1000 gallons of water should be employed each 1 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and severity
upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.  Panther 611 NF Cooling Tower is used to control bacteria in industrial air-washing systems that maintain effective mist eliminating components. Prior to its use, systems should be cleaned to remove bacterial slime and other deposits. An initial slug dose of 24.7 to 41.2 fluid ounces of Panther 611 NF Cooling Tower per 1000 gallons of water is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 16.9 to 41.2 fluid ounces of Panther 611 NF Cooling Tower per 1000 gallons of water should be employed each 1 to 5 days, or as needed. The

STORAGE & DISPOSAL: Keep container closed when not in use. Do not contaminate water, food, or feed by storage, disposal or cleaning of equipment. Rinsate that cannot be used or reprocessed should be disposed of in a landfill approved for pesticides or buried in a safe place away from water supplies. Open dumping is prohibited.

☐ METAL CONTAINERS: Triple ☐ PLASTIC CONTAINERS: Do not rinse and offer for recycling, reconditioning, or disposal in an approved landfill or bury in a safe place.

reuse empty container. Triple rinse and incinerate or dispose of in an approved landfill or bury in safe place.

- place.	piaco.	
	Manufactured by:	
	Panther Chemical Co., Inc.	
P. O. Box 52, 600 N. Beach		
	Fort Worth, TX 76101	
EPA REG. N	NO EPA EST. NO	<del></del>
	NET CONTENTS	

OFF	VIRONHENTAL PROTECTION AGENCY  OF SERVICE OF SERVICE SAME  OFFICE OF SERVICE SAME  AACTOR OF SERVICE ACTOR	ราคภาค (ค.ศ. พ.ศ. พ.ศ. 184) วาย (พ.ศ. 185) เกาะสาราช (ค.ศ. 184)	ALPRIANCE SILANCE	
Un les	The Petrici Decrease of the Petric Dec	NAME OF PESTICISE PROCEST		
NAME AND ADD	RESS OF REGISTRANT In tule ZIP			
٢	- <del>- 1</del>			
L		J		
submitted to a	e, in labeling formula differing in substance f rd accepted by the Registration Division prio refer to the above U.S. EPA registration num	r to use of the label in commerce. I		
	of information furnished by the registrant, the secticide, Funcicide, and Rodenticide Act.	above named pesticide is hereby R	egistered/Reregistered under	
A copy of the	hbeling accepted in connection with this Re	gistration/Reregistration is returne	d herewith.	
Registration is in no way to be construed as an indorsement or approval of this product by this Agency. In order to protect health and the invironment, the Administrator, on his motion, may at any time suspend or cancel the registration of a pesticide in accordance with the Act. The acceptance of any name in connection with the registration of a product under this Act is not to be construed as giving the registrant a right to exclusive use of the name or to its use if it has been covered by others.				
			•	
ATTACHM	IE T IS APPLICABLE			
SIGNATURE OF	A PROVING OFFICIAL		DATE	