



**SUPER 85 CHLORINE CONCENTRATE**

**ACTIVE INGREDIENT:**

Trichloro-s-triazinetriene  
(Available Chlorine 87.5%)

97%

**INERT INGREDIENTS:**

3%

**TOTAL INGREDIENTS:**

100.00%

When used as directed this product is effective as a pool water disinfecting agent.

The filter system should be backwashed or properly cleaned and the pH adjusted between 7.2 and 7.6.

It is recommended that the pool be stabilized with 50-60 ppms trihydroxy triazine to nullify the dissipation effect of sunlight on chlorine. When using this product, both chlorine and trihydroxy triazine are being added to the water, however, it is necessary to initially stabilize pools with 50-60 ppms of trihydroxy triazine to effectively maintain the desired concentration of stabilizer.

**DIRECTIONS**

Use 3 ounces of Pool Chlorine Concentrate per 10,000 gallons of water as an initial treatment. Repeat daily until a residual of 1.0 to 3.0 ppms of available chlorine is established. The regular use of a test kit will determine the amount of chlorine necessary for maintaining 1.0 to 3.0 ppms. An average is 2-3 ounces of this chlorine concentrate per 10,000 gallons of water daily. The final demand for chlorine is to be established through use of a test kit and daily treatment adjusted accordingly.

If a need for superchlorination is indicated, use 12 ounces of this concentrate per 10,000 gallons of water.

NET WEIGHT

USDA REG. NO. 5185-61

# SUPER 85 CHLORINE CONCENTRATE

## ACTIVE INGREDIENT:

Trichloro-s triazinetrione  
(Available Chlorine 87.5%)

97%

## INERT INGREDIENTS:

3%

## TOTAL INGREDIENTS:

100.00%

When used as directed this product is effective as a pool water disinfecting agent.

The filter system should be backwashed or properly cleaned and the pH adjusted between 7.2 and 7.6.

It is recommended that the pool be stabilized with 50-60 ppms trihydroxy triazine to nullify the dissipation effect of sunlight on chlorine. When using this product, both chlorine and trihydroxy triazine are being added to the water, however, it is necessary to initially stabilize pools with 50-60 ppms of trihydroxy triazine to effectively maintain the desired concentration of stabilizer.

## DIRECTIONS

Use 3 ounces of Pool Chlorine Concentrate per 10,000 gallons of water as an initial treatment. Repeat daily until a residual of 1.0 to 3.0 ppms of available chlorine is established. The regular use of a test kit will determine the amount of chlorine necessary for maintaining 1.0 to 3.0 ppms. An average is 2-3 ounces of this chlorine concentrate per 10,000 gallons of water daily. The final demand for chlorine is to be established through use of a test kit and daily treatment adjusted accordingly.

If a need for superchlorination is indicated, use 12 ounces of this concentrate per 10,000 gallons of water.

NET WEIGHT

USDA REG. NO. 5185-61

