

5185-451

5-20-2002

1/4

{All text in brackets [xxx] is optional and may or may not be included on a final label.}
{All text in braces {xxx} is administrative and will not appear on a final label.}

NABR40-E

[For use as a Disinfectant, Bactericide, Fungicide, Algicide, and Mollusk Control Agent, and for Control of Microbial Slimes in: Recirculating Cooling Water Systems, Once-Through Cooling Water Systems, Wastewater Treatment Systems, Brewery Pasteurizers, and Pulp and Paper Mill Water.]

ACTIVE INGREDIENT:

Sodium bromide 40.0%

OTHER INGREDIENTS: 60.0%

TOTAL: 100.0%

KEEP OUT OF REACH OF CHILDREN

CAUTION

FIRST AID:

IF ON SKIN OR CLOTHING:

- Take off contaminated clothing.
- Rinse skin immediately with plenty of water for 15-20 minutes.
- Call a poison control center or doctor for treatment advice.

IF IN EYES:

- Hold eye open and rinse slowly and gently with water for 15-20 minutes.
- Remove contact lenses, if present, after the first 5 minutes, then continue rinsing eye.
- Call a poison control center or doctor for treatment advice.

IF SWALLOWED:


- Call poison control center or doctor immediately for treatment advice.
- Have person sip a glass of water if able to swallow.
- Do not induce vomiting unless told to do so by the poison control center or doctor.
- Do not give anything by mouth to an unconscious person.

[IN CASE OF MEDICAL EMERGENCY, CALL [1-303-623-5715] [1-877-800-5553] [telephone number supplied by supplemental registrant].]


SEE OTHER PRECAUTIONS ON SIDE PANEL

Net Weight _____
Lot No. _____

EPA Reg. No. 5185-451
EPA Est. No. 5785-AR-2



BIOLAB, INC.
P.O. BOX 1489
DECATUR, GA 30031



2/4

DIRECTIONS FOR USE: It is a violation of Federal Law to use this product in a manner inconsistent with its labeling. Read entire label and use strictly in accordance with precautionary statements and directions.

RECIRCULATING COOLING WATER SYSTEMS, INCLUDING AIR WASHERS AND BREWERY PASTEURIZERS:

When used in conjunction with an oxidant, this product effectively controls algal, bacterial, and fungal slime and controls the settlement and growth of mollusks such as the zebra mussel (*Dreissena*) or the Asiatic clam (*Corbicula*) in commercial and industrial cooling towers; influent water systems such as flow through filters, cooling ponds, canals, and lagoons; heat exchange water systems; air washers; pasteurizers; retort systems; and industrial water scrubbing systems.

DOSAGE RATES. Add this product to the system at a 0.125 to 2.0 sodium bromide/oxidant mole ratio. For example:

- 1) 1.6 to 26.5 pounds of chlorine gas (99.9%) per gallon of sodium bromide solution; or,
- 2) 1.3 to 21.2 gallons sodium hypochlorite (12.5% available chlorine) solution per gallon of sodium bromide solution.

Initial Dose: When the system is noticeably fouled, add 0.0003 to 0.024 gallons of this product per 1000 gallons of water contained in the system and oxidize with either gas chlorine (0.008 to 0.040 pounds gas chlorine per 1000 gallons of contained water), or sodium hypochlorite solution (0.007 to 0.032 gallons of 12.5% sodium hypochlorite solution per 1000 gallons of contained water).

Subsequent Dose: When microbial control is evident, add 0.0002 to 0.024 gallons of this product per 1000 gallons of water contained in the system and oxidize with either gas chlorine (0.004 to 0.040 pounds gas chlorine per 1000 gallons of contained water), or sodium hypochlorite solution (0.003 to 0.032 gallons of 12.5% sodium hypochlorite solution per 1000 gallons of contained water).

ONCE-THROUGH COOLING WATER AND WASTE WATER TREATMENT SYSTEMS:



When used in conjunction with an oxidant, this product effectively controls algal, bacterial and fungal slime and controls the settlement and growth of mollusks such as the zebra mussel (*Dreissena*) or the Asiatic clam (*Corbicula*) in once-through fresh and sea water cooling systems, cooling ponds, canals, and lagoons; and disinfects secondary and tertiary wastewater treatment systems.

DOSAGE RATES. Add this product to the system at a 0.125 to 2.0 sodium bromide/oxidant mole ratio. For example:

- 1) 1.6 to 26.5 pounds of chlorine gas (99.9%) per gallon of sodium bromide solution; or,
- 2) 1.3 to 21.2 gallons sodium hypochlorite (12.5% available chlorine) solution per gallon of sodium bromide solution.

Initial Dose: When the system is noticeably fouled, add 0.0008 to 0.049 gallons of this product per 1000 gallons of water contained in the system and oxidize with either gas chlorine (0.02 to 0.08 pounds gas chlorine per 1000 gallons of contained volume), or sodium hypochlorite solution (0.02 to 0.06 gallons of 12.5% sodium hypochlorite solution per 1000 gallons of contained volume).

Subsequent Dose: When microbial control is evident, add 0.0003 to 0.049 gallons of this product per 1000 gallons of water contained in the system and oxidize with either gas chlorine (0.008 to 0.08 pounds gas chlorine per 1000 gallons of contained volume), or sodium hypochlorite solution (0.006 to 0.06 gallons of 12.5% sodium hypochlorite solution per 1000 gallons of contained volume).



PULP AND PAPER MILLS:

When used in conjunction with an oxidant, this product effectively controls algal, bacterial, and fungal slime in pulp and paper mill fresh and sea water influent water systems; cooling water systems, wastewater treatment systems, service water systems, white water systems, non-potable water systems, and other process water.

DOSAGE RATES. Add this product to the system at a 0.125 to 2.0 sodium bromide/oxidant mole ratio. For example:


- 1) 1.6 to 26.5 pounds of chlorine gas (99.9%) per gallon of sodium bromide solution; or,
- 2) 1.3 to 21.2 gallons sodium hypochlorite (12.5% available chlorine) solution per gallon of sodium bromide solution.

Add sufficient amount of mixed product/oxidant solution to achieve a residual bromine level of 0.5 to 5.0 parts per million. For 0.5 parts per million add 0.00057 gallons of product and 0.0018 gallons of (12.5%) bleach or 0.0019 pounds gas chlorine per 1,000 gallons of water treated.

Treatment levels of this product and oxidant can best be measured with test kits for either bromine or chlorine. Tests should be made immediately after drawing water samples from the system. Use test kits according to directions.

- 1. When a bromine test kit is used, results can be read directly as parts per million bromine.
- 2. When a chlorine test kit is used, results can be expressed in terms of bromine by multiplying chlorine values by the conversion factor 2.25.

This product weighs 11.9 pounds/gallon at 70° F.



4/4

STORAGE AND DISPOSAL:

STORAGE. Keep product dry in tightly closed original container when not in use. Store in a cool, dry, well ventilated area. Product should be stored at 0°F or above.

DISPOSAL. Wastes resulting from the use of this product may be disposed of on site or at an approved waste disposal facility. **DO NOT REUSE EMPTY CONTAINER.** Triple rinse the container (or equivalent), then offer for recycling or reconditioning, or puncture and dispose of in a sanitary landfill, or incinerate. Burn only if allowed by state and local authorities. If burned, stay out of smoke.

PRECAUTIONARY STATEMENTS:

HAZARDS TO HUMANS AND DOMESTIC ANIMALS. CAUTION. Causes moderate eye irritation. Avoid contact with eyes, skin and clothing. Wash with soap and water after handling. Remove contaminated clothing and wash before reuse.

PHYSICAL AND CHEMICAL HAZARDS:

Sodium bromide is not flammable. However, in fires fueled by other materials, hydrogen bromide or bromine may be released. In case of fire, wear self-contained breathing apparatus.

ENVIRONMENTAL HAZARDS: This product is toxic to fish and aquatic organisms. Do not discharge effluent containing this product into lakes, streams, ponds, estuaries, oceans or other waters unless in accordance with the requirements of a National Pollutant Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not discharge effluent containing this product to sewer systems without previously notifying the local sewage treatment plant authority. For guidance contact your State Water Board or Regional Office of the EPA.

NOTE: Buyer assumes all responsibility for safety and use not in accordance with directions.

