

{All text in brackets [xxx] is optional and may or may not be included on a final label.}

{All text in braces {xxx} is administrative and will not appear on a final label.}

{Center Panel}

## Bellacide® 325

For control of algae in recirculating cooling water systems,  
and in decorative and ornamental fountains.

### ACTIVE INGREDIENT:

Terbuthylazine:

2-(tert-butylamino)-4-chloro-

6-(ethylamino)-S-Triazine 4.0%

OTHER INGREDIENTS: 96.0%

TOTAL: 100.0%

EPA Reg. No. 5185-479  
EPA Est. No. 55618-SC-001


Bellacide 325  
is an Aqueous Dispersion

KEEP OUT OF REACH  
OF CHILDREN

### CAUTION

Refer to Left Panel for  
Additional Precautionary Statements

Bio-Lab, Inc.  
Water Additives Division  
PO Box 1489  
Decatur, GA 30031



### EMERGENCY TELEPHONE NUMBERS

MEDICAL: 877-800-5553


TRANSPORTATION: 800-424-9300

MEDICAL (OUTSIDE USA): 303-623-5716

Net Weight 450 lbs.

{Right Panel}

### Directions for Use – Recirculating Cooling Water Systems, Decorative and Ornamental Fountains



It is a violation of Federal Law to use this product in a manner inconsistent with its labeling. Read entire label and use strictly in accordance with precautionary statements and directions.

**Industrial Use Application Restrictions:** Open pouring of this products is prohibited. Mixing, loading, and application must be with a closed system (one that prevents the chemical from contacting handlers or other persons) and during handling of the chemical personal protective equipment must be worn. Personal protective equipment includes a long-sleeved shirt, long pants, shoes, socks, and chemical-resistant gloves. A chemical-resistant apron must be immediately available during loading and application and must be worn in case of a leak, spill, or other exposure to the concentrate.

**When to apply:** Heavy algae growth contributes to restricted water flow in recirculating cooling water systems, thereby impairing the efficiency of the system, especially heat-exchange efficiency. Bellacide 325 alone or a combination of Bellacide 325 and chlorine or a chlorine releasing agent (such as sodium, calcium, or lithium hypochlorite) used regularly controls algae and prevents re-establishment of algae when used according to directions.

Clean badly fouled systems before treatment. It is recommended that treatment be used prior to the first signs of algal growth, or after cleaning a system whose efficiency is already impaired by algal growth. Apply at a point in the system where Bellacide 325 will be uniformly mixed, such as in the tower sump.

Bellacide 325 is compatible with other water treatment products, including polymeric anionic scale inhibitors and dispersants, has low-foaming properties, and is non-corrosive to piping and equipment.

Treat the water early in the algal growth period (typically early spring) before the system is in jeopardy of becoming fouled by algae. For maximum effectiveness, systems with heavy algae growth should be cleaned before using Bellacide 325.

**Treatment of algae in recirculating cooling water systems and in decorative and ornamental fountains:** Apply Bellacide 325 at a point in the system where there is good mixing such as in the cooling tower basin near the recirculating water pump or near the fountain recirculating water pump. Bellacide 325 is slow to remove algae from a system and therefore its action will reduce the risk of large algae clumps possibly clogging the distribution deck orifices or the heat exchanger of a recirculating cooling water system.

#### Chlorinated Systems and/or Brominated Systems

##### (I) Continuous addition:

**Initial Treatment** - To keep systems free of algae, maintain up to 3 fluid ounces per 1000 gallons of water, or about 25 ppm, of Bellacide 325 in the system water (which is equivalent to about 1 ppm active ingredient) in conjunction with either continuous dosing or regular shock doses (for example, one hour, twice a day) of 0.1 – 1 ppm free chlorine and/or bromine. In order to achieve a maintenance level of 25 ppm Bellacide 325 by continuous addition it will be necessary to have an appropriate dosing pump and know the volume, half-life (makeup/blowdown rate), evaporative rate, and windage loss of the system.

**Maintenance Treatment** - Concentrations below the recommended level of 25 ppm Bellacide 325 may give adequate control, depending upon the strains of algae present. Experience will demonstrate the level of Bellacide 325 required.

(II) **Slug/Intermittent addition:**

**Initial Treatment** - Apply sufficient Bellacide 325 to maintain up to 25 ppm Bellacide 325 in the water together with chlorination and/or bromination as described under the continuous addition section. Dosing concentration and frequency will be dependent upon a system's volume and half-life (makeup/blowdown rate). For example, to maintain 25 ppm Bellacide 325 in a system with a volume of 10,000 gallons and a half-life of 3 days, an initial dose of 50 ppm Bellacide 325 would be required (about 60 fluid ounces in 10,000 gallons), followed by additions of 25 ppm Bellacide 325 (about 30 fluid ounces in 10,000 gallons) every 3 days.

**Maintenance Treatment** - Concentrations below the recommended level of 25 ppm Bellacide 325 may give adequate control, depending upon the strains of algae present. Experience will demonstrate the level of Bellacide 325 required.

It is recommended that Bellacide 325 be dosed at the same time as the chlorine and/or bromine is dosed and as close as possible to the chlorine and/or bromine dosing point.

**Non-Chlorinated and/or Non-Brominated Systems**

(I) **Continuous addition:**


**Initial Treatment** - To keep systems free of algae, maintain up to 9 fluid ounces per 1000 gallons of water, or about 75 ppm, of Bellacide 325 in the system water (which is equivalent to about 3 ppm active ingredient). In order to achieve a maintenance level of 75 ppm Bellacide 325 by continuous addition it will be necessary to have an appropriate dosing pump and know the volume, half-life (makeup/blowdown rate), evaporative rate, and windage loss of the system.

**Maintenance Treatment** - Concentrations below the recommended level of 75 ppm Bellacide 325 may give adequate control, depending upon the strains of algae present. Experience will demonstrate the level of Bellacide 325 required.

(II) **Slug/Intermittent addition:**

**Initial Treatment** - Apply sufficient Bellacide 325 to maintain up to 75 ppm Bellacide 325 in the water. Dosing concentration and frequency will be dependent upon a system's volume and half-life (makeup/blowdown rate). For Example, to maintain 75 ppm Bellacide 325 in a system with a volume of 10,000 gallons and a half-life of 3 days, an initial dose of 150 ppm Bellacide 325 would be required (about 180 fluid ounces in 10,000 gallons), followed by additions of 75 ppm Bellacide 325 (about 90 fluid ounces in 10,000 gallons) every 3 days.

**Maintenance Treatment** - Concentrations below the recommended level of 75 ppm Bellacide 325 may give adequate control, depending upon the strains of algae present. Experience will demonstrate the level of Bellacide 325 required.



4 8 6  
3


*{Below are two optional warranty statements, short and long versions, which may be used on label interchangeably}*

**[NOTE: Buyer assumes all responsibility for safety and use not in accordance with directions.]**

*{or}*

**[Conditions of Sale and Warranty**

The directions for use of this product reflect the opinion of experts, based on field use and tests. The directions are believed to be reliable and should be followed carefully. However, it is impossible to eliminate all risks inherently associated with the use of this product. Ineffectiveness, or other unintended consequences, may result because of such factors as the presence of other materials or the manner of use, all of which are beyond the control of Bio-Lab, Inc. or the seller. All such risks shall be assumed by the buyer. Bio-Lab, Inc. makes no warranty whether expressed or implied, including warranties of merchantability or of fitness for a particular purpose for this product. Under no circumstances shall Bio-Lab, Inc. be liable for incidental, consequential or other damages from alleged negligence, breach of warranty, strict liability or any other theory, arising out of the use or handling of this product. The sole liability of Bio-Lab, Inc. for any claims arising out of the manufacture, use or sale of its products shall be for the buyer's purchase price.]



5 7 6  
1

{Left Panel}

## Precautionary Statements Hazards to Humans and Domestic Animals

### CAUTION

Harmful if swallowed or absorbed through the skin. Avoid contact with eyes, skin, or clothing. Wash thoroughly with soap and water after handling. Follow personal protective equipment manufacturer's instruction for cleaning/maintaining personal protective equipment. If no such instructions for washables exists, use detergent and hot water. Store and wash personal protective equipment separately from other laundry. Users should wash before eating, drinking, chewing gum, using tobacco, or using the toilet. Users should remove clothing immediately if pesticides gets inside. Then wash thoroughly and put on clean clothes. Users should remove personal protective equipment immediately after handling this product. Wash outside of gloves before removing. As soon as possible, wash thoroughly and change into clean clothing.

#### FIRST AID:

##### IF SWALLOWED:

- Call poison control center or doctor immediately for treatment advice.
- Have person sip a glass of water if able to swallow.
- Do not induce vomiting unless told to do so by the poison control center or doctor.
- Do not give anything by mouth to an unconscious person.

##### IF ON SKIN OR CLOTHING:

- Take off contaminated clothing.
- Rinse skin immediately with plenty of water for 15-20 minutes.
- Call a poison control center or doctor for treatment advice.


##### IF INHALED:

- Move person to fresh air.
- If person is not breathing, call 911 or an ambulance, then give artificial respiration, preferably mouth-to-mouth, if possible.
- Call a poison control center or doctor for treatment advice.

##### IF IN EYES:

- Hold eye open and rinse slowly and gently with water for 15-20 minutes.
- Remove contact lenses, if present, after the first 5 minutes, then continue rinsing eye.
- Call a poison control center or doctor for treatment advice.

Have the label or MSDS with you when calling a poison control center or doctor, or going for treatment. [IN CASE OF MEDICAL EMERGENCY, CALL [1-303-623-5716] [1-877-800-5553] [telephone number supplied by supplemental registrant].]



### ENVIRONMENTAL HAZARDS

Do not discharge effluent containing this product into lakes, streams, ponds, estuaries, oceans, or other waters unless in accordance with the requirements of a National Pollutant Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not discharge effluent containing this product to sewer systems without previously notifying the sewage treatment plant authority. For guidance contact your State Water Board or Regional Office of the EPA.

**Precaution:** Do not use Bellacide 325 in recirculating cooling water systems or decorative and ornamental fountains where the treated water will come into contact with lawns, trees, shrubs, or other desirable plants, since injury may result. Water from treated systems may not be used for irrigation or spraying of agricultural crops, lawns, or ornamental plants, or for watering cattle, goats, hogs, horses, poultry, or sheep, or for human consumption.

### Storage and Disposal

Do not contaminate water, food, or feed by storage or disposal.

**Storage:** Protect from freezing.

**Pesticide Disposal:**

Waste resulting from the use of this product may be disposed of on site or at an approved waste disposal facility.

**Container Disposal:**

Triple rinse (or equivalent). Then offer for recycling or reconditioning, or puncture and dispose of in a sanitary landfill, or incinerate, or, if allowed by state and local authorities, by burning. If burned, stay out of smoke.

**ACCEPTED**

FEB 27 2003

Under the Federal Insecticide, Fungicide, and  
Rodenticide Act as amended, for the  
pesticide, registered under  
EPA Reg. No. 5185-479