

INDUSTRIAL WATER COOLING TOWER ALGAECIDE

Concentrated Algaecide for Industrial re-circulating water cooling towers. Helps keep water cooling tower systems clear and free of visible algae slimes.

ACTIVE INGREDIENTS:

| n-Alkyl (60% C ₁₄ ,30% C ₁₆ , 5% C ₁₂ , 5% C ₁₈) | |
|---|------|
| dimethyl benzyl ammonium chlorides | 5% |
| n-Alkyl (68% C _{12,} 32% C ₁₄) dimethyl | |
| ethylbenzyl ammonium chlorides | 5% |
| INERT INGREDIENTS: | ΩΩ9/ |
| - | |
| | 100% |

DANGER

KEEP OUT OF REACH OF CHILDREN. SEE RIGHT SIDE PANEL FOR FIRST AID AND ADDITIONAL PRECAUTIONARY STATE-MENTS.

FOR INDUSTRIAL USE ONLY NET CONTENTS ____ GALS

EPA Est. No. 1839-36 EPA Reg. No. 5404-7 When ALGACIDE is used as directed, it will aid in controlling and/or preventing the development of unsanitary slime conditions which are unsightly, produce foul odors and which are often the cause of equipment breakdown.

ALGACIDE is compatible with virtually all corrosion inhibition additives, but should not be used in the presence of soap or other anionic detergents. ALGACIDE at use dilution is non-corrosive to inanimate hard surfaces.

DANGER

Keep Out of Reach of Children. Corrosive. Causes severe eye and skin damage. Do not get in eyes, on skin or on clothing. Wear goggles or face shield, and rubber gloves when handling. Harmful or fatal if swallowed. Avoid contamination of food.

FIRST AID

In case of contact, immediately flush eyes or skin with plenty of water for at least 15 minutes. For eyes, call a physician. Remove and wash all contaminated clothing before reuse. If swallowed, drink milk, egg whites, gelatin solution, or if these are not available, drink large quantities of water. Call a physician.

NOTE TO PHYSICIAN

Probable mucosal damage may contraindicate the use of gastric lavage. Measures against circulatory shock, respiratory depression and convulsion may be needed.

Rinse empty container thoroughly with water and discard

DIRECTIONS FOR USE

Begin treatment when the system is in jeopardy of becoming affected or after cleaning systems whose efficiency is already impaired.

INITIAL DOSE: 1-2 gallons of ALGACIDE to each 5,000 gallons of water contained in the system. Repeat until control is evident. When system is in control, add

PERIODIC DOSE: 1-3 quarts of ALGACIDE to each 5,000 gallons of water contained in the system every 7 days or sooner should visible growth appear.

For best results, clean heavily contaminated systems before treatment with this product. If soap or anionic detergent is used, rinse thoroughly before charging with ALGACIDE. Apply ALGACIDE at a point in the system where uniform mixing will take place.

Do not be alarmed with the sudden appearance of organic debris in the system during the first week of operation. This is normal and is a good indication that ALGACIDE has effectively penetrated and dislodged dead organic material which tenaciously adheres to metal and wooden surfaces as living matter. This debris should be removed from the system to avoid clogging of screens and pipes.

FISH AND/OR WILDLIFE PRECAUTIONS

This product is toxic to fish. Treated effluent should not be discharged where it will drain into lakes, streams, ponds or public waters. Apply this product only as specified on this label

81975

GREEN'S, INC.

P. O. BOX 3309 • ALBUQUERQUE, NEW MEXICO 87110 • (505) 881-6550 P. O. BOX 641 • FARMINGTON, NEW MEXICO 87401 • (505) 325-4132

"Serving the Southwest for Over a Quarter Century"