


3. Submit five (5) copies of your final printed labeling before you release the product for shipment. Refer to the A-79 Enclosure for a further description of final printed labeling.

If these conditions are not complied with, the registration will be subject to cancellation in accordance with FIFRA sec. 6(e). Your release for shipment of the product constitutes acceptance of these conditions.

A stamped copy of the label is enclosed for your records.



John H. Lee
Product Manager (31)
Disinfectants Branch
Registration Division (TS-767C)

Enclosure

RD/DIS:JOB--51605:LEE:vg:CBI-26:Kendrick & Co. 898-1270:2/13/85:Del.2/22/85

Team M Cooling Tower Treatment

ACTIVE INGREDIENT:

Potassium dimethyldithiocarbamate 12.5 %

INERT INGREDIENTS 87.5 %

This product contains 1.1 lb. of active ingredient per gallon and weighs 8.77 lb. per gallon.

KEEP OUT OF REACH OF CHILDREN
WARNING

PRECAUTIONARY STATEMENTS
HAZARDS TO HUMANS AND DOMESTIC ANIMALS

WARNING: Causes eye damage and skin irritation. Harmful if swallowed. Do not get in eyes, on skin, or on clothing. Avoid contamination of food. Wear goggles or face shield and rubber gloves when handling. Wash thoroughly after handling.

STATEMENT OF PRACTICAL TREATMENT: In case of skin contact, wash with plenty of soap and water. Remove contaminated clothing and wash before reuse. If product gets in the eyes, flush immediately with copious amounts of clean, cool water for at least 15 minutes. Get medical attention immediately. If product is swallowed, call a physician immediately. If patient is conscious, induce vomiting by stroking or tickling the patient's throat or far back on patient's tongue. Emetics such as 2 teaspoonful (10 mL) of ipecac syrup or 1 teaspoonful (5 mL) of dry mustard in warm water to form a paste or even soap in warm water can be used. Repeat until vomit fluid is clear. Then have patient drink plenty of milk, gelatin solution, beaten egg whites, flour and water, or other nonoily demulcent. Never induce vomiting or give anything by mouth to an unconscious person.

Note to physician: Probable mucosal damage may contraindicate gastric lavage.

ENVIRONMENTAL HAZARDS: This pesticide is toxic to fish. Do not discharge treated effluent into lakes, streams, ponds, or public waters unless in accordance with a NPDES permit. For guidance, contact your Regional Office of the Environmental Protection Agency.

ACCEPTED
with COMMENTS
in EPA Letter Dated:

Manufactured by:

FEB 21 1985

Team Associates
1017 Brown Avenue

Toledo, OH 43607

EPA Reg. No.

EPA Est. No.

Under the Federal Insecticide, Fungicide, and Rodenticide Act as amended, for the pesticide registered under EPA Reg. No.

5700-12

Net Contents:

DIRECTIONS FOR
GENERAL CLASSIFICATION

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

Team M Cooling Tower Treatment is used on recirculating cooling tower systems and industrial microbiological slime. Prior to the use of Team M Cooling Tower Treatment, industrial and/or commercial recirculating cooling towers should be cleaned to remove algal growth, microbiological slime, and other deposits. An initial slug addition of 9.5 to 14.2 fl. oz. of Team M Cooling Tower Treatment per 1000 gal. of water to provide 80 to 120 ppm Team M Cooling Tower Treatment until control is evident. Make subsequent slug additions of Team M Cooling Tower Treatment per 1000 gal. of water until control is evident. Make subsequent slug additions of Team M Cooling Tower Treatment per 1000 ppm Team M Cooling Tower Treatment until control is evident. The rate of addition depends upon the relative amount of microbiological problem. Slug additions should be made to the sump or the bleedoff line of recirculating tower systems.

Team M Cooling Tower Treatment is used on industrial and/or commercial recirculating cooling towers which maintain effective mist-eliminating components. Prior to the use of Team M Cooling Tower Treatment, industrial and/or commercial recirculating cooling towers should be cleaned to remove bacterial slime and other deposits. An initial slug addition of 28.4 fl. oz. of Team M Cooling Tower Treatment per 1000 gal. of water is recommended. Repeat initial dosage until control is evident. Make subsequent slug additions of 16.5 to 28.4 fl. oz. of Team M Cooling Tower Treatment per 1000 gal. of water should be employed every 1 to 5 days until control is evident. The rate of addition depends upon the relative amount of bleedoff line. Slug additions may be made to the sump or the bleedoff line of recirculating tower systems.

STORAGE AND DISPOSAL

Do not contaminate water, food, or feed by storage or disposal.

STORAGE: Do not expose to extreme temperatures. Do not stack drums. Drums should be placed in overpack drums for disposal. Spills should be cleaned up immediately. Keep container closed when not in use.

PESTICIDE DISPOSAL: Pesticide wastes are toxic. Improper disposal is a violation of Federal Law. If these wastes cannot be disposed of by other means, contact your State Pesticide or Environmental Control Agency, or the nearest Regional Office for guidance.

CONTAINER DISPOSAL:

1) PLASTIC: Triple rinse (or equivalent). Then offer for recycling or reuse, or by other procedures approved by state and local officials.

2) METAL: Triple rinse (or equivalent). Then offer for recycling or reuse, or by other procedures approved by state and local officials.