

DIVISION OF CHEMED CORPORATION

Dubois Tower • Cincinnati, Ohio 45202 • U.S.A.

-SOLELY FOR INDUSTRIAL USE-

The state of the s

A 3ACTERIOSTAT AND ALGICIDE FOR MICROORGANISMS (Bacto AND COMMERCIAL RECIRCULAR)

ACTIVE INGREDIENTS:

N-Alkyl (7% C₈, 6.5% C₁₀, 53% (1, 3 — Propanediamine Isopropyl Alcohol 2, 4, 5-Trichlorophenol

INERT INGREDIENTS

EPA Reg.

DANGER: KEEP OUT

SEE SIDE PANEL FOR FIRST AIL

KEEP FROM FREEZING

A BACTERIOSTAT AND ALGICIDE FOR THE CONTROL OF THE GROWTH OF MICROORGANISMS (Bacteria and Algae) IN INDUSTRIAL AND COMMERCIAL RECIRCULATING COOLING TOWERS.

ACTIVE INGREDIENTS:

N-Alkyl (7% C ₈ , 6.5% C ₁₀ , 53% C ₁₂ , 19% C ₁₄ , 8.5% C ₁₆ , 6% C ₁₈) —	-
1, 3 — Propanediamine 1	5.0%
Isopropyl Alcohol	5.0%
2, 4, 5-Trichlorophenol	_
IERT INGREDIENTS	0.5%

EPA Reg. No. 5736-54

CCEPTED

INDER THE FEDERAL II FUNGICIDE AND RODEN. SOR ECONOMIC POISON ID UNDER NO. 5736

DANGER: KEEP OUT OF REACH OF CHILDREN

SEE SIDE PANEL FOR FIRST AID AND ADDITIONAL PRECAUTIONS

KEEP FROM FREEZING

AGITATE BEFORE USING



ACCEPTED

WAR 28 1976

UNDER THE FEDERAL INSECTICID
FUNGICIDE AND RODENTICIDE AC
FOR ECONOMIC POISON REGISTER
ED UNLER NO. 5 736-54

USING DIRECTIONS

evident, apply 12.4 to 18.6 fluid ounces of D-SLIME per 1000 gallons (100 ppm to 150 ppm of product) of water in the system. Repeat until control is achieved. Badly fouled systems should be cleaned before treatment is begun. SUBSEQUENT DOSE — When microbiological control is evident, apply 6.2 to 12.4 fluid ounces of D-SLIME per 1000 gallons (50 ppm to 100 ppm of product) of water in the system once per week, or as needed to maintain control. FEEDING — D-SLIME should be fed at full strength in the cooling tower basin at a point of maximum water circulation. Tower bleedoff valves should be closed to permit a retention time of 4 hours. See Product Bulletin for D-SLIME.

Water treated with DuBois D-SLIME should not be used for food processing irrigations or in the manufacture of paper used for food packaging.

This product is toxic to fish. Treated effluent should not be discharged where it will drain into lakes, streams, ponds, or public water. Do not contaminate water by cleaning of equipment or disposal of wastes. Apply this product only as specified on this label. Do not reuse empty drum. Rinse thoroughly water and return to drum reconditioner, or desby perforating or crushing.

Keep container closed when not in use.

Keep this product away from heat or open fla

DANGER: CORROSIVE KEEP OUT OF REACH OF CHILDREN

Causes eye damage and skin irritation. Do no in eyes, on skin or on clothing. Wear goggle face shield and rubber gloves when handling. H ful or fatal if swallowed. Avoid contamination food.

eyes or skin with plenty of water for at least minutes. For eyes, call a physician. Remove wash contaminated clothing before reuse. If so lowed, drink *PROMPTLY* a large quantity of egg whites, gelatin solution or if these are not a able, drink large quantities of water. Avoid alco Call a physician immediately.

NOTE TO PHYSICIAN: Probable mucosal darmay contraindicate the use of gastric lavage. Mures against circulatory shock, respiratory depoints and convulsion may be needed.

NET WEIGHT-50 lbs.