

Precautionary Statements
Hazards to Humans and Domestic Animals
KEEP OUT OF REACH OF CHILDREN

DANGER

Corrosive. Causes eye damage and skin irritation. Do not get in eyes, on skin, or on clothing. Wear goggles or face shield and rubber gloves when handling. Wash thoroughly with plenty of water after use.

PHYSICAL HAZARDS: None known. Do not use in confined spaces without proper ventilation.

STORAGE AND DISPOSAL

- Do not contaminate water, food, or feed by storage or disposal.
- Open dumping is prohibited.
- Do not reuse empty container.

PESTICIDE DISPOSAL: Pesticide that cannot be used or that can't be repackaged should be disposed of in a landfill approved for pesticides or in a safe place away from water supplies.

CONTAINER DISPOSAL: Do not reuse empty container. Return to drum reconditioner or other qualified person for recycling or disposal.

DIRECTIONS FOR USE

This is a violation of Federal Law to use this product in a manner not consistent with its labeling.
NOTE: ADD GAX-20 SEPARATELY TO THE SYSTEM. DO NOT MIX WITH OTHER ADDITIVES.

INDUSTRIAL RECIRCULATING WATER COOLING TOWERS

Add GAX-20 to the water supply of the cooling tower. Add GAX-20 should be made with a metering pump. The amount to be added depends on the severity of the contamination. When treatment is begun, add 0.192 gal. GAX-20 per 100 gal. of water in the system.

Continue to pump GAX-20 until the water is clear. When the water is clear, stop adding GAX-20. The water should be clear and free of any visible contamination.

FOR CONTROL OF BACTERIA

Add GAX-20 to the water supply of the cooling tower. Add GAX-20 should be made with a metering pump. The amount to be added depends on the severity of the contamination. When treatment is begun, add 0.192 gal. GAX-20 per 100 gal. of water in the system.

Continue to pump GAX-20 until the water is clear. When the water is clear, stop adding GAX-20. The water should be clear and free of any visible contamination.

Continue to pump GAX-20 until the water is clear. When the water is clear, stop adding GAX-20. The water should be clear and free of any visible contamination.

Continue to pump GAX-20 until the water is clear. When the water is clear, stop adding GAX-20. The water should be clear and free of any visible contamination.

Continue to pump GAX-20 until the water is clear. When the water is clear, stop adding GAX-20. The water should be clear and free of any visible contamination.

Continue to pump GAX-20 until the water is clear. When the water is clear, stop adding GAX-20. The water should be clear and free of any visible contamination.

Continue to pump GAX-20 until the water is clear. When the water is clear, stop adding GAX-20. The water should be clear and free of any visible contamination.

Continue to pump GAX-20 until the water is clear. When the water is clear, stop adding GAX-20. The water should be clear and free of any visible contamination.

Continue to pump GAX-20 until the water is clear. When the water is clear, stop adding GAX-20. The water should be clear and free of any visible contamination.

Continue to pump GAX-20 until the water is clear. When the water is clear, stop adding GAX-20. The water should be clear and free of any visible contamination.

Continue to pump GAX-20 until the water is clear. When the water is clear, stop adding GAX-20. The water should be clear and free of any visible contamination.

Continue to pump GAX-20 until the water is clear. When the water is clear, stop adding GAX-20. The water should be clear and free of any visible contamination.

Continue to pump GAX-20 until the water is clear. When the water is clear, stop adding GAX-20. The water should be clear and free of any visible contamination.

Continue to pump GAX-20 until the water is clear. When the water is clear, stop adding GAX-20. The water should be clear and free of any visible contamination.

Continue to pump GAX-20 until the water is clear. When the water is clear, stop adding GAX-20. The water should be clear and free of any visible contamination.

Continue to pump GAX-20 until the water is clear. When the water is clear, stop adding GAX-20. The water should be clear and free of any visible contamination.

Continue to pump GAX-20 until the water is clear. When the water is clear, stop adding GAX-20. The water should be clear and free of any visible contamination.

Continue to pump GAX-20 until the water is clear. When the water is clear, stop adding GAX-20. The water should be clear and free of any visible contamination.

Continue to pump GAX-20 until the water is clear. When the water is clear, stop adding GAX-20. The water should be clear and free of any visible contamination.

Continue to pump GAX-20 until the water is clear. When the water is clear, stop adding GAX-20. The water should be clear and free of any visible contamination.

Continue to pump GAX-20 until the water is clear. When the water is clear, stop adding GAX-20. The water should be clear and free of any visible contamination.

Continue to pump GAX-20 until the water is clear. When the water is clear, stop adding GAX-20. The water should be clear and free of any visible contamination.

Continue to pump GAX-20 until the water is clear. When the water is clear, stop adding GAX-20. The water should be clear and free of any visible contamination.

Continue to pump GAX-20 until the water is clear. When the water is clear, stop adding GAX-20. The water should be clear and free of any visible contamination.

Continue to pump GAX-20 until the water is clear. When the water is clear, stop adding GAX-20. The water should be clear and free of any visible contamination.

Continue to pump GAX-20 until the water is clear. When the water is clear, stop adding GAX-20. The water should be clear and free of any visible contamination.

Continue to pump GAX-20 until the water is clear. When the water is clear, stop adding GAX-20. The water should be clear and free of any visible contamination.

PRODUCT NO. 02273

GAX-20

ANTIMICROBIAL

CONTROLS BACTERIA AND ALGAE IN INDUSTRIAL RECIRCULATING WATER COOLING TOWERS

Controls Slime-Forming Bacteria and Fungi in Air-Washer Systems*

CONTROLS BACTERIA, FUNGI, AND YEASTS IN PAPER MILLS

Active Ingredient: 2,2-Dibromo-3-trichloropropionate
Inert Ingredients: 54% 95%

DANGER

CAUSES SEVERE BURNS OF EYES

CAUSES SKIN IRRITATION

HARMFUL IF SWALLOWED

Do Not Get in Eyes, on Skin, or Clothing

Wear Chemical Worker's Goggles when Handling

FIRST AID: In case of eye contact, flush eyes immediately with plenty of water for at least 15 minutes and get medical attention. In case of skin contact, wash with soap and plenty of water. If swallowed, induce vomiting. Do not use. Get medical attention if irritation persists.

If swallowed, induce vomiting immediately by drinking two glasses of water and sticking finger down throat. Repeat until you are sick. Call a Physician, Never give anything by mouth to an unconscious person.

WASH THOROUGHLY AFTER HANDLING

KEEP CONTAINER TIGHTLY CLOSED WHEN NOT IN USE

Net Contents Indicated somewhere On Container
EPA Reg. No. 18-54A EPA Est. No. 5736 OH-1

*Note: For use only in air-washer systems that maintain effective moist eliminating components.

FOR CONTROL OF ALGAE

Add 0.192 gal. GAX-20 per 100 gal. of water in the system depending on the severity of the contamination.

INITIAL DOSE: 0.192 gal. GAX-20 per 100 gal. of water.

SUBSEQUENT DOSE: When the system is not clearly fouled, add 0.192 gal. GAX-20 per 100 gal. of water in the system. Repeat until control is achieved.

REPEATED DOSE: When a persistent level of fouling is evident, add 0.192 gal. GAX-20 per 100 gal. of water in the system daily, or as needed to maintain control.

BADLY FOULED SYSTEMS: In a badly fouled system, treatment is begun with a 0.192 gal. GAX-20 per 100 gal. of water.

INITIAL DOSE: When the system is not clearly fouled, add 0.192 gal. GAX-20 per 100 gal. of water in the system.

SUBSEQUENT DOSE: When the system is not clearly fouled, add 0.192 gal. GAX-20 per 100 gal. of water in the system.

REPEATED DOSE: When a persistent level of fouling is evident, add 0.192 gal. GAX-20 per 100 gal. of water in the system daily, or as needed to maintain control.

BADLY FOULED SYSTEMS: In a badly fouled system, treatment is begun with a 0.192 gal. GAX-20 per 100 gal. of water.

INITIAL DOSE: When the system is not clearly fouled, add 0.192 gal. GAX-20 per 100 gal. of water in the system.

SUBSEQUENT DOSE: When the system is not clearly fouled, add 0.192 gal. GAX-20 per 100 gal. of water in the system.

REPEATED DOSE: When a persistent level of fouling is evident, add 0.192 gal. GAX-20 per 100 gal. of water in the system daily, or as needed to maintain control.

BADLY FOULED SYSTEMS: In a badly fouled system, treatment is begun with a 0.192 gal. GAX-20 per 100 gal. of water.

INITIAL DOSE: When the system is not clearly fouled, add 0.192 gal. GAX-20 per 100 gal. of water in the system.

SUBSEQUENT DOSE: When the system is not clearly fouled, add 0.192 gal. GAX-20 per 100 gal. of water in the system.

REPEATED DOSE: When a persistent level of fouling is evident, add 0.192 gal. GAX-20 per 100 gal. of water in the system daily, or as needed to maintain control.

BADLY FOULED SYSTEMS: In a badly fouled system, treatment is begun with a 0.192 gal. GAX-20 per 100 gal. of water.

INITIAL DOSE: When the system is not clearly fouled, add 0.192 gal. GAX-20 per 100 gal. of water in the system.

SUBSEQUENT DOSE: When the system is not clearly fouled, add 0.192 gal. GAX-20 per 100 gal. of water in the system.

REPEATED DOSE: When a persistent level of fouling is evident, add 0.192 gal. GAX-20 per 100 gal. of water in the system daily, or as needed to maintain control.

BADLY FOULED SYSTEMS: In a badly fouled system, treatment is begun with a 0.192 gal. GAX-20 per 100 gal. of water.

INITIAL DOSE: When the system is not clearly fouled, add 0.192 gal. GAX-20 per 100 gal. of water in the system.

SUBSEQUENT DOSE: When the system is not clearly fouled, add 0.192 gal. GAX-20 per 100 gal. of water in the system.

REPEATED DOSE: When a persistent level of fouling is evident, add 0.192 gal. GAX-20 per 100 gal. of water in the system daily, or as needed to maintain control.

BADLY FOULED SYSTEMS: In a badly fouled system, treatment is begun with a 0.192 gal. GAX-20 per 100 gal. of water.

INITIAL DOSE: When the system is not clearly fouled, add 0.192 gal. GAX-20 per 100 gal. of water in the system.

SUBSEQUENT DOSE: When the system is not clearly fouled, add 0.192 gal. GAX-20 per 100 gal. of water in the system.

REPEATED DOSE: When a persistent level of fouling is evident, add 0.192 gal. GAX-20 per 100 gal. of water in the system daily, or as needed to maintain control.

BADLY FOULED SYSTEMS: In a badly fouled system, treatment is begun with a 0.192 gal. GAX-20 per 100 gal. of water.

INITIAL DOSE: When the system is not clearly fouled, add 0.192 gal. GAX-20 per 100 gal. of water in the system.

SUBSEQUENT DOSE: When the system is not clearly fouled, add 0.192 gal. GAX-20 per 100 gal. of water in the system.

REPEATED DOSE: When a persistent level of fouling is evident, add 0.192 gal. GAX-20 per 100 gal. of water in the system daily, or as needed to maintain control.

BADLY FOULED SYSTEMS: In a badly fouled system, treatment is begun with a 0.192 gal. GAX-20 per 100 gal. of water.

INITIAL DOSE: When the system is not clearly fouled, add 0.192 gal. GAX-20 per 100 gal. of water in the system.

SUBSEQUENT DOSE: When the system is not clearly fouled, add 0.192 gal. GAX-20 per 100 gal. of water in the system.

REPEATED DOSE: When a persistent level of fouling is evident, add 0.192 gal. GAX-20 per 100 gal. of water in the system daily, or as needed to maintain control.

BADLY FOULED SYSTEMS: In a badly fouled system, treatment is begun with a 0.192 gal. GAX-20 per 100 gal. of water.

INITIAL DOSE: When the system is not clearly fouled, add 0.192 gal. GAX-20 per 100 gal. of water in the system.

SUBSEQUENT DOSE: When the system is not clearly fouled, add 0.192 gal. GAX-20 per 100 gal. of water in the system.

REPEATED DOSE: When a persistent level of fouling is evident, add 0.192 gal. GAX-20 per 100 gal. of water in the system daily, or as needed to maintain control.

BADLY FOULED SYSTEMS: In a badly fouled system, treatment is begun with a 0.192 gal. GAX-20 per 100 gal. of water.

BEST DOCUMENT AVAILABLE



DuBOIS CHEMICALS, A DIVISION OF CHEMED CORPORATION • CH

CONTACT YOUR DuBOIS REPRESENTATIVE FOR ADDITIONAL USE DIRECTIONS AND MATERIAL

DUCT NO 02273

X-20

MICROBIAL

AND ALGAE IN INDUSTRIAL
WATER COOLING TOWERS

Bacteria and Fungi in Air-Washer Systems*

MUNGI, AND YEASTS IN PAPER MILLS

1/10/77, 1/10/77, 3/10/77

DANGER

SEVERE BURNS OF EYES

SKIN IRRITATION

IF SWALLOWED

Eyes, on Skin, or Clothing

Wear Goggles when Handling

Wash eyes immediately with plenty of water for 15 minutes. In case of eye contact, wash with water and flush out thoroughly before use. Get medical attention.

Wash thoroughly with plenty of water. If swallowed, do not induce vomiting. Call a Physician immediately.

WASH THOROUGHLY AFTER HANDLING

KEEP TIGHTLY CLOSED WHEN NOT IN USE

1/10/77, 1/10/77, 3/10/77

Washer systems that in a certain extent will

FOR CONTROL

Initial Dose: 1/10/77, 1/10/77, 3/10/77
Subsequent Dose: 1/10/77, 1/10/77, 3/10/77

Badly fouled systems

Initial Dose: 1/10/77, 1/10/77, 3/10/77

Subsequent Dose: 1/10/77, 1/10/77, 3/10/77

Badly fouled systems

AIR WASHER SYSTEMS

Initial Dose: 1/10/77, 1/10/77, 3/10/77
Subsequent Dose: 1/10/77, 1/10/77, 3/10/77

Badly fouled systems

Initial Dose: 1/10/77, 1/10/77, 3/10/77

Subsequent Dose: 1/10/77, 1/10/77, 3/10/77

Badly fouled systems

Initial Dose: 1/10/77, 1/10/77, 3/10/77

Subsequent Dose: 1/10/77, 1/10/77, 3/10/77

Badly fouled systems

Initial Dose: 1/10/77, 1/10/77, 3/10/77

Subsequent Dose: 1/10/77, 1/10/77, 3/10/77

Badly fouled systems

Initial Dose: 1/10/77, 1/10/77, 3/10/77

Subsequent Dose: 1/10/77, 1/10/77, 3/10/77

Badly fouled systems

Initial Dose: 1/10/77, 1/10/77, 3/10/77

Subsequent Dose: 1/10/77, 1/10/77, 3/10/77

Badly fouled systems

Initial Dose: 1/10/77, 1/10/77, 3/10/77

Subsequent Dose: 1/10/77, 1/10/77, 3/10/77

Badly fouled systems

Initial Dose: 1/10/77, 1/10/77, 3/10/77

Subsequent Dose: 1/10/77, 1/10/77, 3/10/77

Badly fouled systems

Initial Dose: 1/10/77, 1/10/77, 3/10/77

Subsequent Dose: 1/10/77, 1/10/77, 3/10/77

Badly fouled systems

Initial Dose: 1/10/77, 1/10/77, 3/10/77

Subsequent Dose: 1/10/77, 1/10/77, 3/10/77

Badly fouled systems

Initial Dose: 1/10/77, 1/10/77, 3/10/77

Subsequent Dose: 1/10/77, 1/10/77, 3/10/77

Badly fouled systems

Initial Dose: 1/10/77, 1/10/77, 3/10/77

Subsequent Dose: 1/10/77, 1/10/77, 3/10/77

Badly fouled systems

Initial Dose: 1/10/77, 1/10/77, 3/10/77

Subsequent Dose: 1/10/77, 1/10/77, 3/10/77

Badly fouled systems

Initial Dose: 1/10/77, 1/10/77, 3/10/77

Subsequent Dose: 1/10/77, 1/10/77, 3/10/77

Badly fouled systems

Initial Dose: 1/10/77, 1/10/77, 3/10/77

Subsequent Dose: 1/10/77, 1/10/77, 3/10/77

Badly fouled systems

Initial Dose: 1/10/77, 1/10/77, 3/10/77

Subsequent Dose: 1/10/77, 1/10/77, 3/10/77

Badly fouled systems

Initial Dose: 1/10/77, 1/10/77, 3/10/77

Subsequent Dose: 1/10/77, 1/10/77, 3/10/77

Badly fouled systems

Initial Dose: 1/10/77, 1/10/77, 3/10/77

Subsequent Dose: 1/10/77, 1/10/77, 3/10/77

Badly fouled systems

Initial Dose: 1/10/77, 1/10/77, 3/10/77

Subsequent Dose: 1/10/77, 1/10/77, 3/10/77

Badly fouled systems

Initial Dose: 1/10/77, 1/10/77, 3/10/77

Subsequent Dose: 1/10/77, 1/10/77, 3/10/77

Badly fouled systems

Initial Dose: 1/10/77, 1/10/77, 3/10/77

Subsequent Dose: 1/10/77, 1/10/77, 3/10/77

BEST DOCUMENT AVAILABLE



Keep bungs tight to permit stacking of containers. Do not transfer contents to an unmarked container. Do not pressurize container to empty. Rinse empty container thoroughly with water before discarding or removing this label.

CORROSIVE
LIQUID, NOS
UN 1760

SOLELY FOR INDUSTRIAL USE • CAN BE FOR SALE TO USE AND STORAGE BY SERVICE PERSONS

DUBOIS, A DIVISION OF CHEMED CORPORATION • CINCINNATI, OHIO 45202 • U.S.A.

CONTACT YOUR DUBOIS REPRESENTATIVE FOR ADDITIONAL USE DIRECTIONS AND MATERIAL SAFETY DATA SHEET