

**UNITED STATES ENVIRONMENTAL PROTECTION AGENCY**

WASHINGTON, D.C. 20460

SEP 25 2003

OFFICE OF  
PREVENTION, PESTICIDES  
AND TOXIC SUBSTANCES

Robert J. Sloan  
Lonza, Inc.  
17 - 17 Route 208  
Fair Lawn, N.J. 07410


SUBJECT: June 26, 2003 Application Amendment  
Glybrom RW 93.5  
EPA Registration 6836-122

Dear Mr. Sloan:

The labeling referred to above, submitted in connection with registration under the Federal Insecticide, Fungicide, and Rodenticide Act, as amended, is acceptable with the following conditions. You must correct the spelling of INHALED and fix the typo on page 2 to read to the. You must move the word DANGER to the first line under Precautionary Statements and increase the type size of the FIRST AID heading. In addition, your most recent Confidential Statement of Formula (CSF) dated Febuary 24, 1989 needs to be revised and resubmitted. In summary, your request to revise the First Aid, Precautionary and Storage and Disposal statement is acceptable.

A copy of your conditionally approved stamped label is enclosed. Please submit a copy of your revised finished label for our files. If you have any questions regarding this letter, please contact Tom Luminello of my staff at (703) 308-8075.

Sincerely yours,

  
Robert S. Brennis  
Product Manager (32)  
Regulatory Management Branch II  
Antimicrobial Division (7510-C)

Enclosure



3 8 3

**DIRECTIONS FOR USE**

It is violation of Federal Law to use this product in a manner inconsistent with the labeling.

**RECIRCULATING COOLING WATER SYSTEMS**

Glybrom RW-93.5 aids in the control of bacteria, fungal and algal slimes in recirculating cooling water systems servicing heat exchangers, evaporative condensers and other equipment requiring cooling. It is also effective in controlling various microbiological growth formations in influent systems such as lagoons or flow-through filter systems, industrial wet scrubber systems and brewery pasteurizers. This product may be added ~~(to the systems either~~ to the continuously or intermittently or as needed. The frequency of feeding and duration of the treatment will depend upon the severity of the problem.  
Badly fouled systems must be cleaned before treatment is begun.

**FOR CONTROL OF BACTERIAL AND FUNGI**

**INTERMITTENT OR SLUG METHOD**

**INITIAL DOSE.** When the system is noticeably fouled add 0.1 to 1.0 lbs. to 1000 gallons of the water in the system. Repeat until control is achieved.

**SUBSEQUENT DOSE.** When microbial control is evident add 0.1 to 0.75 pounds to 1000 gals. of water in the system every 3 days or as needed to maintain control.

**CONTINUOUS FEED METHOD**

**INITIAL DOSE.** When a system is noticeably fouled, add 0.1 to 1.0 pounds to 1000 gals. of water in the system.

**SUBSEQUENT DOSE.** Continuously feed at a rate of 0.1 to 0.75 pounds per day per 1000 gals. of system water.

**FOR CONTROL OF ALGAE**

**INTERMITTENT OR SLUG METHOD**

**INITIAL DOSE.** When the system is noticeably fouled add 0.1 to 1.0 pound per 1000 gallons of water in the system. Repeat until control is achieved.

**SUBSEQUENT DOSE.** When algae is evident add 0.1 to 0.75 pound to 1000 gallons daily or as needed to maintain control.

**CONTINUOUS FEED METHOD**

**INITIAL DOSE.** When the system is noticeably fouled add 0.1 to 1.0 pound to 1000 gallons of water in the system. Repeat until control is achieved.

**SUBSEQUENT DOSE.** Continuously feed at a rate of 0.1 to 0.75 pounds per day per 1000 gallons of system water.

**ACCEPTED  
with COMMENTS  
in EPA Letter Dated:**

**SEP 25 2003**

Under the Federal Insecticide,  
Fungicide, and Rodenticide Act as  
amended, for the pesticide,  
registered under EPA Reg. No.

**6836-122**

