# PRECAUTIONARY STATEMENTS HAZARDS TO HUMANS AND DOMESTIC ANIMALS

DANGER. HIGHLY CORROSIVE. Causes irreversible eye damage and skin burns. May be facal if swallowed. Do not take internally. Irritating to nose and throat. Avoid breathing dust. Use with adequate ventilation. Do not get into eyes, on skin or on clothing. Wear protective clothing, chemical resistant gloves, protective eyewear (goggles, face shield or safety glasses). Remove contaminated clothing and wash clothing before reuse.

#### FIRST AID

Call a poison control center or doctor for treatment advice. Have the product container or label with you when calling a Poison Control Center or doctor or going for treatment. IF IN EYES: Hold eye open and rinse slowly and gently with water for 15 - 20 minutes. Remove contact lenses, if present, after the first 5 minutes, then continue rinsing eye. IF ON SKIN OR CLOTHING: Take off contaminated clothing. Rinse skin immediately with plenty of water for 15 - 20 minutes. IF SWALLOWED: Call a poison control center or doctor immediately for treatment advice. Have person sip a glass of water if able to swallow. Do not induce vomiting unless told to do so by the poison control center or doctor. Do not give anything by mouth to an unconscious person. IF INHALED: Move person to fresh air. If person is not breathing, call 911 or an ambulance, then give artificial respiration, preferably by mouth-to-mouth, if possible, NOTE TO PHYSICIAN: Probable mucosal damage may

# ENVIRONMENTAL HAZARDS

contraindicate the use of gastric lavage.

This pesticide is toxic to fish. Do not discharge effluent containing this product into lakes, streams, ponds, estuaries, oceans or other waters unless in accordance with the requirements of a National Polutant Discharge Elimination System (NPDES) permit and the permitting authority has been notified in writing prior to discharge. Do not discharge effluent containing this product to sewer systems without previously notifying the local sewage treatment plant authority. For guidance, contact your State Water Board or Regional Office of the EPA.

# PHYSICAL AND CHEMICAL HAZARDS

CHEMICAL HAZARD: STRONG OXIDIZING AGENT. Mix only with water. Use clean dry utensits. Do not add this product to any dispensing device containing remnants of any other product. Such use may cause a violent reaction leading to fire or explosion. Contamination with moisture, organic matter, or other chemicals may start a chemical reaction with generation of heat, liberation of hazardous gases, and possible generation of fire and explosion. In case of contamination or decomposition, do not reseal container. If possible, isolate container in open air or well-ventilated area. Flood with large volumes of water, if necessary.

# **DANTOBROM® TC**

Contents: BRIQUETTES

Active Ingredients:	
1-bromo-3-chloro-5,5-dimethylhydantoin	60.0%
1,3-dichloro-5,5-dimethylhydantoin	27.4%
1,3-dichloro-5-ethyl-5-methylhydantoin	10.6%
Inert Ingredients	<u>2.0%</u>
Total:	100.0%
Available bromine39.2% Available chlorine44.4%	

# KEEP OUT OF REACH OF CHILDREN DANGER

See side / back / right / left panel for Precautionary
Statements and First Aid

EPA Reg. No. 6836-210 EPA Est. No. 6836-PA-01 NET WEIGHT (as marked on container)

> LONZA INC., 17-17 Route 208, Fair Lawn, NJ 07410

and a series recovery and a transfer from the contract of the series of

Emergency Contact Number: (\_\_\_\_\_)

ACGERTE	D
00T LD 2001	

Under the Federal Insecticide, Fungicide, and Redenticide Act as amended, for the

Ending the 6836-210

DANTOBROM TC EPA REG. NO. 6836-210 EPA LABEL AMENDMENT 7-10-0\*

PAGE 1 OF 3

## FOR INDUSTRIAL USE ONLY

Technical advice regarding specific on site problems is available from LONZA INC. A Material Safety Data Sheet relative to the use of this product is also available upon request.

# **DIRECTIONS FOR USE**

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

# RECIRCULATING COOLING WATER SYSTEMS AND SEWAGE SYSTEMS

DANTOBROM TC aids in the control of bacterial, fungal and algal slimes in evaporative condensers, heat exchange water towers, influent systems such as flow through filters, industrial water scrubbing systems, brewery pasteurizers, and sewage systems (septic tanks, leach fields, tank lines, sewers, lagoons, and sewage effluent water).

This product may be added to the systems either continuously or intermittently or as needed. The frequency of feeding and duration of the treatment will depend upon the severity of the problem.

BADLY FOULED SYSTEMS must be cleaned before treatment is begun.

# FOR CONTROL OF BACTERIA AND FUNGI INTERMITTENT OR SLUG METHOD


INITIAL DOSE: When the system is noticeably fouled add 0.1 to 1.0 pounds per 1000 gallons (or 12 to 120 ppm) of the water in the system. Repeat until control is achieved.

SUBSEQUENT DOSE: When microbial control is evident add 0.1 to 0.75 pounds per 1000 gallons (or 12 to 90 ppm) of water in the system every 3 days or as needed to maintain control.

# **CONTINUOUS FEED METHOD**

**INITIAL DOSE:** When a system is noticeably fouled, add 0.1 to 1.0 pound per 1000 gallons (or 12 to 120 ppm) of water in the system.

**SUBSEQUENT DOSE:** Continuously feed to maintain dosage of 0.1 to 0.75 pounds per 1000 gallons (or 12 to 90 ppm) of water in the system.



FOR CONTROL OF ALGAE

INTERMITTENT OR SLUG METHOD

INITIAL DOSE: When the system is noticeably fouled add 0.1 to 1.0 pound per 1000 gallons (or 12 to 120 ppm) of water in the system. Repeat until control is achieved. SUBSEQUENT DOSE: When algae control is evident add 0.1 to 0.75 pounds per 1000 gallons (or 12 to 90 ppm) daily or as needed to maintain control.

**CONTINUOUS FEED METHOD** 

INITIAL DOSE: When the system is noticeably fouled add 0.1 to 1.0 pound per 1000 gallons (or 12 to 120 ppm) of water in the system. Repeat until control is achieved. SUBSEQUENT DOSE: Continuously feed to maintain a dosage of 0.12 to 0.75 pounds per 1000 gallons (or 12 to 90 ppm) of water in the system.

# **AIRWASHERS**

For use only in industrial airwasher systems that maintain effective mist eliminating components.

**DANTOBROM TC** controls slime forming bacteria, fungiand algae in industrial airwasher systems. Add **DANTOBROM TC** at the rate of 0.1 to 1.0 pound (12 to 120 ppm) per 1000 gallons of water in the system, depending upon the severity of the contamination.

Control the application by measuring the free chlorine residual in the treated water. There is no need to exceed 1.0 ppm as free chlorine.

Badly fouled systems must be cleaned before treatment is begun.

# INTERMITTENT OR SLUG METHOD

**INITIAL DOSE:** When system is noticeably fouled add to airwasher sump or chill water sump to insure uniform mixing. Add 0.1 to 1.0 pound per 1000 gallons (or 12 to 120 ppm) of water.

**SUBSEQUENT DOSE:** When microbial control is evident add 0.1 to 0.60 pounds per 1000 gallons (or 12 to 72 ppm) of water.

## **CONTINUOUS FEED METHOD**

**INITIAL DOSE:** When system is noticeably fouled add to airwasher sump or chill water sump to insure uniform mixing. Add 0.1 to 1.0 pound per 1000 gallons (or 12 to 120 ppm) of water.

**SUBSEQUENT DOSE**: When microbial control is evident add 0.1 to 0.6 pounds per 1000 gallons (or 12 to 72 ppm) of water.

DANTOBROM TC EPA REG. NO. 6836-210 EPA LABEL AMENDMENT 7-10-01

PAGE 2 OF 3

# ONCE-THROUGH INDUSTRIAL COOLING WATER SYSTEMS

When used as directed, DANTOBROM TC will effectively control algal, bacterial, fungal slimes and mollusks in open or closed-cycle, fresh or salt water, once-through cooling systems. Treat cooling water with DANTOBROM TC at the system intake or other critical areas, where mixing is uniform.

# **DOSAGE RATES**

INITIAL DOSE: When system is noticeably fouled, add 0.2 - 0.6 pounds per 1000 gallons of water contained in the system. Repeat initial dosage until one to three ppm (mg/L) bromine residual is established for at ⊩east 4 hours.

**SUBSEQUENT DOSE:** When microbial control is evident, add 0.1 to 0.3 pounds per 1000 gallons of water contained in the system. Repeat as needed to maintain one to three ppm bromine residual for at least 4 hours.

# TRANSPORTATION CLEANING

When used as directed, **DANTOBROM TC** will effectively control algal, bacterial, and fungal slimes in automobile wash water systems.

Badly fouled systems should be cleaned before treatment is begun.

# **INITIAL DOSE**

If a heavily fouled system exists and physical cleaning is not possible, add 0.05 to 0.2 lbs. per 1000 gadons of water (or 6 - 24 ppm) of water for two weeks. Then reduce to maintenance levels.

### MAINTENANCE DOSE

Effective control under normal circumstances is maintained by adding 0.025 to 0.1 pounds per 1000 gallons (or 3 - 12 ppm) of water.

## STORAGE AND DISPOSAL

Do not contaminate water, food or feed by storage or disposal.


**PESTICIDE STORAGE:** Keep container tightly closed. Store in a cool, dry, well-ventilated place. Do not store at elevated temperatures.

PESTICIDE DISPOSAL: Pesticide wastes are acutely hazardous. Improper disposal of excess pesticide, spray mixture, or rinsate is a violation of Federal Law. If these wastes cannot be disposed of by use according to the label instructions contact your State pesticide or environmental control agent or the hazardous waste representative at the nearest EPA regional office for guidance.

# **CONTAINER DISPOSAL:**

(Metal and piastic containers): Triple rinse (or equivalent). Then offer for recycling or reconditioning, or puncture and dispose of in a sanitary landfill, or incinerate or burn if allowed by State and local authorities. If burned, stay out of smoke.

(Fiber drums and liners): Completely empty liner by shaking and tapping sides and bottom to loosen clinging particles. Then dispose of liner and drum in a sanitary landfill or incinerate if allowed by State and local authorities. Do not reuse empty drum or liner.



DANTOBROM TC EPA REG. NO. 6836-210 EPA LABEL AMENDMENT 7-10-01

PAGE 3 OF 3