

Harmful if swallowed. Avoid contact with skin and eyes. In case of contact flush with plenty of water for at least 15 minutes. If eye irritation persists get medical attention. Avoid contamination of food.

This product is toxic to fish. Do not add treated effluent to lakes, streams or ponds. Do not contaminate water by cleaning of equipment or disposal of waste. Use only as directed on label.

APPLICATIONS: Algae & Slime Control PR is used to control algae, bacteria and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algal growth, microbiological slime and other

deposits. An initial slug addition of 1.5 to 2.0 pints of Algae & Slime Control PR per 1,000 gallons of water, to provide a concentration of 189 to 252 parts per million of Algae & Slime Control PR based on the total weight of water in the system is recommended. Subsequent slug additions of 1.0 and 2.0 pints of Algae & Slime Control PR per 1,000 gallons of water (126 to 252 parts per million of Algae & Slime Control PR) should be employed every 2 to 5 days or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.

USDA Registration No. 7547-13

WESTERN

FORM 103

PLEASE READ
ANY CAUTION OR
DIRECTION LABELS
ON THIS DRUM

WESTERN CHEMICAL COMPANY

1345 TANEY NORTH KANSAS CITY, MO. 64116

