

SPA-KEM

slow dissolving for automatic feeders

Chlorinator Tabs

TYPE

A

ACTIVE INGREDIENT:
Trichloro-s triazinetrione 99%
INERT INGREDIENTS: 1%
Available Chlorine 88%

KEEP OUT OF REACH OF CHILDREN

DANGER

See back panel for first aid statement and other precautions

NET WT. 1 LB. 14 OZ.



AC...
7616-46
1991

PRECAUTIONARY STATEMENTS HAZARDS TO HUMANS AND DOMESTIC ANIMALS

DANGER: Highly corrosive. Causes skin and eye damage. May be fatal if swallowed. Do not get in eyes, on skin or on clothing. Wear goggles or face shield and rubber gloves when handling product. Wash thoroughly with water after use. Avoid breathing dust. Do not use in confined areas. Keep out of reach of children and pets.

ENVIRONMENTAL HAZARDS: This product is highly toxic to aquatic life. Do not discharge into streams, rivers, or other bodies of water. Do not use in areas where runoff is likely to occur.

PHYSICAL AND CHEMICAL HAZARDS

STRONG OXIDIZING AGENT: Strong oxidizing agent. May cause fire or explosion. Do not mix with water. Do not mix with other chemicals. Do not use in confined areas. Do not use in areas where fire or explosion is a hazard.

PRACTICAL TREATMENT (FIRST AID):

Eye Contact: Flush with water for at least 15 minutes. **Skin Contact:** Wash with water and soap. **Inhalation:** Move to fresh air. **Swallowing:** Do not induce vomiting. Drink water.

DIRECTIONS FOR USE

FOR CONTROL OF BACTERIA AND ALGAE (OUTDOORS) IN SPAS: Before bathing, test water pH, chlorine residual, and alkalinity using a suitable test kit. Adjust chlorine level to 3.0 ppm. Between bathing periods, test and maintain chlorine residual between 1.0 and 1.5 ppm. Use an algae stabilizer in pools with a chlorine residual between 1.0 and 1.5 ppm. Maintain pH of water between 7.4 and 7.8 and total alkalinity between 105 and 140 ppm. With Spa-Kem Chlorinator Tabs, maintain a chlorine residual of 1.0 to 1.5 ppm.

FOR CONTROL OF BACTERIA AND ALGAE (INDOORS) IN SPAS: Before bathing, test water pH, chlorine residual, and alkalinity using a suitable test kit. Adjust chlorine level to 3.0 ppm. Between bathing periods, test and maintain chlorine residual between 1.0 and 1.5 ppm. Use an algae stabilizer in pools with a chlorine residual between 1.0 and 1.5 ppm. Maintain pH of water between 7.4 and 7.8 and total alkalinity between 105 and 140 ppm. With Spa-Kem Chlorinator Tabs, maintain a chlorine residual of 1.0 to 1.5 ppm.

STORAGE AND DISPOSAL

Store in a cool, dry place. Do not store in areas where fire or explosion is a hazard. Dispose of in accordance with local regulations.

CHEM LAB PRODUCTS INC
1991