

ALGENE NO. 2126

FOR SLIME, ALGAE AND FUNGUS CONTROL IN COOLING TOWERS

COMPOSITION

		<u>PERCENT BY WEIGHT</u>
Active Ingredient		10.0 percent
	Poly[oxyethylene(dimethyliminio)ethylene(dimethyliminio)-ethylene dichloride]	10.0 percent
Inert Ingredient		90.0 percent
	Weight per gallon	8.49 pounds
	Weight of active ingredient per gallon	0.85 pound

CAUTION

Keep Out of the Reach of Children

Harmful if swallowed. Avoid contact with skin and eyes. In case of contact flush with plenty of water for at least 15 minutes. If eye irritation persists, get medical attention. Avoid contamination of food.

This product is toxic to fish. Do not acid treated effluent to lakes, streams, or ponds. Do not contaminate water by cleaning of equipment or disposal of waste. Use only as directed on label. Do not reuse container. Destroy when empty.

U.S. Gallons

APPLICATION

EPA REG. NO. 7966-4

ALGENE NO. 2126 is used to control algae, bacteria, and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algal growth, microbiological slime and other deposits. An initial slug addition of 5.7 to 14.25 fluid ounces of ALGENE NO. 2126 per 1000 gallons of water to provide a concentration of 48 to 120 parts per million of ALGENE NO. 2126 based on the total weight of water in the system is recommended. Repeat until control is achieved. Subsequent slug additions of 1.43 to 14.25 fluid ounces of ALGENE NO. 2126 per 1000 gallons of water (12 to 120 parts per million of ALGENE NO. 2126) should be employed every 2 to 5 days or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.

METALENE CHEMICAL CO.

1500 BROOKPARK ROAD • CLEVELAND, OHIO 44109