

(This label is for Metal Containers)



ALCO TOWER ALGAECIDE #14
EPA REG. NO. 8075-5
SEP 1996

ALCO TOWER ALGAECIDE #14

ACTIVE INGREDIENT

Poly[oxyethylene (dimethyliminio) ethylene-(dimethyliminio) ethylene dichloride] 12.0%

INERT INGREDIENT 88.0%

This produce contains 1.02 lb of active ingredient per gallon and weighs 8.53 lb. per gallon.

KEEP OUT OF REACH OF CHILDREN
CAUTION

PRECAUTIONARY STATEMENTS HAZARDS TO HUMANS AND DOMESTIC ANIMALS

CAUTION: Harmful if swallowed. Avoid breathing vapors. Avoid contact with skin, eyes, or clothing.

FIRST AID: If swallowed, drink promptly a large quantity of milk, egg whites, gelatin solution, or, if these are not available, drink large quantities of water. Avoid alcohol. Call a physician immediately.

ENVIRONMENTAL HAZARDS: This pesticide is toxic to fish. Keep out of lakes, streams, or ponds. Permits may be required for discharges containing this pesticide into lakes, streams, ponds or public water. For guidance, contact the regional office of the Environmental Protection Agency.

DIRECTIONS FOR USE GENERAL CLASSIFICATION

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

ALCO TOWER ALGAECIDE #14 is used to control algae, bacteria, and fungi in recirculating commercial and industrial water cooling towers. Prior to its use, systems must be cleaned to remove algal growth, microbiological slime, and other deposits. An initial slug addition of 5.0 to 12.5 fluid ounces of ALCO TOWER ALGAECIDE #14 per 1000 gallons of water to provide a concentration of 40 to 100 parts per million of ALCO TOWER ALGAECIDE #14, based on the total weight of water in the system, is recommended. Repeat initial dosage until control is evident.

Subsequent slug additions of 1.20 to 12.5 fluid ounces of ALCO TOWER ALGAECIDE #14 per 1000 gallons of water (10 to 100 parts per million of ALCO TOWER ALGAECIDE #14) should be employed every 2 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and the severity of the microbiological problem. Slug additions should be made in the sump of water cooling towers.

ALCO TOWER ALGAECIDE #14 is used to control bacteria in industrial air-washing systems that maintain effective mist eliminating components. Prior to its use, systems should be cleaned to remove bacterial slime and other deposits. An initial slug dose of 21.37 to 35.63 fluid ounces of ALCO TOWER ALGAECIDE #14 per 1000 gallons of water is recommended. Repeat initial dosage until control is evident. Subsequent slug additions of 14.44 to 35.63 fluid ounces of ALCO TOWER ALGAECIDE #14 per 1000 gallons of water should be employed each 1 to 5 days, or as needed. The frequency of addition depends upon the relative amount of bleedoff and severity of the bacterial problem. Slug additions may be made to the sump or to the water collection trays of the airwash system.

STORAGE & DISPOSAL: Keep container closed when not in use. Do not contaminate water, food, or feed by storage, disposal, or cleaning of equipment. The container must be triple rinsed (or equivalent) and offered for recycling, reconditioning, or disposal in an approved landfill or buried in a safe place. Residue that cannot be used or reprocessed should be disposed of in a landfill approved for pesticides or buried in a safe place away from water supplies. Open dumping is prohibited.

Manufactured by:
ALLEN CHEMICAL COMPANY
3235 N.W. 37th Street
Miami, Florida 33142

EPA REG. NO. 8075-5

EPA EST. NO. 8075-FL-2

NET CONTENTS

11